



FOR REFERENCE ONLY

PROJECT MANUAL

KITCHEN UPGRADES AT MADISON ES

TWIN RIVERS UNIFIED SCHOOL DISTRICT

NORTH HIGHLANDS, CA

CONSTRUCTION DOCUMENTS

Divisions 00 - 33

DSA Application #01-

File #

1.104.02

June 2024

FOR REFERENCE ONLY

FOR REFERENCE ONLY

SECTION 00 01 01

PROJECT TITLE PAGE

KITCHEN UPGRADES AT MADISON ES

DISTRICT

TWIN RIVERS UNIFIED SCHOOL DISTRICT

5115 DUDLEY BLVD, MCCLELLAN PARK, CA 95652

916.566.1600

WWW.TRUSD.NET

PROJECT LOCATION

MADISON ELEMENTARY SCHOOL PK-8

5421 HARRISON STREET

NORTH HIGHLANDS, CALIFORNIA 95660

PREPARED BY:

ARCHITECT

RUHNAU CLARKE ARCHITECTS

3775 Tenth Street, Riverside CA 92501 - 5751 Palmer Way, Suite C, Carlsbad, CA 92010

951.684.4664 - 760.438.5899

www.ruhnaucclarke.com

Architect's Project Number: 1-104-02

FOR REFERENCE ONLY

NOTICE: This Project Manual, is an unpublished instrument of service of the authors. It is prepared for use only on this Project and in conjunction with the authors' interpretations, observations, decisions and administration, as described in the Conditions of the Contract. Desired results without these services cannot be assured. Use in whole or in part, without the authors' services and expressed written consent may violate Act 17 U.S.C. par. 301 (1991).

SECTION 00 01 02 PROJECT INFORMATION

PART 1 GENERAL

1.01 PROJECT IDENTIFICATION

- A. Project Name: Kitchen Upgrades at Madison ES, located at:

Project Number: 1-104-02.

Madison Elementary School PK-8.

5421 Harrison Street.

North Highlands, California 95660.

- B. The Owner, hereinafter referred to as District:

Twin Rivers Unified School District

5115 Dudley Blvd, McClellan Park, CA 95652

www.trusd.net

916.566.1600

1.02 NOTICE TO PROSPECTIVE BIDDERS

- A. These documents constitute an Invitation to Bid to and request for qualifications from General Contractors for the construction of the project described below.

1.03 PROJECT DESCRIPTION

1.04 PROJECT CONSULTANTS

- A. The Architect, hereinafter referred to as Architect: **Ruhnau Clarke Architects**

3775 Tenth Street, Riverside CA 92501 - 5751 Palmer Way, Suite C, Carlsbad, CA 92010

www.ruhnauclarke.com

951.684.4664 - 760.438.5899

1.05 PROCUREMENT TIMETABLE

- A. Last Request for Substitution Due: 14 days prior to due date of bids.
- B. Last Request for Information Due: 14 days prior to due date of bids.
- C. Contract Time: To be stated in bid documents.
- D. The District reserves the right to change the schedule or terminate the entire procurement process at any time.

1.06 PROCUREMENT DOCUMENTS

- A. Availability of Documents: Complete sets of procurement documents may be obtained:
1. From District at the Project Manager's address listed above.

FOR REFERENCE ONLY

PART 2 PRODUCTS (NOT USED)

PART 3 EXECUTION (NOT USED)

END OF SECTION

**SECTION 00 01 07
SEALS PAGE**

ARCHITECT OF RECORD (AOR)

RUHNAU CLARKE ARCHITECTS

3775 Tenth Street, Riverside CA 92501 - 5751 Palmer Way, Suite C, Carlsbad, CA 92010 -
801 16th Street, Sacramento, CA 95814

Roger Clarke, Architect of Record C-21340



STRUCTURAL ENGINEER OF RECORD (SEOR)

BUELER ENGINEERING

600 Q Street, Suite 200, Sacramento, CA 95811

D. Lee Pursell S-4434



MECHANICAL & PLUMBING ENGINEER OF RECORD (MEOR)

LP CONSULTING ENGINEERS

1209 Pleasant Grove Boulevard, Roseville, CA 95678

Ryan Ennis M-41413




ELECTRICAL ENGINEER OF RECORD (EEOR)

LP CONSULTING ENGINEERS

1209 Pleasant Grove Boulevard, Roseville, CA 95678

Rami S. Zeidan E-16752



FOR REFERENCE ONLY

CIVIL ENGINEER OF RECORD (CEOR)

WARREN CONSULTING ENGINEERS, INC.

1117 Windfield Way, Suite 110, El Dorado Hills, CA 95762

Anthony J. Tassano

RCE-74696



LANDSCAPE ARCHITECT OF RECORD (LAOR)

ROACH & CAMPBELL

947 Enterprise Drive, Loft B, Sacramento, CA 95825

William D. Roach

CRLA-4409



END OF SEALS PAGE

FOR REFERENCE ONLY

SECTION 00 01 10 TABLE OF CONTENTS

PROCUREMENT AND CONTRACTING REQUIREMENTS

DIVISION 00 -- PROCUREMENT AND CONTRACTING REQUIREMENTS

- 00 01 01 - Project Title Page
- 00 01 02 - Project Information
- 00 01 07 - Seals Page
- 00 01 10 - Table of Contents
- 00 40 25 - Request for Information
- 00 43 25 - Substitution Request Form - During Procurement
- 00 63 25 - Substitution Request Form - During Construction

SPECIFICATIONS

DIVISION 01 -- GENERAL REQUIREMENTS

- 01 10 00 - Summary
- 01 20 00 - Price and Payment Procedures
- 01 25 00 - Substitution Procedures
- 01 30 00 - Administrative Requirements
 - 01 30 00.01 - Request for Interpretation
 - 01 30 00.02 - Submittal Transmittal
- 01 31 14 - Facility Services Coordination
- 01 32 16 - Construction Progress Schedule
- 01 35 50 - Requests for Electronic Files
- 01 35 53 - Security Procedures
- 01 40 00 - Quality Requirements
- 01 41 00 - Regulatory Requirements
- 01 42 19 - Reference Standards
- 01 45 33 - Code-Required Special Inspections
- 01 50 00 - Temporary Facilities and Controls
- 01 57 19 - Temporary Environmental Controls
- 01 58 13 - Temporary Project Signage
- 01 60 00 - Product Requirements
- 01 61 16 - Volatile Organic Compound (VOC) Content Restrictions
 - 01 61 16.01 - Accessory Material VOC Content Certification Form

FOR REFERENCE ONLY

- 01 70 00 - Execution and Closeout Requirements
- 01 71 23 - Field Engineering
- 01 73 56 – Alteration and Modernization Execution Procedures
- 01 74 19 - Construction Waste Management and Disposal
- 01 76 10 - Temporary Protective Coverings
- 01 78 00 - Closeout Submittals
- 01 78 00.01 – Warranty Form Letter
- 01 78 39 - Project Record Documents
- 01 79 00 - Demonstration and Training

DIVISION 02 -- EXISTING CONDITIONS

- 02 41 00 - Demolition

DIVISION 03 -- CONCRETE

- 03 10 00 - Concrete Forming and Accessories
- 03 20 00 - Concrete Reinforcing
- 03 30 00 - Cast-in-Place Concrete
- 03 35 11 - Concrete Floor Finishes

DIVISION 04 -- MASONRY

- 04 01 00 - Maintenance of Masonry
- 04 05 11 - Masonry Mortaring and Grouting
- 04 20 00 - Unit Masonry

DIVISION 05 -- METALS

- 05 12 00 - Structural Steel Framing
- 05 50 00 - Metal Fabrications
- 05 52 13 - Pipe and Tube Railings
- 05 59 20 - Tube Steel Enclosure and Gates

DIVISION 06 -- WOOD, PLASTICS, AND COMPOSITES

- 06 05 73 - Wood Treatment
- 06 10 00 - Rough Carpentry
- 06 83 16 - Fiberglass Reinforced Paneling

DIVISION 07 -- THERMAL AND MOISTURE PROTECTION

- 07 01 50.20 - Roofing, Restoration, Patch, and Repair
- 07 21 00 - Thermal Insulation
- 07 25 00 - Weather Barriers
- 07 27 00 - Air Barriers

FOR REFERENCE ONLY

- 07 42 43 - Composite Wall Panels
- 07 54 00 - Thermoplastic Membrane Roofing
- 07 62 00 - Sheet Metal Flashing and Trim
- 07 92 00 - Joint Sealants
- 07 95 13 - Expansion Joint Cover Assemblies

DIVISION 08 -- OPENINGS

- 08 06 71 - Door Hardware Schedule
- 08 11 13 - Hollow Metal Doors and Frames
- 08 14 16 - Flush Wood Doors
- 08 31 00 - Access Doors and Panels
- 08 33 13 - Coiling Counter Doors
- 08 43 13 - Aluminum-Framed Storefronts
- 08 51 13 - Aluminum Windows
- 08 56 59 - Service and Teller Window Units
- 08 71 00 - Door Hardware
- 08 80 00 - Glazing
- 08 87 33 - Architectural Decorative Window Films

DIVISION 09 -- FINISHES

- 09 05 61 - Common Work Results for Flooring Preparation
- 09 21 16 - Gypsum Board Assemblies
- 09 22 36 - Lath
- 09 24 00 - Cement Plastering
- 09 30 00 - Tiling
- 09 51 00 - Acoustical Ceilings
- 09 65 00 - Resilient Flooring
- 09 67 00 - Fluid-Applied Flooring
- 09 90 13 - Painting Existing Facilities
- 09 91 13 - Exterior Painting
- 09 91 23 - Interior Painting
- 09 96 00 - High-Performance Coatings
- 09 96 23 - Graffiti-Resistant Coatings

DIVISION 10 -- SPECIALTIES

- 10 11 00 - Visual Display Units
- 10 14 23 - Panel Signage
- 10 21 13.19 - Plastic Toilet Compartments

10 26 00 - Wall and Door Protection

10 28 00 - Toilet Accessories

10 44 00 - Fire Protection Specialties

10 51 13 - Metal Lockers

10 75 00 - Flagpoles

DIVISION 11 -- EQUIPMENT

11 40 00 - Foodservice Equipment

DIVISION 12 -- FURNISHINGS

12 11 03 - Mural Painting and Faux Finishes

DIVISION 22 -- PLUMBING

22 05 10 - Plumbing General Provisions

22 05 16 - Expansion Fittings and Loops for Plumbing Piping

22 05 23 - General-Duty Valves for Plumbing Piping

22 05 29 - Hangers and Supports for Plumbing Piping and Equipment

22 05 53 - Identification for Plumbing Piping and Equipment

22 07 19 - Plumbing Piping Insulation

22 10 05 - Plumbing Piping

22 10 06 - Plumbing Piping Specialties

22 30 00 - Plumbing Equipment

22 40 00 - Plumbing Fixtures

DIVISION 23 -- HEATING, VENTILATING, AND AIR-CONDITIONING (HVAC)

23 05 10 - Mechanical General Provisions

23 05 29 - Hangers and Supports for HVAC Piping and Equipment

23 05 53 - Identification for HVAC Piping and Equipment

23 05 93 - Testing, Adjusting, and Balancing for HVAC

23 07 13 - Duct Insulation

23 31 00 - HVAC Ducts and Casings

23 33 00 - Air Duct Accessories

23 34 23 - HVAC Power Ventilators

23 37 00 - Air Outlets and Inlets

23 74 13 - Packaged Rooftop Outdoor Central-Station Air-Handling Units

DIVISION 26 -- ELECTRICAL

26 05 00 - Common Work Results for Electrical

26 05 05 - Selective Demolition for Electrical

FOR REFERENCE ONLY

26 05 19 - Low-Voltage Electrical Power Conductors and Cables
26 05 26 - Grounding and Bonding for Electrical Systems
26 05 29 - Hangers and Supports for Electrical Systems
26 05 33.13 - Conduit for Electrical Systems
26 05 33.16 - Boxes for Electrical Systems
26 05 48 - Vibration and Seismic Controls for Electrical Systems
26 05 53 - Identification for Electrical Systems
26 05 73 - Power System Studies
26 05 83 - Wiring Connections
26 08 00 - Electrical Commissioning Requirements
26 09 23 - Lighting Control Devices
26 24 13 – Switchboards
26 24 16 - Panelboards
26 27 26 - Wiring Devices
26 28 13 - Fuses
26 43 00 - Surge Protective Devices
26 51 00 - Interior Lighting

DIVISION 28 -- ELECTRONIC SAFETY AND SECURITY

28 46 00 - Fire Detection and Alarm

DIVISION 31 -- EARTHWORK

31 10 00 - Site Clearing
31 22 00 - Grading
31 23 16 - Excavation
31 23 16.13 - Trenching
31 23 23 - Fill

DIVISION 32 -- EXTERIOR IMPROVEMENTS

32 11 23 - Aggregate Base Courses
32 12 16 - Asphalt Paving
32 13 13 - Site Concrete
32 14 13 - Precast Concrete Unit Paving
32 15 00 - Aggregate Surfacing
32 17 13 - Concrete Wheel Stops
32 17 23 - Pavement Markings
32 17 26 - Tactile Warning Surfacing
32 31 19 - Decorative Metal Fences and Gates

FOR REFERENCE ONLY

32 84 23 - Irrigation System

32 91 19 - Landscape Grading

32 93 00 - Planting

DIVISION 33 -- UTILITIES

33 14 16 - Site Water Distribution Piping

33 31 13 - Site Sanitary Sewerage Piping

33 42 11 - Stormwater Gravity Piping

33 42 30 - Stormwater Drains

END OF SECTION

FOR REFERENCE ONLY

**SECTION 00 40 25
REQUEST FOR INFORMATION**

RFI NUMBER: _____

DATE: _____

PROJECT NAME: KITCHEN UPGRADES AT MADISON ES PROJECT NO.: 1-104-02

TO: RUHNAU CLARKE ARCHITECTS

3775 Tenth Street, Riverside CA 92501 - 5751 Palmer Way, Suite C, Carlsbad, CA 92010

Attention: _____

Contractor: _____

Address: _____

Request By: _____

Date: _____

BRIEF SUMMARY OF RFI: _____

Drawing No. _____ Detail No. _____

Specification Section _____ Title _____

. Page _____ Paragraph _____

DETAILS OF THIS RFI: _____

Attachments: _____

RESPONSE WILL BE INCLUDED IN AN ADDENDUM

FOR REFERENCE ONLY

END OF RFI

FOR REFERENCE ONLY

SECTION 00 43 25 SUBSTITUTION REQUEST FORM - DURING PROCUREMENT

SUBSTITUTION REQUEST NO. _____

DATE: _____

PROJECT NAME: KITCHEN UPGRADES AT MADISON ES

PROJECT NUMBER: 1-104-02

TO: RUHNAU CLARKE ARCHITECTS

3775 Tenth Street, Riverside CA 92501 - 5751 Palmer Way, Suite C, Carlsbad, CA 92010

From: _____

We hereby submit for your consideration the following product comparisons of the specified product and the proposed substitution. The undersigned fully understands that failure to answer any item below may be cause for rejection of request for substitution.

Request for substitution shall only be made during bidding (not later than 7 days prior to bid opening for inclusion by Addendum) except under conditions beyond control of Contractor.

SPECIFIED PRODUCT: _____

Project Manual Section Title _____ Number ___ Page ___ Paragraph ___.

Drawing No. _____ Detail No. _____

Proposed Substitution: _____

Manufacturer: _____ Tel: _____

- A. Is the point-by-point comparative data attached? — REQUIRED BY A/E
- B. Reason request for substitution is being submitted: _____

DIFFERENCES BETWEEN PROPOSED SUBSTITUTION AND SPECIFIED PRODUCT

- C. Does proposed substitution affect in any way the Structural Safety, Access Compliance, or Fire & Life Safety portions of the project? No__ Yes__
Explain _____

- D. Does proposed substitution affect dimensions, gages, weights, etc. on Drawing? No__ Yes__
Explain _____

FOR REFERENCE ONLY

- E. Does proposed substitution require changes in Drawings or design and installation changes?
No___ Yes___ _____
(If yes, cost of these changes is the responsibility of the Contractor.)

- F. Does proposed substitution affect product cost, delivery time, or construction schedule?
No___ Yes___ Explain _____

- G. Does proposed substitution comply with specified ICC Number, UL Rating, ASTM Numbers?
No___ Yes___ Explain _____

- H. Does proposed substitution affect other trades and systems such as wiring, piping, ductwork, structure, etc.? No ___ Yes ___ (Explain which and how) _____

- I. Does proposed substitution product guarantee differ from that of the specified product?
No___ Yes___ Explain _____

Attach a listing of 3 similar projects (one in service for at least 3 years) using the proposed substitution.

Substantiating Data: Attach product data/brochures and Vendor qualifications for both specified and substitute product. Provide samples for both specified and substitute products, if applicable.

Certification: Undersigned has examined Construction Documents, is familiar with specified product, understands indicated application of product, and understands design intent of the Architect caused by the requested substitution.

Submitted by: _____

 .(Type Name) Signature Date

Signature must be made by person having legal authority to bind his firm to the above terms.

END OF SECTION

FOR REFERENCE ONLY

SECTION 00 63 25 SUBSTITUTION REQUEST FORM - DURING CONSTRUCTION

SUBSTITUTION REQUEST NO. _____

DATE: _____

PROJECT NAME: KITCHEN UPGRADES AT MADISON ES

PROJECT NUMBER: 1-104-02

TO: RUHNAU CLARKE ARCHITECTS

3775 Tenth Street, Riverside CA 92501 - 5751 Palmer Way, Suite C, Carlsbad, CA 92010

From: _____

We hereby submit for your consideration the following product comparisons of the specified product and the proposed substitution. The undersigned fully understands that failure to answer any item below may be cause for rejection of request for substitution.

This request for substitution form shall only be used after the end of the bidding period except under conditions beyond control of Contractor.

Specified Product: _____

Project Manual Section Title _____ Number ___ Page ___ Paragraph ___.

Drawing No. _____ Detail No. _____

Proposed Substitution: _____

Manufacturer: _____ Tel: _____

A. Reason request for substitution is being submitted: _____

B. Does proposed substitution affect in any way the Structural Safety, Access Compliance, or Fire & Life Safety portions of the project? No__ Yes__

Explain _____

C. Does proposed substitution affect dimensions, gages, weights, etc. on Drawing? No__ Yes__

Explain _____

FOR REFERENCE ONLY

- D. Does proposed substitution require changes in Drawings or design and installation changes?
No___ Yes___ _____
(If yes, cost of Architect and Engineer document changes are the responsibility of the Contractor.)

FOR REFERENCE ONLY

- E. Does proposed substitution affect product cost, delivery time, or construction schedule?
No ___ Yes ___ Explain _____
- F. Does proposed substitution comply with specified ICC Number, UL Rating, ASTM Numbers?
No ___ Yes ___ Explain _____
- G. Does proposed substitution affect other trades and systems such as wiring, piping, ductwork, structure, etc.? No ___ Yes ___ (Explain which and how) _____

If yes, has impact on their work been included in price of proposed substitution? No__ Yes__.

- H. Does proposed substitution product guarantee differ from that of the specified product?
No ___ Yes ___ Explain _____

If the substitution request is accepted, it will result in:

No cost impact ___ Improve Schedule ___ Credit of \$ _____

Attach a listing of 3 projects (one in service for at least 3 years) using the proposed substitution.

Substantiating Data: Attach product data/brochures and Vendor qualifications for both specified and substitute product. Provide samples for both specified and substitute products, if applicable.

Certification: Undersigned has examined Construction Documents, is familiar with specified product, understands indicated application of product, and understands design intent of the Architect caused by the requested substitution.

Submitted by: _____
 .(Type Name) Signature Date

Signature must be made by person having legal authority to bind his firm to the above terms.

Architect's Comments:

___ Accepted, ___ accepted as noted, ___ not accepted, ___ received too late.

Reviewed by:

 Architect Date

 DSA Date

 District Date

END OF SECTION

SECTION 01 10 00 SUMMARY

PART 1 GENERAL

1.01 PROJECT

- A. Project Name: Kitchen Upgrades at Madison ES.
- B. District's Name: Twin Rivers Unified School District.
- C. Architect's Name: Ruhnau Clarke Architects.
- D. The Project consists of the alteration of an existing kitchen located at Madison Elementary School PK-8.

1.02 CONTRACT DESCRIPTION

- A. Contract Type: A single prime contract based on a Stipulated Price as described in Owner-Contractor Agreement.
- B. The Work is construction and related services for a , CBC, Occupancy Type Educational Group E, Construction Type V-B, , totaling approximately 0 square feet.
 - 1. The Work includes remodeling of an existing building, interior improvements, building utilities, and related site improvements; with patch and repair as required, and other features to the extent indicated on the Drawings.
 - 2. Hazardous Material Abatement is specified in a separate document prepared by the District's Consultant and is not managed by the Architect or the Architect's Consultants.

1.03 CONTRACT DOCUMENTS

- A. Contract Requirements:
 - 1. Conditions of the Contract and other Contract documents have been included in the Project Manual, as indicated in the Table of Contents.
 - a. Such documents are not Specifications.
 - 2. Specifications are found in the technical Divisions of the Project Manual.
- B. Contract Drawings: The Drawings provided with and identified in the Project Manual are the Drawings referenced in the Agreement.
 - 1. The location, extent and configuration of the required construction and improvements are shown and noted on Drawings.
 - a. The Drawings are referenced in the Agreement.
 - b. An index of Drawings is included in the set of Drawings.
 - 2. Drawings are arranged into series according to design discipline. Such organization and all references to trades, subcontractor, specialty contractor or supplier shall not control the Contractor in dividing the Work among subcontractors or in establishing the extent of the Work to be performed by any trade.

3. Where the terms "as shown", "as indicated", "as noted", "as detailed", "as scheduled", or terms of like meaning, are used in the Drawings or Specifications, it shall be understood that reference is being made to the Drawings referenced in the Agreement.
 4. Where reference to the word "plans" is made anywhere in Drawings, Specifications and related Contract Documents, it shall be understood to mean the Drawings referenced in the Agreement.
- C. Contract Specifications: The Specifications provided in the Project Manual are the Specifications referenced in the Agreement.
1. Specifications are organized by Divisions and Sections in accordance with the recommended practices of the Construction Specifications Institute.
 - a. Such organization shall not control the Contractor in dividing the Work among subcontractors or in establishing the extent of Work to be performed by any trade.
 2. Specifications are included in the Project Manual, which may also include other Bidding and Contract Documents.
 - a. Contents of the Project Manual are listed in Document 00 01 10 - Table of Contents, in the Project Manual.

1.04 DESCRIPTION OF ALTERATIONS WORK

- A. Scope of demolition and removal work is indicated on drawings and specified in Section 02 41 00.
 1. The intent of these drawings and specifications are the work of the alteration, rehabilitation, or reconstruction of this facility shall be submitted and approved by DSA before proceeding with the repair work. {RS#10005412} Section 4-317.
- B. Scope of alterations work is indicated on drawings.
- C. Plumbing: Alter existing system and add new construction, keeping existing in operation.
- D. HVAC: Alter existing system and add new construction, keeping existing in operation.
- E. Electrical Power and Lighting: Alter existing system and add new construction, keeping existing in operation.
- F. Fire Alarm: Alter existing system and add new construction, keeping existing in operation.
- G. Telephone: Alter existing system and add new construction, keeping existing in operation.
- H. Security System: Alter existing system and add new construction, keeping existing in operation.
- I. Communications: Alter existing system and add new construction, keeping existing in operation.

1.05 WORK BY OWNER

- A. Concurrent Work Under Separate Contracts:
 1. Work Under Separate Contracts: District will award separate contracts for products and installation for interior improvements and other work as may be indicated on Drawings as NIC (Not in Contract).
 2. Relationship to Work Under the Contract:

FOR REFERENCE ONLY

- a. Work under the Contract shall include all provisions necessary to make such concurrent work under separate contracts complete in every respect and fully functional, including field finishing.
 - b. Provide necessary backing, supports, piping, conduit, conductors and other such provisions from point of service to point of connection, as shown on Drawings and specified herein.
3. Related Contract Documents:
- a. District will make available, in a timely manner, drawings and specifications of work under separate contracts for coordination and further description of that work.
 - b. Such drawings and other data required for the coordination of the work of separate contracts with the Work of this Contract may be included with the Contract Documents.
 - c. If so, they are provided for convenience only and are not to be considered Contract Documents produced by Architect or Architect's consultants.
4. Permits, Notices and Fees:
- a. Permits, Notices and Fees: Notices required by and approvals required of authorities having jurisdiction for work under separate contracts and related fees will be solely the responsibility of District.
- B. Items noted NIC (Not in Contract) will be supplied and installed by District before Date of Final Inspection. Some items include:
1. Movable cabinets.
 2. Furnishings.
 3. Small equipment.
 4. Rugs.
 5. Artwork.
- C. OFCI - District will supply the following for installation by Contractor:
1. District may furnish, for installation by Contractor, products which are identified on the Drawings and in the Specifications as OFCI (Owner-Furnished/Contractor-Installed).
 2. Relationship to Work Under the Contract:
 - a. Work under the Contract shall include all provisions necessary to fully incorporate such products into the Work, including, as necessary.
 - 1) Fasteners.
 - 2) Backing,.
 - 3) Supports.
 - 4) Piping.
 - 5) Conduit.
 - 6) Conductors.
 - 7) Other such provisions from point of service to point of connection, for a complete installation.

- 8) Field finishing, as shown on Drawings and specified herein.
- b. See Section 01 30 00 - Administrative Requirements for additional requirements.

1.06 PERMITS, LICENSES AND FEES

- A. Permits:
 1. For Work included in the Contract, Contractor shall obtain all permits from authorities having jurisdiction and from serving utility companies and agencies.
 2. District will reimburse Contractor for amount charged for such permits, without mark-up.
 3. For Work performed under design/build basis, plan check and permit fees shall be included in the Contract Sum.
- B. Licenses:
 1. Contractor shall obtain and pay all licenses associated with construction activities, such as business licenses, contractors' licenses and vehicle and equipment licenses.
 2. All costs for licenses shall be included in the Contract Sum.
- C. Assessments:
 1. District will pay all assessments and utility service connection fees. Costs of assessments shall not be included in the Contract Sum.
- D. Test and Inspection Fees:
 1. Contractor shall pay all fees charged by authorities having jurisdiction and from serving utility companies and agencies, for tests and inspections conducted by those authorities, companies and agencies.
 2. District will reimburse Contractor for actual amount of such fees, without mark-up.
 3. Refer to Section 01 40 00 - Quality Requirements for additional information on tests and inspections and responsibility for payment of fees.

1.07 OWNER OCCUPANCY

- A. District intends to continue to occupy adjacent portions of the existing site during the entire construction period.
- B. District intends to occupy the Project by the date stated in the Agreement as the contract completion date.
- C. Cooperate with District to minimize conflict and to facilitate District's operations.
- D. Schedule the Work to accommodate District occupancy.

1.08 CONTRACTOR USE OF SITE AND PREMISES

- A. Construction Operations: Limited to areas noted on Drawings.
- B. Arrange use of site and premises to allow:
 1. District occupancy.
 2. Work by Others.
 3. Work by District.
 4. Use of site and premises by the public.

- C. Provide access to and from site as required by law and by District:
 - 1. Emergency Building Exits During Construction: Keep all exits required by code open during construction period; provide temporary exit signs if exit routes are temporarily altered.
 - 2. Site Access:
 - a. Limit access to site to indicated routes and access points as indicated.
 - b. If routes and access points are not indicated, access shall be as approved by District.
 - c. Do not restrict access to adjacent properties and do not restrict access for those performing work under separate contracts for the District.
 - 3. Do not obstruct roadways, sidewalks, or other public ways without permit.
 - 4. Construction Limit:
 - a. Limit construction activities to areas indicated on Drawings as Project Area or, if not indicated, to areas within the parcel as described in the legal description on the Drawings.
 - b. Refer also to Section 01 50 00 - Temporary Construction Facilities and Controls for additional requirements.
- D. Existing building spaces may not be used for storage.
- E. Time Restrictions:
 - 1. Limit conduct of especially noisy, malodorous, and dusty exterior work to the hours of 8 AM to 6 PM.
- F. Utility Outages and Shutdown:
 - 1. Limit disruption of utility services to hours the site is unoccupied.
 - 2. Do not disrupt or shut down life safety systems, including but not limited to fire sprinklers and fire alarm system, without 7 days notice to District and authorities having jurisdiction.
 - 3. Prevent accidental disruption of utility services to other facilities.

1.09 CONSTRUCTION WASTE MANAGEMENT

- A. Construction and waste management, complying with Section 01 74 19 - Construction Waste Management and Disposal, is a requirement for this project.
- B. The Contractor, Prime Contractors, and subcontractors all have obligations in meeting the requirements of this specification.

END OF SECTION

SECTION 01 20 00 PRICE AND PAYMENT PROCEDURES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Procedures for preparation and submittal of applications for progress payments.
- B. Documentation of changes in Contract Sum and Contract Time.
- C. Change procedures.
- D. Correlation of Contractor submittals based on changes.
- E. Procedures for preparation and submittal of application for final payment.

1.02 RELATED REQUIREMENTS

- A. Section 01 78 00 - Closeout Submittals: Project record documents.

1.03 SCHEDULE OF VALUES

- A. Use Schedule of Values Form: Form provided by District.
- B. Electronic media printout including equivalent information will be considered in lieu of standard form specified; submit draft to Architect for approval.
- C. Submit Schedule of Values in duplicate within 15 days after date established in Notice to Proceed.
 - 1. Submit schedule in a spreadsheet calculated format, such as Excel, based upon the attached Schedule of Values augmented by the Table of Contents of this Project Manual.
- D. Format: Utilize the Table of Contents of this Project Manual. Identify each line item with number and title of the major specification section. Identify site mobilization, bonds and insurance, and record drawings .
- E. Where work is separated into phases requiring separately phased payments, provide separate schedule for each phase.
- F. Where work involves multiple sites and/or "A" number, provide separate schedules for each site and/or "A" number.
- G. Where scope of work involves multiples buildings/structures, provide separate schedule for each building.
- H. Include in each line item, the amount of Allowances specified in this section.
- I. Include separately from each line item, a direct proportional amount of Contractor's overhead and profit.
- J. Revise schedule to list approved Change Orders, with each Application For Payment.
 - 1. List each authorized Change Order as an extension on the continuation sheet, listing the Change Order number and dollar value as for an original portion of Work.

1.04 APPLICATIONS FOR PROGRESS PAYMENTS

- A. Payment Period: Submit at intervals stipulated in the Agreement.
 - 1. Substantiating information will normally be required only for those portions of Work whose completion state cannot be readily determined by observation of the completed Work.
- B. Use Form Form as provided by District.
- C. Electronic media printout including equivalent information will be considered in lieu of standard form specified; submit sample to Architect for approval.
- D. Forms filled out by hand will not be accepted.
- E. For each item, provide a column for listing each of the following:
 - 1. Item Number.
 - 2. Description of work.
 - 3. Scheduled Values.
 - 4. Previous Applications.
 - 5. Work in Place and Stored Materials under this Application.
 - 6. Authorized Change Orders.
 - 7. Total Completed and Stored to Date of Application.
 - 8. Balance to Finish.
 - 9. Retainage.
- F. Execute certification by signature of authorized officer.
- G. Use data from approved Schedule of Values. Provide dollar value in each column for each line item for portion of work performed and for stored products.
- H. List each authorized Change Order as a separate line item, listing Change Order number and dollar amount as for an original item of work.
 - 1. No Change Orders shall be included with Application for Payment until approved in writing by District and Architect. Also approved by DSA when appropriate.
- I. Submit one electronic and three hard-copies of each Application for Payment.
- J. Include the following with the application:
 - 1. Transmittal letter as specified for submittals in Section 01 30 00.
 - 2. Construction progress schedule, revised and current as specified in Section 01 32 16.
 - 3. Current construction photographs specified in Section 01 30 00.
 - 4. Partial release of liens from major subcontractors and vendors.
 - a. Provide with each Application for Payment lien releases from all subcontractors, workers and materials suppliers employed for the Project covering their portion of Work to date for which payment application is made. Lien release forms will be provided by District and shall be completed in accordance with directions provided.
 - 5. Project record documents as specified in Section 01 78 00, for review by District which will be returned to the Contractor.

6. Affidavits attesting to off-site stored products.
- K. When Architect requires substantiating information, submit data justifying dollar amounts in question. Provide one copy of data with cover letter for each copy of submittal. Show application number and date, and line item by number and description.

1.05 ADDENDA

- A. Addenda are changes issued prior to the signing of the Contract for Construction. These Addenda shall be signed by the Architect and approved by the Division of the State Architect.
- B. These documents may or may not have approved by the Division of the State Architect prior to the close of Bid.
 1. If not approved by DSA prior to close of the bidding period, the contract price shall include the Addenda.
 2. No work shall proceed regarding any Addendum until approved by DSA.
 3. Revisions to Addenda, when approved by DSA, shall be incorporated by an additional addendum or Change Order as indicated below and as provided for in the Contract for Construction and General Conditions.

1.06 MODIFICATION PROCEDURES

- A. Construction Changes, General:
 1. The following describe administrative procedures to be followed in compliance with provisions of the Conditions of the Contract for Architect's Supplemental Instructions, Construction Change Directives, Construction Change Documents, and Contract Change Orders.
 2. The Architect will prepare and issue: Architect's Supplemental Instructions, a Construction Change Directive or a Request for Proposal to be presented to the Contractor for action.
- B. Submit name of the individual authorized to receive change documents and who will be responsible for informing others in Contractor's employ or subcontractors of changes to Contract Documents.
- C. Contract Change Order Forms: Form as directed by District.
- D. For minor changes not involving an adjustment to the Contract Sum or Contract Time, Architect will issue instructions directly to Contractor.
 1. Architect's Supplemental Instructions:
 - a. Minor changes in the Work, not involving an adjustment in either the Contract Sum or Contract Time, as authorized by the Conditions of the Contract, will be presented by the Architect using the Architect's Bulletin form.
 - b. Should the Architect's Supplemental Instructions result in disputed costs and time adjustments, such dispute shall be resolved in accordance with the provisions of the Conditions of the Contract.
- E. DSA Construction Change Document approval for substitutions and changes to structural, accessibility, or fire-life-safety portions of approved Drawings and Specifications is required from DSA prior to fabrication and installation. DSA IR A-6; CAC Section 4-215, & 4-233(c).

FOR REFERENCE ONLY

1. The approved Construction Change Document shall be signed by:
 - a. Architect of Record.
 - b. When applicable:
 - 1) Structural Engineer of Record.
 - 2) Mechanical Engineer of Record.
 - 3) Electrical Engineer of Record.
 - 4) Civil Engineer of Record.
 - 5) Delegated Professional Engineer.
 - c. Division of the State Architect for final approval.
- F. For other required changes, not involving structural, accessibility, or fire-life-safety portions of approved Drawings and Specifications, Architect will issue a document signed by District instructing Contractor to proceed with the change, for subsequent inclusion in a Change Order.
 1. The document will describe the required changes and will designate method of determining any change in Contract Sum or Contract Time.
 2. Promptly execute the change.
 3. Construction Change Directive approval is required from DSA prior to installation.
 4. Construction Change Directives: In accordance with provisions of the Conditions of the Contract, the District may direct the Contractor to proceed with a change in the Work prior to formal preparation, review and agreement of a Contract Change Order, in order to not delay construction.
 - a. The Architect will prepare and issue a change document containing a Construction Change Directive which, when signed by the District and the Architect, shall instruct the Contractor to proceed with a change in the Work, for subsequent inclusion in a Contract Change Order.
 - b. Should the Construction Change Directive result in disputed costs and time adjustments, such dispute shall be resolved in accordance with the provisions of the Conditions of the Contract.
 - c. Construction Change Directives shall follow procedures specified below for Contract Change Orders except that Contractor shall immediately proceed with the change upon receipt of the signed Change Directive.
- G. For changes for which advance pricing is desired, Architect will issue a document that includes a detailed description of a proposed change with supplementary or revised drawings and specifications, a change in Contract Time for executing the change with a stipulation of any overtime work required and the period of time during which the requested price will be considered valid. Contractor shall prepare and submit a fixed price quotation within 14 days.
 1. Such Request for Proposal may include an estimate of additions or deductions in Contract Time and Contract Sum for executing the change and may include stipulations regarding overtime work and the period of time the requested response from the Contractor shall be considered valid.

FOR REFERENCE ONLY

- H. Contractor may propose a change by submitting a request for change to Architect, describing the proposed change and its full effect on the work, with a statement describing the reason for the change, and the effect on the Contract Sum and Contract Time with full documentation and a statement describing the effect on work by separate or other contractors. Document any requested substitutions in accordance with Section 01 60 00 .
 - 1. After review of the request and with the District's approval, the Architect will prepare a change document containing a Request for Proposal, as described above.
 - 2. Issuance of such a request by the Architect shall not indicate authorization of the Contractor to proceed with the proposed change.
 - 3. Changes will be approved only by an approved Construction Change Directive and Contract Change Order.
- I. Computation of Change in Contract Amount: As specified in the Agreement and Conditions of the Contract.
 - 1. For change requested by Architect for work falling under a fixed price contract, the amount will be based on Contractor's price quotation.
 - 2. For change requested by Contractor, the amount will be based on the Contractor's request for a Change Order as approved by Architect.
 - 3. For pre-determined unit prices and quantities, the amount will be based on the fixed unit prices.
 - 4. For change ordered by Architect without a quotation from Contractor, the amount will be determined by Architect based on the Contractor's substantiation of costs as specified for Time and Material work.
- J. Substantiation of Costs: Provide full information required for evaluation.
 - 1. On request, provide the following data:
 - a. Quantities of products, labor, and equipment.
 - b. Taxes, insurance, and bonds.
 - c. Overhead and profit.
 - d. Justification for any change in Contract Time.
 - e. Credit for deletions from Contract, similarly documented.
 - 2. Support each claim for additional costs with additional information:
 - a. Origin and date of claim.
 - b. Dates and times work was performed, and by whom.
 - c. Time records and wage rates paid.
 - d. Invoices and receipts for products, equipment, and subcontracts, similarly documented.
 - 3. For Time and Material work, submit itemized account and supporting data after completion of change, within time limits indicated in the Conditions of the Contract.

FOR REFERENCE ONLY

- a. Cost and Time Resolution: If amounts for changes in Contract Sum and Contract Time cannot be agreed upon by District and Contractor, amounts shall be resolved in accordance with provisions of the Conditions of the Contract for resolution of disputes and the following:
 - 1) Contractor shall keep accurate records of time, both labor and calendar days, and cost of materials and equipment.
 - 2) Contractor shall prepare and submit an itemized account and supporting data after completion of changed Work, within the time limits indicated in the Conditions of the Contract.
 - 3) Contractor shall provide full information as required and requested, for District and Architect to evaluate and substantiate proposed costs and time for the change in the Work.
 - 4) When District and Contractor determine mutually acceptable amounts for changes in Contract Sum and Contract Time, a Contract Change Order shall be executed for these amounts.
 - 5) District shall have the right to audit Contractor's invoices and bid quotations to substantiate costs for Contract Change Orders.

- K. Construction Changes Based on Stipulated Sum or Time: Based on the Contractor's response to a Request for Proposal or Construction Change Directive, the District and Architect will review the response.
 - 1. The District and Contractor shall negotiate a mutually acceptable adjustment in Contract Sum and Contract Time, as appropriate, prior to performance of the changed Work.
 - 2. A Contract Change Order for the stipulated amounts shall be prepared based on the stipulated sum and change in time.

- L. Execution of Change Orders: Architect will issue Change Orders for signatures of parties as provided in the Conditions of the Contract.
 - 1. When agreement is reached on changes, if any, in the Contract Time and the Contract Sum, the Contractor shall prepare a Contract Change Order using a form as directed by the District, with supplementary documents as necessary to describe the change and the associated costs and schedule impacts.
 - 2. Construction Change Document approval is required from DSA prior to fabrication and installation.
 - 3. Submit Contract Change Orders to District through the Architect.
 - 4. Contractor shall prepare and submit five original sets of documents for each Change Order. District, Architect and DSA shall sign the Change Order indicating acceptance and approval of the change.
 - a. Structural Engineer shall also sign the Change Order, when applicable.
 - 5. All Change Orders must be approved by DSA prior to fabrication and installation.
 - 6. Upon approval of the Change Order, Contractor shall promptly execute the change in the Work.

FOR REFERENCE ONLY

- M. After execution of Change Order, promptly revise Schedule of Values and Application for Payment forms to record each authorized Change Order as a separate line item and adjust the Contract Sum.
- N. Promptly revise progress schedules to reflect any change in Contract Time, revise sub-schedules to adjust times for other items of work affected by the change, and resubmit.
 - 1. Contractor shall submit revised schedules at the next Application for Payment following approval and acceptance of the Contract Change Order.
- O. Promptly enter changes in Project Record Documents.

1.07 APPLICATION FOR FINAL PAYMENT

- A. Prepare Application for Final Payment as specified for progress payments, identifying total adjusted Contract Sum, previous payments, and sum remaining due.
- B. Application for Final Payment will not be considered until the following have been accomplished:
 - 1. All closeout procedures specified in Section 01 70 00.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

END OF SECTION

SECTION 01 25 00 SUBSTITUTION PROCEDURES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Procedural requirements for proposed substitutions.

1.02 RELATED REQUIREMENTS

- A. Division 00 - Procurement and Contracting Requirements: Restrictions on timing of substitution requests.
- B. Section 00 43 25 - Substitution Request Form - During Procurement: Required form for substitution requests made prior to award of contract (During procurement).
- C. Section 00 63 25 - Substitution Request Form - During Construction: Required form for substitution requests made after award of contract (During construction).
- D. Section 01 30 00 - Administrative Requirements: Submittal procedures, coordination.
- E. Section 01 60 00 - Product Requirements: Fundamental product requirements, product options, delivery, storage, and handling.
- F. Section 01 61 16 - Volatile Organic Compound (VOC) Content Restrictions: Restrictions on emissions of indoor substitute products.

1.03 DEFINITIONS

- A. Substitutions: Changes from Contract Documents requirements proposed by Contractor to materials, products, assemblies, and equipment.
 - 1. Substitutions for Cause: Proposed due to changed Project circumstances beyond Contractor's control.
 - a. Unavailability.
 - b. Regulatory changes.
 - 2. Substitutions for Convenience: Proposed due to possibility of offering substantial advantage to the Project.
 - a. Substitution requests offering advantages solely to the Contractor will not be considered.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION

3.01 GENERAL REQUIREMENTS

- A. Requests by Contractor to deviate from specified requirements for products, materials, equipment, and methods, or to provide products other than those specified, shall be considered requests for substitutions except under the following conditions:

FOR REFERENCE ONLY

1. Substitutions are requested during the bidding period, and accepted prior to execution of the Contract. Acceptance shall be in the form of written Addendum to the Bidding documents or revision to the Drawings or Specifications for use as Construction Contract Documents.
 2. Changes in products, materials, equipment, and methods of construction are directed by the District or Architect.
 3. Contractor options for provision of products and construction methods are specifically stated in the Contract Documents.
 4. Change in products, materials, equipment, and methods of construction is required for compliance with Codes, ordinances, regulations, orders and standards of authorities having jurisdiction.
- B. Substitution Provisions: Refer to substitution provisions of the Conditions of the Contract, in addition to the requirements specified herein. Provisions for consideration and acceptance of substitutions shall be as follows:
1. Documentation:
 - a. Substitutions will not be considered if they are indicated or implied on shop drawing, product data or sample submittals.
 - b. All requests for substitution shall be made by separate written request from Contractor.
 2. Cost and Time Considerations: Substitutions will not be considered unless a net reduction in Contract Sum or Contract Time results to the District's benefit, including redesign costs, life cycle costs, changes in related Work and overall performance of building systems.
 3. Design Revision:
 - a. Substitutions will not be considered if acceptance will require substantial revision of the Contract Documents or will substantially change the intent of the design, in the opinion of the Architect.
 - b. The intent of the design shall include functional performance and aesthetic qualities.
 4. Data: It shall be the responsibility of the Contractor to provide adequate data demonstrating the merits of the proposed substitution, including cost data and information regarding changes in related Work.
 5. Determination by Architect:
 - a. Architect will determine the acceptability of proposed substitutions and will notify Contractor, in writing within a reasonable time, of acceptance or rejection.
 - b. The determination by the Architect regarding functional performance and aesthetic quality shall be final.
 6. Non-Acceptance: If a proposed substitution is not accepted, provide the specified product.
 - a. If, in the opinion of the Architect, the substitution request is incomplete or has insufficient data to enable a full and thorough review of the intended substitution, the substitution may be summarily refused and determined to be unacceptable.

FOR REFERENCE ONLY

7. Substitution Limitation: Only one request for substitution will be considered for each product.
- C. A Substitution Request for products, assemblies, materials, and equipment constitutes a representation that the submitter:
1. Has investigated proposed product and determined that it meets or exceeds the quality level of the specified product, equipment, assembly, or system.
 - a. Include a signed certification that the Contractor has:
 - 1) Reviewed the proposed substitution and has determined that the substitution is equivalent or superior in every respect to product requirements indicated or product specified in the Contract Documents.
 - 2) Certify the proposed substitution is suited for and can perform the purpose or application of the specified product indicated or specified in the Contract Documents.
 2. Agrees to provide the same warranty for the substitution as for the specified product.
 3. Agrees to provide same or equivalent maintenance service and source of replacement parts, as applicable.
 4. Agrees to coordinate installation and make changes to other work that may be required for the work to be complete, with no additional cost to District.
 5. Waives claims for additional costs or time extension that may subsequently become apparent.
 - a. Include a signed waiver by the Contractor for changes in the Contract Time or Contract Sum because of the following:
 - 1) Substitution failed to perform adequately.
 - 2) Substitution required changes in on other elements of the Work.
 - 3) Substitution caused problems in interfacing with other elements of the Work.
 - 4) Substitution was determined to be unacceptable by authorities having jurisdiction.
 6. Agrees to reimburse District and Architect for review or redesign services associated with re-approval by authorities.
- D. A Substitution Request for specified installer constitutes a representation that the submitter:
1. Has acted in good faith to obtain services of specified installer, but was unable to come to commercial, or other terms.
- E. Document each request with complete data substantiating compliance of proposed substitution with Contract Documents. Burden of proof is on proposer.
1. Note explicitly any non-compliant characteristics.
- F. Content: Include information necessary for tracking the status of each Substitution Request, and information necessary to provide an actionable response.
1. Forms indicated and included in the Project Manual are adequate for this purpose, and must be used.

FOR REFERENCE ONLY

2. No specific form is required. Contractor's Substitution Request documentation must include the following:
 - a. Project Information:
 - 1) Official project name and number, and any additional required identifiers established in Contract Documents.
 - 2) District's, Architect's, and Contractor's names.
 - b. Substitution Request Information:
 - 1) Discrete and consecutive Substitution Request number, and descriptive subject/title.
 - 2) Indication of whether the substitution is for cause or convenience.
 - 3) Issue date.
 - 4) Reference to particular Contract Document(s) specification section number, title, and article/paragraph(s).
 - 5) Description of Substitution.
 - 6) Reason why the specified item cannot be provided.
 - 7) Differences between proposed substitution and specified item.
 - 8) Description of how proposed substitution affects other parts of work.
 - c. Attached Comparative Data: Provide point-by-point, side-by-side comparison addressing essential attributes specified, as appropriate and relevant for the item:
 - 1) Physical characteristics.
 - 2) In-service performance.
 - 3) Expected durability.
 - 4) Visual effect.
 - 5) Sustainable design features.
 - 6) Warranties.
 - 7) Other salient features and requirements.
 - 8) Include, as appropriate or requested, the following types of documentation:
 - (a) Product Data:
 - (b) Samples.
 - (c) Certificates, test, reports or similar qualification data.
 - (d) Drawings, when required to show impact on adjacent construction elements.
 - 9) Include a detailed description, in written or graphic form as appropriate, indicating all changes or modifications needed to other elements of the Work and to construction to be performed by the District and by others under separate Contract with District, that will be necessary if the proposed substitution is accepted.
 - d. Impact of Substitution:
 - 1) Savings to District for accepting substitution.

- (a) Include detailed cost data, including a proposal for the net change, if any, in the Contract Sum.
- 2) Change to Contract Time due to accepting substitution.
 - (a) Indicate the substitution's effect on the Construction Schedule. Indicate the effect of the proposed substitution on overall Contract Time and, as applicable, on completion of portions of the Work for use by District or for work under separate contract by District.
- G. Limit each request to a single proposed substitution item.
 - 1. Submit an electronic document, combining the request form with supporting data into single document.

3.02 SUBSTITUTION PROCEDURES DURING PROCUREMENT

- A. Submittal Time Restrictions:
 - 1. District will consider requests for substitutions only if submitted at least 10 days prior to the date for receipt of bids.
- B. Instructions to Bidders specifies time restrictions for submitting requests for substitutions during the bidding period, and the documents required.
- C. Pursuant to Section 3400 of the Public Contract Code, requests for substitution will be considered only if received up to 7 days prior to the bid date. Subsequent requests will be considered only in the case of product unavailability, through no fault of the Contractor , or for reasons of cost reducing value analysis requested by the District .
- D. Submittal Form (before award of contract):
 - 1. Submit substitution requests by completing the form in Section 00 43 25; see this section for additional information and instructions. Use only this form; other forms of submission are unacceptable.

3.03 SUBSTITUTION PROCEDURES DURING CONSTRUCTION

- A. Submittal Form (after award of contract):
 - 1. Submit substitution requests by completing the form in Section 00 63 25; see this section for additional information and instructions. Use only this form; other forms of submission are unacceptable.
- B. After Contract award, requests will be considered for cause only; in the case of product unavailability, through no fault of the Contractor , or for reasons of cost reducing value analysis requested by the District.
 - 1. Substitutions will be considered when a product, through no fault of the Contractor, becomes unavailable or unsuitable due to regulatory change.
 - 2. Product Availability Waiver:
 - a. Substitutions will be considered after 35 day time limit only when a product becomes unavailable due to no fault of Contractor.
 - b. Failure to place orders for specified products sufficiently in advance of required date for incorporation into the Work will not be considered as a valid reason for which Contractor may request a substitution or deviation from requirements of the Drawings and Specifications.

FOR REFERENCE ONLY

3. Waiver: At the discretion of the District, limitations on substitutions may be waived.
- C. Submit request for Substitution for Cause within 14 days of discovery of need for substitution, but not later than 14 days prior to time required for review and approval by Architect, in order to stay on approved project schedule.
- D. Submit request for Substitution for Convenience immediately upon discovery of its potential advantage to the project, but not later than 14 days prior to time required for review and approval by Architect, in order to stay on approved project schedule.
 1. In addition to meeting general documentation requirements, document how the requested substitution benefits the District through cost savings, time savings, greater energy conservation, or in other specific ways.
 2. Document means of coordinating of substitution item with other portions of the work, including work by affected subcontractors.
 3. Bear the costs engendered by proposed substitution of:
 - a. District's compensation to the Architect for any required redesign, time spent processing and evaluating the request.
 - b. Other construction by District.
 - c. Other unanticipated project considerations.
- E. Substitutions will not be considered under one or more of the following circumstances:
 1. When they are indicated or implied on shop drawing or product data submittals, without having received prior approval.
 2. Without a separate written request.
 3. When acceptance will require revisions to Contract Documents.

3.04 CONTRACT DOCUMENT REVISIONS:

- A. Should a Contractor-proposed substitution or alternative sequence or method of construction require revision of the Contract Drawings or Specifications;
 1. Including revisions for the purposes of determining feasibility, scope or cost, or revisions for the purpose of obtaining review and approval by authorities having jurisdiction.
 2. Revisions will be made by Architect or other consultant of District who is the responsible design professional, as approved in advance by District.
- B. Services of Architect or other consultant of the District, including time spent in researching and reporting on proposed substitutions or alternative sequence and method of construction, shall be paid by Contractor when such activities are considered additional services to the design services contracts of the Architect or other responsible design professional with the District.
- C. Costs of services by Architect or other responsible design professional of the District shall be paid on a time and materials basis, based on current hourly fee schedules, with reproduction, long distance telephone and shipping costs reimbursable at cost plus usual and customary mark-up for handling and billing.
- D. Such fees shall be paid whether or not the proposed substitution or alternative sequence or method of construction is ultimately accepted by District and a Change Order is executed.

- E. Such fees shall be paid from Contractor's portion of savings, if a net reduction in Contract Sum results. If fees exceed Contractor's portion of net reduction, Contractor shall pay all remaining fees unless otherwise agreed in advance by the District.
- F. Such fees owed shall be deducted from the amount owed Contractor on the Application for Payment next made following completion of revised Contract Drawings and Specifications or completion of research and other services. District will then pay Architect or other consultant of the District.
- G. Certain substitutions require approval from DSA.
 - 1. Substitutions affecting DSA-regulated items shall be considered as construction change documents (CCD's) and shall be approved by DSA prior to construction per DSA IR A-6 and Section 338(c) Part 1, Title 24 CCR. See Section 01 20 00 - Price and Payment Procedures.

3.05 RESOLUTION

- A. Architect may request additional information and documentation prior to rendering a decision. Provide this data in an expeditious manner.
- B. Architect will notify Contractor in writing of decision to accept or reject request.
 - 1. Architect's decision following review of proposed substitution will be noted on the submitted form.

3.06 ACCEPTANCE

- A. Accepted substitutions change the work of the Project. They will be documented and incorporated into work of the project by Change Order, Construction Change Directive, Architectural Supplementary Instructions, or similar instruments provided for in the Conditions of the Contract.

3.07 CLOSEOUT ACTIVITIES

- A. See Section 01 78 00 - Closeout Submittals, for closeout submittals.
- B. Include completed Substitution Request Forms as part of the Project record. Include both approved and rejected Requests.

3.08 ATTACHMENTS

- A. A facsimile of the Substitution Request Form (During Construction) required to be used on the Project is included after this section.

END OF SECTION

SECTION 01 30 00 ADMINISTRATIVE REQUIREMENTS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. General administrative requirements.
- B. Electronic document submittal service.
- C. Preconstruction meeting.
- D. Site mobilization meeting.
- E. Progress meetings.
- F. Contractor's daily reports.
- G. Progress photographs.
- H. Coordination drawings.
- I. Submittals for review, information, and project closeout.
- J. Number of copies of submittals.
- K. Requests for Interpretation or Information (RFI) procedures.
- L. Submittal procedures.

1.02 RELATED REQUIREMENTS

- A. Section 01 60 00 - Product Requirements: General product requirements.
- B. Section 01 70 00 - Execution and Closeout Requirements: Additional coordination requirements.
- C. Section 01 78 00 - Closeout Submittals: Project record documents; operation and maintenance data; warranties and bonds.
- D. Technical Product Sections: Procedures for specific submittals specified in those Sections to be made at Contract closeout.

1.03 DEFINITIONS

- A. Action Submittals: Written and graphic information that requires responsive action by Construction Manager and Architect or other responsible design professional.
- B. Informational Submittals: Written information that does not require responsive action by Construction Manager and Architect or other responsible design professional.
- C. Unsolicited Submittals: Action or informational submittals not required by the Contract Documents or not requested by the reviewer. Unsolicited submittals may be returned with notation "not reviewed."
- D. Product Data: Standard published information ("catalog cuts") and specially prepared data for the Work of the Contract, including standard illustrations, schedules, brochures, diagrams, performance charts, instructions and other information to illustrate a portion of the Work.

- E. Request for Interpretation or Information (RFI): A document submitted by the Contractor requesting clarification of a portion of the Contract Documents, hereinafter referred to as an RFI.
- F. Samples: Physical examples that demonstrate the materials, finishes, features, workmanship and other characteristics of a portion of the Work. Accepted samples shall serve as quality basis for evaluating the Work.
- G. Shop Drawings, Product Data and Samples: Instruments prepared and submitted by Contractor, for Contractor's benefit, to communicate to Architect the Contractor's understanding of the design intent, for review and comment by Architect on the conformance of the submitted information to the general intent of the design. Shop drawings, product data and samples are not Contract Documents.
- H. Shop Drawings: Drawings, diagrams, schedules and illustrations, with related notes, specially prepared for the Work of the Contract, to illustrate a portion of the Work.
- I. Other Submittals: Technical data, test reports, calculations, surveys, certifications, special warranties and guarantees, operation and maintenance data, extra stock and other submitted information and products shall not be considered as Contract Documents but shall be information from Contractor to Architect to illustrate a portion of the Work for confirmation of understanding of design intent.

1.04 PROJECT COORDINATOR

- A. Project Coordinator: Construction Manager.
- B. Cooperate with the Project Coordinator in allocation of mobilization areas of site; for field offices and sheds, for material delivery access, traffic, and parking facilities.
 - 1. Comply with requirements of Section 01 70 00 - Execution and Closeout Requirements for coordination of execution of administrative tasks with timing of construction activities.
- C. During construction, coordinate use of site and facilities through the Project Coordinator.
- D. Comply with Project Coordinator's procedures for intra-project communications; submittals, reports and records, schedules, coordination drawings, and recommendations; and resolution of ambiguities and conflicts.
- E. Comply with instructions of the Project Coordinator for use of temporary utilities and construction facilities. Responsibility for providing temporary utilities and construction facilities is identified in Section 01 10 00 - Summary.
- F. Coordinate field engineering and layout work under instructions of the Project Coordinator.
- G. Make the following types of submittals to Architect through the Project Coordinator:
 - 1. Requests for Interpretation or Information.
 - 2. Requests for substitution.
 - 3. Shop drawings, product data, and samples.
 - 4. Test and inspection reports.
 - 5. Manufacturer's instructions and field reports.
 - 6. Applications for payment and change order requests.
 - 7. Progress schedules.

8. Coordination drawings.
9. Correction Punch List and Final Correction Punch List for Final Inspection.
10. Closeout submittals.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION

3.01 ELECTRONIC DOCUMENT SUBMITTAL SERVICE

- A. All documents transmitted for purposes of administration of the contract are to be in electronic (PDF, MS Word, or MS Excel) format, as appropriate to the document, and transmitted via an Internet-based submittal service that receives, logs and stores documents, provides electronic stamping and signatures, and notifies addressees via email.
 1. Besides submittals for review, information, and closeout, this procedure applies to Requests for Interpretation or Information (RFIs), progress documentation, contract modification documents (e.g. supplementary instructions, change proposals, change orders), applications for payment, field reports and meeting minutes, Contractor's correction punchlist, and any other document any participant wishes to make part of the project record.
 2. Contractor and Architect are required to use this service.
 3. It is Contractor's responsibility to submit documents in allowable format.
 4. Subcontractors, suppliers, and Architect's consultants are to be permitted to use the service at no extra charge.
 5. Users of the service need an email address, internet access, and PDF review software that includes ability to mark up and apply electronic stamps (such as Adobe Acrobat, www.adobe.com, or Bluebeam PDF Revu, www.bluebeam.com), unless such software capability is provided by the service provider.
 6. Unless specifically requested, paper document transmittals will not be reviewed; emailed electronic documents will not be reviewed.
 7. All other specified submittal and document transmission procedures apply, except that electronic document requirements do not apply to samples or color selection charts.
- B. Cost: The cost of the service is to be paid by Contractor; include the cost of the service in the Contract Sum.
- C. Submittal Service: The selected service is:
 1. Bluebeam Software Inc.; Bluebeam Revu Studio: www.bluebeam.com.
 2. Other Service acceptable to both District and Architect.
 - a. Direct email with PDF copies.
- D. Training: One, one-hour, web-based training session will be arranged for all participants, with representatives of Architect and Contractor participating; further training is the responsibility of the user of the service.
 1. Representatives of District are scheduled and included in this training.

- E. Project Closeout: Architect will determine when to terminate the service for the project and is responsible for obtaining archive copies of files for District.

3.02 PRECONSTRUCTION MEETING

- A. District will schedule a meeting after Notice of Award.
- B. Attendance Required:
 - 1. District.
 - 2. Architect.
 - 3. Contractor.
 - 4. Construction Manager.
- C. Agenda:
 - 1. Execution of District-Contractor Agreement.
 - 2. Submission of executed bonds and insurance certificates.
 - 3. Distribution of Contract Documents.
 - 4. Submission of list of subcontractors, list of products, schedule of values, and progress schedule.
 - 5. Submission of initial Submittal schedule.
 - 6. Designation of personnel representing the parties to Contract and Architect.
 - 7. Procedures and processing of field decisions, submittals, substitutions, applications for payments, proposal request, Change Orders, and Contract closeout procedures.
 - 8. Scheduling.
 - 9. Scheduling activities of a Geotechnical Engineer.
- D. Record minutes and distribute copies within two days after meeting to participants, with two copies to Architect, District, participants, and those affected by decisions made.

3.03 SITE MOBILIZATION MEETING

- A. Project Coordinator will schedule meeting at the Project site prior to Contractor occupancy.
- B. Attendance Required:
 - 1. Contractor.
 - 2. District.
 - 3. Architect.
 - 4. Construction Manager.
 - 5. Special consultants.
 - 6. Contractor's superintendent.
 - 7. Major subcontractors.
 - 8. Inspector of Record.
 - 9. DSA Field Representative.
- C. Agenda:

FOR REFERENCE ONLY

1. Designation of Key Personnel: Contractor shall designate key personnel and provide a name and address list which includes the following:
 - a. Contractor: Project Manager and Superintendent.
 - b. Major subcontractors: Principal/Project Manager and Superintendent.
 - c. Major materials suppliers: Contact person.
2. Distribute and discuss list of subcontractors and suppliers.
3. Project Communication Procedures: Review requirements and administrative requirements for written and oral communications.
 - a. Review requirements and administrative procedures Contractor may wish to institute for identification and reporting purposes.
4. Change Procedures: Review requirements and administrative procedures for Change Orders, Construction Change Directives, Architect's supplemental instructions and Contractor's Requests for Interpretation or Information.
5. Use of premises by District and Contractor.
 - a. Site access restrictions, if any, and requirements to avoid disruption of operations at adjoining facilities or operations.
 - b. Construction Facilities and Temporary Utilities: Designate storage and staging areas, construction office areas; review temporary utility provisions; present District's requirements for use of premises.
6. District's requirements.
7. Construction facilities and controls provided by District.
8. Temporary utilities provided by District.
9. Survey and building layout.
10. Security and housekeeping procedures.
11. Schedules.
 - a. Distribute and discuss initial construction schedule and critical work sequencing of major elements of Work;
 - b. Include coordination of District Furnished / Contractor Installed (OFCl) products;
 - c. Work under separate contracts by serving utility agencies;
 - d. Work under separate contracts by companies and District.
12. Review requirements for Contractor's coordination of Work; review sequence and schedule for work being performed for District under separate contracts.
13. Submittals Administration: Review administrative procedures for shop drawings, product data and samples submittals and review of preliminary Submittals Schedule.
14. Materials and Equipment:
 - a. Review substitution requirements;
 - b. Review schedule for major equipment purchases and deliveries;
 - c. Review materials and equipment to be provided by District (OFCl products).

15. Permits and Fees: Review Contract requirements and review schedule and process for obtaining permits and paying fees.
 16. Application for payment procedures.
 17. Procedures for testing.
 - a. Review tests and inspections to be performed by the following:
 - 1) Independent testing and inspection agency.
 - 2) Manufacturers and installers.
 - 3) Serving utilities and public agencies.
 - 4) Authorities having jurisdiction.
 18. Procedures for maintaining record documents.
 19. Requirements for start-up of equipment.
 - a. Operation and Maintenance Data:
 - 1) Format and content of operation and maintenance manuals; instruction of District's personnel.
 20. Inspection and acceptance of equipment put into service during construction period.
- D. Record minutes and distribute copies within two days after meeting to participants, with two copies to Architect, District, participants, and those affected by decisions made.

3.04 PROGRESS MEETINGS

- A. Schedule and administer meetings throughout progress of the work at maximum bi-weekly intervals.
- B. Make arrangements for meetings, prepare agenda with copies for participants, preside at meetings.
- C. Meeting Time and Location: As mutually agreed by District, Architect, and Contractor, at on-site location.
- D. Special Meetings: As necessary, Construction Manager may convene special meetings to discuss specific construction issues in detail and to plan specific activities.
 1. See Section 01 70 00 - Execution and Closeout Requirements.
- E. Attendance Required:
 1. Contractor.
 2. District.
 3. Architect.
 4. Construction Manager.
 5. Special consultants.
 6. Contractor's superintendent.
 7. Major subcontractors.
 8. Inspector of Record.
- F. Agenda:

FOR REFERENCE ONLY

1. Review minutes of previous meetings.
 - a. Unless published minutes are challenged in writing prior to the next regularly scheduled progress meeting, they will be accepted as properly stating the activities and decisions of the meeting.
 - b. Persons challenging published minutes shall reproduce and distribute copies of the challenge to all indicated recipients of the particular set of minutes.
 - c. Challenge to minutes shall be settled as priority portions of "old business" at the next regularly scheduled meeting.
 2. Review of work progress.
 3. Field observations, problems, and decisions.
 4. Identification of problems that impede, or will impede, planned progress.
 5. Review of submittals schedule and status of submittals.
 6. Review of RFIs log and status of responses.
 7. Review of off-site fabrication and delivery schedules.
 8. Maintenance of progress schedule.
 9. Corrective measures to regain projected schedules.
 - a. Develop corrective measures and procedures, including but not necessarily limited to additional personnel loading to regain planned schedule.
 10. Planned progress during succeeding work period.
 11. Coordination of projected progress.
 12. Maintenance of quality and work standards.
 13. Effect of proposed changes on progress schedule and coordination.
 14. Other business relating to work.
- G. Record minutes and distribute copies within two days after meeting to participants, with copies to Architect, District, participants, and those affected by decisions made.

3.05 CONSTRUCTION PROGRESS SCHEDULE

- A. Within 10 days after date of the Agreement, submit preliminary schedule defining planned operations for the first 60 days of work, with a general outline for remainder of work.
- B. Contractor's Review: All schedules shall be reviewed and approved by Contractor prior to submission for Architect's and District's review.
- C. Reviews by Architect and District will be to ascertain the general status of construction and shall not be interpreted to establish or approve the means, methods, techniques and sequences of construction.
- D. If preliminary schedule requires revision after review, submit revised schedule within 10 days.
- E. Within 20 days after review of preliminary schedule, submit draft of proposed complete schedule for review.
 1. Include written certification that major contractors have reviewed and accepted proposed schedule.
- F. Within 10 days after joint review, submit complete schedule.

- G. Submit updated schedule with each Application for Payment.

3.06 DAILY CONSTRUCTION REPORTS

- A. Include only factual information. Do not include personal remarks or opinions regarding operations and/or personnel.
- B. In addition to transmitting electronically a copy to District and Architect, submit two printed copies at weekly intervals.
 - 1. Submit in format acceptable to District.
 - 2. Submit using required form, a sample of which is appended to this section.
- C. Prepare a daily construction report recording the following information concerning events at Project site and project progress:
 - 1. Date.
 - 2. High and low temperatures, and general weather conditions.
 - 3. List of subcontractors at Project site.
 - 4. List of separate contractors at Project site.
 - 5. Approximate count of personnel at Project site.
 - a. Include a breakdown for supervisors, laborers, journeymen, equipment operators, and helpers.
 - 6. Major equipment at Project site.
 - 7. Material deliveries.
 - 8. Safety, environmental, or industrial relations incidents.
 - 9. Meetings and significant decisions.
 - 10. Unusual events (submit a separate special report).
 - 11. Stoppages, delays, shortages, and losses. Include comparison between scheduled work activities (in Contractor's most recently updated and published schedule) and actual activities. Explain differences, if any. Note days or periods when no work was in progress and explain the reasons why.
 - 12. Meter readings and similar recordings.
 - 13. Emergency procedures.
 - 14. Directives and requests of Authority(s) Having Jurisdiction (AHJ).
 - 15. Change Orders received and implemented.
 - 16. Testing and/or inspections performed.
 - 17. List of verbal instruction given by District and/or Architect.
 - 18. Signature of Contractor's authorized representative.

3.07 PROGRESS PHOTOGRAPHS

- A. Submit photographs with each application for payment, taken not more than 3 days prior to submission of application for payment.
- B. Maintain one set of all photographs at project site for reference; same copies as submitted, identified as such.

FOR REFERENCE ONLY

- C. Photography Type: Digital; electronic files.
- D. Provide photographs of site and construction throughout progress of work produced by an experienced photographer, acceptable to Architect.
- E. In addition to periodic, recurring views, take photographs of each of the following events:
 - 1. Completion of site clearing.
 - 2. Excavations in progress.
 - 3. Foundations in progress and upon completion.
 - 4. Structural framing in progress and upon completion.
 - 5. Enclosure of building, upon completion.
 - 6. Final completion, minimum of ten (10) photos.
- F. Take photographs as evidence of existing project conditions as follows:
 - 1. Interior views: each elevation, floor and ceilings prior to demolition.
 - 2. Exterior views: each elevation, roof and areas adjacent to construction limits.
- G. Views:
 - 1. Provide non-aerial photographs from four cardinal views at each specified time, until date of Final Inspection.
 - 2. Consult with Architect for instructions on views required.
 - 3. Provide factual presentation.
 - 4. Provide correct exposure and focus, high resolution and sharpness, maximum depth of field, and minimum distortion.
 - 5. Point of View Sketch: Provide sketch identifying point of view of each photograph.
- H. Digital Photographs: 24 bit color, minimum resolution of 1024 by 768, in JPG format; provide files unaltered by photo editing software.
 - 1. Delivery Medium: Via email.
 - 2. File Naming: Include project identification, date and time of view, and view identification.
 - 3. Point of View Sketch: Include digital copy of point of view sketch with each electronic submittal; include point of view identification in each photo file name.
 - 4. PDF File: Assemble all photos into printable pages in PDF format, with 2 to 3 photos per page, each photo labeled with file name; one PDF file per submittal.
 - 5. Photo CD(s): Provide 1 copy including all photos cumulative to date and PDF file(s), with files organized in separate folders by submittal date.
 - 6. Hard Copy: Printed hardcopy (grayscale) of PDF file and point of view sketch.

3.08 COORDINATION DRAWINGS

- A. See Section 01 31 14 - Facility Services Coordination.
- B. Provide information required by Project Coordinator for preparation of coordination drawings.
- C. Review drawings prior to submission to Architect.

3.09 REQUESTS FOR INTERPRETATION OR INFORMATION (RFI)

- A. Definition: A request seeking one of the following:
 - 1. An interpretation, amplification, or clarification of some requirement of Contract Documents arising from inability to determine from them the exact material, process, or system to be installed; or when the elements of construction are required to occupy the same space (interference); or when an item of work is described differently at more than one place in the Contract Documents.
 - 2. A resolution to an issue which has arisen due to field conditions and affects design intent.
- B. Whenever possible, request clarifications at the next appropriate project progress meeting, with response entered into meeting minutes, rendering unnecessary the issuance of a formal RFI.
- C. Preparation: Prepare an RFI immediately upon discovery of a need for interpretation of Contract Documents. Failure to submit a RFI in a timely manner is not a legitimate cause for claiming additional costs or delays in execution of the work.
 - 1. Prepare a separate RFI for each specific item.
 - a. Review, coordinate, and comment on requests originating with subcontractors and/or materials suppliers.
 - b. Do not forward requests which solely require internal coordination between subcontractors.
 - 2. Prepare in a format and with content acceptable to District.
 - 3. Combine RFI and its attachments into a single electronic file. PDF format is preferred.
- D. Reason for the RFI: Prior to initiation of an RFI, carefully study all Contract Documents to confirm that information sufficient for their interpretation is definitely not included.
 - 1. Include in each request Contractor's signature attesting to good faith effort to determine from Contract Documents information requiring interpretation.
 - a. Submit RFIs from subcontractors and material suppliers through, be reviewed by and be attached to an RFI prepared, signed and submitted by Contractor.
 - 1) RFIs from subcontractors and material suppliers are to be:
 - (a) Reviewed by Contractor.
 - (b) Corrected and rewritten to clarify as required by Contractor.
 - (c) Placed on the proper form, then signed, and submitted by Contractor.
 - (d) RFIs submitted directly by subcontractors or material suppliers will be returned unanswered to the Contractor.
 - 2) RFIs submitted directly by subcontractors or material suppliers will be returned unanswered to the Contractor.
 - b. Review all subcontractor- and supplier-initiated RFIs and take actions to resolve issues of coordination, sequencing and layout of the Work.
 - 1) RFIs submitted to request clarification of issues related to means, methods, techniques and sequences of construction or for establishing trade jurisdictions and scopes of subcontracts will be returned without response.

FOR REFERENCE ONLY

- (a) Such issues are solely the Contractor's responsibility.
- 2) Contractor is responsible for delays resulting from the necessity to resubmit an RFI due to insufficient or incorrect information presented in the RFI.
2. Unacceptable Uses for RFIs: Do not use RFIs to request the following:
 - a. Approval of submittals (use procedures specified elsewhere in this section).
 - b. Approval of substitutions (see Section - 01 60 00 - Product Requirements)
 - c. Changes that entail change in Contract Time and Contract Sum (comply with provisions of the Conditions of the Contract).
 - d. Different methods of performing work than those indicated in the Contract Drawings and Specifications (comply with provisions of the Conditions of the Contract).
3. Improper RFIs: Requests not prepared in compliance with requirements of this section, and/or missing key information required to render an actionable response. They will be returned without a response, with an explanatory notation.
4. Frivolous RFIs: Requests regarding information that is clearly indicated on, or reasonably inferable from, Contract Documents, with no additional input required to clarify the question. They will be returned without a response, with an explanatory notation.
 - a. The District reserves the right to assess the Contractor for the costs (on time-and-materials basis) incurred by the Architect, and any of its consultants, due to processing of such RFIs.
- E. Content: Include identifiers necessary for tracking the status of each RFI, and information necessary to provide an actionable response.
 1. Official Project name and number, and any additional required identifiers established in Contract Documents.
 2. District's, Architect's, and Contractor's names.
 3. Discrete and consecutive RFI number, and descriptive subject/title.
 4. Issue date, and requested reply date.
 5. Reference to particular Contract Document(s) requiring additional information/interpretation. Identify pertinent drawing and detail number and/or specification section number, title, and paragraph(s).
 6. Annotations: Field dimensions and/or description of conditions which have engendered the request.
 - a. Inability to determine from the Contract Documents the exact material, process, or system to be installed;
 - b. Or when the elements of construction are required to occupy the same space (interference);
 - c. Or when an item of Work is described differently at more than one place in the Contract Documents.

FOR REFERENCE ONLY

7. Contractor's suggested resolution: A written and/or a graphic solution, to scale, is required in cases where clarification of coordination issues is involved, for example; routing, clearances, and/or specific locations of work shown diagrammatically in Contract Documents. If applicable, state the likely impact of the suggested resolution on Contract Time or the Contract Sum.
 - a. In all cases, furnish all information required for the Architect to analyze and/or understand the circumstances causing the RFI and prepare a clarification or direction as to proceed for RFIs issued to request clarification of issues related to:
 - 1) Means, methods, techniques and sequences of construction, for example
 - 2) Pipe and duct routing, clearances;
 - 3) Specific locations of Work shown diagrammatically;
 - 4) Apparent interferences and similar items.
 - 5) If information included with this type RFI by the Contractor is insufficient, the RFI will be returned unanswered.
- F. Attachments: Include sketches, coordination drawings, descriptions, photos, submittals, and other information necessary to substantiate the reason for the request.
- G. RFI Log: Prepare and maintain a tabular log of RFIs for the duration of the project.
 1. Indicate current status of every RFI. Update log promptly and on a regular basis.
 2. Note dates of when each request is made, and when a response is received.
 3. Highlight items requiring priority or expedited response.
 4. Highlight items for which a timely response has not been received to date.
 5. Identify and include improper or frivolous RFIs.
- H. Review Time: Architect will respond and return RFIs to Contractor within seven calendar days of receipt. For the purpose of establishing the start of the mandated response period, RFIs received after 12:00 noon will be considered as having been received on the following regular working day.
 1. Response period may be shortened or lengthened for specific items, subject to mutual agreement, and recorded in a timely manner in progress meeting minutes.
- I. Responses: Content of answered RFIs will not constitute in any manner a directive or authorization to perform extra work or delay the project. If in Contractor's belief it is likely to lead to a change to Contract Sum or Contract Time, promptly issue a notice to this effect, and follow up with an appropriate Change Order request to District.
 1. Response may include a request for additional information, in which case the original RFI will be deemed as having been answered, and an amended one is to be issued forthwith. Identify the amended RFI with an R suffix to the original number.
 2. Do not extend applicability of a response to specific item to encompass other similar conditions, unless specifically so noted in the response.
 3. Upon receipt of a response, promptly review and distribute it to all affected parties, and update the RFI Log.

FOR REFERENCE ONLY

4. Notify Architect within seven calendar days if an additional or corrected response is required by submitting an amended version of the original RFI, identified as specified above.

3.10 SUBMITTAL SCHEDULE

- A. Submit to Architect for review a schedule for submittals in tabular format.
 1. Submit at the same time as the preliminary schedule.
 - a. Submit initial Submittals Schedule within 14 days of date of Notice of Award of construction.
 - b. After review and return by Architect, resubmit Submittals Schedule within 10 days and thereafter submit updated Submittals Schedules at each Construction Progress Meeting.
 - c. Submit one copy each to Owner and Architect.
 2. Coordinate with Contractor's construction schedule and schedule of values.
 3. Format schedule to allow tracking of status of submittals throughout duration of construction.
 - a. Prepare schedules in Gantt format using software at Contractor's option, providing clear indication of sequencing and scheduling of Work, for determination of "critical path" of construction progress.
 - 1) Submittals shall be connected to the related construction element by a graphically indicated critical path on the same page.
 - 2) Present schedules using opaque reproductions on substantial paper, with sheet size a multiple of 8-1/2 by 11 inches and large enough to clearly read characters.
 4. Arrange information to include scheduled date for initial submittal, specification number and title, submittal category (for review or for information), description of item of work covered, and role and name of subcontractor.
 5. Account for time required for preparation, review, manufacturing, fabrication and delivery when establishing submittal delivery and review deadline dates.
 - a. For assemblies, equipment, systems comprised of multiple components and/or requiring detailed coordination with other work, allow for additional time to make corrections or revisions to initial submittals, and time for their review.
 - b. Allow time for shipping and distribution to involved parties. Minimum 1 day, including those sent by electronic transmission.
 6. Posting: Post one copy of most recent Submittals Schedule in Contractor's field office, readily available to District, Construction Manager, and Architect. Update bi-weekly with project schedule.
 7. Archive: Preserve a minimum of two copies of all superseded schedules, with one copy available at field office for review by District or Architect.

3.11 SUBMITTALS FOR REVIEW

- A. When the following are specified in individual sections, submit them for review:

1. Product data.
 2. Shop drawings.
 3. Samples for selection.
 4. Samples for verification.
- B. Submit to Architect for review for the limited purpose of checking for compliance with information given and the design concept expressed in Contract Documents.
- C. Samples will be reviewed for aesthetic, color, or finish selection.
- D. After review, provide copies and distribute in accordance with SUBMITTAL PROCEDURES article below and for record documents purposes described in Section 01 78 00 - Closeout Submittals.

3.12 SUBMITTALS FOR INFORMATION

- A. When the following are specified in individual sections, submit them for information:
1. Design data.
 2. Certificates.
 3. Test reports.
 4. Inspection reports.
 5. Manufacturer's instructions.
 6. Manufacturer's field reports.
 7. Other types indicated.
- B. Submit for Architect's knowledge as contract administrator or for District.

3.13 SUBMITTALS FOR COMMISSIONING

- A. The Commissioning Authority will receive a copy of the standard submittals for equipment to be commissioned.
- B. The Commissioning Authority may require additional documentation necessary for the commissioning process. The Contractor will receive a written request from the Commissioning Authority for specific equipment or system information.

3.14 SUBMITTALS FOR PROJECT CLOSEOUT

- A. Submit Correction Punch List for Substantial Completion.Final Inspection.
- B. Submit Final Correction Punch List for Final Inspection.
- C. When the following are specified in individual sections, submit them at project closeout in compliance with requirements of Section 01 78 00 - Closeout Submittals:
1. Project record documents.
 2. Operation and maintenance data.
 - a. Include operation and maintenance data submittals in Submittals Schedule specified above.
 - b. Provide space for review action stamps and, if required by governing authorities having jurisdiction, license seal of design Professional, if applicable.

3. Warranties.
 4. Bonds.
 5. Other types as indicated.
- D. Submit for District's benefit during and after project completion.

3.15 NUMBER OF COPIES OF SUBMITTALS

- A. Electronic Documents: Submit one electronic copy in PDF format with renderable text; an electronically-marked up file will be returned. Create PDFs at native size and right-side up; illegible files will be rejected.
- B. Small Size Sheets, Not Larger Than 11 by 17 inch: Submit one copy; the Contractor shall make his own copies from original returned by the Architect after making his own file copy.
- C. Extra Copies at Project Closeout: See Section 01 78 00.
- D. Samples: Submit the number specified in individual specification sections; one of which will be retained by Architect.
 1. After review, produce duplicates.
 2. Retained samples will not be returned to Contractor unless specifically so stated.
 3. Quantity:
 - a. Submit minimum of four (4) samples of each of color, texture and pattern.
 - b. Submit one item only of actual assembly or product.
 - c. Unless otherwise noted, full-size and complete samples will be returned and may be incorporated into field mock-ups and the Work.

3.16 SUBMITTAL PROCEDURES

- A. General Requirements:
 1. Use a separate transmittal for each item.
 2. Submit separate packages of submittals for review and submittals for information, when included in the same specification section.
 3. Transmit using approved form.
 4. Sequentially identify each item. For revised submittals use original number and a sequential numerical suffix.
 5. Identify: Project; Contractor; subcontractor or supplier; pertinent drawing and detail number; and specification section number and article/paragraph, as appropriate on each copy.
 - a. For example:
 - 1) 09 21 16-1 - First submittal for Section 09 21 16 - Gypsum Board Assemblies.
 - 2) 09 21 16-2 - Second submittal for Section 09 21 16 - Gypsum Board Assemblies.
 - b. Use same number for resubmittals as original submittal, followed by a letter indicating sequential resubmittal. For example:
 - 1) 09 21 16-2A - Resubmission of second submittal for Section 09 21 16 - Gypsum Board Assemblies.

FOR REFERENCE ONLY

- 2) 09 21 16-2B - Second resubmission of second submittal for Section 09 21 16 - Gypsum Board Assemblies.
6. Apply Contractor's stamp, signed or initialed certifying that review, approval, verification of products required, field dimensions, adjacent construction work, and coordination of information is in accordance with the requirements of the work and Contract Documents.
 - a. Submittals from sources other than the Contractor, or without Contractor's stamp will not be acknowledged, reviewed, or returned.
 - b. Field measurements have been determined and verified.
 - c. Conformance with requirements of Contract Drawings and Specifications is confirmed.
 - d. Catalog numbers and similar data are correct.
 - e. Work being performed by various subcontractors and trades is coordinated.
 - f. Field construction criteria have been verified, including confirmation that information submitted has been coordinated with the work being performed by others for District and actual site conditions.
 - g. All deviations from requirements of Drawings and Specifications have been identified and noted.
7. Deliver each submittal on date noted in submittal schedule, unless an earlier date has been agreed to by all affected parties, and is of the benefit to the project.
 - a. Send submittals in electronic format via email to Architect.
 - b. Upload submittals in electronic form to Electronic Document Submittal Service website.
8. Schedule submittals to expedite the Project, and coordinate submission of related items.
 - a. For each submittal for review, allow 15 days excluding delivery time to and from the Contractor.
 - b. For sequential reviews involving Architect's consultants, District, or another affected party, allow an additional 7 days.
 - c. For sequential reviews involving approval from authorities having jurisdiction (AHJ), in addition to Architect's approval, allow an additional 30 days.
9. Identify variations from Contract Documents and product or system limitations that may be detrimental to successful performance of the completed work.
 - a. Changes in the Work shall not be authorized by submittals review actions.
 - b. No review action, implicit or explicit, shall be interpreted to authorized changes in the Work.
 - c. Changes shall only be authorized by separate written Contract Change Order or Construction Change Directive, in accordance with the Conditions of the Contract and Section 01 20 00 - Price and Payment Procedures.
10. Provide space for Contractor and Architect review stamps.
11. When revised for resubmission, identify all changes made since previous submission.

FOR REFERENCE ONLY

12. Distribute reviewed submittals. Instruct parties to promptly report inability to comply with requirements.
 13. Incomplete submittals will not be reviewed, unless they are partial submittals for distinct portion(s) of the work, and have received prior approval for their use.
 14. Submittals not requested will be recognized, but will be returned without comment,
- B. Product Data Procedures:
1. Submit only information required by individual specification sections.
 2. Collect required information into a single submittal.
 3. Submit concurrently with related shop drawing submittal.
 4. Do not submit (Material) Safety Data Sheets for materials or products.
- C. Shop Drawing Procedures:
1. Prepare accurate, drawn-to-scale, original shop drawing documentation by interpreting Contract Documents and coordinating related work.
 2. Use of reproductions of Contract Documents in digital data form to create shop drawings is only permitted as defined in Division 01 and individual product sections.
 3. Coordination: Show all field dimensions and relationships to adjacent or critical features of Work.
 4. Generic, non-project-specific information submitted as shop drawings do not meet the requirements for shop drawings.
- D. Samples Procedures:
1. Transmit related items together as single package.
 2. Samples will be reviewed for aesthetic, color, or finish selection.
 3. Identify each item to allow review for applicability in relation to shop drawings showing installation locations.
 4. Color Selection Samples: Architect will review and select colors for Project only after all colors are received, so that colors may be properly coordinated.
 5. Copies: Submit actual samples. Photographic or printed reproductions will not be accepted.
 6. Review of Field Samples: Review by Architect of field samples will be made for the following example products, as applicable, if not otherwise required and if requested by Contractor.
 - a. Concrete wall finishes and detailing (edges, corners and reveals).
 - b. Concrete paving colors and textures.
 - c. Gypsum board textures and finishes.
 - d. Field-applied paint colors and finishes.

3.17 SUBMITTAL REVIEW

- A. Submittals for Review: Architect will review each submittal, and approve, or take other appropriate action.

FOR REFERENCE ONLY

- B. Submittals for Information: Architect will acknowledge receipt and review. See below for actions to be taken.
- C. Architect's actions will be reflected by marking each returned submittal using virtual stamp on electronic submittals.
 - 1. Notations may be made directly on submitted items and/or listed on appended Submittal Review cover sheet.
- D. Architect's and consultants' actions on items submitted for review:
 - 1. Authorizing purchasing, fabrication, delivery, and installation:
 - a. "Approved", "Reviewed", or language with same legal meaning.
 - b. "Approved as Noted, Resubmission not required", or language with same legal meaning.
 - 1) At Contractor's option, submit corrected item, with review notations acknowledged and incorporated.
 - c. "Approved as Noted, Resubmit for Record", "Reviewed as Noted, Resubmit for Record", or language with same legal meaning.
 - 1) Resubmit corrected item, with review notations acknowledged and incorporated. Resubmit separately, or as part of project record documents.
 - 2) Non-responsive resubmittals may be rejected.
 - 2. Not Authorizing fabrication, delivery, and installation:
 - a. "Revise and Resubmit".
 - 1) Resubmit revised item, with review notations acknowledged and incorporated.
 - 2) Non-responsive resubmittals may be rejected.
 - b. "Rejected".
 - 1) Submit item complying with requirements of Contract Documents.
- E. Architect's and consultants' actions on items submitted for information:
 - 1. Items for which no action was taken:
 - a. "Received" - to notify the Contractor that the submittal has been received for record only.
 - 2. Items for which action was taken:
 - a. "Reviewed" - no further action is required from Contractor.

END OF SECTION

FOR REFERENCE ONLY

**SECTION 01 30 00.01
REQUEST FOR INTERPRETATION**

RFI NUMBER: _____

DATE: _____

PROJECT NAME: KITCHEN UPGRADES AT MADISON ES PROJECT NO.: 1-104-02

TO: RUHNAU CLARKE ARCHITECTS

3775 Tenth Street, Riverside CA 92501 - 5751 Palmer Way, Suite C, Carlsbad, CA 92010

Attention: _____

Contractor: _____

Address: _____

BRIEF SUMMARY OF RFI: _____

Drawing No. _____ Detail No. _____

Specification Section _____ Title _____

.Page _____ Paragraph _____

DETAILS OF THIS RFI: _____

SUGGESTED SOLUTION: _____

Response required by: _____ (min. 3 full days) Submitted By:

Organization: _____

RESPONSE: _____

Attachments: _____

Response By: _____

Date:

Organization: _____

FOR REFERENCE ONLY

Copies: File District Structural Mechanical Plumbing Electrical
 Civil Landscape other consultants

END OF RFI



FOR REFERENCE ONLY

SUBMITTAL / SHOP DRAWING TRANSMITTAL

To:	Ruhnau Clarke Architects		Contractor's Submittal No.
Attn:	Construction Dept.		
Contractor:		Project Name:	
Street:		RCA's Project No.	
City, State:		Subcontractor:	

CONTRACTOR TO FILL OUT THE FOLLOWING COVERING ONE COMPLETE SECTION OF THE SPECIFICATIONS ONLY:

Specification Section #:	Section Title:
--------------------------	----------------

<input type="checkbox"/>	Initial Submittal	Scheduled Date of Submittal	
<input type="checkbox"/>	1st Resubmittal	Scheduled Date of Submittal Return	
<input type="checkbox"/>	___ Resubmittal	Date Sent	
<input type="checkbox"/>	Submittal was a previously approved substitution.	Number of Copies	
	Approved Substitution Request Transmittal Form is enclosed.	Number of Samples	

CONTRACTOR COMPLETE EITHER (A) OR (B) FOLLOWING, <u>CHECK ONE</u> :	CONSTRUCTION MANAGERS CERTIFICATION
<p>(A) WE HAVE VERIFIED THAT THE MATERIAL OR EQUIPMENT CONTAINED IN THIS SUBMITTAL MEETS ALL THE REQUIREMENTS SPECIFIED OR SHOWN (NO EXCEPTIONS).</p> <p><input type="checkbox"/></p>	<p>THIS IS TO CERTIFY THAT THE CONSTRUCTION MANAGER IS REASONABLY CERTAIN THAT THE MATERIAL SPECIFIED IN THIS SUBMITTAL MEETS THE REQUIREMENTS OF THE CONTRACT DOCUMENTS, AND THE SUBMITTAL IS COMPLETE PER THE CONTRACT DOCUMENTS.</p> <p>SIGNATURE: _____</p>
<p>(B) WE HAVE VERIFIED THAT THE MATERIAL OR EQUIPMENT CONTAINED IN THIS SUBMITTAL MEETS ALL THE REQUIREMENTS SPECIFIED OR SHOWN, EXCEPT FOR THE FOLLOWING DEVIATIONS (LIST DEVIATIONS ON AN ATTACHED SHEET OR INDICATE DEVIATIONS CLEARLY ON SHOP DRAWINGS OR SUBMITTALS).</p> <p><input type="checkbox"/></p>	<p style="text-align: center; background-color: #f2f2f2; margin: 0;">CONTRACTORS CERTIFICATION</p> <p>THIS IS TO CERTIFY THAT THE CONTRACTOR IS REASONABLY CERTAIN THAT THE MATERIAL SPECIFIED IN THIS SUBMITTAL MEETS THE REQUIREMENTS OF THE CONTRACT DOCUMENTS.</p> <p>SIGNATURE: _____</p>

ARCHITECT'S USE ONLY BELOW THIS LINE.

Action:

No Exception Taken
 Make Corrections Noted
 Rejected/Resubmit
 Revise and Resubmit

<p>Comments:</p> <hr/> <hr/> <hr/> <hr/> <hr/> <hr/> <hr/> <hr/>	<p>Date Received By RRC:</p> <p>Date Sent to Consultant:</p> <p style="text-align: right;">Structural _____</p> <p style="text-align: right;">Mechanical _____</p> <p style="text-align: right;">Electrical _____</p> <p style="text-align: right;">Other _____</p> <p>Date Received From:</p> <p>Consultant _____</p> <p>No. of Copies Received _____</p>
--	--

Final Distribution: Contractor _____ Inspector _____ District/P.M. _____ Architect _____

Final Distribution Date: _____

SECTION 01 31 14 FACILITY SERVICES COORDINATION

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Services of a coordinator for facility services construction.
- B. Coordination documents.

1.02 RELATED REQUIREMENTS

- A. Section 01 10 00 - Summary: Responsibilities of separate contractors.
 - 1. Various types of Work to be coordinated, including Owner-Furnished / Contractor-Installed products.
- B. Section 01 30 00 - Administrative Requirements: Additional requirements for coordination.
- C. Section 01 60 00 - Product Requirements: Spare parts and maintenance materials.
 - 1. Coordination of products, especially general requirements for system completeness and product substitutions.
- D. Section 01 70 00 - Execution and Closeout Requirements: Starting of Systems. Systems Demonstration.
- E. Section 01 78 00 - Closeout Submittals: Project record documents.

1.03 MECHANICAL AND ELECTRICAL COORDINATOR

- A. Employ and pay for services of a person, technically qualified and administratively experienced in field coordination of the type of work required to be coordinated, for the duration of the Work.
 - 1. This designated individual may serve a dual role on the project team.

1.04 SUBMITTALS

- A. Submit name, address, and telephone number of coordinator and name of principal officer for review.
- B. Submit coordination drawings and schedules prior to submitting shop drawings, product data, and samples.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION

3.01 COORDINATION REQUIRED

- A. Coordinate the Work as stated in the Conditions of the Contract.
 - 1. Coordinate Work under the Contract with work under separate contracts by District.

FOR REFERENCE ONLY

2. Preinstallation Meetings: Coordinate and document work between trades. See Section 01 70 00 - Execution and Closeout Requirements.
 3. Cooperate with District, Construction Manager, and others as directed by District in scheduling and sequencing the incorporation into the Work of Owner Furnished / Contractor Installed (OFCI) products identified in the Contract Drawings and Specifications.
- B. Relationship of Documents:
1. Drawings, Specifications and other Contract Documents in the Project Manual are intended to be complementary.
 2. What is required by one shall be as if required by all.
 3. What is shown or required, or may be reasonably inferred to be required, or which is usually and customarily provided for similar work, shall be included in the Work.
- C. Discrepancies:
1. Error, omission, ambiguity or conflict in Drawings or Specifications shall be brought to Architect's attention during the bidding period, for Architect's determination and direction in accordance with provisions of the Conditions of the Contract.
- D. Construction Interfacing and Coordination: Layout, scheduling and sequencing of Work shall be solely the Contractor's responsibility.
1. Contractor shall verify, confirm and coordinate field measurements so that new construction correctly and accurately interfaces with conditions existing prior to construction.
- E. Contractor shall bring together the various parts, components, systems and assemblies as required for the correct interfacing and interpretation of all elements of the Work.
1. All work required to provide complete and fully operational systems shall be included in the contract price.
 2. Contractor shall coordinate Work to correctly and accurately connect abutting, adjoining, overlapping and related elements, including work under separate contracts by District, utility agencies and companies.
- F. Coordinate the work listed below:
1. Structural: Division 03, Division 04, Division 05, and Division 06.
 2. Architectural: Division 7, Division 8, and Division 9.
 3. Specialties: Division 10.
 4. Equipment: Division 11.
 - a. Food Service.
 5. Plumbing: Division 12.
 6. Heating, Ventilating, and Air Conditioning: Division 13.
 7. Electrical: Division 14.
 8. Communications: Division 15.
 9. Electronic Safety and Security: Division 16.
- G. Coordinate progress schedules, including dates for submittals and for delivery of products.

FOR REFERENCE ONLY

- H. Conduct meetings among subcontractors and others concerned, to establish and maintain coordination and schedules, and to resolve coordination matters in dispute.
- I. Participate in progress meetings. Report on progress of work to be adjusted under coordination requirements, and any required changes in schedules. Transmit minutes of meetings and reports to concerned parties.
- J. Coordination of subcontracts and separate contracts
 - 1. Superintendence of Work:
 - a. Contractor shall appoint a field superintendent and a project manager, who shall directly and full time supervise and coordinate all Work of the Contract.
 - 2. Subcontractors, Trades and Materials Suppliers:
 - a. Require all subcontractors, trades, crafts and suppliers to coordinate their portions of Work with the Contractor's field superintendent to prevent scheduling, sequencing, dimensional and other conflicts and omissions.
 - 3. Coordination with Work Under Separate Contracts:
 - a. Coordinate and schedule Work under the Contract with work being performed for Project under separate contracts by District, serving utilities and public agencies.
 - b. Make and facilitate direct contacts with parties responsible for work of the Project under separate contracts, in order to provide timely notifications and to facilitate information exchanges.

3.02 COORDINATION DOCUMENTS

- A. Prepare coordination drawings to organize installation of products for efficient use of available space, for proper sequence of installation, and to identify potential conflicts.
 - 1. Produce BIM Drawings with clash detection for the proposed installation and the placement of pipes, conduits, other materials, and the locations, size and reinforcement of penetrations in the building structure to conform to the structural Drawing and Specifications.
 - 2. Structural requirements take precedence when the requirements of the Mechanical, Electrical or other items are in conflict with structural.
 - 3. Take all precautions prior to coring into an existing building structure.
 - 4. Notify the structural engineer and obtain written approval prior to completing any structural penetrations if the structural integrity of an existing or new building structure may be compromised. Refer to Section 01 70 00 - Execution and Closeout Requirements for cutting and patching.
 - 5. Review limitations in available space for installation or service.
 - a. Overlay plans of each trade and verify space requirements and conflicts between trades.
 - b. Minor changes and adjustments that do not affect design intent may be made by Contractor and highlighted for Architect's review prior to purchase and installation.
 - 6. Incompatibility between items provided under different trades.

7. Inconsistencies between drawings, specifications and codes (between trades and within each trade).
8. Items required for existing facilities construction projects are designed and prepared from available as-built drawings that are verified through non-invasive and non-destructive, visual observation only.
 - a. Field verify actual existing conditions during and upon completion of demolition work and incorporate findings into preparation of coordination drawings.
 - b. Minor changes and adjustments that do not affect design intent may be made by Contractor and highlighted for Construction Manager and Architect's review prior to purchase and installation.
- B. Prepare a master schedule identifying responsibilities for activities that directly relate to this work, including submittals and temporary utilities; organize by specification section.
- C. Verify that utility, and other building system requirement characteristics of operating equipment are compatible with provided utilities, and other building systems.
 1. Coordinate work of various trades having interdependent responsibilities for installing, connecting to, and placing in service, such equipment.
- D. Identify electrical power characteristics and control wiring required for each item of equipment.
- E. Maintain documents for the duration of the work, recording changes due to site instructions, modifications or adjustments.
- F. After Architect review of original and revised documents, reproduce and distribute copies to concerned parties.

3.03 COORDINATION OF SUBMITTALS

- A. Review shop drawings, product data, and samples for compliance with Contract Documents and for coordination with related work. Transmit copies of reviewed documents to Architect.
- B. Check field dimensions and clearances and relationship to available space and anchors.
- C. Check compatibility with equipment and work of other sections, electrical characteristics, and operational control requirements.
- D. Check motor voltages and control characteristics.
- E. Coordinate controls, interlocks, wiring of switches, and relays.
- F. Coordinate wiring and control diagrams.
- G. When changes in the work are made, review their effect on other work.
- H. Verify information and coordinate maintenance of record documents.

3.04 COORDINATION OF SUBSTITUTIONS AND MODIFICATIONS

- A. Review proposals and requests for substitution prior to submission to Architect.
- B. Verify compliance with Contract Documents and for compatibility with work of other sections.
- C. Submit with recommendation for action.

3.05 OBSERVATION OF WORK

- A. Observe work for compliance with Contract Documents.
- B. Maintain a list of observed deficiencies and defects; promptly submit.

3.06 DOCUMENTATION

- A. Observe and maintain a record of tests. Record:
 - 1. Specification section number and product name.
 - 2. Name of Contractor, subcontractor and special inspector.
 - 3. Name of testing agency and name of inspector.
 - 4. Name of manufacturer's representative present.
 - 5. Date, time, and duration of tests.
 - 6. Type of test, and results.
 - 7. Retesting required.
- B. Assemble background documentation for dispute and claim settlement.
- C. Submit copies of documentation to Architect upon request.

3.07 EQUIPMENT START-UP

- A. Verify utilities, connections, and controls are complete and equipment is in operable condition as required by Section 01 70 00.
- B. Observe start-up and adjustments, test run, record time and date of start-up, and results.
- C. Observe equipment demonstrations made to District; record times and additional information required for operation and maintenance manuals.

3.08 INSPECTION AND ACCEPTANCE OF EQUIPMENT

- A. Prior to inspection, verify that equipment is tested, operational, clean, and ready for operation.
- B. Assist Architect with review. Prepare list of items to be completed and corrected.

END OF SECTION

SECTION 01 32 16 CONSTRUCTION PROGRESS SCHEDULE

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Responsibilities of individual Multi-Prime Contractors to coordinate with the Construction Manager's Master Project Schedule.
- B. Preliminary schedule.
- C. Construction progress schedule, with network analysis diagrams and reports.
- D. Summary schedule.
- E. Weekly/Short term (Look Ahead) Schedule.

1.02 RELATED SECTIONS

- A. Section 01 10 00 - Summary: Work sequence.
- B. Section 01 30 00 - Administrative Requirements: Submittal Schedule.

1.03 REFERENCE STANDARDS

- A. AGC (CPSM) - Construction Planning and Scheduling Manual.
- B. M-H (CPM) - CPM in Construction Management - Project Management with CPM.

1.04 SUBMITTALS

- A. Within 10 days after date of Agreement, submit preliminary schedule.
- B. Submit two copies to Construction Manager and one copy to Architect.
- C. If preliminary schedule requires revision after review, submit revised schedule within 10 days.
- D. Within 20 days after review of preliminary schedule, submit draft of proposed complete schedule for review.
 - 1. Include written certification that major contractors have reviewed and accepted proposed schedule.
- E. Within 10 days after joint review, submit complete schedule.
- F. Submit updated schedule with each Application for Payment.
 - 1. Revise schedule also upon issuance of Change Orders and Construction Change Directives which substantially affect construction sequence or schedule.
- G. Submit the number of opaque reproductions that Contractor requires, plus two copies that will be retained by Architect.
- H. Submit under transmittal letter form specified in Section 01 30 00 - Administrative Requirements.

1.05 QUALITY ASSURANCE

- A. Scheduler: Contractor's personnel or specialist Consultant specializing in CPM scheduling with one year's minimum experience in scheduling construction work of a complexity comparable to this Project, and having use of computer facilities capable of delivering a detailed graphic printout within 48 hours of request.
 - 1. Designate the Scheduler in writing and within ten (10) workdays after Notice of Intent to Award, as the qualified responsible person for preparation, maintenance, updating, and revision of all schedules for the full term of construction.
 - 2. Scheduler:
 - a. Dedicated to this project and available on-site as needed to meet the strict requirement of this spec. section.
 - b. All scheduling software and hardware located on-site.
 - c. Scheduler will attend all project meetings called for as specified in Division 01.
 - 3. Qualifications of responsible person:
 - a. Knowledge of critical path method (CPM) scheduling utilizing Primavera P6 latest release software.
 - 4. References:
 - a. Submit written reference of three (3) project Owners who have personal experience with this scheduler on previous projects.
 - b. Identify name, address, telephone number, project name, and cost.
 - 5. District reserves the right to disapprove Scheduler when submitted by Contractor based on his/or her sole discretion. District reserves the right to remove Scheduler from the project without cause.
- B. Contractor's Administrative Personnel: Three years minimum experience in using and monitoring CPM schedules on comparable projects.
- C. Reviews by Architect and Construction Manager: Reviews by Architect and Construction Manager will be to ascertain the general status of construction and shall not be interpreted to establish or approve the means, methods, techniques and sequences of construction.
- D. Contractor's Review: All schedules shall be reviewed and approved by Contractor prior to submission for Architect's and District's review.
- E. Changes and Deviations: Identify all deviations from requirements of Drawings and Specifications.
 - 1. Changes in the Work shall not be authorized by submittals review actions.
 - 2. No review action, implicit or explicit, shall be interpreted to authorized changes in the Work.
 - 3. Changes shall only be authorized by separate written Change Order or Field Change Directive, in accordance with the Conditions of the Contract.

1.06 SCHEDULE FORMAT

- A. Format: Prepare schedules in format at Contractor's option, either bar chart, PERT or GANTT format, providing clear indication of sequencing and scheduling of Work, for determination of "critical path" of construction progress.
 - 1. Prepare schedules in MS Project or Primavera.
 - 2. Provide clear indication of sequencing and scheduling of work for determination of "critical path" of construction progress.
 - 3. Present schedule in both electronic and reproducible paper formats with sheet size large enough to clearly read the characters.
- B. Listings: In chronological order according to the start date for each activity. Identify each activity with the applicable specification section number.
- C. Diagram Sheet Size: Maximum 30 x 42 inches.
- D. Sheet Size: Multiples of 8-1/2 x 11 inches.
- E. Scale and Spacing: To allow for notations and revisions.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION

3.01 PRELIMINARY SCHEDULE

- A. Prepare preliminary schedule in the form of a preliminary network diagram.
- B. Prescheduling Conference:
 - 1. Construction Manager will conduct a conference within fifteen (15) work days after the Notice of Intent to Award.
 - a. Review methods and procedures related to the preliminary construction schedule and Contractor's construction schedule, including, but not limited to, the following:
 - 1) Review software limitations and content and format for reports.
 - 2) Verify availability of qualified personnel needed to develop and update schedule.
 - 3) Discuss constraints, including phasing work stages area separations interim milestones and partial District occupancy.
 - 4) Review delivery dates for District-furnished products.
 - 5) Review schedule for work of District's separate contracts.
 - 6) Review submittal requirements and procedures.
 - 7) Review time required for review of submittals and resubmittals.
 - 8) Review requirements for tests and inspections by independent testing and inspecting agencies.
 - 9) Review District's IT requirements for installation of their Work.

- 10) Review time required for Project closeout and District startup procedures, including commissioning activities for MEP, Security Electronics Equipment.
 - 11) Review and finalize list of construction activities to be included in schedule.
 - 12) Review procedures for updating schedule.
- C. At the meeting, the Construction Manager will review scheduling requirements. These include schedule preparation, reporting requirements, labor and equipment loading, updates, revisions, and schedule delay analysis.
1. The Contractor will present schedule methodology, planned sequence of operations, resource loading methodology, and proposed activity coding structure.
- D. Coding structure:
1. Submit proposed coding structure, identifying the code fields and the associated code values it intends to use in the project schedule.
 2. A minimum, include code fields for Project Segment or Phase, Area of Work, Type of Work, Submittal/Procurement/Construction and Responsibility/Subcontractor.
 - a. Refer to NETWORK DETAILS AND GRAPHICAL OUTPUT for listing of activity categories to be included in the schedule.

3.02 CONTENT

- A. Show complete sequence of construction by activity, with dates for beginning and completion of each element of construction.
- B. Identify each item by specification section number.
- C. Identify work of separate stages and other logically grouped activities.
 1. Identify Work of separate buildings, phases, units or other logically grouped activities to facilitate review of Application for Payment with completed Work.
- D. Provide sub-schedules for each stage of Work identified in Section 01 10 00 - Summary.
- E. Provide sub-schedules to define critical portions of the entire schedule.
- F. Include conferences and meetings in schedule.
- G. Show accumulated percentage of completion of each item, and total percentage of Work completed, as of the first day of each month.
- H. Provide separate schedule of submittal dates for shop drawings, product data, and samples, owner-furnished products, products identified under Allowances, and dates reviewed submittals will be required from Architect. Indicate decision dates for selection of finishes.
 1. Format: Prepare Submittals Schedule in a format comparable to Construction Progress Schedule, specified in Article above.
 2. Content: List all items specified to be submitted, indicating submittal number (see instructions specified in Section 01 30 00 - Administrative Requirements, submittal type (i.e., product data, shop drawings, sample, quality control report, maintenance and operating data, etcetera), scheduled date submittal is to be made and date review should be complete in order to maintain construction on schedule.
 3. The Contractor shall submit to the Architect a schedule of the shop drawings that lists their required submission and approval dates.

FOR REFERENCE ONLY

- a. Allow minimum one (1) week for the Architect to review the submittals. Some submittals may require a longer review period. See Section 01 30 00 - Administrative Requirements.
- b. Allow for the possibility that the consultant team will request revisions and resubmittal following the initial submittal.
- c. The schedule shall encompass the entire construction period and will be revised by the Contractor and reviewed by the project team at each project meeting.
4. Changes and Deviations: Identify all deviations from requirements of Drawings and Specifications.
 - a. Changes in the Work shall not be authorized by submittals review actions.
 - b. No review action, implicit or explicit, shall be interpreted to authorized changes in the Work.
 - c. Changes shall only be authorized by separate written Change Order or Construction Change Directive, in accordance with the Conditions of the Contract and Section 01 20 00 - Price and Payment Procedures.
5. Administration: Review of Submittals Schedules by Architect, Construction Manager, and District will be to ascertain the general status of submittals review and shall not be interpreted to establish or approve the means, methods, techniques and sequences of construction.
 - a. Submit one copy each to Construction Manager and Architect.
 - b. Submit initial Submittals Schedule within 14 days of construction start date established in Notice to Proceed.
 - c. After review, resubmit Submittals Schedule within 10 days and thereafter submit updated Submittals Schedules at each Construction Progress Meeting.
- I. Indicate delivery dates for owner-furnished products.
- J. Coordinate content with schedule of values specified in Section 01 20 00 - Price and Payment Procedures.
 1. Include Submittals Schedule.
- K. Provide legend for symbols and abbreviations used.

3.03 BAR CHARTS

- A. Include a separate bar for each major portion of Work or operation.
- B. Identify the first work day of each week.

3.04 NETWORK ANALYSIS

- A. Prepare network analysis diagrams and supporting mathematical analyses using the Critical Path Method.
- B. Illustrate order and interdependence of activities and sequence of work; how start of a given activity depends on completion of preceding activities, and how completion of the activity may restrain start of subsequent activities.
- C. Mathematical Analysis: Tabulate each activity of detailed network diagrams, using calendar dates, and identify for each activity:

FOR REFERENCE ONLY

1. Preceding and following event numbers.
2. Activity description.
3. Estimated duration of activity, in maximum 15 day intervals.
4. Project Milestones; include "Project Start" and "End Project" Milestones.
 - a. Schedule starts no earlier than the Project Duration (Day 1) will start on the Notice To Proceed (NTP) date.
5. Earliest start date.
6. Earliest finish date.
7. Actual start date.
 - a. "Project Start" Milestone to have no predecessors and "End Project" Milestone has no successors.
 - b. "Project Start": Constrained by a "Mandatory Start" Milestone.
 - c. "End Project": Constrained by a "Mandatory Finish" Milestone.
 - d. No other activities on the schedule may have constraints, unless reviewed and approved by Construction Manager and Architect.
8. Actual finish date.
9. Latest start date.
10. Latest finish date.
11. Total and free float; float time shall accrue to District and to District's benefit.
 - a. Contractor does not own the float.
 - b. "Float time" refers to the time between earliest finish date and the latest finish date of each activity shown on the Construction Schedule.
 - c. Any float time indicated in the Construction Schedules required by this Section are to be held jointly by the District and Contractor.
 - d. Any delay (including District caused) encountered is to be subtracted from the available days ahead of progress against the Construction Schedule.
 - 1) District may claim float days equal to the delay until such float days are exhausted.
 - 2) No compensation of any type will be due the Contractor until the delay extends the overall project Final Inspection date.
 - e. Weather (Rain) day requirements are as specified in the "Construction Services Agreement."
12. Monetary value of activity, keyed to Schedule of Values.
13. Percentage of activity completed.
14. Responsibility.
- D. Analysis Program: Capable of compiling monetary value of completed and partially completed activities, accepting revised completion dates, and recomputation of all dates and float.
- E. Required Reports: List activities in sorts or groups:
 1. By preceding work item or event number from lowest to highest.

2. By amount of float, then in order of early start.
3. Contractor's periodic payment request sorted by Schedule of Values listings.
4. Listing of activities on the critical path.

3.05 CREW SCHEDULES

- A. Separate and concurrent with the Baseline Schedule, submit a schedule histogram depicting crew loading for Contractor's own labor forces and those of each subcontractor. Submit this crew schedule electronically.
- B. Provide the breakdown of a typical crew, by trade, for resource loading quantification.

3.06 WEATHER DAYS ALLOWANCE- AS ANTICIPATED BY THE CONTRACTOR

- A. Based on historical weather in the local area, the Baseline Schedule shall include all non-work days on which the Contractor anticipates Work will not be performed due to adverse weather days that are anticipated to occur within the work day calendar and impact critical activities.
- B. The Contractor shall not receive any additional compensation for unavoidable delays due to inclement or unsuitable weather, and no time extension to complete any Contractual Completion Events as defined in General Conditions, will be considered due to inclement or unsuitable weather or conditions resulting there from.

3.07 REVIEW AND EVALUATION OF SCHEDULE

- A. Review all schedules reviewed and approved by Contractor prior to submission for review by Architect and District.
- B. Participate in joint review and evaluation of schedule with Construction Manager and Architect at each submittal.
- C. Evaluate project status to determine work behind schedule and work ahead of schedule.
- D. After review, revise as necessary as result of review, and resubmit within 10 days.
- E. Review by Architect and District will be to ascertain the general status of construction and shall not be interpreted to establish or approve the means, methods, techniques and sequences of construction.

3.08 SUMMARY SCHEDULE

- A. Provide Summary Schedule, upon request, which consolidates groups of activities associated with Major Items of Work shown on Baseline Schedule.
 1. Summary Schedule is intended to give an overall indication of the project schedule without a large amount of detail.
 2. This schedule shall include the current status of each of the contract Milestones listed in the Agreement, and any significant activities that are critical to the completion of the Milestone work at the required time.
- B. Include in the Summary Schedule a separate Gantt Chart depicting only the critical path of the project at the time of the update.
- C. Updated and submitted monthly and with each Schedule Update or Schedule Revision.

3.09 WEEKLY (SHORT TERM LOOK-AHEAD) SCHEDULE

- A. Submit to Construction Manager, twenty four (24) hours prior to each weekly progress meeting, a short term look ahead schedule showing the activities completed during the previous week and the schedule of activities for the following 4 weeks.
- B. Using the same computer software as the progress schedule, use the Activity ID's, Descriptions, and logic of the current progress schedule when producing a Weekly Schedule in CPM schedule or a bar chart format.
 - 1. In the event that the Weekly Schedule no longer conforms to the current schedule, Contractor may be required to revise either or both schedule(s).
- C. The activity designations used in the Weekly Schedule must be consistent with those used in the Baseline Schedule and the monthly Schedule Updates.
- D. Contractor and Construction Manager must agree on the format of the Weekly Schedule.
- E. Weekly Schedule should indicate locations of work, critical activities, early start and early finish dates, actual start and actual finish dates, progress, and remaining durations for each activity in the three-week schedule.

3.10 UPDATING SCHEDULE

- A. Maintain schedules to record actual start and finish dates of completed activities.
- B. Indicate progress of each activity to date of revision, with projected completion date of each activity.
- C. Annotate diagrams to graphically depict current status of Work.
- D. Identify activities modified since previous submittal, major changes in Work, and other identifiable changes.
- E. Indicate changes required to maintain Date of Final Completion.
- F. Submit reports required to support recommended changes.
- G. Provide narrative report to define problem areas, anticipated delays, and impact on the schedule. Report corrective action taken or proposed and its effect.

3.11 ADJUSTMENT OF CONTRACT TIMES

- A. Subject to the terms of General Conditions, contract time will be adjusted only for causes specified as generally described below.
 - 1. Non-excusable delay:
 - a. Includes actions or inactions of the Contractor, or events for which the Contractor has assumed contractual responsibility that would independently delay the completion of the Work beyond the current Contract completion date.
 - 1) This also includes actions or inactions of subcontractors, suppliers, or material manufacturers at any tier.
 - b. No time extensions will be granted for non-excusable delays.
 - 2. Excusable delay:

FOR REFERENCE ONLY

- a. Events which are unforeseeable, outside the control of, and without the fault or negligence of either the District or the Contractor (or any party for whom either is responsible), which would independently delay the completion of the Work beyond the current Contract completion date.
- b. The Contractor is entitled to a time extension only.
- c. No other damages will be approved.
3. Compensable delay:
 - a. Actions or inactions of the District, or events for which the District has assumed contractual responsibility, which would independently delay the completion of the Work beyond the current Contract completion date.
 - b. The Contractor is entitled to a time extension and delay damages.
4. Concurrent delay:
 - a. Any combination of the above three (3) types of delay occurring on the same calendar date, or cases where the combination consists of two (2) or more instances of the same type of delay occurring on the same calendar date.
 - 1) Exception to concurrent delay:
 - (a) When one cause of delay is District-caused or caused by an event which is beyond the control and without the fault or negligence of either the District or the Contractor and the other Contractor-caused, the Contractor is entitled only to a time extension and no delay damages.
- B. If the Contractor believes that the District has impacted its work, such that the project completion date will be delayed, the Contractor must submit proof demonstrating the delay to the critical path.
 1. Proof, in the form of a Time Impact Analysis, may entitle the Contractor to an adjustment of Contract Time.
- C. Notify Construction Manager of a potential request for Contract Time adjustment within five (5) days of the start of the impact.
- D. The Contractor shall prepare and submit along with any Change Order Request (COR), response to Request for Proposal/Quote (RFP/RFQ), Differing Site Condition (DSC) notification or Request for Additional Compensation (RAC) a Time Impact Analysis (TIA) which includes both a written narrative and a schedule diagram depicting how the changed work may affect the progress of work and other schedule activities.
 1. The schedule diagram shall show how the Contractor proposes to incorporate the changed work in the schedule, and how it impacts the current updated schedule and critical path.
 2. The TIA shall not be resource constrained, or leveled using resource limits.
 3. Failure to include a TIA with the COR, Proposal, Quote, DSC or RAC shall constitute a waiver of the right to later claim any adjustment in time based upon changed or unforeseen Work.
- E. Time Impact Analysis (TIA):

FOR REFERENCE ONLY

1. Use the accepted schedule update that is current relative to the time frame of the delay event (change order, third party delay, or other District-caused delay). Represent the delay event in the schedule by:
 - a. Inserting new activities associated with the delay event into the schedule.
 - b. Revising activity logic.
 - c. Revising activity durations.
2. If the project schedule's critical path and milestone date(s) are impacted as a result of adding this delay event to the schedule, a time extension equal to the magnitude of the impact without resource constraints may be warranted.
3. The Time Impact Analysis submittal must include the following information:
 - a. A fragment of the portion of the schedule affected by the delay event.
 - b. A narrative explanation of the delay issue and how it impacted the schedule.
 - c. A digital file containing the schedule file used to perform the Time Impact Analysis.
- F. When a delay to the project as a whole can be avoided by revising preferential sequencing or logic, and the Contractor chooses not to implement the revisions, the Contractor will be entitled to a time extension and no compensation for extended overhead.
- G. Indicate clearly that the Contractor has used, in full, all project float available for the work involved in the request, including any float that may exist between the Contractor's planned completion date and the Contract completion date.
 1. Utilize the latest version of the Schedule Update accepted at the time of the alleged delay, and all other relevant information, to determine the adjustment of the Contract Time.
- H. Adjustment of the Contract Times will be granted only when the Contract Float has been fully utilized and only when the revised date of completion of the Work has been pushed beyond the Contract completion date.
 1. Adjustment of the Contract Times will be made only for the number of days that the planned completion of the work has been extended.
- I. Actual delays in activities which do not affect the critical path work or which do not move the Contractor's planned completion date beyond the Contract completion date will not be the basis for an adjustment to the Contract Time.
- J. Submit request as specified with Contract Documents.
 1. In cases where the Contractor does not submit a request for Contract Time adjustment for a specific change order, delay, or Contractor request within the specified period of time, then it is mutually agreed that the particular change order, delay, or Contractor request has no time impact on the Contract completion date and no time extension is required.
- K. The Construction Manager will, within five (5) working days after receipt of a Contract Time adjustment, request any supporting evidence, review the facts, and advise the Contractor in writing.
 1. Include the new Progress Schedule data, if accepted by the District, in the next monthly Schedule Update.

2. When the District has not yet made a final determination as to the adjustment of the Contract Time, and the parties are unable to agree as to the amount of the adjustment to be reflected in the Progress Schedule, reflect that amount of time adjustment in the Progress Schedule as the Construction Manager may accept as appropriate for such interim purpose.
 - a. It is understood and agreed that any such interim acceptance by the Construction Manager shall not be binding.
 - b. Interim acceptance shall be made only for the purpose of continuing to schedule the Work
 - c. Interim acceptance shall remain until such time as a final determination as to any adjustment of the Contract Time acceptable to the Construction Manager has been made.
 - d. Revise the Progress Schedule prepared thereafter in accordance with the final decision.

3.12 DISTRIBUTION OF SCHEDULE

- A. Distribute copies of updated schedules to Contractor's project site file, to Subcontractors, suppliers, Construction Manager, Architect, District, and other concerned parties.
- B. Posting: Post one copy, minimum, of most recent Construction and Submittals Schedules in the Contractor's jobsite office, readily available to Construction Manager and Architect.
- C. Instruct recipients to promptly report, in writing, problems anticipated by projections indicated in schedules.
- D. Archive: Preserve a minimum of two copies of all superseded schedules, with a minimum of one copy available at job office for review by Construction Manager or Architect.

3.13 FINAL SCHEDULE SUBMITTAL

- A. The final Schedule Update becomes the Record (As-Built) Schedule.
 1. The As-Built Schedule reflects the exact manner in which the project was constructed by reflecting actual logic, start and completion dates for all activities accomplished on the project.
 2. Contractor's Project Manager and Scheduler sign and certify the Record (As-Built) Schedule as being an accurate record of the way the project was actually constructed.
- B. Retainage will not be released until final Schedule Update is provided.

END OF SECTION

SECTION 01 35 50 REQUESTS FOR ELECTRONIC FILES

PART 1 - GENERAL

1.01 SECTION INCLUDES

- A. Requirements to request electronic construction document files from Architect.
- B. Hold Harmless Agreement form.

1.02 RELATED SECTIONS

- A. Section 01 30 00 - Administrative Requirements: Shop Drawings, Product Data and Samples.
- B. Section 01 70 00 - Execution and Closeout Requirements.
- C. Divisions 31 through 33 - Site Work.

1.03 REQUIREMENTS

- A. Electronic files have legal ramifications as information therein can be modified.
- B. In order to receive this electronic information, the following Hold Harmless Agreement form must be executed in its entirety, including signature by a company officer.
- C. Costs for processing and handling electronic files, however limited, will be \$250.00

PART 2 - PRODUCTS - (NOT APPLICABLE TO THIS SECTION.)

PART 3 - EXECUTION

3.01 ELECTRONIC FILE TRANSFER PROCEDURE

- A. Submit a check in the amount of \$250.00 along with a list of the requested sheet numbers and an acknowledged copy of this waiver to the office of the Architect, Ruhnau Clarke Architects, 3775 Tenth Street, Riverside CA 92501 - 5751 Palmer Way, Suite C, Carlsbad, CA 92010.
- B. In order to expedite the transfer, upon receipt of a PDF copy of this acknowledgement, the requested CAD/Revit/BIM files will be sent in the form of a compact disc, DVD, or thumb drive to the recipient, as requested, by UPS, similar delivery service, or other method of electronic transfer after payment is received.
- C. It is expressly understood that any transfer is done as a courtesy and can be revoked at any time by the Architect.

Agreement is on next page



HOLD HARMLESS AGREEMENT

ARCHITECT'S PROJECT: KITCHEN UPGRADES AT MADISON ES

ARCHITECT'S PROJECT NUMBER: 1-104-02

We, _____, understand that we may be receiving electronic media containing design information, not necessarily intended for construction. We agree to hold Ruhnau Clarke Architects harmless for any defects in this data. We agree that it shall be our responsibility to reconcile this electronic data with the paper plans, and that only the paper plans shall be regarded as legal documents for the referenced project.

Further, the Contractor acknowledges that the Architect's reports, drawings, specifications, field data, field notes, laboratory test data, calculations, estimates and other similar documents are instruments of professional service, not products. In accepting and utilizing any drawings or other data on any form of electronic media generated and provided by the Design Professionals, the Parties listed above covenant and agree that all such drawings and data are instruments of service of the Design Professionals, who shall be deemed the author of the drawings and data, and shall retain all common law, statutory law and other rights, including copyrights.

The Parties agree that in accepting and utilizing any drawings and other data, that the Design Professionals waive all responsibility for any subsequent use of these data, the accuracy of dimensions, and the interpretation of information contained herein.

The Parties further agree not to use these drawings and data, in whole or in part, for any purpose or project other than the project which is the subject of this Agreement. The Parties further agree to waive all claims against the Design Professionals resulting in any way from any unauthorized changes of the drawings and data or any other use other than for the project which is the subject of this Agreement.

The Contractor shall indemnify, defend and hold harmless the Design Professionals and its subconsultants and their officers, agents, employees from any claims, damages, losses, liabilities or expenses (including attorneys' fees) arising out of use of such documents without Consultant's prior written authorization.

Under no circumstances shall transfer of the drawings and other data be deemed a sale by the Design Professionals, and the Design Professionals make no warranties, either express or implied of the merchantability and fitness of the data for any particular purpose.

Sheet numbers or discipline requested: _____

Acknowledged by: Company Name _____

Signature of Company Officer Print or Type Name Date
Street Address _____
City, State, Zip Code _____
E-mail Address _____

END OF SECTION

SECTION 01 35 53 SECURITY PROCEDURES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Security measures including formal security program, entry control, personnel identification, guard service, and miscellaneous restrictions.

1.02 RELATED REQUIREMENTS

- A. Section 01 10 00 - Summary: use of premises and occupancy.
- B. Section 01 50 00 - Temporary Facilities and Controls: Temporary lighting.

1.03 SECURITY PROGRAM

- A. Protect Work , existing premises and District's operations from theft, vandalism, and unauthorized entry.
- B. Initiate program in coordination with District's existing security system at project mobilization.
- C. Maintain program throughout construction period until District acceptance precludes the need for Contractor security.

1.04 ENTRY CONTROL

- A. Restrict entrance of persons and vehicles into Project site and existing facilities.
- B. Allow entrance only to authorized persons with proper identification.
- C. Maintain log of workers and visitors, make available to District on request.
- D. District will control entrance of persons and vehicles related to District's operations.
- E. Contractor shall control entrance of persons and vehicles related to District's operations.
- F. Coordinate access of District's personnel to site in coordination with District's security forces.

1.05 PERSONNEL IDENTIFICATION

- A. Shall be worn by Contractor's superintendent and all sub contractors
- B. Provide identification badge to each person authorized to enter premises.
- C. Badge To Include: Personal photograph, name, assigned number , expiration date and employer.
- D. Maintain a list of accredited persons, submit copy to District on request.
- E. Special badges shall be issued to construction personnel when term of construction exceeds six months.
- F. Require return of badges at expiration of their employment on the Work.

1.06 RESTRICTIONS

- A. Do not allow cameras on site or photographs taken except by written approval of District.

FOR REFERENCE ONLY

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

END OF SECTION

SECTION 01 40 00 QUALITY REQUIREMENTS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Contractor Quality assurance submittals.
- B. Quality assurance.
- C. Inspection agencies and services.
- D. Contractor's construction-related professional design services.
- E. Contractor's design-related professional design services.
- F. Control of installation.
- G. Mock-ups.
- H. Tolerances.
- I. Manufacturers' field services.
- J. Defect Assessment.

1.02 RELATED REQUIREMENTS

- A. Section 01 30 00 - Administrative Requirements: Submittal procedures.
- B. Section 01 41 00 - Regulatory Requirements: Compliance with applicable codes, ordinances and standards.
- C. Section 01 42 19 - Reference Standards.
- D. Section 01 45 33 - Code-Required Special Inspections: Testing laboratory services and inspections required by Division of the State Architect (DSA), during the course of construction.
- E. Section 01 60 00 - Product Requirements: Requirements for material and product quality.
 - 1. Product options, substitutions, transportation and handling requirements, storage and protection requirements, and system completeness requirements.

1.03 REFERENCE STANDARDS

- A. ASTM C1021 - Standard Practice for Laboratories Engaged in Testing of Building Sealants.
- B. ASTM C1077 - Standard Practice for Agencies Testing Concrete and Concrete Aggregates for Use in Construction and Criteria for Testing Agency Evaluation.
- C. ASTM C1093 - Standard Practice for Accreditation of Testing Agencies for Masonry.
- D. ASTM D3740 - Standard Practice for Minimum Requirements for Agencies Engaged in Testing and/or Inspection of Soil and Rock as Used in Engineering Design and Construction.
- E. ASTM E329 - Standard Specification for Agencies Engaged in Construction Inspection, Testing, or Special Inspection.
- F. ASTM E543 - Standard Specification for Agencies Performing Nondestructive Testing.

- G. ASTM E699 - Standard Specification for Agencies Involved in Testing, Quality Assurance, and Evaluating of Manufactured Building Components.
- H. IAS AC89 - Accreditation Criteria for Testing Laboratories.

1.04 DEFINITIONS

- A. Contractor's Quality Control Plan: Contractor's management plan for executing the Contract for Construction.

1.05 CONTRACTOR'S CONSTRUCTION-RELATED PROFESSIONAL DESIGN SERVICES

- A. Coordination: Contractor's professional design services are subject to requirements of project's Conditions for Construction Contract.
- B. Provide such engineering design services as may be necessary to plan and safely conduct certain construction operations, pertaining to, but not limited to the following:
 - 1. Temporary sheeting, shoring, or supports.
 - 2. Temporary scaffolding.
 - 3. Temporary bracing.
 - 4. Temporary falsework for support of spanning or arched structures.
 - 5. Temporary stairs or steps required for construction access only.
 - 6. Temporary hoist(s) and rigging.
 - 7. Investigation of soil conditions to support construction equipment.

1.06 CONTRACTOR'S DESIGN-RELATED PROFESSIONAL DESIGN SERVICES

- A. Coordination: Contractor's professional design services are subject to requirements of project's Conditions for Construction Contract.
- B. Base design on performance and/or design criteria indicated in individual specification sections.
- C. Scope of Contractor's Professional Design Services: Provide for the following items of work:
 - 1. Structural Design of Formwork: As described in Section 03 10 00 - Concrete Forming and Accessories.
 - 2. Concrete Mix Design: As described in Section 03 30 00 - Cast-in-Place Concrete. No specific designer qualifications are required.

1.07 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Designer's Qualification Statement: Submit for Architect's knowledge as contract administrator, or for District's information.
 - 1. Include information for each individual professional responsible for producing, or supervising production of, design-related professional services provided by Contractor.
 - a. Full name.
 - b. Professional licensure information.

FOR REFERENCE ONLY

- c. Statement addressing extent and depth of experience specifically relevant to design of items assigned to Contractor.
- C. Quality Control Submittals Schedule
 1. Schedule Format: Include quality control submittals on Submittals Schedule specified in accordance with General Conditions
 2. Schedule Content: List all tests, inspections and reports specified to be submitted, indicating submittal number, submittal type (field test, field inspection, fabrication inspection, etcetera), scheduled date of quality control activity and date report should be made.
- D. Design Data: Submit for Architect's knowledge as contract administrator for the limited purpose of assessing compliance with information given and the design concept expressed in the Contract Documents, or for District's information.
 1. Include calculations that have been used to demonstrate compliance to performance and regulatory criteria provided, and to determine design solutions.
 2. Include required product data and shop drawings.
 3. Include a statement or certification attesting that design data complies with criteria indicated, such as building codes, loads, functional, and similar engineering requirements.
 4. Include signature and seal of design professional responsible for allocated design services on calculations and drawings.
- E. Test Reports: After each test/inspection, promptly submit two copies of report to Architect and to Contractor.
 1. Include:
 - a. Date issued.
 - b. Project title and number.
 - c. Name of inspector.
 - d. Date and time of sampling or inspection.
 - e. Identification of product and specifications section.
 - f. Location in the Project.
 - g. Type of test/inspection.
 - h. Date of test/inspection.
 - i. Results of test/inspection.
 - j. Compliance with Contract Documents.
 - k. When requested by Architect, provide interpretation of results.
 2. Test report submittals are for Architect's knowledge as contract administrator for the limited purpose of assessing compliance with information given and the design concept expressed in the Contract Documents, or for District's information.
- F. Certificates: When specified in individual specification sections, submit certification by the manufacturer and Contractor or installation/application subcontractor to Architect, in quantities specified for Product Data.

FOR REFERENCE ONLY

1. Indicate material or product complies with or exceeds specified requirements. Submit supporting reference data, affidavits, and certifications as appropriate.
 2. Certificates may be recent or previous test results on material or product, but must be acceptable to Architect.
- G. Manufacturer's Instructions: When specified in individual specification sections, submit printed instructions for delivery, storage, assembly, installation, start-up, adjusting, and finishing, for the District's information. Indicate special procedures, perimeter conditions requiring special attention, and special environmental criteria required for application or installation.
- H. Manufacturer's Field Reports: Submit reports for Architect's benefit as contract administrator or for District.
1. Submit report in duplicate within 30 days of observation to Architect for information.
 2. Submit for information for the limited purpose of assessing compliance with information given and the design concept expressed in the Contract Documents.
- I. Erection Drawings: Submit drawings for Architect's benefit as contract administrator or for District.
1. Submit for information for the limited purpose of assessing compliance with information given and the design concept expressed in the Contract Documents.
 2. Data indicating inappropriate or unacceptable Work may be subject to action by Architect or District.

1.08 QUALITY ASSURANCE

- A. Testing Agency Qualifications:
1. Prior to start of work, submit agency name, address, and telephone number, and names of full time registered Engineer and responsible officer.
 2. Submit copy of report of laboratory facilities inspection made by NIST Construction Materials Reference Laboratory during most recent inspection, with memorandum of remedies of any deficiencies reported by the inspection.
 3. Qualification Statement: Provide documentation showing testing laboratory is approved by Division of the State Architect.
 4. Qualification Statement: Provide documentation showing testing laboratory is accredited under IAS AC89.
- B. Designer Qualifications: Where professional engineering design services and design data submittals are specifically required of Contractor by Contract Documents, provide services of a Professional Engineer experienced in design of this type of work and licensed in California.
- C. Contractor's Quality Control (CQC) Plan:
1. Prior to start of work, submit a comprehensive plan describing how contract deliverables will be produced. Tailor CQC plan to specific requirements of the project. Include the following information:
 - a. Management Structure: Identify personnel responsible for quality. Include a chart showing lines of authority.

FOR REFERENCE ONLY

- 1) Include qualifications (in resume form), duties, responsibilities of each person assigned to CQC function.
 - b. Management Approach: Define, describe, and include in the plan specific methodologies used in executing the work.
 - 1) Management and control of documents and records relating to quality.
 - 2) Communications.
 - 3) Coordination procedures.
 - 4) Resource management.
 - 5) Process control.
 - 6) Inspection and testing procedures and scheduling.
 - 7) Control of noncomplying work.
 - 8) Tracking deficiencies from identification, through acceptable corrective action, and verification.
 - 9) Control of testing and measuring equipment.
 - 10) Project materials certification.
 - 11) Managerial continuity and flexibility.
 - c. District will not make a separate payment for providing and maintaining a Quality Control Plan. Include associated costs in Bid price.
 - d. Acceptance of the plan is required prior to start of construction activities not including mobilization work. District's acceptance of the plan will be conditional and predicated on continuing satisfactory adherence to the plan. District reserves the right to require Contractor to make changes to the plan and operations, including removal of personnel, as necessary, to obtain specified quality of work results.
- D. Quality-Control Personnel Qualifications. Engage a person with requisite training and experience to implement and manage quality assurance (QA) and quality control (QC) for the project.

1.09 REFERENCES AND STANDARDS - SEE SECTION 01 42 19

1.10 REGULATORY REQUIREMENTS FOR TESTING AND INSPECTION

- A. Inspections, testing and approvals as required by authorities having jurisdiction. Refer to Section 01 41 00 - Regulatory Requirements and Section 01 45 33 - Code-Required Special Inspections.
- B. Standards and Code Compliance and Manufacturer's Instructions and Recommendations: Unless more stringent requirements are indicated or specified, comply with manufacturer's instructions and recommendations, reference standards and building code research report requirements in preparing, fabricating, erecting, installing, applying, connecting and finishing Work.

- C. Deviations from Standards and Code Compliance and Manufacturer's Instructions and Recommendations: Document and explain all deviations from reference standards and building code research report requirements and manufacturer's product installation instructions and recommendations, including acknowledgement by the manufacturer that such deviations are acceptable and appropriate for the Project.

1.11 TESTING AND INSPECTION AGENCIES AND SERVICES

- A. District will employ and pay for services of an independent testing agency approved by DSA to perform specified testing.
- B. As indicated in individual specification sections, District or Contractor shall employ and pay for services of an independent testing agency to perform specified testing.
- C. Employment of agency in no way relieves Contractor of obligation to perform Work in accordance with requirements of Contract Documents.
- D. Contractor Employed Agency:
 - 1. Testing agency: Comply with requirements of ASTM E329, ASTM E543, ASTM E699, ASTM C1021, ASTM C1077, ASTM C1093, ASTM D3740, and DSA.
 - 2. Laboratory Qualifications: Accredited by IAS according to IAS AC89.
 - 3. Laboratory: Authorized to operate in California.
 - 4. Laboratory Staff: Maintain a full time registered Engineer on staff to review services.
 - 5. Testing Equipment: Calibrated at reasonable intervals either by NIST or using an NIST established Measurement Assurance Program, under a laboratory measurement quality assurance program.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION

3.01 CONTRACTOR'S QUALITY ASSURANCE

- A. Quality Requirements: Work shall be accomplished in accordance with quality requirements of the Drawings and Specifications, including, by reference, all Codes, laws, rules, regulations and standards. When no quality basis is prescribed, the quality shall be in accordance with the best accepted practices of the construction industry for the locale of the Project, for projects of this type.
- B. Quality Control Personnel: Contractor shall employ and assign knowledgeable and skilled personnel as necessary to perform quality control functions to ensure that the Work is provided as required.

3.02 CONTROL OF INSTALLATION

- A. Quality of Products: Unless otherwise indicated or specified, all products shall be new, free of defects and fit for the intended use.
- B. Monitor quality control over suppliers, manufacturers, products, services, site conditions, and workmanship, to produce work of specified quality.
- C. Comply with manufacturers' instructions, including each step in sequence.

FOR REFERENCE ONLY

- D. Should manufacturers' instructions conflict with Contract Documents, request clarification from Architect before proceeding.
- E. Comply with specified standards as minimum quality for the work except where more stringent tolerances, codes, or specified requirements indicate higher standards or more precise workmanship.
- F. Have work performed by persons qualified to produce required and specified quality.
- G. Verify that field measurements are as indicated on shop drawings or as instructed by the manufacturer.
- H. Secure products in place with positive anchorage devices designed and sized to withstand stresses, vibration, physical distortion, and disfigurement.
- I. Quality of Installation: All Work shall be produced plumb, level, square and true, or true to indicated angle, and with proper alignment and relationship between the various elements.
- J. Protection of Existing and Completed Work: Take all measures necessary to preserve and protect existing and completed Work free from damage, deterioration, soiling and staining, until Acceptance by the District.
- K. Verification of Quality: Work shall be subject to verification of quality by District, or Architect in accordance with provisions of the General Conditions of the Contract.
 - 1. Contractor shall cooperate by making Work available for inspection by District, Architect or their designated representatives.
 - 2. Such verification may include mill, plant, shop, or field inspection as required.
 - 3. Provide access to all parts of the Work, including plants where materials or equipment are manufactured or fabricated.
 - 4. Provide all information and assistance as required, including that by and from subcontractors, installers, fabricators, materials suppliers and manufacturers, for verification of quality by District, or Architect.
 - 5. Contract modifications, if any, resulting from such verification activities shall be governed by applicable provisions in the General Conditions.

3.03 MOCK-UPS

- A. Before installing portions of the Work where mock-ups are required, construct mock-ups in location and size indicated for each form of construction and finish required to comply with the following requirements, using materials indicated for the completed Work. The purpose of mock-up is to demonstrate the proposed range of aesthetic effects and workmanship.
- B. Accepted mock-ups establish the standard of quality the Architect will use to judge the Work.
- C. Notify Architect fifteen (15) working days in advance of dates and times when mock-ups will be constructed.
- D. Provide supervisory personnel who will oversee mock-up construction. Provide workers that will be employed during the construction at Project.
- E. Tests shall be performed under provisions identified in this section and identified in the respective product specification sections.
- F. Assemble and erect specified items with specified attachment and anchorage devices, flashings, seals, and finishes.

- G. Obtain Architect's approval of mock-ups before starting work, fabrication, or construction.
 - 1. Architect will issue written comments within seven (7) working days of initial review and each subsequent follow up review of each mock-up.
 - 2. Make corrections as necessary until Architect's approval is issued.
- H. Architect will use accepted mock-ups as a comparison standard for the remaining Work.
- I. Where mock-up has been accepted by Architect and is specified in product specification sections to be removed, protect mock-up throughout construction, remove mock-up and clear area when directed to do so by Architect.
- J. Where possible salvage and recycle the demolished mock-up materials.

3.04 TOLERANCES

- A. Monitor fabrication and installation tolerance control of products to produce acceptable Work. Do not permit tolerances to accumulate.
- B. Comply with manufacturers' tolerances. Should manufacturers' tolerances conflict with Contract Documents, request clarification from Architect before proceeding.
- C. Adjust products to appropriate dimensions; position before securing products in place.

3.05 TESTING AND INSPECTION

- A. See individual specification sections for testing required.
- B. Testing Agency Duties:
 - 1. Test samples of mixes submitted by Contractor.
 - 2. Provide qualified personnel at site. Cooperate with Architect and Contractor in performance of services.
 - 3. Perform specified sampling and testing of products in accordance with specified standards.
 - 4. Ascertain compliance of materials and mixes with requirements of Contract Documents.
 - 5. Promptly notify Architect and Contractor of observed irregularities or non-compliance of Work or products.
 - 6. Perform additional tests and inspections required by Architect.
 - 7. Submit reports of all tests/inspections specified.
- C. Limits on Testing/Inspection Agency Authority:
 - 1. Agency may not release, revoke, alter, or enlarge on requirements of Contract Documents.
 - 2. Agency may not approve or accept any portion of the Work.
 - 3. Agency may not assume any duties of Contractor.
 - 4. Agency has no authority to stop the Work.
- D. Contractor Responsibilities:
 - 1. Deliver to agency at designated location, adequate samples of materials proposed to be used that require testing, along with proposed mix designs.

FOR REFERENCE ONLY

2. Cooperate with laboratory personnel, and provide access to the Work and to manufacturers' facilities.
3. Provide incidental labor and facilities:
 - a. To provide access to Work to be tested/inspected.
 - b. To facilitate tests/inspections.
 - c. To provide for storage and curing of test samples.
4. Notify Architect and laboratory 24 hours prior to expected time for operations requiring testing/inspection services.
5. Employ services of an independent qualified testing laboratory and pay for additional samples, tests, and inspections required by Contractor beyond specified requirements.
6. Arrange with District's agency and pay for additional samples, tests, and inspections required by Contractor beyond specified requirements.
7. Inspections and Tests by Authorities Having Jurisdiction:
 - a. Contractor shall cause all tests and inspections to be made for Work under this Contract, as required by Building Departments, Department of Public Works, Fire Department, Health Department and similar agencies having jurisdiction.
 - b. Excepted as specifically noted, scheduling, conducting and paying for such inspections shall be solely the Contractor's responsibility.
8. Inspections and Tests by Serving Utilities:
 - a. Contractor shall cause all tests and inspections required by serving utilities to be made for Work under this Contract.
 - b. Scheduling, conducting and paying for such inspections shall be solely the Contractor's responsibility.
- E. Re-testing required because of non-compliance with specified requirements shall be performed by the same agency on instructions by Architect.
- F. Costs of re-testing required because of non-compliance with specified requirements are to be reimbursed to the District by the Contractor through a deductive change order, CAC 4-335(b).

3.06 MANUFACTURERS' FIELD SERVICES

- A. When specified in individual specification sections, require material or product suppliers or manufacturers to provide qualified staff personnel to observe site conditions, conditions of surfaces and installation, quality of workmanship, start-up of equipment, test, adjust, and balance equipment as applicable, and to initiate instructions when necessary.
- B. Submit qualifications of observer to Architect 30 days in advance of required observations.
 1. Observer subject to approval of Architect.
 2. Observer subject to approval of District.
- C. Report observations and site decisions or instructions given to applicators or installers that are supplemental or contrary to manufacturers' written instructions.

3.07 FIELD QUALITY CONTROL SUBMITTALS

- A. Administration: Make all submittals to the Architect, unless otherwise directed.

FOR REFERENCE ONLY

B. Submittal Identification: Identify each submittal by Specification Section number followed by a number indicating sequential submittal for that Section. Coordinate submittal numbers with submittals specified in Section 01 30 00 - Administrative Requirements.

1. Resubmittals shall use same number as original submittal, followed by a letter indicating sequential resubmittal.

03 30 00 - 1	First submittal for Section 03 30 00 - Cast in Place Concrete.
03 30 00 - 2	Second submittal for Section 03 30 00 - Cast in Place Concrete.
03 30 00 - 2A	Resubmittal of second submittal for Section 03 30 00 - Cast in Place Concrete.
03 30 00 - 2B	Second resubmittal of second submittal for Section 03 30 00 - Cast in Place Concrete.

C. Project Identification: Title each submittal with Project name, submittal date and Architect's Project number.

D. Copies: Provide PDF copies electronically transmitted or submit 6 copies, minimum, of reports of quality control reports on dry-process xerographic copies only.

E. Contractor's Review:

1. Submittals shall be made in accordance with requirements specified herein and in individual Sections.
2. Indicate clearly on each submittal the specified or referenced values for each quality control activity and the values obtained.
3. Note clearly and sign each submittal certifying that reported quality control activity "Conforms" or "Does Not Conform".

F. Changes and Deviations:

1. Identify all deviations from requirements of Drawings and Specifications.
2. Changes in the Work shall not be authorized by submittals review actions.
3. No review action, implicit or explicit, shall be interpreted to authorized changes in the Work.
4. Changes shall only be authorized by separate written Change Order or Construction Change Directive, in accordance with the General Conditions and 01 20 00 - Price and Payment Procedures.

G. Record Submittals: When record submittals are specified, submit three copies or sets only. Record submittals will not be reviewed but will be retained for historical and maintenance purposes.

H. Unsolicited Submittals: Unsolicited submittals will be returned unreviewed.

3.08 ARCHITECT'S REVIEW

A. General:

FOR REFERENCE ONLY

1. Submitted Report review by Architect and Architect's consultants shall be only for general conformance with the design concept and requirements based on the information presented.
 2. Neither Architect nor Architect's consultants shall verify submitted quality control data.
- B. Contract Requirements:
1. Review by Architect and Architect's consultants shall not relieve the Contractor from compliance with requirements of the Drawings and Specifications.
 2. Changes shall only be authorized by separate written Change Order or Construction Change Directive, in accordance with the General Conditions and 01 20 00 - Price and Payment Procedures.
- C. Observations by Architect and Architect's Consultants: Periodic and occasional observations of Work in progress will be made by Architect and Architect's consultants as deemed necessary to review progress of Work and general conformance with design intent.

3.09 DEFECT ASSESSMENT

- A. Replace Work or portions of the Work not conforming to specified requirements, at no change in Contract Sum or Contract Time.
- B. If, in the opinion of Architect, it is not practical to remove and replace the work, Architect will direct an appropriate remedy or adjust payment.
- C. Architect's Acceptance and Rejection of Work: Architect reserves the right to reject all Work not in conformance to the requirements of the Drawings and Specifications.
- D. Acceptance of Non-Conforming Work: Acceptance of non-conforming Work, without specific written acknowledgement and approval of the District, shall not relieve the Contractor of the obligation to correct such Work.
1. Acceptance of structurally related non-conforming work shall be submitted to DSA for review and approval.
- E. Contract Adjustment for Non-conforming Work:
1. Should Architect or District determine that it is not feasible or in District's interest to require non-conforming Work to be repaired or replaced, an equitable reduction in Contract Sum shall be made by agreement between District and Contractor.
 2. If equitable amount cannot be agreed upon, a Construction Change Directive will be issued and the amount in dispute resolved in accordance with applicable provisions of the General Conditions.
- F. Non-Responsibility for Non-Conforming Work: Architect and Architect's consultants disclaim any and all responsibility for Work produced not in conformance with the Drawings and Specifications.

END OF SECTION

SECTION 01 41 00 REGULATORY REQUIREMENTS

PART 1 GENERAL

1.01 AUTHORITY AND PRECEDENCE OF CODES, ORDINANCES AND STANDARDS

- A. Authority: All codes, ordinances and standards referenced in the Drawings and Specifications shall have the full force and effect as though printed in their entirety in the Specifications.
- B. Precedence:
 - 1. Where specified requirements differ from the requirements of applicable codes, ordinances and standards, the more stringent requirements take precedence.
 - 2. Where the Drawings or Specifications require or describe products or execution of better quality, higher standard or greater size than required by applicable codes, ordinances and standards, the Drawings and Specifications take precedence so long as such increase is legal.
 - 3. Where no requirements are identified in the Drawings or Specifications, comply with all requirements of applicable codes, ordinances and standards of authorities having jurisdiction.
- C. Applicable Codes, Laws and Ordinances: Refer also to Section 01 10 00 - Summary, regarding permits and licenses.
 - 1. Performance of the Work is be governed by all applicable laws, ordinances, rules and regulations of Federal, State and local governmental agencies and jurisdictions having authority over the Project, including accessibility requirements.
 - 2. Performance of the Work shall be accomplished in conformance with all rules and regulations of public utilities, utility districts and other agencies serving the development.
 - 3. Where such laws, ordinances, rules and regulations require more care or greater time to accomplish Work, or require better quality, higher standards or greater size of products, Work shall be accomplished in conformance to such requirements with no change to the Contract Time and Contract Sum, except where changes in laws, ordinances, rules and regulations occur subsequent to the execution date of the Agreement.
- D. Applicable Building Codes: References on the Drawings or in the Specifications to "code" or "building code" not otherwise identified shall mean the codes specified below, together with all additions, amendments, changes, and interpretations adopted by code authorities of the jurisdiction having authority over the Project.
- E. Performance of the Work shall meet or exceed the minimum regulatory requirements applicable to this project are summarized in this section, as adopted by Division of the State Architect:
 - 1. Part 1, Title 24 CCR - 2022 California Administrative Code.
 - 2. Part 2, Title 24 CCR - 2022 California Building Code (CBC); Volumes 1 and 2.
 - a. Based on ICC (IBC) - ICC International Building Code, 2021.

FOR REFERENCE ONLY

- b. Effective dates of referenced standards are according to Chapter 35.
 3. Part 3, Title 24 CCR - 2022 California Electrical Code.
 - a. 2023 is current use, use the CEC based on the NFPA 70-NEC 2020 edition as modified.
 4. Part 4, Title 24 CCR - 2022 California Mechanical Code (CMC).
 - a. Based on IAPMO (UMC) - Uniform Mechanical Code, 2021.
 5. Part 5, Title 24 CCR - 2022 California Plumbing Code (CPC).
 - a. Based on IAPMO (UPC) - Uniform Plumbing Code, 2021.
 6. Part 6, Title 24 CCR - 2022 California Energy Code.
 7. Part 8, Title 24 CCR - 2022 California Historical Building Code.
 8. Part 9, Title 24 CCR - 2022 California Fire Code (CFC).
 - a. Based on ICC (IFC) - International Fire Code; 2021.
 9. Part 10, Title 24 CCR - 2022 California Existing Buildings Code.
 - a. Based on ICC (IEBC) - ICC International Existing Buildings Code, 2021.
 10. Part 11, Title 24 CCR - 2022 California Green Building Standards Code (CalGreen).
 11. Part 12, Title 24 CCR - 2022 California Referenced Standards Code.
- F. Maintain on site during construction, a copy of California Codes and Regulations; Title 24, California Building Code, Parts 1 through 5.

1.02 SUMMARY OF REFERENCE STANDARDS

- A. Regulatory requirements applicable to this project are the following:
- B. California Referenced Standards Code: Chapter 12-7-4 Fire Resistive Standards, for fire rated doors.
- C. National Fire Protection Association (NFPA): (Partial List of Applicable Standards)
 1. Reference CBC for applicable NFPA Standards - 2021 CBC (SFM) Chapter 35.
 2. NFPA 72 - National Fire Alarm and Signaling Code (CA Amended); 2022, as amended in 2022 CBC Ch.35 Referenced Standards.
 3. NFPA 80 - Standard for Fire Doors and Other Opening Protectives; 2022 is current; use 2019 as indicated in 2022 CBC Ch. 35 Referenced Standards.
 4. NFPA 105 - Standard for the Installation of Smoke Door Assemblies and other Opening Protectives; 2022 is current; use 2019 as indicated in 2022 CBC Ch.35 Referenced Standards..
 5. NFPA 241 - Standard for Safeguarding Construction, Alteration, and Demolition Operations; 2019.
- D. 28 CFR 35 - Nondiscrimination on the Basis of Disability in State and Local Government Services; Final Rule; Department of Justice.
- E. 28 CFR 36 - Nondiscrimination by Public Accommodations and in Commercial Facilities; Final Rule; Department of Justice.

FOR REFERENCE ONLY

- F. 36 CFR 1191 - Americans with Disabilities Act (ADA) Accessibility Guidelines for Buildings and Facilities; Architectural Barriers Act (ABA) Accessibility Guidelines.
- G. ADA Standards - 2010 ADA Standards for Accessible Design.
- H. 29 CFR 1910 - Occupational Safety and Health Standards.

1.03 RELATED REQUIREMENTS

- A. Section 01 40 00 - Quality Requirements.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

END OF SECTION

SECTION 01 42 19 REFERENCE STANDARDS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Requirements relating to referenced standards.
- B. Reference standards full title and edition date.

1.02 QUALITY ASSURANCE

- A. For products or workmanship specified by reference to a document or documents not included in the Project Manual, also referred to as reference standards, comply with requirements of the standard, except when more rigid requirements are specified or are required by applicable codes.
- B. Conform to reference standard of date of issue specified in the individual specification sections, except where a specific date is established by applicable code.
- C. Obtain copies of standards when required by Contract Documents.
- D. Maintain copy at project site during submittals, planning, and progress of the specific work, until Date of Final Inspection.
- E. Should specified reference standards conflict with Contract Documents, request clarification from the Architect before proceeding.
- F. Neither the contractual relationships, duties, or responsibilities of the parties in Contract nor those of the Architect shall be altered by Contract Documents by mention or inference otherwise in any reference document.

PART 2 CALIFORNIA DEPARTMENT OF GENERAL SERVICES, DIVISION OF THE STATE ARCHITECT

2.01 INTERPRETATION OF REGULATIONS

- A. Document IR A-5 - Acceptance of Products, Materials, and Evaluations Reports .
- B. Current listings are on the DGS website:
<http://www.dgs.ca.gov/dsa/Resources/IRManual.aspx>.

PART 3 UNITED STATES GOVERNMENT AND RELATED AGENCIES DOCUMENTS

3.01 CFR -- CODE OF FEDERAL REGULATIONS

- A. ADA Standards - 2010 ADA Standards for Accessible Design.
- B. 16 CFR 260.13 - Guides for the Use of Environmental Marketing Claims; Federal Trade Commission; Recycled Content.
- C. 16 CFR 1201 - Safety Standard for Architectural Glazing Materials.
- D. 28 CFR 36 - Nondiscrimination by Public Accommodations and in Commercial Facilities; Final Rule; Department of Justice.

FOR REFERENCE ONLY

- E. 29 CFR 1910 - Occupational Safety and Health Standards.
- F. 29 CFR 1910, Subpart D - Walking-Working Surfaces, 1910.21-1910.30.
- G. 29 CFR 1910.23 - Ladders.
- H. 29 CFR 1910.38 - Emergency action plans.
- I. 29 CFR 1910.132-138 - Personal Protective Equipment.
- J. 29 CFR 1910.134 - Respiratory protection.
- K. 29 CFR 1926.62 - Lead.
- L. 29 CFR 1926.1101 - Asbestos.
- M. 36 CFR 1191 - Americans with Disabilities Act (ADA) Accessibility Guidelines for Buildings and Facilities; Architectural Barriers Act (ABA) Accessibility Guidelines.
- N. 39 CFR 111 - U.S. Postal Service Standard 4C.
- O. 40 CFR 59, Subpart D - National Volatile Organic Compound Emission Standards for Architectural Coatings; U.S. Environmental Protection Agency.
- P. 40 CFR 60 - Standards of Performance for New Stationary Sources.
- Q. 40 CFR 273 - Standards For Universal Waste Management.
- R. 40 CFR 280 - Technical Standards and Corrective Action Requirements for Owners and Operators of Underground Storage Tanks.
- S. 40 CFR 761 - Polychlorinated Biphenyls (PCBs) Manufacturing, Processing, Distribution In Commerce, And Use Prohibitions.
- T. 47 CFR 15 - Radio Frequency Devices.
- U. 47 CFR 68 - Connection of Terminal Equipment to the Telephone Network.
- V. 49 CFR 37 - Transportation Services for Individuals with Disabilities (ADA).
- W. 49 CFR 178 - Specifications for Packaging.
- X. 49 CFR 192.285 - Plastic Pipe: Qualifying Persons to Make Joints.

3.02 CPSC -- CONSUMER PRODUCTS SAFETY COMMISSION

- A. CPSC Pub. No. 325 - Public Playground Safety Handbook.

3.03 EPA -- ENVIRONMENTAL PROTECTION AGENCY

- A. EPA (NPDES) - National Pollutant Discharge Elimination System (NPDES), Construction General Permit.
- B. EPA 600/4-90/010 - Compendium of Methods for the Determination of Air Pollutants in Indoor Air.
- C. EPA 600-4-790-20 - Methods for Chemical Analysis of Water and Wastes.
- D. EPA 625/1-86/021 - Design Manual: Municipal Wastewater Disinfection.
- E. EPA 625/R-96/010b - Compendium of Methods for the Determination of Toxic Organic Compounds in Ambient Air.
- F. EPA 712-C-02-190 - Health Effects Test Guidelines OPPTS 870.1100 Acute Oral Toxicity.

3.04 FDA -- FOOD AND DRUG ADMINISTRATION

- A. FDA Food Code - Chapter 6 - Physical Facilities.

3.05 FEMA -- U.S. FEDERAL EMERGENCY MANAGEMENT AGENCY

- A. FEMA (MAPS) - FEMA Map Service Center.
- B. FEMA 412 - Installing Seismic Restraints for Mechanical Equipment.
- C. FEMA 413 - Installing Seismic Restraints for Electrical Equipment.
- D. FEMA 414 - Installing Seismic Restraints for Duct and Pipe.
- E. FEMA E-74 - Reducing the Risks of Nonstructural Earthquake Damage.

3.06 FS -- FEDERAL SPECIFICATIONS AND STANDARDS (GENERAL SERVICES ADMINISTRATION)

- A. FED-STD-595C - Colors Used in Government Procurement (Fan Deck)..
- B. FS L-F-001641 - Floor Covering Translucent or Transparent Vinyl Surface with Backing; 1971, and Amendment 2, 1982.
- C. FS L-S-125 - Screening, Insect, Nonmetallic.
- D. FS RR-P-1352 - Partitions, Toilet, Complete; Revision C, 1989.
- E. FS RR-T-650 - Treads, Metallic and Nonmetallic, Skid Resistant.
- F. FS RR-W-365 - Wire Fabric (Insect Screening); 1980, Rev. A (Amended 1986).
- G. FS SS-T-312 - Tile, Floor: Asphalt, Rubber, Vinyl, and Vinyl Composition; Revision B, 1974, and Amendment 1, 1979.
- H. FS TT-B-1325 - Beads (Glass Spheres) Retro-Reflective.
- I. FS TT-P-115 - Paint, Traffic (Highway, White and Yellow); Revision F, 1984.
- J. FS TT-P-1952 - Paint, Traffic and Airfield Marking, Waterborne.
- K. FS W-C-375 - Circuit Breakers, Molded Case; Branch Circuit and Service.
- L. FS W-C-596 - Connector, Electrical, Power, General Specification for.
- M. FS W-S-896 - Switches, Toggle (Toggle and Lock), Flush Mounted (General Specification).
- N. STATE STD 01.01 - Certification Standard Forced Entry and Ballistic Resistance of Structural Systems; Physical Security Division, Office of Physical Security Programs, Bureau of Diplomatic Security, United States Department of State.
- O. UFC 4-010-01 - DoD Minimum Antiterrorism Standards for Buildings.
- P. USPS Handbook AS-503 - Standard Design Criteria; United States Postal Service.

3.07 GSA -- U.S. GENERAL SERVICES ADMINISTRATION

- A. GSA PBS-P100 - Facilities Standards for the Public Buildings Service.

3.08 NIJ -- NATIONAL INSTITUTE OF JUSTICE (DEPT. OF JUSTICE)

- A. NIJ 0108.01 - Standard for Ballistic Resistant Protective Materials.

3.09 PS -- PRODUCT STANDARDS

- A. PS 1 - Structural Plywood.

FOR REFERENCE ONLY

- B. PS 2 - Performance Standard for Wood Structural Panels.
- C. PS 20 - American Softwood Lumber Standard.

3.10 USDA -- UNITED STATES DEPARTMENT OF AGRICULTURE

- A. USDA TR-55 - Urban Hydrology for Small Watersheds; USDA Natural Resources Conservation Service.

3.11 USGS -- UNITED STATES GEOLOGICAL SURVEY

- A. USGS (FMWQ) - National Field Manual for the Collection of Water-Quality Data; United States Geological Survey.

END OF SECTION

SECTION 01 45 33 CODE-REQUIRED SPECIAL INSPECTIONS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Division of the State Architect (DSA) Procedures for construction oversight and inspections required during the course of construction.
- B. Code-required special inspections.
 - 1. Division of the State Architect (DSA) approved testing laboratory services and inspections required during the course of construction.
- C. Testing services incidental to special inspections.
- D. Submittals.
- E. Manufacturers' field services.
- F. Fabricators' field services.

1.02 RELATED REQUIREMENTS

- A. Document 00 31 00 - Available Project Information: Soil investigation data.
- B. Section 01 30 00 - Administrative Requirements: Submittal procedures.
- C. Section 01 40 00 - Quality Requirements.
- D. Section 01 42 19 - Reference Standards.
- E. Section 01 42 19 - Reference Standards: See also CBC Chapter 35 for current code adopted editions.
- F. Section 01 60 00 - Product Requirements: Requirements for material and product quality.

1.03 DEFINITIONS

- A. Code or Building Code: California Building Code and, more specifically, Chapter 17A - Structural Tests and Special Inspections, of same.
- B. Authority Having Jurisdiction (AHJ): Agency or individual officially empowered to enforce the building, fire and life safety code requirements of the permitting jurisdiction in which the Project is located. AHJ for this Project is Division of the State Architect.
- C. Special Inspection:
 - 1. Special inspections are inspections and testing of materials, installation, fabrication, erection or placement of components and connections mandated by the CBC that also require special expertise to ensure compliance with the approved contract documents and the referenced standards.
 - 2. Special inspections are separate from and independent of tests and inspections conducted by District or Contractor for the purposes of quality assurance and contract administration.

1.04 REFERENCE STANDARDS

- A. ACI CODE-318 - Building Code Requirements for Structural Concrete and Commentary.
- B. AISC 341 - Seismic Provisions for Structural Steel Buildings.
- C. ASCE 7 - Minimum Design Loads and Associated Criteria for Buildings and Other Structures.
- D. ASTM A615/A615M - Standard Specification for Deformed and Plain Carbon-Steel Bars for Concrete Reinforcement.
- E. ASTM A706/A706M - Standard Specification for Deformed and Plain Low-Alloy Steel Bars for Concrete Reinforcement.
- F. ASTM C143/C143M - Standard Test Method for Slump of Hydraulic-Cement Concrete.
- G. ASTM C31/C31M - Standard Practice for Making and Curing Concrete Test Specimens in the Field.
- H. ASTM C172/C172M - Standard Practice for Sampling Freshly Mixed Concrete.
- I. ASTM D1556/D1556M - Standard Test Method for Density and Unit Weight of Soil in Place by Sand-Cone Method.
- J. ASTM D1557 - Standard Test Methods for Laboratory Compaction Characteristics of Soil Using Modified Effort (56,000 ft-lbf/ft³ (2,700 kN-m/m³)).
- K. ASTM D3740 - Standard Practice for Minimum Requirements for Agencies Engaged in Testing and/or Inspection of Soil and Rock as Used in Engineering Design and Construction.
- L. ASTM E329 - Standard Specification for Agencies Engaged in Construction Inspection, Testing, or Special Inspection.
- M. ASTM E543 - Standard Specification for Agencies Performing Nondestructive Testing.
- N. ASTM E2174 - Standard Practice for On-Site Inspection of Installed Firestop Systems.
- O. ASTM E2393 - Standard Practice for On-Site Inspection of Installed Fire Resistive Joint Systems and Perimeter Fire Barriers.
- P. ASTM E2570/E2570M - Standard Test Methods for Evaluating Water-Resistive Barrier (WRB) Coatings Used Under Exterior Insulation and Finish Systems (EIFS) or EIFS with Drainage.
- Q. AWS D1.1/D1.1M - Structural Welding Code - Steel.
- R. AWS D1.3/D1.3M - Structural Welding Code - Sheet Steel.
- S. AWS D1.4/D1.4M - Structural Welding Code - Steel Reinforcing Bars.
- T. {RSTEMP#10005412}
- U. {RSTEMP#10005050}
- V. CBC Chapter 11B - California Building Code-Chapter 11B.
- W. CBC Chapter 35 - CBC Chapter 35 - Referenced Standards.
- X. DSA IR 17-13 - Batch Plant Inspection.
- Y. DSA PR 13-01 - Construction Oversight Process.
- Z. ICC-ES AC308 - Acceptance Criteria for Post-Installed Adhesive Anchors in Concrete Elements.
- AA. TMS 402/602 - Building Code Requirements and Specification for Masonry Structures.

- BB. RCSC (HSBOLT) - Specification for Structural Joints Using High-Strength Bolts; Research Council on Structural Connections.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Special Inspection Agency Qualifications: Prior to the start of work, the Special Inspection Agency is required to:
1. Submit agency name, address, and telephone number, names of full time registered Engineer and responsible officer.
 2. Submit copy of report of laboratory facilities inspection made by NIST Construction Materials Reference Laboratory during most recent inspection, with memorandum of remedies of any deficiencies reported by the inspection.
 3. Submit certification that Special Inspection Agency is acceptable to AHJ.
- C. Testing Agency Qualifications: Prior to the start of work, the Testing Agency is required to:
1. Submit agency name, address, and telephone number, and names of full time registered Engineer and responsible officer.
 2. Submit certification that Testing Agency is acceptable to AHJ.
 3. Testing and inspections will be performed by an independent testing laboratory selected and employed by the District and approved by the Division of the State Architect (DSA).
 - a. Qualification of a testing agency or laboratory will be under the jurisdiction of the DSA Structural Safety Section (SSS). Procedural and acceptance criteria are set forth in the California Administrative Code (CBC) Chapter 4.
- D. Manufacturer's Qualification Statement: Manufacturer is required to submit documentation of manufacturing capability and quality control procedures. Include documentation of AHJ approval.
- E. Fabricator's Qualification Statement: Fabricator is required to submit documentation of fabrication facilities and methods as well as quality control procedures.
- F. Distribution List: The Testing Laboratory will make the following distribution of test and inspection reports:
- 1 District
 - 2 Architect
 - 1 Structural Engineer
 - 1 Contractor
 - 1 District's Project Inspector
 - 1 Division of the State Architect
- G. Each and every test or inspection report shall bear the File Number and Application Number assigned to this project by the DSA.
- H. DSA Form 291: From the engineering manager of the laboratory of record.
- I. Special Inspection Reports: After each special inspection, Special Inspector is required to promptly submit at least two copies of report; one to Architect and one each to the distribution list.

FOR REFERENCE ONLY

1. Include:
 - a. Date issued.
 - b. Project title and number.
 - c. Name of Special Inspector.
 - d. Date and time of special inspection.
 - e. Identification of product and specifications section.
 - f. Location in the Project.
 - g. Type of special inspection.
 - h. Date of special inspection.
 - i. Results of special inspection.
 - j. Compliance with Contract Documents.
 2. Final Special Inspection Report: Document special inspections and correction of discrepancies prior to the start of the work.
 3. Comply with DSA IR 17-12, revised 04/23/20.
- J. Fabricator Special Inspection Reports: After each special inspection of fabricated items at the Fabricator's facility, Special Inspector is required to promptly submit at least two copies of report; one to Architect and one each to the distribution list.
1. Include:
 - a. Date issued.
 - b. Project title and number.
 - c. Name of Special Inspector.
 - d. Date and time of special inspection.
 - e. Identification of fabricated item and specification section.
 - f. Location in the Project.
 - g. Results of special inspection.
 - h. Verification of fabrication and quality control procedures.
 - i. Compliance with Contract Documents.
 - j. Compliance with referenced standard(s).
- K. Test Reports: After each test or inspection, promptly submit at least two copies of report; one to Architect and one each to the distribution list.
1. Include:
 - a. Date issued.
 - b. Project title and number.
 - c. Name of inspector.
 - d. Date and time of sampling or inspection.
 - e. Identification of product and specifications section.
 - f. Location in the Project.

FOR REFERENCE ONLY

- g. Type of test or inspection.
 - h. Date of test or inspection.
 - i. Results of test or inspection.
 - j. Compliance with Contract Documents.
 - k. Test reports shall be signed by a Civil Engineer licensed in the State of California.
2. Test reports shall include all tests made, regardless of whether such tests indicate that the material is satisfactory or unsatisfactory.
 - a. Samples taken but not tested shall also be reported.
 - b. Records of special sampling operations as required shall also be reported.
 - c. Reports shall show that the material or materials were sampled and tested in accordance with the requirements of the CBC, and with the approved specifications.
 - d. They shall also state definitely whether or not the material or materials tested comply with requirements.
 - e. Test reports shall be issued within 14 days of finding being known, to all parties listed above.
 3. At the completion of the project, Testing Laboratory shall certify in writing and on all required DSA forms, that all work specified or required to be tested and inspected conforms to drawings, specifications and applicable building codes.
 4. Verification of Test Reports:
 - a. The Testing Laboratory of record shall submit to the Division of the State Architect (DSA) a verified report covering all tests which are required to be made by that agency during the progress of the project.
 - 1) Such report shall be furnished each time that work on the project is suspended, covering the tests up to that time, and at the completion of the project.
 - 2) Specific testing requirements as listed on the Structural Test and Inspections (T&I) Form DSA-103 for this project. These tests may include the following forms:
 - (a) DSA-201: Soils Compaction.
 - (b) DSA-202: Sieve Analysis.
 - (c) DSA-203: Tension/Bend.
 - (d) DSA-204: Compression.
 - (e) DSA-205: Concrete Masonry Unit.
 - (f) DSA-206: Anchor Load.
 - (g) DSA-207: Masonry Core Shear/Compression.
 - (h) DSA-208: High-Strength Bolt.
 - (i) DSA-210: Ultrasonic (NDT).
 - (j) DSA-250: Special Inspection(s).
 - (k) DSA-291: Laboratory Verified Report.
 - (l) DSA-292: Special Inspection(s) Verified Report(s).
 - (m) DSA-293: Geotechnical Verified Report.

- (n) DSA-403: Energy Compliance Checklist.
- 3) Other Division of the State Architect (DSA) Certification Documents (Reports) as may be required.
 - b. DSA Form 292 - Special Inspection Verified Report shall be from all special inspectors contracting directly and individually with the school board.
- L. Certificates: When specified in individual special inspection requirements, Special Inspector shall submit certification by the manufacturer, fabricator, and installation subcontractor to Architect and AHJ, in quantities specified for Product Data.
 - 1. Indicate material or product complies with or exceeds specified requirements. Submit supporting reference data, affidavits, and certifications as appropriate.
 - 2. Certificates may be recent or previous test results on material or product, but must be acceptable to Architect and AHJ.
- M. Manufacturer's Field Reports: Submit reports to Architect.
 - 1. Submit report in duplicate within 7 days of observation to Architect for information.
 - 2. Submit for information for the limited purpose of assessing compliance with information given and the design concept expressed in Contract Documents.
- N. Fabricator's Field Reports: Submit reports to Architect and AHJ.
 - 1. Submit report in duplicate within 30 days of observation to Architect for information.
 - 2. Submit for information for the limited purpose of assessing compliance with information given and the design concept expressed in Contract Documents.

1.06 SPECIAL INSPECTION AGENCY

- A. District will employ services of a Special Inspection Agency to perform inspections and associated testing and sampling in accordance with ASTM E329 and required by the building code.
- B. The Special Inspection Agency may employ and pay for services of an independent testing agency to perform testing and sampling associated with special inspections and required by the building code.
- C. Employment of agency in no way relieves Contractor of obligation to perform work in accordance with requirements of Contract Documents.

1.07 TESTING AND INSPECTION AGENCIES

- A. District is to employ services of an independent inspection and testing agency to perform observation, testing and sampling associated with special inspections including those not required by the building code. CAC
 - 1. Project Inspector and testing lab are employed by the District and approved by:
 - a. A/E of Record.
 - b. Structural Engineer (when applicable).
 - c. DSA.
- B. Employment of agency in no way relieves Contractor of obligation to perform work in accordance with requirements of Contract Documents.

1.08 QUALITY ASSURANCE

- A. Special Inspection Agency Qualifications:
 - 1. Independent firm specializing in performing testing and inspections of the type specified in this section.
- B. Testing Agency Qualifications:
 - 1. Independent firm specializing in performing testing and inspections of the type specified in this section.
 - 2. Testing Agency must possess DSA LEA Program acceptance.
- C. Testing and inspection services which are performed shall be in accordance with requirements of the CBC, and as specified herein. Testing and inspection services shall verify that work meets the requirements of the Construction Documents.
- D. In general, tests and inspections for structural materials shall include all items enumerated on the Structural Tests and Inspections list for this project as prepared and distributed by the Architect.
- E. Copies of Documents at Project Site: Maintain at the project site a copy of each referenced document.

1.09 INSPECTION BY THE DISTRICT

- A. The District shall have the right to reject materials and workmanship which are defective, or to require their correction.
 - 1. Rejected workmanship shall be satisfactorily corrected and rejected materials shall be removed from the premises without charge to the District.
 - 2. If the Contractor does not correct such rejected work within a reasonable time, the District may correct such rejected work and charge the expense to the Contractor.
- B. Should it be considered necessary or advisable by the District at any time before final acceptance of the entire work to make an examination of work already completed by removing or tearing out the completed work; the Contractor shall on request promptly furnish necessary facilities, labor and materials.
 - 1. If such work is found to be defective in any respect due to fault of the Contractor or his subcontractor, he shall defray all expenses of such examinations and of satisfactory reconstruction. .
 - 2. If, however, such work is found to meet the requirements of the Contract, the additional cost of labor and material necessarily involved in the examination and replacement shall be allowed the Contractor.

1.10 DISTRICT'S INSPECTOR

- A. A Project Inspector (IOR) employed by the District and approved by Architect, Structural Engineer and DSA in accordance with the requirements of the California Building Code will be assigned to the work.
 - 1. Project Inspector duties are specifically defined in {RS#10005412} Section 4-211(b), 4-219, 4-333(b), 4-336 and 4-342.

- B. The District's Inspector shall at all times have access for the purpose of inspection to all parts of the work and to the shops where the work is in preparation, and the Contractor shall at all times maintain proper facilities and provide safe access for such inspection.
- C. The work of construction in all stages of progress shall be subject to the personal continuous observation of the District's Inspector.
 - 1. The Contractor shall furnish the Inspector reasonable facilities for obtaining such information as may be necessary to keep him fully informed respecting the progress and manner of the work and the character of the materials.
 - 2. Inspection of the work shall not relieve the Contractor from any obligation to fulfill this Contract.
 - 3. Inspector of Record is required to work a normal 40 hour week on this project only. Any overtime required will be included in a deductive change order to the Contractor and sub-contractor requiring the inspection.

1.11 PAYMENTS

- A. Costs of initial testing and inspection, except as specifically modified herein, or specified otherwise in technical sections, will be paid for by the District, providing such testing and inspection indicates compliance with Contract Documents. Initial tests and inspections are defined as the first tests and inspections as herein specified.
- B. In the event a test or inspection indicates failure of a material or procedure to meet requirements of Contract Documents, costs for retesting and reinspection will be paid by the District and backcharged to the Contractor.
- C. Additional tests and inspections not herein specified but requested by District or Architect, will be paid for by District, unless results of such tests and inspections are found to be not in compliance with Contract Documents, in which case the District will pay all costs for initial testing as well as retesting and reinspection and backcharge the Contractor.
- D. Costs for additional tests or inspections required because of change in materials being provided or change of source or supply will be paid by District and backcharged to the Contractor.
- E. Costs for tests or inspections which are required to correct deficiencies will be paid by the District and backcharged to the Contractor.
- F. Cost of testing which is required solely for the convenience of Contractor in his scheduling and performance of work will be paid by the District and backcharged to the Contractor.
- G. Overtime costs for testing and inspections performed outside the regular work day hours, including weekends and holidays, will be paid for by the District and backcharged to the Contractor. Such costs include overtime costs for the District's Inspector.
- H. Testing Laboratory shall separate and identify on the invoices, the costs covering all testing and inspections which are to be backcharged to the Contractor as specified above.
- I. Testing Laboratory shall furnish to District a cost estimate breakdown covering initial tests and inspections required by Contract Documents. Estimate shall include number of tests, man-hours required for tests, field and plant inspections, travel time, and costs.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION

3.01 SCHEDULE OF SPECIAL INSPECTIONS, GENERAL

- A. Tests and inspections for the following are required in accordance with DSA 103 Form.
- B. Frequency of Special Inspections: Special Inspections are indicated as continuous or periodic.
 - 1. Continuous Special Inspection: Special Inspection Agency is required to be present in the area where the work is being performed and observe the work at all times the work is in progress.
 - 2. Periodic Special Inspection: Special Inspection Agency is required to be present in the area where work is being performed and observe the work part-time or intermittently and at the completion of the work.
- C. Tests and inspections for the following will be required in accordance with the current CBC, unless otherwise specified.

3.02 SPECIAL INSPECTIONS FOR STEEL CONSTRUCTION (CHAPTER 17A AND 22A)

- A. Structural Steel: Comply with quality assurance inspection requirements of CBC.
- B. Erection Inspection: Testing Laboratory will visually inspect bolted and field welded connections, perform such additional tests and inspections of field work as are required by the Architect and prepare test reports for the Architect's review.
- C. Inspect High Strength Bolt Installation per CBC 1705A.2.1, Table 1705A.2.1.
 - 1. Special inspection for high tension bolting will be provided by the Testing Laboratory. Inspection in accordance with RCSC (HSBOLT).
 - 2. Comply with DSA Interpretations:
 - a. IR 17-8: Sampling and Testing of High Strength Bolts, Nuts, and Washers; Revised 09/24/19.
 - b. IR 17-9: High-Strength Structural Bolting Inspection; Revised 09/24/19.
- D. Welding:
 - 1. Testing Laboratory will review welding procedure specifications as prepared by the fabricator.
 - 2. Structural Steel:
 - a. Inspect welding per CBC 1705A.2.5.
 - 1) Comply with DSA IR 17-3: Structural Welding Inspection; Revised 09/24/19.
 - b. Complete and Partial Joint Penetration Groove Welds: Verify compliance with AWS D1.1/D1.1M and AWS D1.8/D1.8M; continuous.
 - c. Multipass Fillet Welds: Verify compliance with AWS D1.1/D1.1M and AWS D1.8/D1.8M; continuous.
 - d. Single Pass Fillet Welds Less than 5/16 inch Wide: Verify compliance with AWS D1.1/D1.1M and BHMA A156.31; periodic.

FOR REFERENCE ONLY

- e. Plug and Slot Welds: Verify compliance with AWS D1.1/D1.1M and AWS D1.8/D1.8M; continuous.
- f. Single Pass Fillet Welds 5/16 inch or Greater: Verify compliance with AWS D1.1/D1.1M and AWS D1.8/D1.8M; continuous.
- g. Floor and Roof Deck Welds: Verify compliance with AWS D1.3/D1.3M; continuous.
3. Reinforcing Steel: Verify items listed below comply with AWS D1.4/D1.4M and ACI CODE-318, Section 26.6.
 - a. Provide continuous inspection of welding of reinforcing steel per CBC 1705A.3.1; Table 1705A.3, Item 2; 1903A.8.
4. Ultrasonic Testing: All full penetration groove welds in material 5/16 inch or greater shall be subject to ultrasonic testing.
 - a. Defective welds shall be repaired and retested with ultrasonic equipment.
 - b. Initially, all multi-pass groove field welds shall be tested at the rate of 100 percent of each individual welder.
 - 1) If rejectable defects occur in less than 5 percent of the welds tested, the frequency of testing may be reduced to 25 percent.
 - 2) If the rate of rejectable defects increases to 5 percent or more, 100 percent testing shall be reestablished until the rate is reduced to less than 5 percent.
 - 3) The percentage of rejects shall be calculated for each welder independently.
 - c. When ultrasonic indications arising from the weld root can be interpreted as either a weld defect or the backing strip itself, the backing strip shall be removed at the expense of the Contractor, and if no root defect is visible, the weld shall be retested.
 - 1) If no defect is indicated on this retest, and no significant amount of the base and weld metal have been removed, no further repair or welding is necessary.
 - 2) If a defect is indicated, it shall be repaired at the Contractor's expense.
5. Technician to calibrate ultrasonic instrumentation to evaluate the quality of the welds in accordance with AWS D1.1/D1.1M latest Edition.
6. Should defects appear in welds tested, inspect repairs similarly at the Contractor's expense and at the direction of the Architect until satisfactory performance is assured.
7. Other methods of inspection, for example, X-ray, gamma ray, magnetic particle, or dye penetrant, may be used on welds if felt necessary by the Architect.
- E. Corrections:
 1. Correct deficiencies in structural steel work which inspections and test reports indicate to be not in compliance with the specified requirements.
 2. Perform additional tests required to reconfirm noncompliance of the original work and to show compliance of corrected work. Costs for all additional tests will be paid for by the District and backcharged to the Contractor.

3.03 SPECIAL INSPECTIONS FOR CONCRETE CONSTRUCTION (CHAPTER 17A AND 19A)

- A. Inspection:

FOR REFERENCE ONLY

1. Job Site Inspection: CBC 1705A.3, 1705A.3.5 (Conc. Preplacement), 1705A.3.6 (Placing Record), and 1910A.
2. Batch Plant or Weighmaster Inspection: CBC 1705.3.3.
 - a. Continuous or Periodic Batch Plant Inspection per DSA IR 17-13
- B. Reinforcing Steel, Including: Verify compliance with approved contract documents and ACI CODE-318, Sections 20.2, 25.2 through 25.7, and 26.6.
 1. Reinforcing Bars: CBC 1901A.6; 1910A.2.
 2. Tests:
 - a. Tests shall be performed before the delivery of steel to Project site. Steel not meeting specifications shall not be shipped to the Project.
 - b. Testing procedure shall conform to ASTM A615/A615M or ASTM A706/A706M.
 - c. Sample at the place of distribution, before shipment:
 - 1) Make one tensile test and one bending test from samples out of 10 tons, or fraction thereof, of each size and kind of reinforcing steel, where taken from bundles as delivered from the mill and properly identified as to heat number.
 - 2) Mill analysis shall accompany report.
 - 3) Where identification number cannot be ascertained, or where random samples are taken, make one series of tests from each 2-1/2 tons, or fraction thereof, of each size and kind of reinforcing steel.
 - 4) Tests on unidentified reinforcing steel will be paid by the District and backcharged to the Contractor.
 - 5) Samples shall include not fewer than 2 pieces, each 18 inches long, of each size and kind of reinforcing steel.
 - d. District's Inspector will inspect all reinforcement for concrete work for size, dimensions, locations and proper placement.
- C. Reinforcing Bar Welding: Verify compliance with AWS D1.4/D1.4M and ACI CODE-318, 26.6.4; continuous.
 1. Verify weldability of reinforcing bars other than those complying with ASTM A706/A706M; periodic.
 2. Inspect single-pass fillet welds, maximum 5/16 inch; periodic.
 3. Inspect all other welds; continuous.
 4. Reinforcing Bar Welding Inspection: CBC 1705A.3.1; Table 1705A.3, Item 2; 1903A.8.
- D. Anchors Cast in Concrete: Verify compliance with ACI CODE-318; periodic.
- E. Bolts Installed in Concrete: Where allowable loads have been increased or where strength design is used, verify compliance with approved Contract Documents and ICC-ES AC308 approved report prior to and during placement of concrete; continuous.
 1. Comply with CBC Section 1910A.5; Table 1705A.3, items 4a & 4b, ASCE 7, Section 13.4.
- F. Anchors Post-Installed in Hardened Concrete: Verify compliance with ACI CODE-318.
 1. Comply with CBC Section 1910A.5; Table 1705A.3, items 4a & 4b, ASCE 7, Section 13.4.

FOR REFERENCE ONLY

2. Adhesive Anchors: Verify horizontally or upwardly-inclined orientation installations resisting sustained tension loads - Section 17.8.2.4; continuous.
3. Other Mechanical and Adhesive Anchors: Verify as per Chapter 17.8.2; periodic.
- G. Anchors Installed in Hardened Concrete: Verify compliance with ACI CODE-318; periodic.
- H. Design Mix: Verify plastic concrete complies with the design mix in approved contract documents and with CBC Chapter 19A, ACI CODE-318, Sections 26.4.3, 26.4.4; periodic.
 1. Portland Cement Tests: CBC 1705A.3.2, 1910A.1.
 2. Concrete Aggregates: CBC 1705A.3.2, 1903A.5.
 3. Batch Plant Inspection: CBC 1705A.3.3.
 4. Waiver of Continuous Batch Plant Inspection and Tests: CBC 1705A.3.3.1.
 5. Admixtures: CBC 1910A.1.
 6. Proportions of Concrete: CBC 1904A (Durability) and 1905A (Modifications to ACI CODE-318).
- I. Concrete Sampling Concurrent with Strength Test Sampling: Each time fresh concrete is sampled for strength tests, verify compliance with ASTM C172/C172M, ASTM C31/C31M, and ACI CODE-318, Chapter 26.5, 26.12, and record the following, continuous:
 1. Slump.
 2. Air content.
 3. Temperature of concrete.
 4. Strength Tests of Concrete: CBC 1905A.1.17; Table 1705A.3 Item 6; ACI CODE-318 Sec. 26.12.
- J. Concrete Placement: Verify application techniques comply with approved Contract Documents and ACI CODE-318, Chapter 26.5; continuous.
- K. Specified Curing Temperature and Techniques: Verify compliance with ACI CODE-318, Chapter 26.5.3-26.5.5; continuous.
- L. Formwork Shape, Location and Dimensions: Verify compliance with approved Contract Documents and ACI CODE-318, Chapter 26.11.1.2(b); continuous.
- M. Welding of Reinforcing Bars: Conduct special inspections and verify Special Inspector's qualifications in accordance with requirements of AWS D1.4/D1.4M.
- N. District Inspector (IOR) will do the following:
 1. Inspect placing of reinforcing steel and concrete at Project.
 2. Obtain weighmaster's certificate and identify mix before accepting each load.
 3. Keep daily record of concrete placement, identifying each truck load, time of receipt, and location of concrete in structure.
 4. Keep record until completion of Project and make available for inspection by DSA Field Engineer or representative.
 5. See also subparagraph on Waiver of Continuous Batch Plant Inspection above.

6. During progress of work, take an additional number of test cylinders as directed by Architect. Conform to CBC 1905A.1.17 (modified ACI CODE-318). Test cylinders need not be made for concrete used in exterior flatwork.
 - a. ACI CODE-318 Section 26.12.2.1 shall be replaced and the Contractor shall comply with the following:
 - 1) Samples for strength test of each class of concrete placed each day shall not be taken less than once for each 50 cubic yards (38.3m³) of concrete, or not less than once for each 2,000 square feet (186 m²) of surface area of for slabs or walls.
 - 2) Additional samples for seven day compressive strength tests shall be taken for each class of concrete at the beginning of the concrete work or whenever the mix or aggregate is changed.
7. One set of cylinders shall consist of 4 samples all taken from same batch, one to be tested at age of 7 days and two at 28 days.
8. Make and store cylinders according to ASTM C31/C31M.
9. Deliver cylinders to laboratory or store cylinders in a suitable protected environment for pick up by laboratory personnel.
10. Make slump test of wet concrete according to test for slump of portland cement concrete, ASTM C143/C143M, at least at the same frequency that the cylinders are taken.

3.04 SPECIAL INSPECTIONS FOR MASONRY CONSTRUCTION (CHAPTER 17A AND 21A)

- A. Masonry Structures Subject to Special Inspection:
 1. Masonry construction when required by the quality assurance program of TMS 402/602.
 2. Engineered masonry in structures classified as "low hazard..." and "substantial hazard to human life in the event of failure".
- B. Verify each item below complies with approved Contract Documents and the applicable articles of TMS 402/602.

1. Materials:

Masonry Units	CBC 2103A.1
Mortar, Portland Cement	CBC 2103A.2
Mortar and Grout Aggregates	CBC 2103A.3.1
Reinforcing Bars	CBC 2103A.4

2. Masonry Quality:

Portland Cement Tests	CBC 1903A, 1910A.1
Mortar and Grout Tests	CBC 2105A.3
Masonry Prism Tests	CBC 2105A.2
Masonry Core Tests	CBC 2105A.4
Masonry Unit Tests	CBC 2105A.2, 2105A.3, 1705A.4
Unit Strength Method Testing	CBC 2105A.2
Reinforcing Bar Tests	CBC 1910A.2

FOR REFERENCE ONLY

3. Masonry Inspection:

Reinforced Masonry	CBC 1705A.4; TMS 602 Tables 3 & 4, level 3
Reinforcing Bar Welding Inspection	CBC 1705A.3.1; Table 1705A.3, Item 2; 1903A.8
Post Installed Anchors in Masonry	CBC 1617A.1.19; 1705A.4, Table 1705A.3, Items 4a & 4b; 1910A.5

4. Inspections and Approvals:

- a. Verify compliance with the required inspection provisions of the approved Contract Documents; periodic.
- b. Verify approval of submittals required by Contract Documents; periodic.

5. Compressive Strength of Masonry: Verify compressive strength of masonry units prior to start of construction unless specifically exempted by code; periodic.

- a. Comply with CBC 2105A.2 Compressive Strength.

6. Slump Flow and Visual Stability Index (VSI): Verify compliance as self consolidating grout arrives on site; continuous.

7. Joints and Accessories: When masonry construction begins, verify:

- a. Proportions of site prepared mortar; periodic.
- b. Construction of mortar joints; periodic.
- c. Location of reinforcement, connectors, prestressing tendons, anchorages, etc; periodic.

8. Structural Elements, Joints, Anchors, Protection: During masonry construction, verify:

- a. Size and location of structural elements; periodic.
- b. Type, size and location of anchors, including anchorage of masonry to structural members, frames or other construction; periodic.
- c. Size, grade and type of reinforcement, anchor bolts and prestressing tendons and anchorages; periodic.
- d. Welding of reinforcing bars; continuous.
- e. Preparation, construction and protection of masonry against hot weather above 90 degrees F and cold weather below 40 degrees F; periodic.

9. Grouting Preparation: Prior to grouting, verify:

- a. Comply with CBC 2105A.2 Compressive Strength.
- b. Grout space is clean; periodic.
- c. Correct placement of reinforcing, connectors, prestressing tendons and anchorages; periodic.
- d. Correctly proportioned site prepared grouts and prestressing grout for bonded tendons; periodic.
- e. Correctly constructed mortar joints; periodic.

10. Preparation of Grout Specimens, Mortar Specimens and Prisms: Observe preparation of specimens; periodic.
 - a. Comply with CBC 2105A.2 Compressive Strength.

3.05 SPECIAL INSPECTIONS FOR PREFABRICATED AND SITE-BUILT WOOD CONSTRUCTION

- A. Conform to CBC 1705A.5.3 Wood Structural Elements and Assemblies.
- B. High Load Diaphragms: Verify compliance of each item below with approved Contract Documents.
 1. Grade and thickness of sheathing.
 2. Nominal size of framing members at adjacent panel edges.
 3. Nail or staple diameter and length.
 4. Number of fastener lines.
 5. Fastener spacing at lines and at edges.

3.06 SPECIAL INSPECTIONS FOR SOILS

- A. Materials and Placement: Verify each item below complies with approved construction documents and approved geotechnical report.
 1. Design bearing capacity of material below shallow foundations; periodic.
 2. Design depth of excavations and suitability of material at bottom of excavations; periodic.
 3. Materials, densities, lift thicknesses; placement and compaction of backfill: continuous.
 4. Subgrade, prior to placement of compacted fill verify proper preparation; periodic.
- B. Testing: Classify and test excavated material; periodic.
- C. Excavations, Foundations and Retaining Walls (Chapters 17A, 18A, and 33):
 1. Earth Compaction: CBC 1705A.6; Table 1705A.6, continuous; 1804A.6.
 2. Verify use of proper materials, densities, and lift thicknesses during placement and compaction of compacted fill: CBC 1705A.6.1; Table 1705A.6, periodic; 1804A.6.
- D. The Geotechnical Engineer of record or a Geotechnical Engineer selected by the District will provide continuous inspection of fill and will field test fill and earth backfill as placed and compacted, and inspect excavations and subgrade before concrete is placed and provide periodic inspection of open excavations, embankments, and other cuts or vertical surfaces of earth.
 1. The Geotechnical Engineer will submit a Verified Report indicating observations, tested fills, and opinion the fills were placed in accordance with the project specifications.
- E. Contractor shall remove unsatisfactory material, re-roll, adjust moisture, place new material, or in the case of excavations, provide proper protective measures, perform other operations necessary, as directed by the Geotechnical Engineer whose decisions and directions will be considered final.
- F. Soils Test and Inspection Procedure:
 1. Allow sufficient time for testing, and evaluation of results before material is needed. The Geotechnical Engineer shall be sole and final judge of suitability of all materials.

2. Laboratory compaction tests to be used will be in accordance with ASTM D1557.
3. Field density tests will be made in accordance with ASTM D1556/D1556M.
4. Number of tests will be determined by Geotechnical Engineer. Materials in question may not be used pending test results.
5. Excavation and embankment inspection procedure. Geotechnical Engineer will visually or otherwise examine such areas for bearing values, cleanliness and suitability.
6. Earthwork Test Reports: In order to avoid misinterpretations by the reviewing agencies, all retest results shall be reported on the same sheet, immediately following the previous failure test to which it is related. Retests shall be clearly noted as such.

3.07 SPECIAL INSPECTIONS FOR FIRE RESISTANT PENETRATIONS AND JOINTS

- A. Verify penetration firestops in accordance with ASTM E2174.
- B. Verify fire resistant joints in accordance with ASTM E2393.
- C. Inspection: Comply with CBC 1705A.17.

3.08 SPECIAL INSPECTIONS FOR SEISMIC RESISTANCE

- A. Inspection: Comply with CBC 1705A.13.
- B. Testing: Comply with CBC 1705A.13.
- C. Structural Steel: Comply with the quality assurance plan requirements of AISC 341.
- D. Structural Wood:
 1. Field gluing; continuous.
 2. Nailing, bolting, anchoring and other fastening of components within the seismic force-resisting system; periodic.
- E. Architectural Components: Erection and fastening of components below; periodic.
 1. Exterior cladding; per ICC ESR Report when applicable.
 2. Interior and exterior veneer.
 3. Interior and exterior non-loadbearing walls and partitions.
 4. Suspended ceiling systems and their anchorage, per ICC ESR Report. CBC Section 1705A.12.5 and 1705A.13.2.
- F. Mechanical and Electrical Components:
 1. Anchorage of electric equipment required for emergency or standby power systems; periodic.
 2. Installation and anchorage of other electrical equipment; periodic.
 3. Vibration isolation systems where the approved Contract Documents require a nominal clearance of 1/4 inch or less between support frame and seismic restraint; periodic.
 4. Installation of mechanical and electrical equipment, including duct work, piping systems and their structural supports, where automatic fire sprinkler systems are installed.
 - a. Verify clearances have been provide as required by Section 13.2.3 of ASCE 7.

- b. Verify nominal clearance of 3 inches has been provided between fire protection sprinkler drops and sprigs and: structural members not used collectively or independently to support the sprinklers; equipment attached to the building structure; and other systems' piping.
- G. Designated Seismic System Verification: Verify label, anchorage or mounting complies with certificate of compliance provided by manufacturer or fabricator.
- H. Structural Testing for Seismic Resistance:
 - 1. Concrete reinforcement: Comply with ACI CODE-318, Section 20.2.2.5 and 21.1.52.
 - a. Materials Obtain mill certificates demonstrating compliance with ASTM A615/A615M; periodic.
 - b. Welding: Perform chemical tests complying with ACI CODE-318, Section 26.6.4 to determine weldability; periodic.
 - 2. Structural Steel: Comply with the quality assurance requirements of AISC 341.
- I. Structural Observations for Seismic Resistance: Visually observe structural system for general compliance with the approved Contract Documents; periodic.

3.09 SPECIAL INSPECTIONS FOR WIND RESISTANCE

- A. Structural Wood:
 - 1. Field gluing of components in the main wind force-resisting system; continuous.
 - 2. Nailing, bolting, anchoring and other fastening of components within the main wind force-resisting system; periodic.
- B. Cold-Formed Steel Light Frame Construction:
 - 1. Field welding; periodic.
 - 2. Screw attachment, bolting, anchoring and other fastening of components within the main wind force-resisting system; periodic
- C. Wind Resisting Components:
 - 1. Roof covering, roof deck, and floor framing connections; periodic.
 - 2. Exterior wall covering and wall connections to roof and floor diaphragms and framing; periodic.

3.10 STRUCTURAL OBSERVATIONS FOR STRUCTURES

- A. Provide Observations: For structure where one or more of the following conditions exist:
 - 1. Such observation is required by the registered design professional responsible for the structural design.
 - 2. Such observation is specifically required by AHJ.

3.11 SPECIAL ARCHITECTURAL INSPECTIONS

- A. Signs and/or identification devices:
 - 1. Prior to issuance of a final Certificate of Occupancy, Enforcing Agency shall verify installation of signs for information content, appearance, location and Braille per CBC Chapter 11B-703.1.1.2.

FOR REFERENCE ONLY

- a. Inspection shall include, but not limited to:
 - 1) Braille dots and cells are properly spaced and the size proportion and type raised characters are in compliance with these regulations.
 - 2) Tactile exit signage per CBC 1013.4 and 11B-216.4.1 Exit doors.
 - 3) Tactile floor designation signs in stairways per CBC 1023.9 Stairway identification signs.
 - 4) Elevator car control identification per CBC Chapter 11B-407.4.6-8 Elevator car controls.
 - 5) Sanitary facilities signage per CBC Chapter 11B-216.8 Toilet rooms and bathing rooms; and 11B-703.7.2.6 Toilet and bathing facilities geometric symbols.
- B. Water-resistive barrier coating:
 1. Installation over sheathing substrate per ASTM E2570/E2570M.
- C. Glass and glazing identification:
 1. Verify installation of manufacturer's material mark inspection per CBC 2403.1.
 - a. Safety glazing shall be labeled per CBC 2406.3.
- D. Waterproofing Verification:
 1. The District's Inspector will check surfaces and approve before application of membrane materials and verify that substrate surfaces are in satisfactory condition to receive membrane materials and furnish continuous inspection during application of membrane.
 2. Check minimum specified thickness of membrane waterproofing. For fluid-applied membrane check thickness every 100 square feet during application with a mil-thickness gage especially manufactured for the purpose.
- E. Inspection by Health Department:
 1. CONSTRUCTION INSPECTIONS: Contact the Health Department Plan Checker for a Preliminary Inspection when construction is approximately 80% complete, with plumbing, rough ventilation, and rough equipment installed. Request for inspection should be made at least five (5) working days in advance.
 2. A FINAL INSPECTION MUST be made upon completion of ALL work including finished details. APPROVAL to operate shall not be granted, or remodeled areas approved to operate, until the facility has passed the FINAL INSPECTION, and "APPLICATION TO OPERATE" has been completed and PERMIT FEES have been paid.

3.12 SPECIAL INSPECTION AGENCY DUTIES AND RESPONSIBILITIES

- A. Special Inspection Agency shall:
 1. Verify samples submitted by Contractor comply with the referenced standards and the approved Contract Documents.
 2. Provide qualified personnel at site. Cooperate with Architect and Contractor in performance of services.
 3. Perform specified sampling and testing of products in accordance with specified reference standards.

4. Ascertain compliance of materials and products with requirements of Contract Documents.
 5. Promptly notify Architect, SEOR, IOR, DSA, District and Contractor of observed irregularities or non-conformance of work or products.
 6. Perform additional tests and inspections required by Architect.
 7. Attend preconstruction meetings and progress meetings.
 8. Submit reports of all tests or inspections specified.
- B. Limits on Special Inspection Agency Authority:
1. Agency may not release, revoke, alter, or enlarge on requirements of Contract Documents.
 2. Agency may not approve or accept any portion of the work.
 3. Agency may not assume any duties of Contractor.
 4. Agency has no authority to stop the work.
- C. Re-testing required because of non-compliance with specified requirements shall be performed by the same agency on instructions by Architect.
- D. Re-testing required because of non-compliance with specified requirements shall be included in a deductive change order to the Contractor.
1. CAC 4-335 (b).

3.13 TESTING AGENCY DUTIES AND RESPONSIBILITIES

- A. Testing Agency Duties:
1. Provide qualified personnel at site. Cooperate with Architect and Contractor in performance of services.
 2. Perform specified sampling and testing of products in accordance with specified standards.
 3. Ascertain compliance of materials and mixes with requirements of Contract Documents.
 4. Promptly notify Architect and Contractor of observed irregularities or non-compliance of work or products.
 5. Perform additional tests and inspections required by Architect.
 6. Attend preconstruction meetings and progress meetings.
 7. Submit reports of all tests or inspections specified.
- B. Limits on Testing or Inspection Agency Authority:
1. Agency may not release, revoke, alter, or enlarge on requirements of Contract Documents.
 2. Agency may not approve or accept any portion of the work.
 3. Agency may not assume any duties of Contractor.
 4. Agency has no authority to stop the work.

FOR REFERENCE ONLY

- C. Immediately upon determination of a test failure, the Laboratory shall telephone the results to the Architect. On the same day, Laboratory shall send test results by email to the Architect and to all relevant responsible parties of the project team, and District's Inspector
- D. On instructions by Architect, perform re-testing required because of non-compliance with specified requirements, using the same agency.
- E. Contractor will pay for re-testing required because of non-compliance with specified requirements by a deductive change order.
- F. At the completion of the project, Testing Laboratory shall certify in writing and on all required DSA forms, that all work specified or required to be tested and inspected conforms to drawings, specifications and applicable building codes.
 - 1. See DSA Procedure PR 13-01.
- G. Duties of the Laboratory of Record related to the use of form DSA 152 are as follows:
 - 1. Meet with the Project Inspector, design professionals, and contractor as needed to mutually communicate and understand the testing and inspection program and the methods of communication appropriate for the project.
 - 2. Obtain a copy of the DSA approved construction documents from the design professional in general responsible charge prior to the commencement of construction
 - 3. Obtain a copy of the DSA approved Statement of Structural Tests and Special Inspections (form DSA 103) from the design professional in general responsible charge prior to the commencement of construction.
 - 4. Report all project related activities to the Project Inspector. The Project Inspector is responsible for monitoring the work of the Laboratory of Record and Special Inspectors to ensure the testing and special inspection program is satisfactorily completed
 - 5. Provide material testing as identified in the DSA approved construction documents.
 - 6. Submit test reports to the Project Inspector on the day the tests were performed for any tests performed on-site
 - 7. Submit material test reports in a timely manner such that construction is not delayed and not to exceed 14 days from the date the material tests were performed. Test reports are to be submitted to DSA, the Architect, structural engineer, Project Inspector and school district.
 - a. As a convenience, and if agreed upon by involved parties, the test reports may be submitted electronically as identified in Section 4 of this procedure.
 - 8. Immediately submit reports of material tests not conforming to the requirements of the DSA approved construction documents. These reports shall be submitted to the DSA, Architect, structural engineer, Project Inspector and school district.
 - 9. The Engineering Manager shall submit an interim Laboratory of Record Verified Report (form DSA 291) and the Geotechnical Engineer shall submit an interim Geotechnical Verified Report (form DSA 293) to DSA, the project inspector, school district and the Design Professional in General Responsible Charge.
 - a. The reports are required to be submitted upon any of the following events occurring:

FOR REFERENCE ONLY

- 1) Within 14 days of the completion of the material testing/special inspection program.
 - 2) Work on the project is suspended for a period of more than one month.
 - 3) The services of the laboratory of record are terminated for any reason prior to completion of the project.
 - 4) The DSA requests a Verified Report. (See interim verified reports below. This is a “DSA request.”)
10. The Engineering Manager shall submit an interim verified report (form DSA 291) and the Geotechnical Engineer shall submit form DSA 293 to DSA and a copy to the project inspector for each of the applicable sections of the form DSA 152, prior to the project inspector signing off that section of the project inspection card, if that section required material testing. The sections are:
- a. Initial Site Work
 - b. Foundation Prep
 - c. Vertical Framing
 - d. Horizontal Framing
 - e. Appurtenances
 - f. Finish Site Work
 - g. Other Work
 - h. Final
- H. Duties of Special Inspectors, employed by the Laboratory of Record, related to the use of form DSA 152 are as follows:
1. Meet with the Project Inspector, design professionals, and contractor as needed to mutually communicate and understand the testing and inspection program and the methods of communication appropriate for the project.
 2. Report all project related activities to the Project Inspector. The Project Inspector is responsible for monitoring the work of the Laboratory of Record and Special Inspectors to ensure the testing and special inspection program is satisfactorily completed.
 3. Perform work under the supervision of the Engineering Manager for the Laboratory of Record
 4. Perform inspections in conformance with the DSA approved construction documents, applicable codes and code reference standards
 5. Prepare detailed daily inspection reports outlining the work inspected and provide the Project Inspector a copy of the reports on the same day the inspections were performed.
 6. Prepare detailed daily inspection reports outlining the work inspected and provide the Project Inspector a copy of the reports on the same day the inspections were performed.
 7. Immediately submit reports of materials or work not conforming to the requirements of the DSA approved construction documents. These reports shall be submitted to the DSA, Architect, structural engineer, Project Inspector and school district.

FOR REFERENCE ONLY

8. Submit daily special inspection reports in a timely manner such that construction is not delayed and not to exceed 14 days from the date the special inspections were performed. The reports are to be submitted to the Architect, structural engineer, Project Inspector and school district.
9. Submit Verified Report forms DSA 292 to the DSA, Project Inspector, district and design professional in responsible charge.
10. The reports are required to be submitted upon any of the following events occurring:
 11. Within 14 days of the completion of the special inspection work.
 12. Work on the project is suspended for a period of more than one month.
 13. The services of the special inspector are terminated for any reason prior to completion of the project.
 14. The DSA requests a Verified Report. (See interim verified reports below. This is a “DSA request”)
 15. Submit an interim Verified Report (form DSA 292) to the DSA and a copy to the Project Inspector for each of the applicable sections of the form DSA 152, prior to the Project Inspector signing off that section of the project inspection card, if that section required special inspections. The sections are:
 - a. Initial Site Work
 - b. Foundation
 - c. Vertical Framing
 - d. Horizontal Framing
 - e. Appurtenances
 - f. Non-Building Site Structures
 - g. Finish Site Work
 - h. Other Work
 - i. Final
 16. The Verified Reports shall be sent electronically to the DSA.
- I. Duties of Special Inspectors, not employed by the Laboratory of Record, related to the use of form DSA 152 are as follows:
 1. Meet with the project inspector, Laboratory of Record, the design professionals, and the contractors as needed to mutually communicate and understand the testing and inspection program, and the methods of communication appropriate for the project.
 2. Report all project related activities to the project inspector. The project inspector is responsible for monitoring the work of the Laboratory of Record and special inspectors to ensure the testing and special inspection program is satisfactorily completed.
 3. Perform work under the direction of the design professional in general responsible charge, as defined in Section 4-335(f)1B of the California Administrative Code (Title 24, Part 1).
 4. Perform inspections in conformance with the DSA approved construction documents, applicable codes and code reference standards.

FOR REFERENCE ONLY

5. Prepare detailed daily inspection reports outlining the work inspected and provide the project inspector a copy of the reports on the same day the inspections were performed.
6. Immediately submit reports of materials or work not conforming to the requirements of the DSA approved construction documents. These reports shall be submitted to DSA, the Architect, structural engineer, project inspector and the school district.
7. Submit daily special inspection reports in a timely manner such that construction is not delayed and not to exceed 14 days from the date the special inspections were performed. The reports are to be submitted to DSA, the Architect, structural engineer, project inspector and the school district.
8. Submit Special Inspection Verified Report forms DSA 292 to DSA, the project inspector, the school district and the Design Professional in General Responsible Charge.
 - a. The reports are required to be submitted upon any of the following events occurring:
 - 1) Within 14 days of the completion of the special inspection work.
 - 2) Work on the project is suspended for a period of more than one month.
 - 3) The services of the special inspector are terminated for any reason prior to completion of the project.
 - 4) DSA requests a verified report. (See interim verified reports below. This is a “DSA request.”)
9. Submit an interim Special Inspection Verified Report (form DSA 292) to DSA and a copy to the project inspector for each of the applicable sections of the form DSA 152, prior to the project inspector signing off that section of the project inspection card, if that section required special inspections.
 - a. The sections are:
 - 1) Initial Site Work
 - 2) Foundation Prep
 - 3) Vertical Framing
 - 4) Horizontal Framing
 - 5) Appurtenances
 - 6) Finish Site Work
 - 7) Other Work
 - 8) Final

3.14 CONTRACTOR DUTIES AND RESPONSIBILITIES

A. DSA Requirements:

1. Each Multi-Prime Contractor or Subcontractor shall comply with DSA Construction Oversight Procedure DSA PR 13-01. California Code of Regulations (CCR), Title 24, Part 1, CCR, Chapter 4, Article 1 (Sections 4-211 through 4-220) and Group1, Articles 5 and 6 (Sections 4-331 through 4-344) which provide regulations governing the construction process for projects under the jurisdiction of the Division of the State Architect (DSA).

FOR REFERENCE ONLY

- a. Assist the Project Inspector (IOR) and complete and fill out the following forms during the course of construction.
 - 1) Form-102-IC: Construction Start Notice/ Inspection Card Request: Verify Project Inspector has an active form issued by DSA.
 - 2) Form-151: Project Inspector Notifications: Contractor to notify IOR and assist.
 - 3) Form-152: Project Inspection Card: See below.
 - 4) Form-154: Notice of Deviations/ Resolution of Deviations: Contractor to verify all deviations are reviewed, corrected, and accepted by the design professional, and filed with DSA through the Project Inspector (IOR).
 - (a) When the Project Inspector identifies deviations from the DSA approved construction documents the inspector must verbally notify the contractor. If the deviations are not corrected within a reasonable time frame, the inspector is required to promptly issue a written notice of deviation to the contractor, with a copy sent to the design professional in general responsible charge and the DSA.
 - (b) When the noticed deviations are corrected, the inspector is required to promptly issue a written notice of resolution to the contractor, with a copy sent to the design professional in general responsible charge and the DSA.
 - (c) Deviations include both construction deviations and material deficiencies.
 - (d) The written notice of deviations shall be made using form DSA 154.
 - (e) The notice of resolution of deviations shall be made using the original form DSA 154 that reported the deviations.
 - 5) Form-156: Commencement/Completion of Work Notification
 - 6) Form-6.C: Verified Report – Contractor: From each contractor having a contract with the school board.
2. Duties of Contractor related to the use of form DSA 152 are as follows:
 - a. The Contractor shall carefully study the DSA approved documents and shall plan a schedule of operations well ahead of time.
 - b. If at any time it is discovered that work is being done which is not in accordance with the DSA approved construction documents, the Contractor shall correct the work immediately.
 - c. Verify that forms DSA 152 are issued for the project prior to the commencement of construction.
 - d. Meet with the design team, the Laboratory of Record and the Project Inspector to mutually communicate and understand the testing and inspection program and the methods of communication appropriate for the project.
 - e. Notify the Project Inspector, in writing, of the commencement of construction of each and every aspect of the work at least 48 hours in advance by submitting form DSA 156 (or other agreed upon written documents) to the Project Inspector.
 - f. Notify the Project Inspector of the completion of construction of each and every aspect of the work by submitting form DSA 156 (or other agreed upon written documents) to the Project Inspector.

FOR REFERENCE ONLY

- g. Consider the relationship of the signed off blocks and sections of the form DSA 152 and the commencement of subsequent work. Until the Project Inspector has signed off applicable blocks and sections of the form DSA 152, the Contractor may be prohibited from proceeding with subsequent construction activities that cover up the unapproved work. Any subsequent construction activities, that cover up the unapproved work, will be subject to a "Stop Work Order" from the DSA or the district and are subject to removal and remediation if found to be in non-compliance with the DSA approved construction documents.
 - h. Submit the final verified report. All prime contractors are required to submit final Contractor Verified Reports (form DSA 6-C) to DSA and the project inspector.
 - 1) The reports are required to be submitted upon any of the following events occurring:
 - (a) The project is substantially complete. DSA considers the project to be complete when the construction is sufficiently complete in accordance with the DSA approved construction documents so that the owner can occupy or utilize the project.
 - (b) Work on the project is suspended for a period of more than one month.
 - (c) The services of the contractor are terminated for any reason prior to the completion of the project.
 - (d) DSA requests a verified report.
- B. Contractor Responsibilities, General:
- 1. Deliver to agency at designated location, adequate samples of materials for special inspections that require material verification.
 - 2. Availability of Samples
 - a. Provide access to materials required for testing available to Laboratory and assist in acquiring these materials as directed by the District's Inspector. Samples shall only be taken under the immediate direction and supervision of the Testing Laboratory or District's Inspector.
 - b. If work which is required to be tested or inspected is covered up without prior notice or approval, such work may be uncovered at the discretion of Architect at no additional cost to the District. Refer to paragraph "Payments" herein.
 - c. Unless otherwise specified, Contractor shall notify Testing Laboratory a minimum of 10 working days in advance of all required tests, and a minimum of 2 working days in advance of all required inspections. All extra expenses resulting from a failure to notify the Laboratory will be paid by the District and backcharged to the Contractor.
 - d. Contractor shall give sufficient advance notice to Testing Laboratory in the event of cancellation or time extension of a scheduled test or inspection. Charges due to insufficient advance, notice of cancellations, or time extension will be paid for by the District and backcharged to the Contractor.
 - 3. Cooperate with agency and laboratory personnel; provide access to approved documents at project site, to the work, to manufacturers' facilities, and to fabricators' facilities.
 - 4. Provide incidental labor and facilities:
 - a. To provide access to work to be tested or inspected.

FOR REFERENCE ONLY

- b. To obtain and handle samples at the site or at source of Products to be tested or inspected.
 - c. To facilitate tests or inspections.
 - d. To provide storage and curing of test samples.
5. Notify Architect and laboratory 24 hours prior to expected time for operations requiring testing or inspection services.
 6. Arrange with District's agency and pay for additional samples, tests, and inspections required by Contractor beyond specified requirements.
 7. The Contractor shall notify the District's Inspector a minimum of 5 working days in advance of the manufacture of material to be supplied by him under the Contract Documents, which must be by terms of the Contract be tested, in order that the District may arrange for the testing of such material at the source of supply.
 8. Material shipped by the Contractor from the source of supply before having satisfactorily passed such testing and inspection or before the receipt of notice from said Inspector that such testing and inspection will not be required, shall not be incorporated in the Project.
 9. The District will select and pay testing laboratory costs for all tests and inspections, but may be reimbursed by the Contractor for such costs under the Contract conditions. Any direct payments by the Contractor to the testing laboratory on this project is prohibited.
- C. Contractor shall submit a written statement of responsibility to comply with CBC section 1704A.4.
1. Each contractor responsible for the construction of a main wind- or seismic-force-resisting system, designated seismic system or a wind- or seismic-resisting component listed in the statement of special inspections shall submit a written statement of responsibility to the building official and the owner prior to the commencement of work on the system or component. The contractor's statement of responsibility shall contain the following:
 - a. Acknowledgment of awareness of the special requirements contained in the statement of special inspections;
 - b. Acknowledgment that control will be exercised to obtain conformance with the construction documents approved by the building official;
 - c. Procedures for exercising control within the contractor's organization, the method and frequency of reporting and the distribution of the reports; and
 - d. Identification and qualifications of the person(s) exercising such control and their position(s) in the organization.
- D. Contractor Responsibilities, Seismic Force-Resisting System, Designated Seismic System, and Seismic Force-Resisting Component: Submit written statement of responsibility for each item listed in the Statement of Special Inspections to AHJ and District prior to starting work. Statement of responsibility shall acknowledge awareness of special construction requirements and other requirements listed.

- E. Contractor Responsibilities, Wind Force-Resisting System and Wind Force-Resisting Component: Submit written statement of responsibility for each item listed in the Statement of Special Inspections to AHJ and District prior to starting work. Statement of responsibility shall acknowledge awareness of special construction requirements and other requirements listed.
- F. Unless otherwise directed, materials not conforming to the requirements of Contract Documents shall be promptly removed from the Project site.

3.15 MANUFACTURERS' AND FABRICATORS' FIELD SERVICES

- A. When specified in individual specification sections, require material suppliers, assembly fabricators, or product manufacturers to provide qualified staff personnel to observe site conditions, conditions of surfaces and installation, quality of workmanship, start-up of equipment, to test, adjust, and balance equipment as applicable, and to initiate instructions when necessary.
- B. Submit qualifications of observer to Architect 30 days in advance of required observations.
 - 1. Observer subject to approval of Architect.
 - 2. Observer subject to approval of District.
- C. Report observations and site decisions or instructions given to applicators or installers that are supplemental or contrary to manufacturers' written instructions.

END OF SECTION

SECTION 01 50 00 TEMPORARY FACILITIES AND CONTROLS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Temporary telecommunications services.
- B. Temporary sanitary facilities.
- C. Temporary Controls: Barriers, enclosures, and fencing.
- D. Security requirements.
- E. Waste removal facilities and services.

1.02 RELATED REQUIREMENTS

- A. Section 01 35 53 - Security Procedures
- B. Section 01 57 19 - Temporary Environmental Controls: Filtration requirements during construction and final cleaning.
- C. Section 01 58 13 - Temporary Project Signage.

1.03 REFERENCE STANDARDS

- A. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials.
- B. ASTM E90 - Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions and Elements.

1.04 TEMPORARY UTILITIES

- A. Provide and pay for all electrical power, lighting, water, heating and cooling, and ventilation required for construction purposes.
- B. Use trigger-operated nozzles for water hoses, to avoid waste of water.

1.05 TELECOMMUNICATIONS SERVICES

- A. Provide, maintain, and pay for telecommunications services to field office at time of project mobilization.
- B. Telecommunications services shall include:
 - 1. Windows-based personal computer dedicated to project telecommunications, with necessary software and laser printer.
 - 2. Telephone Land Lines: One line, minimum; one handset per line.
 - 3. Internet Connections: Minimum of one; DSL modem or faster.
 - 4. Email: Account/address reserved for project use.

1.06 TEMPORARY SANITARY FACILITIES

- A. Provide and maintain required facilities and enclosures. Provide at time of project mobilization.

1. Provide temporary toilet facilities if maximum number of personnel on project is greater than 10.
2. Submit proposed location of temporary toilet(s) to Construction Manager for approval.
 - a. Place on-site portable toilets away from building air intakes and entryway.
- B. Maintain daily in clean and sanitary condition.

1.07 BARRIERS

- A. Provide barriers to prevent unauthorized entry to construction areas, to prevent access to areas that could be hazardous to workers or the public, to allow for owner's use of site and to protect existing facilities and adjacent properties from damage from construction operations and demolition.
- B. Provide barricades and covered walkways required by governing authorities for public rights-of-way and for public access to existing building.
- C. Protect non-owned vehicular traffic, stored materials, site, and structures from damage.

1.08 FENCING

- A. Construction: Contractor's option.
- B. Provide 6 foot high fence around construction site; equip with vehicular and pedestrian gates with locks.

1.09 EXTERIOR ENCLOSURES

- A. Provide temporary weather tight closure of exterior openings to accommodate acceptable working conditions and protection for Products, to allow for temporary heating and maintenance of required ambient temperatures identified in individual specification sections, and to prevent entry of unauthorized persons. Provide access doors with self-closing hardware and locks.

1.10 INTERIOR ENCLOSURES

- A. Provide temporary partitions and ceilings as indicated to separate work areas from District-occupied areas, to prevent penetration of dust and moisture into District-occupied areas, and to prevent damage to existing materials and equipment.
- B. Construction: Framing and reinforced polyethylene sheet materials with closed joints and sealed edges at intersections with existing surfaces:
 1. STC rating of 35 in accordance with ASTM E90.
 2. Maximum flame spread rating of 75 in accordance with ASTM E84.
- C. Paint surfaces exposed to view from District-occupied areas.

1.11 SECURITY

- A. Provide security and facilities to protect Work, existing facilities, and District's operations from unauthorized entry, vandalism, or theft.

1.12 CAFETERIA AND FOOD

- A. Construction personnel shall police their own areas. All cups, cans, paper, wrappers, and discarded food must be placed in trash receptacles at end of each break.
- B. Contractor(s) shall submit to Construction Manager proposed location of any break areas and eating areas for approval.

1.13 SMOKING AND TOBACCO

- A. Smoking and vaping is not permitted on property.
- B. No chewing tobacco or spitting of tobacco is permitted.

1.14 VEHICULAR ACCESS AND PARKING

- A. Comply with regulations relating to use of streets and sidewalks, access to emergency facilities, and access for emergency vehicles.
- B. Coordinate access and haul routes with governing authorities and District.
- C. Provide and maintain access to fire hydrants, free of obstructions.
- D. Provide means of removing mud from vehicle wheels before entering streets.
- E. Provide temporary parking areas to accommodate construction personnel. When site space is not adequate, provide additional off-site parking.

1.15 WASTE REMOVAL

- A. See Section 01 74 19 - Construction Waste Management and Disposal, for additional requirements.
- B. Provide waste removal facilities and services as required to maintain the site in clean and orderly condition.
- C. Provide containers with lids. Remove trash from site periodically.
- D. If materials to be recycled or re-used on the project must be stored on-site, provide suitable non-combustible containers; locate containers holding flammable material outside the structure unless otherwise approved by the authorities having jurisdiction.
- E. Open free-fall chutes are not permitted. Terminate closed chutes into appropriate containers with lids.

1.16 PROJECT SIGNS - SEE SECTION 01 58 13

1.17 FIELD OFFICES

- A. Office: Weathertight, with lighting, electrical outlets, heating, cooling equipment, and equipped with sturdy furniture, drawing rack, and drawing display table.
- B. Provide space for Project meetings, with table and chairs to accommodate 6 persons.
- C. Provide separate private office similarly equipped and furnished, for use of District.
- D. Locate offices a minimum distance of 30 feet from existing and new structures.

FOR REFERENCE ONLY

1.18 REMOVAL OF UTILITIES, FACILITIES, AND CONTROLS

- A. Remove temporary utilities, equipment, facilities, materials, prior to Final Application for Payment inspection.
- B. Remove underground installations to a minimum depth of 2 feet. Grade site as indicated.
- C. Clean and repair damage caused by installation or use of temporary work.
- D. Restore existing facilities used during construction to original condition.
- E. Restore new permanent facilities used during construction to specified condition.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

END OF SECTION

SECTION 01 57 19 TEMPORARY ENVIRONMENTAL CONTROLS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Construction procedures to promote adequate indoor air quality after construction.
- B. Building flush-out after construction and before occupancy.
- C. Testing indoor air quality before commencement of construction; existing building areas only.
- D. Testing indoor air quality after completion of construction.
- E. Testing air change effectiveness after completion of construction.

1.02 PROJECT GOALS

- A. Dust and Airborne Particulates: Prevent deposition of dust and other particulates in HVAC ducts and equipment.
 - 1. Cover duct openings and protect mechanical equipment during construction. Provide tape, plastic, sheet metal or other methods acceptable to Construction Manager.
 - a. Comply with California Green Code Section 5.504.3.
 - 2. Cleaning of ductwork is not contemplated under this Contract.
 - 3. Contractor shall bear the cost of cleaning required due to failure to protect ducts and equipment from construction dust.
 - 4. Establish condition of existing ducts and equipment prior to start of alterations.
- B. Airborne Contaminants: Procedures and products have been specified to minimize indoor air pollutants.
 - 1. Furnish products meeting the specifications.
 - 2. Avoid construction practices that could result in contamination of installed products leading to indoor air pollution.

1.03 RELATED REQUIREMENTS

- A. Section 01 40 00 - Quality Requirements: Testing and inspection services.
- B. Section 01 50 00 - Temporary Facilities and Controls: Temporary construction requirements.
- C. Section 01 61 16 - Volatile Organic Compound (VOC) Content Restrictions.
- D. Section 01 91 13 - General Commissioning Requirements: Verification of installed Work and it's performance.
- E. Division 23 - Heating, Ventilating, and Air-Conditioning (HVAC): HVAC filters.
- F. Division 23 - Heating, Ventilating, and Air-Conditioning (HVAC): Testing HVAC systems for proper air flow rates, adjustment of dampers and registers, and settings for equipment.
- G. Division 23 - Heating, Ventilating, and Air-Conditioning (HVAC): Cleaning air ducts, equipment, and terminal units.

1.04 REFERENCE STANDARDS

- A. ASHRAE Std 52.2 - Method of Testing General Ventilation Air-Cleaning Devices for Removal Efficiency by Particle Size.
- B. ASHRAE Std 129 - Measuring Air-Change Effectiveness.
- C. ASTM D5197 - Standard Test Method for Determination of Formaldehyde and Other Carbonyl Compounds in Air (Active Sampler Methodology).
- D. ASTM E779 - Standard Test Method for Determining Air Leakage Rate by Fan Pressurization.
- E. CAL (CDPH SM) - Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers Version 1.2.
- F. EPA 600/4-90/010 - Compendium of Methods for the Determination of Air Pollutants in Indoor Air.
- G. EPA 625/R-96/010b - Compendium of Methods for the Determination of Toxic Organic Compounds in Ambient Air.
- H. SMACNA (OCC) - IAQ Guidelines for Occupied Buildings Under Construction.

1.05 DEFINITIONS

- A. Adsorptive Materials: Gypsum board, acoustical ceiling tile and panels, carpet and carpet tile, fabrics, fibrous insulation, and other similar products.
- B. Contaminants: Gases, vapors, regulated pollutants, airborne mold and mildew, and the like, as specified.
- C. Particulates: Dust, dirt, and other airborne solid matter.
- D. Wet Work: Concrete, plaster, coatings, and other products that emit water vapor or volatile organic compounds during installation, drying, or curing.

1.06 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Indoor Air Quality Management Plan: Describe in detail measures to be taken to promote adequate indoor air quality upon completion; use SMACNA (OCC) as a guide.
 - 1. Submit not less than 60 days before enclosure of building.
 - 2. Identify potential sources of odor and dust.
 - 3. Identify construction activities likely to produce odor or dust.
 - 4. Identify areas of project potentially affected, especially occupied areas.
 - 5. Evaluate potential problems by severity and describe methods of control.
 - 6. Describe construction ventilation to be provided, including type and duration of ventilation, use of permanent HVAC systems, types of filters and schedule for replacement of filters.
 - 7. Describe cleaning and dust control procedures.
 - 8. Describe coordination with commissioning procedures.

FOR REFERENCE ONLY

- C. Interior Finishes Installation Schedule: Identify each interior finish that either generates odors, moisture, or vapors or is susceptible to adsorption of odors and vapors, and indicate air handling zone, sequence of application, and curing times.
- D. Duct and Terminal Unit Inspection Report.
- E. Air Contaminant Test Plan: Identify:
 - 1. Testing agency qualifications.
 - 2. Locations and scheduling of air sampling.
 - 3. Test procedures, in detail.
 - 4. Test instruments and apparatus.
 - 5. Sampling methods.
- F. Air Contaminant Test Reports: Show:
 - 1. Location where each sample was taken, and time.
 - 2. Test values for each air sample; average the values of each set of 3.
 - 3. HVAC operating conditions.
 - 4. Certification of test equipment calibration.
 - 5. Other conditions or discrepancies that might have influenced results.
- G. Ventilation Effectiveness Test Plan: Identify:
 - 1. Testing agency qualifications.
 - 2. Description of test spaces, including locations of air sampling.
 - 3. Test procedures, in detail; state whether tracer gas decay or step-up will be used.
 - 4. Test instruments and apparatus; identify tracer gas to be used.
 - 5. Sampling methods.
- H. Ventilation Effectiveness Test Reports: Show:
 - 1. Include preliminary tests of instruments and apparatus and of test spaces.
 - 2. Calculation of ventilation effectiveness, E.
 - 3. Location where each sample was taken, and time.
 - 4. Test values for each air sample.
 - 5. HVAC operating conditions.
 - 6. Other information specified in ASHRAE Std 129.
 - 7. Other conditions or discrepancies that might have influenced results.

1.07 QUALITY ASSURANCE

- A. Testing and Inspection Agency Qualifications: Independent testing agency having minimum of 5 years experience in performing the types of testing specified.

PART 2 PRODUCTS

2.01 MATERIALS

- A. Low VOC Materials: See Section 01 61 16.
- B. Low VOC Materials: See other sections for specific requirements for materials with low VOC content.
- C. Auxiliary Air Filters: MERV of 8, minimum, when tested in accordance with ASHRAE Std 52.2.

PART 3 EXECUTION

3.01 CONSTRUCTION PROCEDURES

- A. Prevent the absorption of moisture and humidity by adsorptive materials by:
 - 1. Sequencing the delivery of such materials so that they are not present in the building until wet work is completed and dry.
 - 2. Delivery and storage of such materials in fully sealed moisture-impermeable packaging.
 - 3. Provide sufficient ventilation for drying within reasonable time frame.
- B. Begin construction ventilation when building is substantially enclosed.
- C. If extremely dusty or dirty work must be conducted inside the building, shut down HVAC systems for the duration; remove dust and dirt completely before restarting systems.
- D. When working in a portion of an occupied building, prevent movement of air from construction area to occupied area.
- E. HVAC equipment and supply air ductwork may be used for ventilation during construction:
 - 1. Operate HVAC system on 100 percent outside air, with 1.5 air changes per hour, minimum.
 - 2. Ensure that air filters are correctly installed prior to starting use; replace filters when they lose efficiency.
 - 3. Do not use return air ductwork for ventilation unless absolutely necessary.
 - 4. Where return air ducts must be used for ventilation, install auxiliary filters at return inlets, sealed to ducts; use filters with at least the equivalent efficiency as those required at supply air side; inspect and replace filters when they lose efficiency.
- F. Do not store construction materials or waste in mechanical or electrical rooms.
- G. Prior to use of return air ductwork without intake filters clean up and remove dust and debris generated by construction activities.
 - 1. Inspect duct intakes, return air grilles, and terminal units for dust.
 - 2. Clean plenum spaces, including top sides of lay-in ceilings, outsides of ducts, tops of pipes and conduit.
 - 3. Clean tops of doors and frames.
 - 4. Clean mechanical and electrical rooms, including tops of pipes, ducts, and conduit, equipment, and supports.

5. Clean return plenums of air handling units.
 6. Remove intake filters last, after cleaning is complete.
- H. Do not perform dusty or dirty work after starting use of return air ducts without intake filters.
- I. Use other relevant recommendations of SMACNA (OCC) for avoiding unnecessary contamination due to construction procedures.

3.02 BUILDING FLUSH-OUT

- A. Contractor's Option: Either full continuous flush-out OR satisfactory air contaminant testing is required, not both.
- B. Perform building flush-out before occupancy.
- C. Do not start flush-out until:
1. All construction is complete.
 2. HVAC systems have been tested, adjusted, and balanced for proper operation.
 3. Cleaning of inside of HVAC ductwork, specified elsewhere, has been completed.
 4. Inspection of inside of return air ducts and terminal units confirms that cleaning is not necessary.
 5. New HVAC filtration media have been installed.
- D. Building Flush-Out: Operate all ventilation systems at normal flow rates with 100 percent outside air until a total air volume of 14,000 cubic feet per square foot of floor area has been supplied.
1. Obtain District's concurrence that construction is complete enough before beginning flush-out.
 2. Maintain interior temperature of at least 60 degrees F and interior relative humidity no higher than 60 percent.
 3. If additional construction involving materials that produce particulates or any of the specified contaminants is conducted during flush-out, start flush-out over.
 4. If interior spaces must be occupied prior to completion of the flush-out, supply a minimum of 25 percent of the total air volume prior to occupancy, and:
 - a. Begin ventilation at least three hours prior to daily occupancy.
 - b. Continue ventilation during all occupied periods.
 - c. Provide minimum outside air volume of 0.30 cfm per square foot or design minimum outside air rate, whichever is greater.
- E. Install new HVAC filtration media after completion of flush-out and before occupancy or further testing.

3.03 AIR CONTAMINANT TESTING

- A. Contractor's Option: Either full continuous flush-out, or satisfactory air contaminant testing is required, not both.
- B. Perform air contaminant testing before starting construction, as base line for evaluation of post-construction testing.

FOR REFERENCE ONLY

- C. Perform air contaminant testing before occupancy.
- D. Do not start air contaminant testing until:
 - 1. All construction is complete, including interior finishes.
 - 2. HVAC systems have been tested, adjusted, and balanced for proper operation.
 - 3. Cleaning of inside of HVAC ductwork, specified elsewhere, has been completed.
 - 4. New HVAC filtration media have been installed.
- E. Indoor Air Samples: Collect from spaces representative of occupied areas:
 - 1. Collect samples while operable windows and exterior doors are closed, HVAC system is running normally as if occupied, with design minimum outdoor air, but with the building unoccupied.
 - 2. Collect samples from spaces in each contiguous floor area in each air handler zone, but not less than one sample per 25,000 square feet; take samples from areas having the least ventilation and those having the greatest presumed source strength.
 - 3. Collect samples from height from 36 inches to 72 inches above floor.
 - 4. Collect samples from same locations on 3 consecutive days during normal business hours; average the results of each set of 3 samples.
 - 5. Exception: Areas with normal very high outside air ventilation rates, such as laboratories, do not need to be tested.
 - 6. When retesting the same building areas, take samples from at least the same locations as in first test.
- F. Outdoor Air Samples: Collect samples at outside air intake of each air handler at the same time as indoor samples are taken.
- G. Analyze air samples and submit report.
- H. Air Contaminant Concentration Limits:
 - 1. Comply with CalGreen Building Standards Section 5.504.4.5, Table 504.4.4.5 "Formaldehyde Limits".
 - 2. Formaldehyde: Not more than 16.3 parts per billion.
 - 3. PM10 Particulates: Not more than 20 micrograms per cubic meter.
 - 4. Comply with CalGreen Building Standards Section 5.504, Table 504.4.3 "VOC Content Limits for Architectural Coatings".
 - 5. Comply with CalGreen Building Standards Section 5.504, Table 504.4.1 "Adhesive VOC Limit" and Table 504.4.2 "Sealant VOC Limit".
 - 6. Total Volatile Organic Compounds (TVOCs): Not more than 200 micrograms per cubic meter.
 - 7. Chemicals Listed in CAL (CDPH SM) Table 4-1, except Formaldehyde: Allowable concentrations listed in Table 4-1.
 - 8. Carbon Monoxide: Not more than 9 parts per million and not more than 2 parts per million higher than outdoor air.
 - 9. Airborne Mold and Mildew: Measure in relation to outside air; not higher than outside air.

10. Regulated Pollutants: Measure in relation to outside air; not more than contained in outside air.
- I. Air Contaminant Concentration Test Methods:
 1. Formaldehyde: ASTM D5197, EPA 625/R-96/010b Method TO-11A, or EPA 600/4-90/010 Method IP-6.
 2. Particulates: EPA 600/4-90/010 Method IP-10.
 3. Total Volatile Organic Compounds (TVOC): EPA 625/R-96/010b Method TO-1, TO-15, or TO-17; or EPA 600/4-90/010 Method IP-1.
 4. Chemicals Listed in CAL (CDPH SM) Table 4-1, except Formaldehyde: ASTM D5197, or EPA 625/R-96/010b Method TO-1, TO-15, or TO-17.
 5. Carbon Monoxide: EPA 600/4-90/010 Method IP-3, plus measure outdoor air; measure in ppm; report both indoor and outdoor measurements.
- J. If air samples show concentrations higher than those specified, ventilate with 100 percent outside air and retest at no cost to District, or conduct full building flush-out specified above.

3.04 VENTILATION EFFECTIVENESS TESTING

- A. Perform ventilation effectiveness testing during commissioning period.
- B. Do not begin ventilation effectiveness testing until:
 1. HVAC testing, adjusting, and balancing has been satisfactorily completed.
 2. Building flush-out or air contaminant testing has been completed satisfactorily.
 3. New HVAC filtration media have been installed.
- C. Test each air handler zone in accordance with ASHRAE Std 129.
- D. If calculated air change effectiveness for a particular zone is less than 0.9 due to inadequate balancing of the system, adjust, and retest at no cost to District.

END OF SECTION

SECTION 01 58 13 TEMPORARY PROJECT SIGNAGE

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Project identification sign.
- B. Project informational signs.

1.02 RELATED REQUIREMENTS

- A. Section 01 10 00 - Summary: Responsibility to provide signs.
- B. Section 01 50 00 - Temporary Facilities and Controls: Temporary wood barriers and enclosures.
- C. Section 06 10 53 - Miscellaneous Rough Carpentry: General requirements for structural and non-structural rough carpentry Work.

1.03 REFERENCE STANDARDS

- A. FHWA (SHS) - Standard Highway Signs and Markings.

1.04 QUALITY ASSURANCE

- A. Design sign and structure to withstand 80 miles/hr wind velocity.
- B. Sign Painter: Experienced as a professional sign painter for minimum three years.
 - 1. Sign painter shall be regularly engaged and specializing in the design, execution, construction and installation of exterior signage of equivalent type, size and complexity as those required for Project.
- C. Finishes, Painting: Adequate to withstand weathering, fading, and chipping for duration of construction.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Shop Drawing: Show content, layout, lettering, color, foundation, structure, sizes and grades of members.

PART 2 PRODUCTS

2.01 SIGN MATERIALS

- A. Structure and Framing: New, wood, structurally adequate to support sign panel and suitable for specified finish.
- B. Sign Surfaces: Exterior grade plywood with medium or high density phenolic sheet overlay, minimum 3/4 inch thick, standard large sizes to minimize joints. Provide sheet thickness as required to span across framing members and provide even, smooth surface without waves or buckles.

- C. Rough Hardware: Galvanized steel, as specified in Section 05 50 00 - Metal Fabrications..
- D. Sign Face Paint and Primers: Exterior quality, primer, two gloss enamel finish coats; sign background of color as selected. Provide paint type as customarily used for sign painting, adequate to resist weathering and fading for the scheduled construction period.
- E. Sign Structure Paint and Primers: Exterior quality, primer, one gloss enamel finish coats; color as selected. Provide paint type as customarily used for sign painting, adequate to resist weathering and fading for the scheduled construction period.
- F. Lettering: Exterior quality paint, colors as selected.

2.02 PROJECT IDENTIFICATION SIGN

- A. One painted sign, 48 sq ft area, bottom 6 feet above ground.
- B. Content:
 - 1. Project number, title, logo and name of District as indicated on Contract Documents.
 - 2. Include organizational logos of parties identified on sign.
 - 3. Names and titles of authorities.
 - 4. Names and titles of Architect and Consultants.
 - 5. Name of Prime Contractor and major Subcontractors.
- C. Graphic Design, Colors, Style of Lettering: Designated by Architect.
 - 1. Sign Painting: Sign panels shall be shop painted and field installed.
 - a. Sign painting shall be performed by professional sign painters. Silk screen method is recommended in order to accurately depict graphics.
 - b. Paint back and edges of sign panels for complete weather resistance and finished appearance.
- D. Project Address Signs: Provide Project name and street address signs, minimum of 4 feet wide, to identify Project to facilitate deliveries.
 - 1. Graphic design and colors shall match Project Identification Sign.
 - 2. Text shall be as directed.
- E. Lettering: Standard Alphabet Series C, as specified in FHWA (SHS).

2.03 PROJECT INFORMATIONAL SIGNS

- A. Restrictions: Signs other than Project Identification Sign specified above and Project Informational Signs specified below shall not be displayed without approval of Architect.
- B. Project Informational Signs: Informational signs, necessary for conduct of construction activities or required by governmental authorities having jurisdiction may be displayed when in conformance to sign construction and graphic requirements specified in this Section.
 - 1. Architect may review such signs. If so, review will be for sign construction, and graphic designs only.
 - 2. Adequacy of signage for safety and conformance to requirements of authorities having jurisdiction and trade practices shall be solely Contractor's responsibility.

FOR REFERENCE ONLY

- C. Painted informational signs of same colors and lettering as Project Identification sign, or standard products; size lettering to provide legibility at 100 foot distance.
 - 1. Colors shall be as required by authorities having jurisdiction and, if not otherwise required, of colors consistent with Project graphics.
 - 2. Informational signage shall be produced by professional sign painters and be of size and lettering style consistent with use.
- D. Provide at each field office, storage shed , and directional signs to direct traffic into and within site. Relocate as Work progress requires.
- E. Provide municipal traffic agency directional traffic signs to and within site.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install project identification sign within 30 days after date fixed by Notice to Proceed.
- B. Erect at location of high public visibility adjacent to main entrance to site.
- C. Erect supports and framing on secure foundation, rigidly braced and framed to resist wind loadings.
- D. Install sign surface plumb and level, with butt joints. Anchor securely.
- E. Paint exposed surfaces and edges of sign, supports, and framing for a finished appearance.
- F. Project Identification Sign Installation
 - 1. Construction: Construct sign support structure and install panels in durable manner, to resist high winds.
 - 2. Installation: Erect Sign on site at a lighted location of high public visibility, adjacent to the main entrance to the site, as approved by Architect.
 - a. Install sign at height for optimum visibility, on ground-mounted poles or attached to portable structure on skids.
 - b. Portable structure shall resist overturning force of wind.
 - 3. Street Address Signs: Locate and install signs at each access point from public streets.
- G. Project Informational Signs Installation:
 - 1. Construction: Construct sign support structure and install panels in durable manner, to resist high winds.
 - 2. Project Informational Signs Installation:
 - a. Locate signs as necessary for construction activities and as required by authorities having jurisdiction.
 - b. Install informational signs for optimum visibility, on ground-mounted posts or temporarily attached to surfaces of structures.
 - c. Attachment methods shall leave no permanent disfiguration or discoloration on completed Work.

FOR REFERENCE ONLY

3.02 MAINTENANCE

- A. Maintain signs and supports neat clean condition. Repair all deterioration, weathering and damage to structure framing, and signage.
- B. Sign Relocation: Relocate signs as required by progress of the Work.

3.03 REMOVAL

- A. Remove signs, framing, supports, and foundations at completion of Project and restore the area prior to Final Inspection review.

END OF SECTION

SECTION 01 60 00 PRODUCT REQUIREMENTS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. General product requirements.
 - 1. System Completeness.
 - 2. Installation of Products.
- B. Re-use of existing products.
- C. Transportation, handling, storage and protection.
- D. Product option requirements.
- E. Substitution limitations.
- F. Procedures for District-supplied products.
- G. Maintenance materials, including extra materials, spare parts, tools, and software.

1.02 RELATED REQUIREMENTS

- A. Section 01 10 00 - Summary: Identification of District-supplied products.
- B. Section 01 25 00 - Substitution Procedures: Substitutions made during procurement and/or construction phases.
- C. Section 01 40 00 - Quality Requirements: Product quality monitoring.
- D. Section 01 61 16 - Volatile Organic Compound (VOC) Content Restrictions: Requirements for VOC-restricted product categories.
- E. Section 01 74 19 - Construction Waste Management and Disposal: Waste disposal requirements potentially affecting product selection, packaging and substitutions.
- F. Technical Specifications Sections.

1.03 REFERENCE STANDARDS

- A. CAL (CDPH SM) - Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers Version 1.2.
- B. CEC - California Electrical Code.
- C. NFPA 70 - National Electrical Code.
 - 1. Use California Electrical Code, CEC.

1.04 SUBMITTALS

- A. Proposed Products List: Submit list of major products proposed for use, with name of manufacturer, trade name, and model number of each product.
 - 1. Submit within 15 days after date of Agreement.
 - 2. For products specified only by reference standards, list applicable reference standards.

- B. Product Data Submittals: Submit manufacturer's standard published data. Mark each copy to identify applicable products, models, options, and other data. Supplement manufacturers' standard data to provide information specific to this Project.
- C. Shop Drawing Submittals: Prepared specifically for this Project; indicate utility and electrical characteristics, utility connection requirements, and location of utility outlets for service for functional equipment and appliances.
- D. Sample Submittals: Illustrate functional and aesthetic characteristics of the product, with integral parts and attachment devices. Coordinate sample submittals for interfacing work.
 - 1. For selection from standard finishes, submit samples of the full range of the manufacturer's standard colors, textures, and patterns.

1.05 QUALITY ASSURANCE

- A. CAL (CDPH SM) v1.1: California Department of Public Health (CDPH) Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers, v. 1.1–2010, for the emissions testing and requirements of products and materials.

PART 2 PRODUCTS

2.01 GENERAL REQUIREMENTS

- A. Drawings and Specifications:
 - 1. If a conflict exists between the Drawings and the Specifications (Project Manual), then the Contractor is to submit a Request for Interpretation from the Architect.
 - a. As noted in the General Conditions, the more stringent requirements govern, including cost of materials and/or installation.
 - 2. If a specific product is indicated on the Drawings for use, then that product is to be used without exception in the location identified.
 - 3. If the Contractor proposes the use of another "or Equal" product other than the item indicated, whether or not listed in these specifications, Contractor must submit the product using the complete substitution process, **prior to bid**. See the the Article titled "SUBSTITUTIONS".
 - 4. DSA (Division of the State Architect) approval is also required prior to the use or installation of any substitution, on any product or location of product (requiring a revision to the Drawings or Specifications), included in these construction documents.
 - a. Installation of a non-approved product may result in the Contractor removing and replacing the non-approved product at the Contractor's own expense.
- B. General: Items purchased for incorporation in the Work, whether purchased for the Project or taken from previously purchased stock, and include materials, equipment, assemblies, fabrications and systems.
 - 1. Named Products: Items identified by manufacturer's product name, including make or model designations indicated in the manufacturer's published product data.
 - 2. Materials: Products that are shaped, cut, worked, mixed, finished, refined or otherwise fabricated, processed or installed to form a part of the Work.

FOR REFERENCE ONLY

3. Equipment: A product with operating parts, whether motorized or manually operated, that requires connections such as wiring or piping.
- C. Specific Product Requirements: Refer to requirements of Section 01 40 00 - Quality Requirements and individual product technical Sections for specific requirements for products.
- D. Minimum Requirements: Specified requirements for products are minimum requirements. Refer to general requirements for quality of the Work specified in Section 01 40 00 - Quality Requirements and elsewhere herein.
- E. Standard Products:
 1. Where specific products are not specified, provide standard products of types and kinds that are suitable for the intended purposes and that are usually and customarily used on similar projects under similar conditions.
 2. Products shall be as selected by Contractor and subject to review and acceptance by the District and Architect.
- F. Product Completeness:
 1. Provide products complete with all accessories, trim, finish, safety guards and other devices and details needed for a complete installation and for the intended use and effect.
 2. Comply with additional requirements specified herein in Article titled "SYSTEM COMPLETENESS".
- G. Code Compliance:
 1. All products, other than commodity products prescribed by Code, are to have a current ICC Evaluation Service Research Report (ICC ESR), CABO National Evaluation Report (NER), or other testing agencies as accepted by the Division of the State Architect.
 2. Refer to additional requirements specified in Section 01 41 00 - Regulatory Requirements.
- H. Mechanical and Plumbing: Comply with requirements specified in Divisions 22 and 23, as included in this Project Manual and in the Drawings.
- I. Electrical, Communications, and Electronic Safety and Security: Comply with requirements specified in Divisions 26, 27, and 28, as included in this Project Manual and in the Drawings.

2.02 SYSTEM COMPLETENESS

- A. The Contract Drawings and Specifications are not intended to be comprehensive directions on how to produce the Work. Rather, the Drawings and Specifications are instruments of service prepared to describe the design intent for the completed Work.
- B. It is intended that all equipment, systems and assemblies be complete and fully functional even though not fully described. Provide all products and operations necessary to achieve the design intent described in the Contract Documents.
- C. Refer to related general requirements specified in Section 01 41 00 - Regulatory Requirements regarding compliance with minimum requirements of applicable codes, ordinances and standards.

- D. Omissions and Misdescriptions: Contractor shall report to Architect immediately when elements essential to proper execution of the Work are discovered to be missing or misdescribed in the Drawings and Specifications or if the design intent is unclear.
1. Should an essential element be discovered as missing or misdescribed prior to receipt of Bids, an Addendum will be issued so that all costs may be accounted for in the Contract Sum.
 2. Should an obvious omission or misdescription of a necessary element be discovered and reported after execution of the Agreement, Contractor shall provide the element as though fully and correctly described, and a no-cost Change Order shall be executed.
 3. Refer to related General Requirements specified in Section 01 30 00 - Administrative Requirements regarding construction interfacing and coordination.

2.03 EXISTING PRODUCTS

- A. Do not use materials and equipment removed from existing premises unless specifically required or permitted by Contract Documents.
- B. Unforeseen historic items encountered remain the property of the District; notify District promptly upon discovery; protect, remove, handle, and store as directed by District.
- C. Existing materials and equipment indicated to be removed, but not to be re-used, relocated, reinstalled, delivered to the District, or otherwise indicated as to remain the property of the District, become the property of the Contractor; remove from site.

2.04 NEW PRODUCTS

- A. Provide new products unless specifically required or permitted by Contract Documents.
 1. Provide products that fully comply with the Contract Documents, are undamaged and unused at installation.
 2. Comply with additional requirements specified herein in Article titled "PRODUCT OPTIONS".
- B. See Section 01 40 00 - Quality Requirements, for additional source quality control requirements.
- C. Use of products having any of the following characteristics is not permitted:
 1. Made outside the United States, its territories, Canada, or Mexico.
 2. Containing lead, cadmium, or asbestos.
- D. Where other criteria are met, Contractor shall give preference to products that:
 1. If used on interior, have lower emissions, as defined in Section 01 61 16.
 2. If wet-applied, have lower VOC content, as defined in Section 01 61 16.
 3. Are extracted, harvested, and/or manufactured closer to the location of the project.
 4. Have longer documented life span under normal use.
 5. Result in less construction waste. See Section 01 74 19
- E. Provide interchangeable components by the same manufacture for components being replaced.

FOR REFERENCE ONLY

1. To the fullest extent possible, provide products of the same kind from a single source. Products required to be supplied in quantity shall be the same product and interchangeable throughout the Work.
 2. When options are specified for the selection of any of two or more products, provide product selected to be compatible with products previously selected.
- F. Product Nameplates and Instructions:
1. Except for required Code-compliance labels and operating and safety instructions, locate nameplates on inconspicuous, accessible surfaces. Do not attach manufacturer's identifying nameplates or trademarks on surfaces exposed to view in occupied spaces or to the exterior.
 2. Provide a permanent nameplate on each item of service-connected or power-operated equipment. Nameplates shall contain identifying information and essential operating data such as the following example:
 - a. Name of manufacturer
 - b. Name of product
 - c. Model and serial number
 - d. Capacity
 - e. Operating and Power Characteristics
 - f. Labels of Tested Compliance with Codes and Standards
 3. Refer to additional requirements which may be specified in various sections, as included in this Project Manual.
 4. For each item of service-connected or power-operated equipment, provide operating and safety instructions, permanently affixed and of durable construction, with legible machine lettering. Comply with all applicable requirements of authorities having jurisdiction and listing agencies.
- G. Wiring Terminations: Provide terminal lugs to match branch circuit conductor quantities, sizes, and materials indicated. Size terminal lugs to CEC/NFPA 70, include lugs for terminal box.
- H. Cord and Plug: Provide minimum 6 foot cord and plug including grounding connector for connection to electric wiring system. Cord of longer length is specified in individual specification sections.

2.05 PRODUCT OPTIONS

- A. Products Specified by Reference Standards or by Description Only: Use any product meeting those standards or description.
1. Reference Standards:
 - a. Where Specifications require compliance with a standard, provided product shall fully comply with the standard specified.
 - b. Refer to general requirements specified in Section 01 42 19 - Reference Standards regarding compliance with referenced standards, standard specifications, codes, practices and requirements for products.

FOR REFERENCE ONLY

2. Product Description:
 - a. Where Specifications describe a product, listing characteristics required, with or without use of a brand name, provide a product that has the specified attributes and otherwise complies with specified requirements.
3. Performance Requirements:
 - a. Where Specifications require compliance with performance requirements, provide product(s) that comply and are recommended by the manufacturer for the intended application.
 - b. Verification of manufacturer's recommendations may be by product literature or by certification of performance from manufacturer.
- B. Products Specified by Naming One or More Manufacturers: Use a product of one of the manufacturers named and meeting specifications, no options or substitutions allowed.
- C. Products Specified by Naming One or More Manufacturers with a Provision for Substitutions: Submit a request for substitution for any manufacturer not named, prior to bid .
- D. Products Specified by Identification of Manufacturer and Product Name or Number:
 1. "Specified Manufacturer": Provide the specified product(s) of the specified manufacturer.
 - a. If only one manufacturer is specified, without "acceptable manufacturers" being identified, provide only the specified product(s) of the specified manufacturer.
 - b. If District standard is indicated make all efforts to provide that product.
 - c. If the phrase "or equal" or "approved equal" is stated or reference is made to the "or equal provision," products of other manufacturers may be provided if such products are equivalent to the specified product(s) of the specified manufacturer.
 - 1) Equivalence shall be demonstrated by submission of information in compliance with requirements of Section 01 25 00 - Substitution Procedures.
 2. "Acceptable Manufacturers":
 - a. Product(s) of the named manufacturers, if equivalent to the specified product(s) of the specified manufacturer, will be acceptable in accordance with the requirements of Section 01 25 00 - Substitution Procedures.
 - 1) Exception: Considerations regarding changes in Contract Time and Contract Sum will be waived if no increase in Contract Time or Contract Sum results from use of such equivalent products.
 3. Unnamed manufacturers: Product(s) of unnamed manufacturers will be acceptable **when disclosed during the bidding period** and only as follows:
 - a. Unless specifically stated that substitutions will not be accepted or considered, the phrase "or equal" shall be assumed to be included in the description of specified product(s).
 - b. Equivalent products of unnamed manufacturers will be accepted in accordance with the "or equal" provision specified herein, below.
 - c. If provided, prior to bid, products of unnamed manufacturers shall be subject to the requirements of Section 01 25 00 - Substitution Procedures.

4. Quality basis:
 - a. Specified product(s) of the specified manufacturer shall serve as the basis by which products by named acceptable manufacturers and products of unnamed manufacturers will be evaluated.
 - b. Where characteristics of the specified product are described, where performance characteristics are identified or where reference is made to industry standards, such characteristics are specified to identify the most significant attributes of the specified product(s) which will be used to evaluate products of other manufacturers.
- E. Products Specified by Combination of Methods: Where products are specified by a combination of attributes, including manufacturer's name, product brand name, product catalog or identification number, industry reference standard, or description of product characteristics, provide products conforming to all specified attributes.
- F. "Or Equal" Provision: Where the phrase "or equal" or the phrase "or approved equal" is included, equivalent product(s) of unnamed manufacturer(s) may be provided as specified above in subparagraph titled "Unnamed manufacturers" and Section 01 25 00 - Substitution Procedures with the following conditions:
 1. The requirements of Section 01 25 00 - Substitution Procedures applies to products provided under the "or equal" provision.
 - a. Exception: If the proposed product(s) are determined to be equivalent to the specified product(s) of the specified manufacturer, the requirement specified for substitutions to result in a net reduction in Contract Time or Contract Sum may be waived.
 2. Use of product(s) under the "or equal" provision shall not result in any delay in completion of the Work, including completion of portions of the Work for use by District or for work under separate contract by District.
 3. Use of product(s) under the "or equal" provision shall not result in any costs to the District, including design fees and permit and plan check fees.
 4. Use of product(s) under the "or equal" provision shall not require substantial change in the intent of the design, in the opinion of the Architect.
 - a. The intent of the design shall include functional performance and aesthetic qualities.
 5. The determination of equivalence will be made by the Architect and District, and such determination shall be final.
- G. Visual Matching:
 1. Where Specifications require matching a sample, the decision by the Architect on whether a proposed product matches shall be final.
 2. Where no product visually matches but the product complies with other requirements, comply with provisions for substitutions for selection of a matching product in another category.
- H. Visual Selection of Products:

FOR REFERENCE ONLY

1. Where requirements include the phrase "as selected from manufacturer's standard colors, patterns and textures", or a similar phrase, selections of products will be made by indicated party or, if not indicated, by the Architect. The will select color, pattern and texture from the product line of submitted manufacturer, if all other specified provisions are met.
2. The Architect will select color, pattern and texture from the product line of submitted manufacturer, if all other specified provisions are met.

2.06 MAINTENANCE MATERIALS

- A. Furnish extra materials, spare parts, tools, and software of types and in quantities specified in individual specification sections.
- B. Deliver to Project site; obtain receipt prior to final payment.

PART 3 EXECUTION

3.01 SUBSTITUTION LIMITATIONS

- A. See Section 01 25 00 - Substitution Procedures.

3.02 OWNER-SUPPLIED PRODUCTS

- A. See Section 01 10 00 - Summary for identification of District-supplied products.
- B. District's Responsibilities:
 1. Arrange for and deliver District reviewed shop drawings, product data, and samples, to Contractor.
 2. Arrange and pay for product delivery to site.
 3. On delivery, inspect products jointly with Contractor.
 4. Submit claims for transportation damage and replace damaged, defective, or deficient items.
 5. Arrange for manufacturers' warranties, inspections, and service.
- C. Contractor's Responsibilities:
 1. Review District reviewed shop drawings, product data, and samples.
 2. Receive and unload products at site; inspect for completeness or damage jointly with District.
 3. Handle, store, install and finish products.
 4. Repair or replace items damaged after receipt.

3.03 TRANSPORTATION AND HANDLING

- A. Package products for shipment in manner to prevent damage; for equipment, package to avoid loss of factory calibration.
- B. If special precautions are required, attach instructions prominently and legibly on outside of packaging.
- C. Coordinate schedule of product delivery to designated prepared areas in order to minimize site storage time and potential damage to stored materials.

1. Schedule delivery to minimize long-term storage and prevent overcrowding construction spaces.
 2. Coordinate with installation to ensure minimum holding time for items that are flammable, hazardous, easily damaged, or sensitive to deterioration, theft and other losses.
- D. Transport and handle products in accordance with manufacturer's instructions.
- E. Transport products by methods to avoid product damage.
- F. Transport materials in covered trucks to prevent contamination of product and littering of surrounding areas.
- G. Promptly inspect shipments to ensure that products comply with requirements, quantities are correct, and products are undamaged.
- H. Provide equipment and personnel to handle products by methods to prevent soiling, disfigurement, or damage, and to minimize handling.
- I. Arrange for the return of packing materials, such as wood pallets, where economically feasible.

3.04 STORAGE AND PROTECTION

- A. Provide protection of stored materials and products against theft, casualty, or deterioration.
- B. Designate receiving/storage areas for incoming products so that they are delivered according to installation schedule and placed convenient to work area in order to minimize waste due to excessive materials handling and misapplication. See Section 01 74 19.
1. Structural Loading Limitations: Handle and store products and materials so as not to exceed static and dynamic load-bearing capacities of project floor and roof areas.
- C. Inspection Provisions: Arrange storage to provide access for inspection and measurement of quantity or counting of units.
- D. Structural Considerations: Store heavy materials away from the structure in a manner that will not endanger supporting construction.
- E. Store and protect products in accordance with manufacturers' instructions.
- F. Store with seals and labels intact and legible.
- G. Arrange storage of materials and products to allow for visual inspection for the purpose of determination of quantities, amounts, and unit counts.
- H. Store sensitive products in weathertight, climate-controlled enclosures in an environment favorable to product.
- I. For exterior storage of fabricated products, place on sloped supports above ground.
1. Place products on raised blocks, pallets or other supports, above ground and in a manner to not create ponding or misdirection of runoff.
- J. Provide bonded off-site storage and protection when site does not permit on-site storage or protection.
1. Execute a formal supplemental agreement between District and Contractor allowing off-site storage, for each occurrence.

- K. Protect products from damage or deterioration due to construction operations, weather, precipitation, humidity, temperature, sunlight and ultraviolet light, dirt, dust, and other contaminants.
 - 1. Periodically inspect to ensure products are undamaged, and are maintained under required conditions.
 - 2. Remove and replace products damaged by improper storage or protection with new products at no change in Contract Sum or Contract Time.
 - 3. Weather-Resistant Storage:
 - a. Store moisture-sensitive products above ground, under cover in a weathertight enclosure or covered with an impervious sheet covering. Provide adequate ventilation to avoid condensation.
 - b. Maintain storage within temperature and humidity ranges required by manufacturer's instructions.
 - c. Store loose granular materials on solid surfaces in a well-drained area. Prevent mixing with foreign matter.
- L. Comply with manufacturer's warranty conditions, if any.
- M. Do not store products directly on the ground.
- N. Cover products subject to deterioration with impervious sheet covering. Provide ventilation to prevent condensation and degradation of products.
- O. Store loose granular materials on solid flat surfaces in a well-drained area. Prevent mixing with foreign matter.
- P. Prevent contact with material that may cause corrosion, discoloration, or staining.
- Q. Provide equipment and personnel to store products by methods to prevent soiling, disfigurement, or damage.
- R. Arrange storage of products to permit access for inspection. Periodically inspect to verify products are undamaged and are maintained in acceptable condition.

3.05 INSTALLATION OF PRODUCTS

- A. Comply with manufacturer's instructions and recommendations for installation of products, except where more stringent requirements are specified, are necessary due to Project conditions or are required by authorities having jurisdiction.
- B. Anchor each product securely in place, accurately located and aligned with other Work.
- C. Clean exposed surfaces and provide protection to ensure freedom from damage and deterioration at time of Completion review. Refer to additional requirements specified in General Conditions along with Section 01 50 00 - Temporary Facilities and Controls and Section 01 70 00 - Execution and Closeout Requirements.

3.06 PROTECTION OF COMPLETED WORK

- A. Provide barriers, substantial coverings and notices to protect installed Work from traffic and subsequent construction operations.
- B. Remove protective measures when no longer required and prior to Completion review of the Work.

FOR REFERENCE ONLY

- C. Comply with additional requirements specified in Section 01 50 00 - Temporary Construction Facilities and Controls.

END OF SECTION

SECTION 01 61 16 VOLATILE ORGANIC COMPOUND (VOC) CONTENT RESTRICTIONS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Requirements for Indoor-Emissions-Restricted products.
- B. Requirements for VOC-Content-Restricted products.
- C. Requirement for installer certification that they did not use any non-compliant products.

1.02 RELATED REQUIREMENTS

- A. Section 01 30 00 - Administrative Requirements: Submittal procedures.
- B. Section 01 40 00 - Quality Requirements: Procedures for testing and certifications.
- C. Section 01 60 00 - Product Requirements: Fundamental product requirements, substitutions and product options, delivery, storage, and handling.
- D. Section 07 92 00 - Joint Sealants: Emissions-compliant sealants.

1.03 DEFINITIONS

- A. Indoor-Emissions-Restricted Products: All products in the following product categories, whether specified or not:
 - 1. Interior paints and coatings applied on site.
 - 2. Interior adhesives and sealants applied on site, including flooring adhesives.
 - 3. Flooring.
 - 4. Products making up wall and ceiling assemblies.
 - 5. Thermal and acoustical insulation.
 - 6. Other products when specifically stated in the specifications.
- B. VOC-Content-Restricted Products: All products in the following product categories, whether specified or not:
 - 1. Exterior and interior paints and coatings.
 - 2. Exterior and interior adhesives and sealants, including flooring adhesives.
 - 3. Wet-applied roofing and waterproofing.
 - 4. Other products when specifically stated in the specifications.
- C. Interior of Building: Anywhere inside the exterior weather barrier.
- D. Adhesives: All gunnable, trowelable, liquid-applied, and aerosol adhesives, whether specified or not; including flooring adhesives, resilient base adhesives, and pipe jointing adhesives.
- E. Sealants: All gunnable, trowelable, and liquid-applied joint sealants and sealant primers, whether specified or not; including firestopping sealants and duct joint sealers.

FOR REFERENCE ONLY

- F. Inherently Non-Emitting Materials: Products composed wholly of minerals or metals, unless they include organic-based surface coatings, binders, or sealants; and specifically the following:
1. Concrete.
 2. Clay brick.
 3. Metals that are plated, anodized, or powder-coated.
 4. Glass.
 5. Ceramics.
 6. Solid wood flooring that is unfinished and untreated.

1.04 REFERENCE STANDARDS

- A. 40 CFR 59, Subpart D - National Volatile Organic Compound Emission Standards for Architectural Coatings; U.S. Environmental Protection Agency.
- B. ASTM D3960 - Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings.
- C. CAL (CDPH SM) - Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers Version 1.2.
- D. CARB (ATCM) - Airborne Toxic Control Measure to Reduce Formaldehyde Emissions from Composite Wood Products.
- E. CARB (SCM) - Suggested Control Measure for Architectural Coatings; California Air Resources Board.
- F. CHPS (HPPD) - High Performance Products Database.
- G. CRI (GL) - Green Label Testing Program - Certified Products.
- H. CRI (GLP) - Green Label Plus Testing Program - Certified Products.
- I. GreenSeal GS-36 - Standard for Adhesives for Commercial Use.
- J. SCAQMD 1113 - Architectural Coatings.
- K. SCAQMD 1168 - Adhesive and Sealant Applications.
- L. SCS (CPD) - SCS Certified Products.
- M. UL (GGG) - GREENGUARD Gold Certified Products.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: For each VOC-restricted product used in the project, submit evidence of compliance.
- C. Installer Certifications Regarding Prohibited Content: Require each installer of any type of product (not just the products for which VOC restrictions are specified) to certify that either 1) no adhesives, joint sealants, paints, coatings, or composite wood or agrifiber products have been used in the installation of installer's products, or 2) that such products used comply with these requirements.
 1. Use the form following this section for installer certifications.

- D. Verification of compliance with VOC limits as specified in the CalGreen Code Section 5.504 shall be provided at the request of the Building Inspector.
1. Product certification and specifications.
 2. Chain of custody certifications.
 3. Product, labeled and invoiced as meeting the Composite Wood Products regulation.
 4. Exterior grade products marked as meeting the PS-1 or PS-2 standards of the Engineered Wood Association, the Australian AS/NZS 2269 or European 636 3S standards
 5. Other methods approved by the building official.

1.06 QUALITY ASSURANCE

- A. Indoor Emissions Standard and Test Method: CAL (CDPH SM), using Standard Private Office exposure scenario and the allowable concentrations specified in the method, and range of total VOC's after 14 days.
1. Wet-Applied Products: State amount applied in mass per surface area.
 2. Paints and Coatings: Test tinted products, not just tinting bases.
 3. Evidence of Compliance: Acceptable types of evidence are the following;
 - a. Current UL (GGG) certification.
 - b. Current SCS (CPD) Floorscore certification.
 - c. Current SCS (CPD) Indoor Advantage Gold certification.
 - d. Current listing in CHPS (HPPD) as a low-emitting product.
 - e. Current CRI (GLP) certification.
 - f. Test report showing compliance and stating exposure scenario used.
 4. Product data submittal showing VOC content is NOT acceptable evidence.
 5. Manufacturer's certification without test report by independent agency is NOT acceptable evidence.
- B. VOC Content Test Method: 40 CFR 59, Subpart D (EPA Method 24), or ASTM D3960, unless otherwise indicated.
1. Evidence of Compliance: Acceptable types of evidence are:
 - a. Report of laboratory testing performed in accordance with requirements.
 - b. Published product data showing compliance with requirements.
 - c. Certification by manufacturer that product complies with requirements.
- C. Composite Wood Emissions Standard: CARB (ATCM) for ultra-low emitting formaldehyde (ULEF) resins.
1. Evidence of Compliance: Acceptable types of evidence are:
 - a. Current SCS "No Added Formaldehyde (NAF)" certification; www.scs-certified.com.
 - b. Report of laboratory testing performed in accordance with requirements.
 - c. Published product data showing compliance with requirements.
 - d. Certification by manufacturer that product complies with requirements.

- D. Testing Agency Qualifications: Independent firm specializing in performing testing and inspections of the type specified in this section.

PART 2 PRODUCTS

2.01 REGULATORY REQUIREMENTS

- A. All VOC restricted products shall be compliant with local jurisdiction, South Coast Air Quality Management District, and California Green Standards Code, Rules and Regulations in effect at the time of installation. Products specified in this project shall be used as a basis of design. Updated products that are compliant with the rules in force at the time of installation shall be submitted as substitutions when they become available.
 - 1. If a product is found to be non-compliant with the VOC rules at the scheduled time of installation, notify the Architect a minimum of 90 days prior to installation. Contractor shall submit a suggested compliant product that is equal to the performance and cost of the specified product using the substitution procedure.

2.02 MATERIALS

- A. All Products: Comply with the most stringent of federal, State, and local requirements, or these specifications.
- B. Indoor-Emissions-Restricted Products: Comply with Indoor Emissions Standard and Test Method, except for:
 - 1. Composite Wood, Wood Fiber, and Wood Chip Products: Comply with Composite Wood Emissions Standard or contain no added formaldehyde resins.
 - a. Comply with CalGreen Building Standards Section 5.504.4.5, Table 504.4.4.5 "Formaldehyde Limits".
 - 2. Inherently Non-Emitting Materials.
- C. VOC-Content-Restricted Products: VOC content not greater than required by the following:
 - 1. Adhesives, Including Flooring Adhesives: SCAQMD 1168 Rule.
 - 2. Aerosol Adhesives: GreenSeal GS-36.
 - 3. Joint Sealants: SCAQMD 1168 Rule.
 - 4. Paints and Coatings: Each color; most stringent of the following:
 - a. 40 CFR 59, Subpart D.
 - b. SCAQMD 1113 Rule.
 - c. CARB (SCM).
 - d. CalGreen Building Standards Section 5.504, Table 504.4.3 "VOC Content Limits for Architectural Coatings".
 - e. Clear Wood Finishes, Floor Coatings, Stains, Primers and Shellacs: Do not exceed the VOC content limits established in SCAQMD 1113 rule.
 - 5. Wet-Applied Roofing and Waterproofing: Comply with requirements for paints and coatings.

FOR REFERENCE ONLY

6. Carpet, Carpet Tile, and Adhesive: Provide products having VOC content not greater than that required for CRI (GLP) certification.
 - a. Comply with CalGreen Building Standards Section 5.504, Table 504.4.1 "Adhesive VOC Limit".
 7. Carpet Cushion: Provide products having VOC content not greater than that required for CRI (GL) certification.
 - a. Comply with CalGreen Building Standards Section 5.504, Table 504.4.1 "Adhesive VOC Limit".
- D. Other Product Categories: Comply with limitations specified elsewhere.

PART 3 EXECUTION

3.01 FIELD QUALITY CONTROL

- A. District reserves the right to reject non-compliant products, whether installed or not, and require their removal and replacement with compliant products at no extra cost to District.
- B. Additional costs to restore indoor air quality due to installation of non-compliant products will be borne by Contractor.

END OF SECTION

SECTION 01 61 16.01 ACCESSORY MATERIAL VOC CONTENT CERTIFICATION FORM

FORM

1.01 IDENTIFICATION:

- A. Project Name: Kitchen Upgrades at Madison ES
- B. Project No.: 1-104-02
- C. Architect: Ruhnau Clarke Architects

1.02 USE OF THIS FORM:

- A. Because installers are allowed and directed to choose accessory materials suitable for the applicable installation, there is a possibility that such accessory materials might contain VOC content in excess of that permitted, especially where such materials have not been explicitly specified.
 - 1. Each installer of work on this project is required to certify that his/their use of these particular materials complies with the contract documents and to provide documentation showing that the products used do not contain the prohibited content.
- B. Contractor is required to obtain and submit this form from each installer of work on this project.
- C. For each product category listed, check the correct paragraph.
- D. If any of these accessory materials has been used, attach to this form product data and MSDS sheet for each such product.

1.03 VOC CONTENT RESTRICTIONS ARE SPECIFIED IN SECTION 01 61 16.

- A. Volatile organic compounds (VOCs) are defined by the U.S. EPA, California Air Resources Board (CARB), South Coast Air Quality Management District (SCAQMD), along with other state and local regulations applicable to this project.

2.01 PRODUCT CERTIFICATION

- A. I certify that the installation work of my firm on this project:
 - 1. [HAS] [HAS NOT] required the use of any ADHESIVES.
 - 2. [HAS] [HAS NOT] required the use of any JOINT SEALANTS.
 - 3. [HAS] [HAS NOT] required the use of any PAINTS OR COATINGS.
 - 4. [HAS] [HAS NOT] required the use of any COMPOSITE WOOD or AGRIFIBER PRODUCTS.
- B. Product data and MSDS sheets are attached.

FOR REFERENCE ONLY

3.01 CERTIFIED BY: (INSTALLER/MANUFACTURER/SUPPLIER FIRM)

- A. Firm Name: _____
- B. Print Name: _____
- C. Signature: _____
- D. Title: _____ (officer of company)
- E. Date: _____

END OF SECTION

SECTION 01 70 00 EXECUTION AND CLOSEOUT REQUIREMENTS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Examination, preparation, and general installation procedures.
- B. Requirements for alterations work, including selective demolition, except removal, disposal, and/or remediation of hazardous materials and toxic substances.
- C. Pre-installation meetings.
- D. Cutting and patching.
- E. Surveying for laying out the work.
- F. Cleaning and protection.
- G. Starting of systems and equipment.
- H. Demonstration and instruction of District personnel.
- I. Closeout procedures, including Contractor's Correction Punch List, except payment procedures.
- J. General requirements for maintenance service.

1.02 RELATED REQUIREMENTS

- A. Section 01 10 00 - Summary: Limitations on working in existing building; continued occupancy; work sequence; identification of salvaged and relocated materials.
- B. Section 01 30 00 - Administrative Requirements: Submittals procedures.
- C. Section 01 31 14 - Facility Services Coordination: Coordination of trades.
- D. Section 01 40 00 - Quality Requirements: Testing and inspection procedures.
- E. Section 01 45 33 - Code-Required Special Inspections: Construction oversight procedures by Division of the State Architect regarding the execution, approval, and closeout of this building project.
 - 1. Project Type:
 - a. Public
 - 2. Code agency:
 - a. California Building Code
 - b. DSA
- F. Section 01 71 23 - Field Engineering: Additional requirements for field engineering and surveying work.
- G. Section 01 74 19 - Construction Waste Management and Disposal: Additional procedures for trash/waste removal, recycling, salvage, and reuse.
- H. Section 01 78 00 - Closeout Submittals: Project record documents, operation and maintenance data, warranties, and bonds.

FOR REFERENCE ONLY

- I. Section 01 79 00 - Demonstration and Training: Demonstration of products and systems to be commissioned and where indicated in specific specification sections
- J. Section 02 41 00 - Demolition: Demolition of whole structures and parts thereof; site utility demolition.
- K. Section 07 84 00 - Firestopping.
- L. Individual Product Specification Sections:
 - 1. Advance notification to other sections of openings required in work of those sections.
 - 2. Limitations on cutting structural members.

1.03 REFERENCE STANDARDS

- A. CBC Chapter 11B - California Building Code-Chapter 11B.
- B. CFC Chapter 33 - California Fire Code - Chapter 33 - Fire Safety during Construction and Demolition.
- C. CFC Chapter 35 - California Fire Code - Chapter 35 - Welding and other Hot Work.
- D. NFPA 241 - Standard for Safeguarding Construction, Alteration, and Demolition Operations.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Survey work: Submit name, address, and telephone number of Surveyor before starting survey work.
 - 1. On request, submit documentation verifying accuracy of survey work.
 - 2. Submit a copy of site drawing signed by the Land Surveyor, that the elevations and locations of the work are in compliance with Contract Documents.
 - 3. Submit surveys and survey logs for the project record.
- C. Cutting and Patching: Submit written request in advance of cutting or alteration that affects:
 - 1. Structural integrity of any element of Project.
 - 2. Integrity of weather exposed or moisture resistant element.
 - 3. Efficiency, maintenance, or safety of any operational element.
 - 4. Visual qualities of sight exposed elements.
 - 5. Work of District or separate Contractor.
 - 6. Include in request:
 - a. Identification of Project.
 - b. Location and description of affected work.
 - c. Necessity for cutting or alteration.
 - d. Description of proposed work and products to be used.
 - e. Effect on work of District or separate Contractor.
 - f. Effect on existing construction of District and, if applicable, work for Project being provided by District under separate contract.
 - g. Written permission of affected separate Contractor.

- h. Date and time work will be executed.
- 7. Include written evidence that those performing work under separate contract for District have been notified and acknowledge that cutting and patching work will be occurring. Include written permission for intended cutting and patching, included scheduled times.
- D. Project Record Documents: Accurately record actual locations of capped and active utilities.

1.05 QUALIFICATIONS

- A. For demolition work, employ a firm specializing in the type of work required.
 - 1. Minimum of 5 years of documented experience.
- B. For surveying work, employ a land surveyor registered in California and acceptable to Architect. Submit evidence of surveyor's Errors and Omissions insurance coverage in the form of an Insurance Certificate. Employ only individual(s) trained and experienced in collecting and recording accurate data relevant to ongoing construction activities,
- C. For field engineering, employ a professional engineer of the discipline required for specific service on Project, licensed in California. Employ only individual(s) trained and experienced in establishing and maintaining horizontal and vertical control points necessary for laying out construction work on project of similar size, scope and/or complexity.
- D. For design of temporary shoring and bracing, employ a Professional Engineer experienced in design of this type of work and licensed in California.

1.06 PROJECT CONDITIONS

- A. Ventilate enclosed areas to assist cure of materials, to dissipate humidity, and to prevent accumulation of dust, fumes, vapors, or gases.
- B. Erosion and Sediment Control: Plan and execute work by methods to control surface drainage from cuts and fills, from borrow and waste disposal areas. Prevent erosion and sedimentation.
 - 1. Minimize amount of bare soil exposed at one time.
 - 2. Provide temporary measures such as berms, dikes, and drains, to prevent water flow.
 - 3. Construct fill and waste areas by selective placement to avoid erosive surface silts or clays.
 - 4. Periodically inspect earthwork to detect evidence of erosion and sedimentation; promptly apply corrective measures.
- C. Noise Control: Provide methods, means, and facilities to minimize noise produced by construction operations.
 - 1. At All Times: Excessively noisy tools and operations will not be tolerated inside the building at any time of day; excessively noisy includes jackhammers, pneumatic hammers, and air-operated nail guns.
 - 2. Outdoors: Limit conduct of especially noisy exterior work to the hours of 8 am to 5 pm.
- D. Pest and Rodent Control: Provide methods, means, and facilities to prevent pests and insects from damaging the work.
- E. Rodent Control: Provide methods, means, and facilities to prevent rodents from accessing or invading premises.

1.07 COORDINATION

- A. See Section 01 10 00 for occupancy-related requirements.
- B. Coordinate scheduling, submittals, and work of the various sections of the Project Manual to ensure efficient and orderly sequence of installation of interdependent construction elements, with provisions for accommodating items installed later.
- C. Notify affected utility companies and comply with their requirements.
- D. Verify that utility requirements and characteristics of new operating equipment are compatible with building utilities. Coordinate work of various sections having interdependent responsibilities for installing, connecting to, and placing in service, such equipment.
- E. Coordinate space requirements, supports, and installation of mechanical and electrical work that are indicated diagrammatically on drawings. Follow routing indicated for pipes, ducts, and conduit, as closely as practicable; place runs parallel with lines of building. Utilize spaces efficiently to maximize accessibility for other installations, for maintenance, and for repairs.
- F. In finished areas except as otherwise indicated, conceal pipes, ducts, and wiring within the construction. Coordinate locations of fixtures and outlets with finish elements.
- G. Coordinate completion and clean-up of work of separate sections.
- H. After District occupancy of premises, coordinate access to site for correction of defective work and work not in accordance with Contract Documents, to minimize disruption of District's activities.

PART 2 PRODUCTS

2.01 PATCHING MATERIALS

- A. New Materials: As specified in product sections; match existing products and work for patching and extending work.
- B. Type and Quality of Existing Products: Determine by inspecting and testing products where necessary, referring to existing work as a standard.
- C. Product Substitution: For any proposed change in materials, submit request for substitution described in Section 01 60 00 - Product Requirements.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that existing site conditions and substrate surfaces are acceptable for subsequent work. Start of work means acceptance of existing conditions.
- B. Verify that existing substrate is capable of structural support or attachment of new work being applied or attached.
- C. Examine and verify specific conditions described in individual specification sections.
- D. Take field measurements before confirming product orders or beginning fabrication, to minimize waste due to over-ordering or misfabrication.

- E. Verify that utility services are available, of the correct characteristics, and in the correct locations.
- F. Prior to Cutting: Examine existing conditions prior to commencing work, including elements subject to damage or movement during cutting and patching. After uncovering existing work, assess conditions affecting performance of work. Beginning of cutting or patching means acceptance of existing conditions.

3.02 PREPARATION

- A. Clean substrate surfaces prior to applying next material or substance.
- B. Seal cracks or openings of substrate prior to applying next material or substance.
- C. Apply manufacturer required or recommended substrate primer, sealer, or conditioner prior to applying any new material or substance in contact or bond.

3.03 PREINSTALLATION MEETINGS

- A. When required in individual specification sections, convene a preinstallation meeting at the site prior to commencing work of the section.
 - 1. Coordinate operations of the various trades to assure efficient and orderly installation of each part of Work.
 - 2. Coordinate Work operations of the various trades that depend on each other for proper installation, connection, and operation of Work, including but not limited to:
 - a. Schedule construction operations in sequence required where installation of one part of Work depends on installation of other components, before or after its own installation.
 - b. Coordinate installation of different components to assure maximum accessibility for required maintenance, service, and repair.
 - c. Provide provisions to accommodate items scheduled for later installation.
- B. Require attendance of parties directly affecting, or affected by, work of the specific section.
- C. Notify Architect four days in advance of meeting date.
- D. Prepare agenda and preside at meeting:
 - 1. Review conditions of examination, preparation and installation procedures.
 - 2. Review coordination with related work.
- E. Record minutes and distribute copies within two days after meeting to participants, with electronic copies to Architect, District, participants, and those affected by decisions made.

3.04 LAYING OUT THE WORK

- A. Verify locations of survey control points prior to starting work.
- B. Promptly notify Architect of any discrepancies discovered.
- C. Protect survey control points prior to starting site work; preserve permanent reference points during construction.
- D. Promptly report to Architect the loss or destruction of any reference point or relocation required because of changes in grades or other reasons.

- E. Replace dislocated survey control points based on original survey control. Make no changes without prior written notice to Architect.
- F. Utilize recognized engineering survey practices.
- G. Establish a minimum of two permanent bench marks on site, referenced to established control points. Record locations, with horizontal and vertical data, on project record documents.
- H. Establish elevations, lines and levels. Locate and lay out by instrumentation and similar appropriate means:
 - 1. Site improvements including pavements; stakes for grading, fill and topsoil placement; utility locations, slopes, and invert elevations.
 - 2. Grid or axis for structures.
 - 3. Building foundation, column locations, ground floor elevations.
- I. Periodically verify layouts by same means.
- J. Maintain a complete and accurate log of control and survey work as it progresses.

3.05 GENERAL INSTALLATION REQUIREMENTS

- A. Dimensions for Accessibility:
 - 1. Conventions: See CBC Chapter 11B Figure 11B-104. Dimensions that are not stated as "maximum" or "minimum" are absolute.
 - 2. Tolerances shall be per CBC Chapter 11B-104.1.1 "Construction and manufacturing tolerances. All dimensions are subject to conventional industry tolerances except where the requirement is stated as a range with specific minimum and maximum end points."
- B. In addition to compliance with regulatory requirements, conduct construction operations in compliance with CFC Chapter 33, CFC Chapter 35, and NFPA 241, including applicable recommendations in Appendix A.
 - 1. When welding or doing other hot work, comply with CFC Chapter 35.
- C. Install products as specified in individual sections, in accordance with manufacturer's instructions and recommendations, and so as to avoid waste due to necessity for replacement.
- D. Make vertical elements plumb and horizontal elements level, unless otherwise indicated.
- E. Install equipment and fittings plumb and level, neatly aligned with adjacent vertical and horizontal lines, unless otherwise indicated.
- F. Make consistent texture on surfaces, with seamless transitions, unless otherwise indicated.
- G. Make neat transitions between different surfaces, maintaining texture and appearance.

3.06 ALTERATIONS

3.07 CUTTING AND PATCHING

- A. Whenever possible, execute the work by methods that avoid cutting or patching.
- B. See Alterations article above for additional requirements.
- C. Perform whatever cutting and patching is necessary to:
 - 1. Complete the work.
 - 2. Fit products together to integrate with other work.

FOR REFERENCE ONLY

3. Provide openings for penetration of mechanical, electrical, and other services.
 4. Match work that has been cut to adjacent work.
 5. Repair areas adjacent to cuts to required condition.
 6. Repair new work damaged by subsequent work.
 7. Remove samples of installed work for testing when requested.
 8. Remove and replace defective and non-complying work.
- D. Execute work by methods that avoid damage to other work and that will provide appropriate surfaces to receive patching and finishing. In existing work, minimize damage and restore to original condition.
1. Coordinate installation or application of products for integrated Work.
 2. Uncover completed Work as necessary to install or apply products out of sequence.
 3. Remove and replace defective or non-conforming Work.
 4. Provide openings for penetration of utility services, such as plumbing, mechanical and electrical Work.
- E. After uncovering existing Work, inspect conditions affecting proper accomplishment of Work.
- F. Temporary Supports: Provide supports to ensure structural integrity of the Work. Provide devices and methods to protect other portions of Project from damage.
- G. Beginning of cutting or patching shall be interpreted to mean that existing conditions were found by Contractor to be acceptable.
- H. Employ skilled and experienced installer to perform cutting for weather exposed and moisture resistant elements, and sight exposed surfaces.
- I. Cut rigid materials using masonry saw or core drill. Pneumatic tools not allowed without prior approval.
1. Use a diamond grit abrasive saw or similar cutter for smooth edges. Do not overcut corners.
- J. Restore work with new products in accordance with requirements of Contract Documents.
- K. Fit work air tight to pipes, sleeves, ducts, conduit, and other penetrations through surfaces.
- L. Fit work neat and tight allowing for expansion and contraction.
- M. At penetrations of fire rated walls, partitions, ceiling, or floor construction, completely seal voids with fire rated material in accordance with Section 07 84 00, to full thickness of the penetrated element.
- N. Patching:
1. Finish patched surfaces to match finish that existed prior to patching. On continuous surfaces, refinish to nearest intersection or natural break. For an assembly, refinish entire unit.
 2. Match color, texture, and appearance.
 3. Repair patched surfaces that are damaged, lifted, discolored, or showing other imperfections due to patching work. If defects are due to condition of substrate, repair substrate prior to repairing finish.

- O. Finishing: Refinish surfaces to match adjacent and similar finishes as used for the Project.
 - 1. For continuous surfaces, refinish to nearest intersection or natural break.
 - 2. For an assembly, refinish entire unit.

3.08 PROGRESS CLEANING

- A. Maintain areas free of waste materials, debris, and rubbish. Maintain site in a clean and orderly condition.
- B. Remove debris and rubbish from pipe chases, plenums, attics, crawl spaces, and other closed or remote spaces, prior to enclosing the space.
- C. Broom and vacuum clean interior areas prior to start of surface finishing, and continue cleaning to eliminate dust.
- D. Collect and remove waste materials, debris, and trash/rubbish from site weekly and dispose off-site; do not burn or bury.

3.09 PROTECTION OF INSTALLED WORK

- A. Protect installed work from damage by construction operations.
- B. Provide special protection where specified in individual specification sections.
- C. Provide temporary and removable protection for installed products. Control activity in immediate work area to prevent damage.
- D. Provide protective coverings at walls, projections, jambs, sills, and soffits of openings.
- E. Protect finished floors, stairs, and other surfaces from traffic, dirt, wear, damage, or movement of heavy objects, by protecting with durable sheet materials.
- F. Protect work from spilled liquids. If work is exposed to spilled liquids, immediately remove protective coverings, dry out work, and replace protective coverings.
- G. Prohibit traffic or storage upon waterproofed or roofed surfaces. If traffic or activity is necessary, obtain recommendations for protection from waterproofing or roofing material manufacturer.
- H. Prohibit traffic from landscaped areas.
- I. Remove protective coverings when no longer needed; reuse or recycle coverings if possible.

3.10 SYSTEM STARTUP

- A. Coordinate schedule for start-up of various equipment and systems.
- B. Verify that each piece of equipment or system has been checked for proper lubrication, drive rotation, belt tension, control sequence, and for conditions that may cause damage.
- C. Verify tests, meter readings, and specified electrical characteristics agree with those required by the equipment or system manufacturer.
- D. Verify that wiring and support components for equipment are complete and tested.
- E. Execute start-up under supervision of applicable Contractor personnel and manufacturer's representative in accordance with manufacturers' instructions.

- F. When specified in individual specification Sections, require manufacturer to provide authorized representative to be present at site to inspect, check, and approve equipment or system installation prior to start-up, and to supervise placing equipment or system in operation.
- G. Submit a written report that equipment or system has been properly installed and is functioning correctly.

3.11 COMMISSIONING PROJECT

- A. Project Completion
 - 1. Prior to notifying the Architect that the project is complete according to the construction and contract documents, submit to the Architect:
 - a. Approved pre-functional checklists and functional performance testing reports from the commissioning documentation.
- B. Final Acceptance
 - 1. Prior to requesting inspection for verification of completion of all outstanding items, submit to the Architect:
 - a. The commissioning requirements of Section 01 91 13 - General Commissioning Requirements must be complete prior to final acceptance, unless approved in writing by the District. Exceptions to this are any required seasonal or approved deferred testing.

3.12 DEMONSTRATION AND INSTRUCTION

- A. See Section 01 79 00 - Demonstration and Training.

3.13 ADJUSTING

- A. Adjust operating products and equipment to ensure smooth and unhindered operation.

3.14 FINAL CLEANING

- A. Execute final cleaning prior to final project assessment.
 - 1. Clean areas to be occupied by District prior to final completion before District occupancy.
- B. Use cleaning materials that are nonhazardous.
 - 1. Cleaning Agents and Materials: Use only those cleaning agents and materials which will not create hazards to health or property and which will not damage or degrade surfaces.
 - a. Use only those cleaning agents, materials and methods recommended by manufacturer of the material to be cleaned.
 - b. Use cleaning materials only on surfaces recommended by cleaning agent manufacturer.
 - c. Before use, review cleaning agents and materials with Construction Manager for suitability and compatibility. Use no cleaning agents and materials without approval as noted above.

2. Cleaning Procedures: All cleaning processes, agents and materials shall be subject to Architect, District and/or Construction Manager review and approval. Processes and degree of cleanliness shall be as directed by Architect, District and/or Construction Manager.
- C. Clean interior and exterior glass, surfaces exposed to view; remove temporary labels, stains and foreign substances, polish transparent and glossy surfaces, vacuum carpeted and soft surfaces.
- D. Remove all labels that are not permanent. Do not paint or otherwise cover fire test labels or nameplates on mechanical and electrical equipment.
- E. Clean equipment and fixtures to a sanitary condition with cleaning materials appropriate to the surface and material being cleaned.
- F. Clean filters of operating equipment.
- G. Clean debris from roofs, gutters, downspouts, scuppers, overflow drains, area drains, and drainage systems.
- H. Clean site; sweep paved areas, rake clean landscaped surfaces.
- I. Remove waste, surplus materials, trash/rubbish, and construction facilities from the site; dispose of in legal manner; do not burn or bury.

3.15 PROJECT CLOSEOUT CONFERENCE

- A. Schedule and conduct a project closeout conference, at a time convenient to District and Architect, but no later than 90 days prior to the scheduled date of Completion.
 1. Conduct the conference to review requirements and responsibilities related to Project closeout.
 2. Attendees: Authorized representatives of District, Commissioning Authority (CxA), Architect, and relevant consultants; Contractor and project superintendent; major subcontractors; suppliers; and other concerned parties shall attend the meeting. Participants at the meeting shall be familiar with Project and authorized to conclude matters relating to the Work.
 3. Agenda: Discuss items of significance that could affect or delay Project closeout, including the following:
 - a. Preparation of record documents.
 - b. Procedures required prior to inspection for Completion and for final inspection for acceptance.
 - c. Submittal of written warranties.
 - d. Coordination of separate contracts.
 - e. Installation of District's furniture, fixtures, and equipment.
 - f. Responsibility for removing temporary facilities and controls.
 4. Record minutes and distribute copies within two days after meeting to participants, with two copies to Architect, District, participants, and those affected by decisions made.

3.16 CLOSEOUT PROCEDURES

- A. Make submittals that are required by governing or other authorities.

FOR REFERENCE ONLY

1. Provide copies to Architect and District.
- B. Accompany District, Architect, and Construction Manager on preliminary inspection to determine items to be listed for completion or correction in the Contractor's Correction Punch List for Contractor's comprehensive list of items to be completed or corrected.
 1. As authorized by the District; Architect and Architect's / District's consultants, as appropriate, will attend a meeting at the Project site to review Contract closeout procedures and to review the list of items to be completed and corrected (punch list) to make the Work ready for acceptance by the District.
 2. This meeting shall be scheduled not earlier than 14 days prior to the date anticipated for the Final Inspection review.
- C. Notify Architect when work is considered ready for Architect's Substantial Completion inspection.
- D. Submit written certification containing Contractor's Correction Punch List, that Contract Documents have been reviewed, work has been inspected, and that work is complete in accordance with Contract Documents and ready for Architect's Substantial Completion inspection.
 1. Final Application for Payment: In the Application for Payment that coincides with the date Final Inspection/Completion is claimed, show 100 percent completion for the portion of the Work claimed substantially complete.
 2. Warranties, Bonds and Certificates: Submit specific warranties, guarantees, workmanship bonds, maintenance agreements, final certifications and similar documents.
 3. Locks and Keys: Change temporary lock cylinders over to permanent keying and transmit keys to the District, unless otherwise directed or specified.
 4. Tests and Instructions: Complete start-up testing of systems, and instruction of the District's personnel. Remove temporary facilities from the site, along with construction tools, mock-ups, and similar elements.
- E. Clearing and Cleaning: Prior to the Final Inspection review, Contractor shall conduct a thorough cleaning and clearing of the Project area, including removal of construction facilities and temporary controls.
- F. Inspection and Testing: Prior to the Final Inspection review, complete inspection and testing required for the Work, including securing of approvals by authorities having jurisdiction.
- G. District will occupy all of the building as specified in Section 01 10 00.
- H. Conduct Final inspection and create Final Correction Punch List containing Architect's and Contractor's comprehensive list of items identified to be completed or corrected and submit to Architect.
 1. Correction (Punch) List: Contractor shall prepare and distribute at the preliminary Contract closeout review meeting, a typewritten, comprehensive list of items to be completed and corrected (punch list) to make the Work ready for acceptance by the District.
 - a. Include all items to be completed or corrected prior to the Contractor's application for final payment.

FOR REFERENCE ONLY

- b. Identify items by location (room number or name) and consecutive number. For example, 307-5 would identify item 5 in Room 307, Roof-4 would identify item 4 on Roof.
 - c. Prepare separate lists according to categories used for Drawings. For example, provide lists for Architectural, Structural, Plumbing, Mechanical, Electrical, Fire Protection, Civil, and Landscape.
 - d. Architect, Architect's consultants and District's consultants, if in attendance, will conduct a brief walk-through of Project with the Contractor to review scope and adequacy of the punch list.
 - e. Verbal comments will be made to the Contractor by the DSA, the Architect and the Architect's and District's consultants, if in attendance, during the walk-through. These comments will indicate generally the additions and corrections to be made to the punch list. Such comments shall not be considered to be comprehensive; Contractor shall use the comments as guidance in preparing the punch list for the Final Inspection review.
2. Final Inspection Meeting: On a date mutually agreed by the District, Architect, and Contractor, a meeting shall be conducted at the Project site to determine whether the Work is satisfactory and complete for filing a Notice of Completion.
 - a. Contractor shall provide three working days notice to Architect for requested date of Final Inspection meeting.
 - b. The Construction Manager, the Architect with Architect's / District's consultants, as authorized by the District, will attend the Final Inspection meeting.
 - c. In addition to conducting a walk-through of the facility and reviewing the punch list, the purpose of the meeting shall include submission of warranties, guarantees and bonds to the District, submission of operation and maintenance data (manuals), provision of specified extra materials to the District, and submission of other Contract closeout documents and materials as required and if not already submitted.
 - d. The Construction Manager, Architect and Architect's consultants, as appropriate, will conduct a walk-through of the facility with the Contractor and review the punch list.
 - e. Contractor shall correct the punch list and record additional items as may identified during the walk-through, including notations of corrective actions to be taken.
 - f. Retype the punch list and distribute it within three working days to those attending the meeting.
 - g. If additional site visits by the Construction Manager, the Architect and the Architect's and District's consultants are required to review completion and correction of the Work, the costs of additional visits shall be reimbursed to the District by the Contractor by deducting such costs from the Final Payment.
 - I. Correct items of work listed in Final Correction Punch List and comply with requirements for access to District-occupied areas.
 - J. Notify Architect when work is considered finally complete and ready for Architect's Final Inspection.
 1. Architect's Certification of Completion:

- a. When Architect determines that list of items to be completed and corrected (Punch List) is sufficiently complete for District to occupy Project for the use to which it is intended.
- K. Complete items of work determined by Architect listed in executed Certificate of Substantial Completion.

3.17 FINAL PAYMENT

- A. After completion of all items listed for completion and correction, after submission of all documents and products and after final cleaning, submit final Application for Payment, identifying total adjusted Contract Sum, previous payments and sum remaining due.
- B. Payment will not be made until the following are accomplished:
 - 1. All Project Record Documents have been transferred and accepted by District.
 - 2. All extra materials and maintenance stock have been transferred and received by District.
 - 3. All warranty documents and operation and maintenance data have been received and accepted by District.
 - 4. All liens have been released or bonded by Contractor.
 - 5. Contractor's surety has consented to Final Payment.
 - 6. All documentation required by DSA has been completed.

3.18 MAINTENANCE

- A. Provide service and maintenance of components indicated in specification sections.
- B. Maintenance Period: As indicated in specification sections or, if not indicated, not less than one year from the Date of Project Completion or the length of the specified warranty, whichever is longer.
- C. Examine system components at a frequency consistent with reliable operation. Clean, adjust, and lubricate as required.
- D. Include systematic examination, adjustment, and lubrication of components. Repair or replace parts whenever required. Use parts produced by the manufacturer of the original component.
- E. Maintenance service shall not be assigned or transferred to any agent or subcontractor without prior written consent of the District.

END OF SECTION

SECTION 01 71 23 FIELD ENGINEERING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Field engineering services by Contractor.
- B. Construction surveying by Contractor.
- C. Support and bracing.

1.02 DESCRIPTION OF SERVICES

- A. Specific services listed in this section are in addition to, and do not supersede, general Execution and Closeout Requirements.
- B. Sole responsibility for establishing all locations, dimensions and levels of items of work.
- C. Sole responsibility for provision of all materials required to establish and maintain benchmarks and control points, including batter boards, grade stakes, structure, and pipeline elevation stakes, and other items.
- D. Having a skilled instrument person(s) available on short notice when necessary for laying out the work.
- E. Provision of facilities and assistance necessary for Architect to check lines and grade points placed by Contractor.
 - 1. Performance of excavation or embankment work until after all cross-sectioning necessary for determining payment quantities for Unit Price work have been completed and accepted by Architect.
- F. Preparation and maintenance of daily reports of activity on the work. Submission of reports containing key progress indicators and job conditions to Architect.
 - 1. Number of employees at the Site.
 - 2. Number employees at the Site for each of Contractor's subcontractors.
 - 3. Breakdown of employees by trades.
 - 4. Major equipment and materials installed as part of the work.
 - 5. Major construction equipment utilized.
 - 6. Location of areas in which construction was performed.
 - 7. Materials and equipment received.
 - 8. Work performed, including field quality control measures and testing.
 - 9. Weather conditions.
 - 10. Safety.
 - 11. Delays encountered, amount of delay incurred, and the reasons for the delay.
 - 12. Instructions received from Architect or District, if any.

- G. Preparation and maintenance of professional-quality, accurate, well organized, legible notes of all measurements and calculations made while surveying and laying out the work.
- H. Prior to backfilling operations, surveying - locating, and recording on a copy of Contract Documents - an accurate representation of buried work and Underground Facilities encountered.
- I. Setting up and executing time-lapse photography of construction activities.

1.03 REFERENCE STANDARDS

- A. SMACNA (SRM) - Seismic Restraint Manual Guidelines for Mechanical Systems.
- B. State Plane Coordinate System for California.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Preinstallation Meeting: Conduct a preinstallation meeting one week prior to the start of the work of this section; require attendance by all affected installers.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Submit in addition to items required in Section 01 70 00 - Execution and Closeout Requirements.
- C. Informational Submittals: Submit the following:
 - 1. Field Engineering: Submit daily reports, with content as indicated in this section.
 - a. When requested by Architect, submit for Record documentation verifying accuracy of field engineering including, but not limited to, Contractor's survey notes and field notes.
 - 2. Final property survey.

1.06 QUALITY ASSURANCE

- A. Field Engineer's Qualifications: As established in Section 01 70 00 - Execution and Closeout Requirements.
- B. Use adequate number of skilled and thoroughly-trained workers to perform the work of this section in a timely and comprehensive manner.
- C. Minimum accuracy for required work is as follows:
 - 1. Grade: Horizontal Tolerance: Plus or minus 0.5 feet, Vertical Tolerance: Plus or minus 0.05 feet.
 - 2. Culverts and ditches: Horizontal Tolerance: Plus or minus 0.5 feet, Vertical Tolerance: Plus or minus 0.05 feet.
 - 3. Structures: Horizontal Tolerance: Plus or minus 0.5 feet (location), Vertical Tolerance: Plus or minus 0.05 feet.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify layout information shown on drawings in relation to property survey and existing benchmarks.
- B. Notify District's representative and Architect of discrepancies immediately in writing before proceeding to lay out work.
- C. Locate and protect existing benchmarks, base lines, and demarcations. Preserve permanent reference points during construction.
- D. Existing Utilities and Equipment: The existence and location of underground and other utilities and construction indicated as existing are not guaranteed. Before beginning sitework, investigate and verify existing conditions.

3.02 FIELD ENGINEERING

- A. Maintain field office files, drawings, specifications, and record documents.
- B. Coordinate field engineering services with Contractor's subcontractors, installers, and suppliers as appropriate.
- C. Prepare layout and coordination drawings for construction operations.
- D. Check and coordinate the work for conflicts and interferences, and immediately advise Architect and District of all discrepancies of which Contractor is aware.
- E. Cooperate as required with Architect and District in observing the work and performing field inspections.
- F. Review and coordinate work on a regular basis with shop drawings and Contractor's other submittals.
- G. In general, match existing adjacent grades and maintain existing flow lines.
- H. Check the location, line and grade of every major element as the work progresses. Notify the Architect when deviations from required lines or grades exceed allowable tolerances. Include in such notifications a thorough explanation of the problem, and a proposed plan and schedule for remedying the deviation. Do not proceed with remedial work without District's concurrence of the remediation plan.
- I. Check all formwork, reinforcing, inserts, structural steel, bolts, sleeves, piping, other materials and equipment for compliance with shop drawings and Contract Documents requirements.
- J. Check all bracing and shoring for structural integrity and compliance with designs prepared by the Contractor.

3.03 CONSTRUCTION SURVEYING

- A. General: Perform surveying as applicable to specific items necessary for proper execution of work.

FOR REFERENCE ONLY

1. Alignment Staking: Provide alignment stakes at 50 foot intervals on tangent, and at 25 foot intervals on curves.
 2. Slope Staking: Provide slope staking at 50 foot intervals on tangent, and at 25 foot intervals on curves. Re-stake at every ten-foot difference in elevation.
 3. Structure: Stake out structures, including elevations, and check prior to and during construction.
 4. Pipelines: Stake out pipelines including elevations, and check prior to and during construction.
 5. Site Utilities: Stake out utility lines including elevations, and check prior to and during construction.
 6. Cross-sections: Provide original, intermediate, and final staking as required, for site work and other locations as necessary for quantity surveys.
 7. Easement Staking: Provide easement staking at 50 foot intervals on tangent, and at 25 foot intervals on curves. If required by project conditions, provide wooden laths with flagging at 100 foot intervals.
 8. Record Staking: Provide permanent stake at each blind flange and each utility cap is provided for future connections. Use stakes for record staking of material(s) acceptable to Architect.
 9. Structural Frame: Upon completion, certify location and plumbness.
- B. Surveying to Determine Quantities for Payment.
1. For each application for progress payment, perform such surveys and computations necessary to determine quantities of work performed or placed. Perform surveys necessary for Architect to determine final quantities of work in place.
 2. Notify Architect at least 24 hours before performing survey services for determining quantities. Unless waived in writing by Architect, perform quantity surveys in presence of Architect.
- C. Record Log: Maintain a log of layout control work. Record any deviations from required lines and levels. Include beginning and ending dates and times of surveys, weather conditions, name and duty of each survey party member, and types of instruments and tapes used.
- D. Use by the Architect: The Architect may at any time use line and grade points and markers established by the Contractor. The Contractor's surveys are a part of the work and may be checked by the Architect at any time.
- E. Accuracy:
1. Establish Contractor's temporary survey references points for Contractor's use to at least second-order accuracy (e.g., 1:10000). Set construction staking used as a guide for the work to at least third-order accuracy (e.g., 1:5000). Provide the absolute margin for error specified below on the basis established by such orders.
 - a. Horizontal Accuracy of Easement Staking: Plus/minus 0.1 foot.
 - b. Accuracy of Other Staking: Plus/minus 0.04 foot horizontally and plus/minus 0.02 foot vertically.
 - c. Include an error analysis sufficient to demonstrate required accuracy in survey calculations.

2. District reserves the right to check the Contractor's survey, measurements, and calculations. The requirement for accuracy will not be waived, whether this right is exercised or not.

3.04 SUPPORT AND BRACING

- A. General requirements: Design all support and bracing systems, if required. Provide for attachment to portions of the building structure capable of bearing the loads imposed. Design systems to not overstress the building structure.
- B. Seismic Bracing: Design where required by authorities having jurisdiction.
 1. Design and install all support systems to comply with the seismic requirements of the Construction Code of California.
 2. Design and install seismic bracing so as not to defeat the operation on any required vibration isolation or sound isolation devices.
 3. For seismic bracing guidelines for mechanical, electrical and plumbing systems, refer to SMACNA (SRM).

3.05 REPORTS

- A. Submit two copies of Contractor's daily reports electronically to Architect and Construction Manager by 9:00 AM the next working day after the day covered in the associated report. Daily report shall be signed by responsible member of Contractor's staff, such as project manager or superintendent, or foreman designated by Contractor as having authority to sign daily reports.

3.06 RECORDS

- A. Maintain at the Site a complete and accurate log of control and survey work as it progresses.
 1. Organize and record survey data in accordance with recognized professional surveying standards, Laws and Regulations, and prevailing standards of practice in California. Record Contractor's surveyor's original field notes, computations, and other surveying data in Contractor-furnished hard-bound field books. Contractor is solely responsible for completeness and accuracy of survey work, and completeness and accuracy of survey records, including field books. Survey records,(including field books) may be rejected by District due to failure to organize and maintain survey records in a manner that allows reasonable and independent verification of calculations, and/or allows identification of elevations, dimensions, and grades of the work.
 2. Illegible notes or data, and erasures on any page of field books, are unacceptable. Do not submit copied notes or data. Corrections by ruling or lining out errors will be unacceptable unless initialed by the surveyor. Violation of these requirements may require re-surveying the data questioned by Architect.
- B. Submit three copies of final property survey to District. Include on the survey a certification, signed by the surveyor, that principal metes, bounds, lines, and levels of the Project are accurately positioned as shown on the survey. Include the following information:
 1. Structure locations from property lines, and distances to adjacent buildings.
 2. Dimensions and locations of drives, walks, walls, underground utilities, appurtenances, and major site features.

FOR REFERENCE ONLY

3. Location of easements.
4. Final grading topographic survey.

3.07 CLOSEOUT ACTIVITIES

- A. See Section 01 78 00 - Closeout Submittals, for closeout submittals.
- B. See Section 01 79 00 - Demonstration and Training, for additional requirements.

END OF SECTION

SECTION 01 73 56 ALTERATION AND MODERNIZATION EXECUTION PROCEDURES

PART 1 - GENERAL

1.01 SUMMARY

- A. Alteration and Modernization work consisting of necessary demolition, dismantling, cutting, removal and repair of designated existing work and installation of new work as indicated herein and specified in applicable technical sections of the Project Manual.

1.02 ALTERATIONS

- A. Regulatory Requirements:
 - 1. Demolition work shall conform to:
 - a. California Fire Code, Chapter 14, "Fire Safety During Construction and Demolition."
 - b. California Building Code Chapter 33 - "Safeguards During Construction" and Chapter 34 - "Existing Structures."
- B. Verification of Existing Conditions:
 - 1. Drawings show the existing conditions, as they are believed to exist. Examine the existing conditions prior to alterations to existing buildings as indicated.
 - 2. Verify, at the site, conditions affecting the work.
 - a. Obtain accurate field dimensions of related areas, spaces, openings, levels, and items of adjacent work.
 - b. Before commencing work, report to Architect in writing, discrepancies between drawings and specifications and actual field conditions.
 - c. Commencement of work constitutes acceptance of all adjacent conditions affecting work of the section involved.
 - 3. Information provided represents to the best of the District's knowledge, conditions and materials to be found in this project.
 - a. The District assumes no responsibility whatsoever in respect to the sufficiency or accuracy of the Drawings or interpretation thereof.
 - b. There is no warranty or guarantee, either expressed or implied, that conditions and locations indicated are representative of those existing throughout the existing structures or that unforeseen developments may not occur.
- C. Continued Occupancy: Comply with Section 01 10 00 - Summary.
 - 1. District will continuously occupy buildings adjacent to areas of demolition operations. Conduct demolition operations in a manner that will minimize need for disruption of District's normal operations.
 - 2. Provide minimum 3 working days advance notice to District of demolition activities which might severely impact District's operations.

FOR REFERENCE ONLY

- D. Protection of Property, Public, Occupants (when applicable) and Workmen: Comply with 02 41 00 - Demolition.
1. Portions of existing structures where existing work is to be demolished or removed, and where new work is to be done, connections made, materials handled or equipment moved and related, shall be temporarily protected prior to start of demolition.
 2. Temporary protection shall be such that interior of existing structures will at all time be protected from dust fumes, smoke and weather inclemency. Comply with 01 50 00 - Temporary Facilities and Controls.
 3. Protect temporary openings in exterior walls by temporary weatherproof plywood closures. Comply with 01 50 00 - Temporary Facilities and Controls.
 4. Contractor will be held responsible for damage to existing structures and contents by reason of insufficiency of such protection. Comply with 01 40 00 - Quality Requirements
 5. Provide barricades, and maintenance and supervision thereof, in accordance with applicable Federal, State and local codes and their respective requirements, or as may be directed from time to time. Comply with 01 50 00 - Temporary Facilities and Controls.
- E. Transitions to Existing Work: Comply with 01 70 00 - Execution and Closeout Requirements.
1. Where alterations occur or new and old work are joined, immediately adjacent surfaces that are involved shall be cut, removed, patched, repaired or refinished, and left in as good condition as existed before commencing work.
 - a. Materials and workmanship employed in alterations involving new construction, unless otherwise indicated or specified, shall conform to no less than that of original work.
 2. Where remaining existing materials interfere with installation of new work, remove existing materials. After installation of new work is complete, or in conjunction with installation of new work as applicable, reinstall existing materials, patch and refinish, or provide new to match existing.
- F. Relocation of Existing Materials and Equipment: Comply with 01 70 00 - Execution and Closeout Requirements.
1. Relocate certain materials and equipment only as indicated or specified. Refinish certain existing surfaces as specified in applicable technical sections.
 2. Repair and refinish relocated materials and equipment as necessary to leave finished work in good condition.
- G. Salvage: Comply with 01 70 00 - Execution and Closeout Requirements and 02 41 00 - Demolition.
1. Salvaged materials occurring from work demolished or removed become property of Contractor unless otherwise noted in the Project Manual or Drawings to remain property of District, and shall be removed from project site.
 2. Exceptions:
 - a. Existing materials or equipment may be removed by District at any time prior to start of work.

FOR REFERENCE ONLY

- b. Do not reuse in this project, materials and items removed from existing site or buildings, except with specific written approval by the Architect in each case, unless such removed material or item is specifically indicated or specified to be reused.
- c. Remove materials and equipment indicated to be salvaged for reinstallation and store to prevent damage, and reinstall as the work progresses.
 - 1) Do not reuse in this project, other materials and equipment removed from existing site or building, except with specific written approval by the Architect in each case.
- d. Dismantled materials and items indicated to be reused must be in good condition without objectionable cracks, chips, splits, checks, dents, scratches, or other defects.
 - 1) Operating items shall operate properly.
 - 2) Notify Architect immediately of items found to be to the contrary.
- e. Historic artifacts, including cornerstones and their contents, commemorative plaques and tablets and similar items remain the property of the District.
 - 1) Notify District if such items are encountered and obtain acceptance regarding method of removal and salvage.
- H. Submittals: Demolition Plan per 02 41 00 - Demolition.
 - 1. Before commencing alteration, removal and demolition work, prepare and submit for review by District, a schedule showing commencement, order and completion dates of various parts of work, including utilities disruptions and proposal to ensure uninterrupted progress of District's on-site operations.
- I. Utilities: Comply with 02 41 00 - Demolition.
 - 1. Before starting work relating to existing utilities (electrical, sewer, water, heat, gas, fire lines, etc.), that will temporarily discontinue or disrupt service to existing buildings, provide two (2) working days notice to utility company, Architect and District, and obtain their approval in writing before proceed with this phase of Work.
 - 2. Disconnect, remove, and cap designated utility services, or those utility services required to be altered, within demolition areas.
 - 3. Mark locations of disconnected utilities. Identify and indicate capping locations on project record drawings.

PART 2 - PRODUCTS

2.01 PRODUCTS FOR NEW WORK

- A. Comply with 01 60 00 - Product Requirements
- B. Products for New Work: Products specified in Part 2 - PRODUCTS of applicable technical sections of the Project Manual, shall be utilized for patching and extending Work.
- C. Type and Quality of Existing Products: Determine by inspection and testing Products where necessary, referring to existing construction as a standard.

PART 3 - EXECUTION

3.01 DEMOLITION

- A. Comply with 02 41 00 - Demolition.
- B. Conduct demolition to minimize interference with building or exterior areas to remain used or occupied, and surrounding landscaped areas.
 - 1. Maintain protected egress and access at all times.
- C. Demolish in an orderly and careful manner.
 - 1. Protect existing and remaining foundations and structural members.
 - 2. Perform cutting, drilling and removal of existing work with extreme care, with small tools in order not to jeopardize structural integrity of building or its parts. See also Section 01 70 00 - Execution and Closeout Requirements

3.02 MODERNIZATION

- A. The following is an expansion of some of the main reconstruction notes and specifications used on this project, and apply where and whenever described work is required.
- B. Concrete Floor or Slab:
 - 1. Repair existing concrete floor.
 - a. Fill cracks and voids with epoxy mortar per 03 01 00 - Maintenance of Concrete, 03 30 00 - Cast-in-Place Concrete, and 03 35 11 - Concrete Floor Finishes.
 - b. Paint per 09 91 23 - Interior Painting, at existing painted floors and where scheduled to receive paint.
 - 2. Replacement of concrete slabs:
 - a. Use normal methods that will not crack or structurally disturb adjacent walls, partitions or slabs. Use power saws where possible.
- C. Concrete and Masonry: Comply with 01 70 00 - Execution and Closeout Requirements
 - 1. Demolish concrete and masonry in small sections.
 - a. Cut concrete and masonry at junctures with construction to remain using power-driven masonry saw or hand tools; do not use power-driven impact tools.
 - b. Saw concrete along straight lines to a depth of not less than 1-1/2 inches.
 - c. Make each cut in walls perpendicular to the face and in alignment with the cut in the opposite face.
 - d. Break out the remainder of the concrete or masonry provided that the broken area is concealed in the finished work, and the remaining concrete or masonry is sound.
 - e. At locations where the broken face cannot be concealed, grind smooth or saw cut entirely through the concrete or masonry.
 - 2. Remove anchorages to at least 1/2-inch below the surface of concrete or masonry and patch depressions to provide a flush surface. Comply with 03 01 00 - Maintenance of Concrete.

FOR REFERENCE ONLY

- a. Where surface will be concealed in the finished work, anchors may be cut flush with the surface.
- D. Cabinets, Countertops and Casework: Comply with 06 20 00 - Finish Carpentry and 06 41 00 - Architectural Wood Casework.
 1. Provide new plastic laminated top (over existing cabinet), where indicated:
 - a. Remove existing countertop and splash.
 - b. Provide new plastic laminate countertop and splash per Section 06 41 00 - Architectural Wood Casework, and attach to existing cabinet conforming to the requirements of Architectural Woodwork Standards, second edition.
 - c. Provide clearances for accessibility compliance where indicated.
 - 1) If it results in a lower cost or no additional cost for the District; With District approval, remove cabinet and provide new to match existing.
 2. Refinish, prep, and repaint existing cabinets and shelves:
 - a. Prepare cabinet surfaces for painting per 09 91 23 - Interior Painting.
 - b. Fill and sand smooth holes, scratches and voids.
 - c. Paint interior and exterior surfaces of cabinets exposed and not exposed, except backs and covered ends, per Section 09 91 23 - Interior Painting.
 - 1) If existing cabinets are color painted (one or more colors), new painting shall be done in one single color, as selected by District.
 - 2) If existing cabinets have natural finish, new re-finishing shall be also natural finish.
 - d. Where accessibility compliance is required, modify existing cabinets accordingly.
 - 1) If it results in a lower cost or no additional cost for the District; With District approval, remove cabinet and provide new to match existing.
 - e. Replace missing or damaged beyond repair existing cabinet hardware with new hardware to match existing. Verify all existing hardware is functioning properly.
 3. New cabinets with or without sinks:
 - a. Provide new cabinets per Section 06 41 00 - Architectural Wood Casework.
 - b. Provide sink (where indicated) in cabinet with all rough and finish plumbing as scheduled on Drawings and as required in Division 22.
 - c. Provide clearances for accessibility compliance where indicated.
 4. New shelves:
 - a. Provide new shelves per Drawings and Section 06 41 00 - Architectural Wood Casework.
 - b. Prepare and paint shelves per Section 09 91 23 - Interior Painting.
- E. Roof: Comply with 07 01 50.19 - Preparation for Re-Roofing and 07 01 50.20 - Roofing, Restoration, Patch, and Repair.
 1. Remove existing roofing to roof sheathing .

FOR REFERENCE ONLY

- a. Patch roof sheathing and parapet walls, fill voids at removal items with matching construction.
 - b. Re-roof and re-flash buildings and connecting covered walkways.
 2. Patch and repair existing roof where indicated on Drawings.
- F. Walls and Partitions:
1. Interior Partitions:
 - a. Remove partitions including finish, studs, plates and sills.
 - b. Where only a partial run is removed, cut back the finish material to the centerline of the next adjacent support to remain.
 - c. Leave remaining material with a clean terminal line with no loose adhering material. Where partitions have been installed on curbs, remove curbs and patch existing floor to receive new finish.
 2. Clean, patch and paint exposed walls, trims, columns, window frames, doors and door frames:
 - a. Painting shall include all surfaces and materials between the floor and the finish ceiling.
 - 1) Exceptions:
 - (a) Window glazing
 - (b) Anodized or other new pre-finished metal
 - (c) Vinyl wall covering
 - (d) Mechanical and electrical equipment
 - (e) Cabinets of stained finish and plastic laminate.
 - b. Prepare and patch existing gypsum wall board per Section 09 21 16 - Gypsum Board Assemblies.
 3. Gypsum board:
 - a. Cut back gypsum board to the centerline of the next adjacent support to remain. Leave remaining material with a clean terminal line with no loose adhering material.
 4. Prepare and patch existing plaster (where present) per 09 24 00 - Portland Cement Plastering.
 - a. Smooth/patch existing plaster walls:
 - 1) Cut existing plaster back to sound plaster on straight lines. Repair existing underlayment and metal lath for proper overlapping in shingle fashion to receive new plaster.
 - (a) See Drawings for additional details.
 - 2) Patch existing plaster with same type of plaster (gypsum or cement) where reconstruction work occurs.
 - 3) Plaster patching shall meet flush and match surrounding existing plaster texture.
 5. New tile backer cement board and new ceramic tile wainscot:
 - a. Conform to 09 21 16 - Gypsum Board Assemblies for installation of tile backer board.

FOR REFERENCE ONLY

- b. Conform to 09 30 00 - Tiling for installation of new ceramic tile.
6. Paint per 09 91 13 - Exterior Painting and 09 91 23 - Interior Painting.
- G. Openings:
 1. Doors: Comply with 08 11 13 - Hollow Metal Doors and Frames, 08 14 16 - Flush Wood Doors, 08 71 00 - Door Hardware, 09 91 13 - Exterior Painting, 09 91 23 - Interior Painting, and 09 96 00 - High-Performance Coatings
 - a. Re-Use of Existing Doors:
 - 1) Existing doors indicated to re-used, provide new hardware per District Standards.
 - 2) Remove door from frame, label door with the door number as indicated in the Drawings at the bottom sill edge of the door panel.
 - 3) Where doors are indicated to be re-used in the new work, leave hardware attached to the door.
 - (a) Where this is not practical, place items of hardware in a labeled cloth bag attached to the door. Protect for re-installation.
 - 4) Stack removed doors in a method to protect from damage.
 - 5) When ready for re-installation see paragraph below for refinish of existing doors.
 - b. New door frame, door and hardware:
 - 1) Remove existing door, frame, wall section and other existing construction in order to install new door and frame.
 - 2) Construct new filler wall where required.
 - (a) Interior and exterior wall finishes to meet flush and match existing adjacent wall materials in type, texture and color.
 - (b) Frame new filler wall using materials to match existing, unless indicated otherwise.
 - (c) Provide secure, rigid head and jamb framing members to receive new door frames.
 - 3) Provide new frames per Specifications and Drawings.
 - 4) Provide new doors per Specifications and Drawings.
 - (a) Match door finish (paint or natural/stained) with existing doors to remain in the building/room.
 - 5) Prepare and paint or natural / stained finish doors and frames per Section 09 91 13 - Exterior Painting, 09 91 23 - Interior Painting, and 09 96 00 - High-Performance Coatings.
 - 6) Provide new door hardware as indicated on Drawings and 08 71 00 - Door Hardware.
 - 7) Relocate light switch where door opening is enlarged to fit new door.
 - c. New doors to replace existing (including new hardware):
 - 1) Remove existing door and hardware.

FOR REFERENCE ONLY

- 2) Field verify existing clear opening dimension.
 - 3) Patch, fill and sand smooth holes in wood frames where old hardware has been removed. Position new hardware such as to avoid old locations and holes.
 - 4) At existing metal frames to remain, use new hinges to match hole mounting.
 - 5) Provide new door to fit in existing openings.
 - 6) Provide new door hardware per 08 71 00 - Door Hardware.
 - 7) Prepare and paint or natural / stained finish new doors and frames.
- d. Refinish existing doors:
- 1) If existing wood door is natural/stained:
 - (a) Remove hardware.
 - (b) Strip existing finish entirely from all exposed surfaces and prepare for new clear or stained wood finish per 08 14 16 - Flush Wood Doors.
 - (c) Repair damaged portions of door.
 - (1) Fill and sand smooth all holes, voids and repairs.
 - (2) Fill Material: Match exposed existing wood color when finished.
 - (d) Finish existing, stripped and prepared door.
 - (e) Replace/reinstall hardware.
 - 2) If existing wood door is painted:
 - (a) Remove hardware.
 - (b) Prepare all door surfaces for painting.
 - (c) Repair damaged portion of door.
 - (1) Fill and sand smooth all holes, voids and repairs.
 - (d) Paint existing, prepared door.
 - (e) Replace/reinstall hardware.
- H. Glazing: 08 11 13 - Hollow Metal Doors and Frames, 08 80 00 - Glazing, 09 91 13 - Exterior Painting, and 09 91 23 - Interior Painting
1. Replace existing glass panes with new glass:
 - a. Remove existing glass or acrylic glazing where indicated and provide new glass as specified.
 - b. Prepare and paint window frames as specified for the specific type of window frame.
 2. Refurbish existing windows:
 - a. Steel windows:
 - 1) Scrape, and wire brush clean, steel frames and sash.
 - (a) Remove rust, scale, dirt, grease and paint in preparation for new paint.
 - 2) Repair damaged or broken frames or sash.
 - (a) Weld and grind smooth or replace broken steel members.
 - 3) Tighten and otherwise secure loose bolts, screws or other connectors.
 - (a) Steel sash shall move freely and easily in steel frames when work is complete.

FOR REFERENCE ONLY

- 4) Clean, repair and lubricate window hardware.
 - (a) Replace damaged components which cannot be repaired.
 - (b) Window hardware shall be in good working order when work is complete.
 - 5) Paint steel window components.
 - 6) Clean existing glazing following manufacturers' instructions for specific type of glazing.
- b. Wood Windows and Frames: Comply with 06 20 00 - Finish Carpentry, 09 91 13 - Exterior Painting, and 09 91 23 - Interior Painting.
- 1) Prepare wood window frames and sash for painting or stain.
 - 2) Repair or replace damaged or broken portion of frame or sash.
 - (a) Fill and sand smooth all holes, voids and repairs.
 - 3) Paint existing prepared wood frames and sash.
 - 4) Clean, repair and lubricate window hardware.
 - (a) Replace damaged components which cannot be repaired.
 - (b) Window hardware shall be in good working order when work is complete.
 - 5) Clean existing glazing following manufacturers' instruction for the specific type of glazing.
- I. Finishes:
1. Ceramic tile: Comply with 09 30 00 - Tiling.
 - a. New Ceramic Tile:
 - 1) Remove tile back to next full unit beyond the removal line.
 - 2) Saw cut setting bed at line to remain.
 - 3) Remove individual damaged tile and backing mortar as required to provide for installation of new tile within the specified tolerances.
 - b. Remove existing finish floor to receive new ceramic tile floor.
 - c. Provide new slip resistant ceramic tile floor and base .
 - d. Steam clean all existing ceramic tile surfaces, where indicated to remain:
 - 1) Clean and seal existing ceramic tile.
 2. New suspended ceiling systems: Comply with 09 51 00 - Acoustical Ceilings.
 - a. Remove existing ceiling materials where interfacing with the installation of new ceiling. Remove back to next full unit beyond removal line.
 - b. Remove individual panels where required for new light fixtures.
 - c. Store and protect units suitable for re-installation where indicated.
 - d. Install new ceiling.
 3. New Resilient Flooring and Rubber Base: Comply with 09 65 00 - Resilient Flooring.
 - a. Prepare floor in compliance with 09 05 61 - Common Work Results for Flooring Preparation.
 - b. Install new resilient tile flooring over existing concrete floor.

FOR REFERENCE ONLY

- 1) Remove existing carpet or resilient floor finish, including adhesives.
- c. Remove existing wood, rubber or vinyl base and mastic, patch and repair wall prior to installation of new base.
 - 1) Remove existing plaster grounds behind removed base and provide in-fill plaster finish; flush and smooth to receive new base.
- d. Patching exposed above new base shall be finished to match surrounding wall.
- e. Provide new topset base to match or existing as applicable.
4. New carpet and base: Comply with 09 68 16 - Sheet Carpeting, 09 68 13 - Tile Carpeting, and 09 65 00 - Resilient Flooring
 - a. Remove existing carpet, carpet mastic, edging strips and accessories, and thoroughly clean existing substrate.
 - b. Existing vinyl flooring is to remain beneath carpet to remain, unless noted otherwise.
 - c. Patch existing substrate (vinyl tile, concrete, etc.).
 - d. Provide new carpet and base.
5. New fabric covered tack paneling: Comply with 10 11 00 - Visual Display Units, 10 11 23.13 - Fixed Tackboards, and 10 11 24 - Tackable Wall Systems.
 - a. Remove from wall existing conflicting surface treatment: trim, shelving, boards, electrical / mechanical devices etc.
 - b. Patch wall prior to installation of new tack paneling.
 - c. Provide new tack paneling.
 - d. Adjust existing recessed outlets and switches to be flush with tack panel.
6. Patch, clean and paint existing ceiling: Comply with 09 21 16 - Gypsum Board Assemblies, 09 24 00 - Portland Cement Plastering, and 09 91 23 - Interior Painting
 - a. Patch, clean and paint existing plaster ceiling or soffit.
 - b. Patch, clean and paint existing gypsum board ceiling or soffit
 - c. At existing acoustic tile ceilings, replace only damaged tiles when indicated, clean and paint entire ceiling.
 - d. Paint.
- J. Accessories and Components:
 1. New markerboards and tackboards: Comply with 10 11 00 - Visual Display Units.
 - a. Remove from wall existing conflicting surface treatment: Trim, shelving, boards, etc. Patch wall prior to installation of new boards.
 - b. Provide new markerboards and tackboards.
 2. New toilet compartments: Comply with 10 21 13.19 - Plastic Toilet Compartments.
 - a. Remove existing toilet compartments.
 - 1) Patch walls, floor and ceiling as required elsewhere in these notes.
 - b. Provide solid blocking or backing plates in existing walls.
 - c. Provide new toilet compartments

3. New signage: Comply with 10 14 00 - Signage and 101453 - Traffic, Parking and Site Signage.
 - a. Provide interior and exterior signage as indicated on Drawings.
4. New toilet accessories: Comply with 10 28 00 - Toilet Accessories.
 - a. Remove existing toilet accessories.
 - b. Provide backing plates or blocking in existing walls as indicated and/or specified, and patch walls.
 - c. Provide new toilet accessories as scheduled on Drawings and as specified in 10 28 00 - Toilet Accessories.
5. New fire extinguisher cabinets: Comply with 10 44 00 - Fire Protection Specialties.
 - a. Remove existing fire extinguisher cabinets as indicated and patch walls flush, in preparation for new semi-recessed cabinets complete with fire extinguisher.

3.03 EXAMINATION

- A. Verify that demolition is complete, and areas are ready for execution of Work.
- B. Beginning of restoration Work will be interpreted to mean acceptance of existing conditions.

3.04 PREPARATION

- A. Cut, move or remove items as necessary for access for alterations, renovation and extension Work. Replace and restore at completion.
- B. Remove unsuitable material not marked for salvage, such as rotted wood, corroded metals, and deteriorated masonry and concrete. Replace materials as specified for finished Work.
- C. Remove debris and abandoned items from area from concealed spaces.
- D. Prepare surface and remove surface finishes to provide for proper installation of new work and finishes.
- E. Close openings in exterior surfaces to protect existing work, and salvage items where applicable, from weather and extremes of temperature and humidity. Insulate ductwork and piping to prevent condensation in exposed areas.

3.05 INSTALLATION

- A. Coordinate Work for alterations and renovations to expedite completion sequentially and to accommodate District occupancy.
- B. Designated areas: Complete in all respects including operational mechanical and electrical work.
- C. Remove, cut, and patch Work in a manner to minimize damage and to provide a means of restoring products and finishes to original or specified condition, including finish paint on exterior. Refer to Section 01 70 00 - Execution and Closeout Requirements.
- D. Refinish visible existing surfaces to remain in renovated rooms and spaces, to specified condition for each material, with a neat transition to adjacent finishes.
- E. In addition to specified replacement of equipment and fixtures, restore existing and remaining plumbing, heating, ventilation, air conditioning, and electrical systems to full operational conditions.

- F. Install Products as specified in applicable Sections.

3.06 TRANSITIONS

- A. Where Work abuts or aligns with existing construction, perform a smooth and even transition. Patches shall match existing adjacent construction in texture and appearance.
- B. When finished surfaces are cut so that a smooth transition is not possible, terminate existing surface along a straight line at a natural line of division. Refer to Section 01 70 00 - Execution and Closeout Requirements.
- C. Where a waterproofing system is interrupted, leave sufficient material to allow for overlapping of new material over or behind existing maintaining a watertight installation.

3.07 ADJUSTMENTS

- A. Where removal of partitions or walls results in adjacent spaces becoming one, rework floors, walls, and ceilings to a smooth plane without breaks, steps, or bulkheads.
- B. Where a change of plane of 1/4 inch or more occurs, submit recommendation for providing a smooth transition for Architect's review.
- C. Trim existing doors as necessary to clear new floor finish. Refinish trim as required.
- D. Fit work at penetrations of surfaces as specified in Section 01 70 00 - Execution and Closeout Requirements.

3.08 REPAIR OF DAMAGED SURFACES

- A. Patch or replace portions of existing surfaces which are damaged, lifted, discolored, or showing other imperfections.
- B. Repair substrate prior to patching finish.

3.09 FINISHES

- A. Finish surfaces as specified in applicable Sections.
- B. Finish patches to produce uniform finish and texture over entire area.
 - 1. When finish cannot be matched, refinish entire surface to nearest intersections.

3.10 CLEANING

- A. In addition to cleaning specified in section 01 70 00 - Execution and Closeout Requirements, clean District-occupied areas of existing construction affected by construction activities.
- B. Do not burn or bury materials on site.

3.11 DEMOLITION RESTRICTIONS

- A. Noise Abatement:
 - 1. Limit noise to a reasonable level as related to specific items of equipment used and their hours of use.
 - 2. This does not preclude use of mechanical equipment, i.e. jack hammers, power-driven fasteners.
- B. Do not operate air compressors inside of existing buildings.

- C. Drilling or cutting of columns, beams, joists, girders, or other structural support elements not permitted, unless specifically approved by Architect.

3.12 DISPOSAL OF DEMOLISHED MATERIALS

- A. Do not burn or bury materials on site.
- B. Immediately remove demolished materials from site or stockpile where directed if designated for re-use.
- C. Remove and promptly dispose of contaminated, vermin infested, or dangerous materials encountered.
- D. If hazardous materials are encountered during demolition operations, comply with applicable regulations, laws, and ordinances concerning removal, handling and protection against exposure or environmental pollution.

END OF SECTION

SECTION 01 74 19 CONSTRUCTION WASTE MANAGEMENT AND DISPOSAL

PART 1 GENERAL

1.01 WASTE MANAGEMENT REQUIREMENTS

- A. Comply with the requirements Section 5.408 of the California Green Building Standards Code.
 - 1. Recycle and/or salvage for reuse a minimum of 65 percent of the nonhazardous construction and demolition waste in accordance with Section 504.8.1.1, 5.408.1.2, or 5.408.1.3; or meet a local construction and demolition waste management ordinance, whichever is more stringent.
- B. District requires that this project generate the least amount of trash and waste possible.
- C. Employ processes that ensure the generation of as little waste as possible due to error, poor planning, breakage, mishandling, contamination, or other factors.
- D. Minimize trash/waste disposal in landfills; reuse, salvage, or recycle as much waste as economically feasible.
- E. Required Recycling, Salvage, and Reuse: The following may not be disposed of in landfills or by incineration:
 - 1. Aluminum and plastic beverage containers.
 - 2. Corrugated cardboard.
 - 3. Wood pallets.
 - 4. Clean dimensional wood.
 - 5. Land clearing debris, including brush, branches, logs, and stumps; see Section 31 10 00 - Site Clearing for use options.
 - 6. Concrete: May be crushed and used as riprap, aggregate, sub-base material, or fill.
 - 7. Bricks: May be used on project if whole, or crushed and used as landscape cover, sub-base material, or fill.
 - 8. Concrete masonry units: May be used on project if whole, or crushed and used as sub-base material or fill.
 - 9. Asphalt paving: May be recycled into paving for project.
 - 10. Metals, including packaging banding, metal studs, sheet metal, structural steel, piping, reinforcing bars, door frames, and other items made of steel, iron, galvanized steel, stainless steel, aluminum, copper, zinc, lead, brass, and bronze.
 - 11. Glass.
 - 12. Gypsum drywall and plaster.
 - 13. Carpet, carpet cushion, carpet tile, and carpet remnants, both new and removed: DuPont (<http://flooring.dupont.com>) and Interface (www.interfaceinc.com) conduct reclamation programs.
 - 14. Roofing.

FOR REFERENCE ONLY

15. Paint.
16. Plastic sheeting.
17. Rigid foam insulation.
18. Windows, doors, and door hardware.
19. Plumbing fixtures.
20. Mechanical and electrical equipment.
21. Fluorescent lamps (light bulbs).
22. Acoustical ceiling tile and panels.
23. Materials which could be hazardous and subject to special disposal regulations include but are not limited to the following: CalGreen Section 5.408.2
 - a. Lead-Based Paint
 - b. Asbestos: Found in older pipe insulation, asphalt floor tiles, linoleum, insulation, etc.
 - c. Polychlorinated Biphenyls (PCBs):
 - 1) Found in electrical oil filled equipment manufactured prior to 1978 such as transformers, switches and fluorescent lamp ballasts.
 - 2) Also found in adhesive, sealant, caulk, glazing putty, roofing material, pesticide vehicle, ink, paper, fabric dye, gaskets, and hydraulic fluid.
 - d. HVAC Refrigerants: Containing Fluorinated and Chlorinated compounds.
 - e. Drinking Fountain Refrigerants: Containing Fluorinated and Chlorinated compounds.
 - f. Fluorescent Light Tubes: Contain mercury.
 - g. EXIT signs and Smoke Detectors: May contain unregulated, radioactive tritium. · Required to be returned to manufacturer.
 - h. Contaminated Soils.
 - i. Pressure Treated Lumber.
- F. Contractor shall submit periodic Waste Disposal Reports; all landfill disposal, recycling, salvage, and reuse must be reported regardless of to whom the cost or savings accrues; use the same units of measure on all reports.
 1. Contractor's quantitative reports for construction waste materials as a condition of approval of progress payments.
- G. Contractor shall develop and follow a Waste Management Plan designed to implement these requirements. CalGreen Section 5.408.1.1.
 - 1.
- H. The following sources may be useful in developing the Waste Management Plan:
 1. California Recycling Department, at www.dgs.ca.gov/BSC/CALGreen.
 2. General information contacts regarding construction and demolition waste:
 - a. Directory of Wood-Framed Building Deconstruction and Reused Building Materials Companies: www.fpl.fs.fed.us/documnts/fplgtr/fpl_gtr150.pdf.
 - b. Additional resources to be developed by Contractor with assistance from District and **Contractor, as requested.**

3. Recycling Haulers and Markets: The source list below contains local haulers and markets for recyclable materials. This list is provided for information only and is not necessarily comprehensive; other haulers and markets are acceptable.
 - a. CAL-MAX: www.calrecycle.ca.gov/calmax/.
 - 1) A free service designed to help businesses find markets for non-hazardous materials they have traditionally discarded.
 - b. General Recycling/Reuse Centers: For information on qualified local solid waste haulers contact the California Department of Resources Recycling and Recovery - CalRecycle. The website lists wastes recycling facilities in counties throughout the State of California.
 - 1) www.calrecycle.ca.gov.
4. Recycling Economics Information: The above lists contain information that may be useful in estimating the costs or savings or recycling options.
- I. Methods of trash/waste disposal that are not acceptable are:
 1. Burning on the project site.
 2. Burying on the project site.
 3. Dumping or burying on other property, public or private.
 4. Other illegal dumping or burying.
 5. Incineration, either on- or off-site.
- J. Regulatory Requirements: Contractor is responsible for knowing and complying with regulatory requirements, including but not limited to Federal, state and local requirements, pertaining to legal disposal of all construction and demolition waste materials.

1.02 RELATED REQUIREMENTS

- A. Section 01 10 00 - Summary: List of items to be salvaged from the existing building for relocation in project or for District.
- B. Section 01 30 00 - Administrative Requirements: Additional requirements for project meetings, reports, submittal procedures, and project documentation.
- C. Section 01 50 00 - Temporary Facilities and Controls: Additional requirements related to trash/waste collection and removal facilities and services.
- D. Section 01 60 00 - Product Requirements: Waste prevention requirements related to delivery, storage, and handling.
- E. Section 01 70 00 - Execution and Closeout Requirements: Trash/waste prevention procedures related to demolition, cutting and patching, installation, protection, and cleaning.
- F. Section 31 10 00 - Site Clearing: Handling and disposal of land clearing debris.

1.03 DEFINITIONS

- A. Clean: Untreated and unpainted; not contaminated with oils, solvents, caulk, or the like.
- B. Construction and Demolition Waste: Solid wastes typically including building materials, packaging, trash, debris, and rubble resulting from construction, remodeling, repair and demolition operations.

FOR REFERENCE ONLY

1. Debris that is not hazardous as defined in CalGreen Section 5.408.2 and California Code of Regulations, Title 22, Section 66261.3 et seq.
 2. This term includes, but is not limited to, asphalt concrete, Portland cement concrete, brick, lumber, gypsum wallboard, cardboard and other associated packaging, roofing material, ceramic tile, carpeting, plastic pipe, and steel.
 3. The debris may be commingled with rock, soil, tree stumps, and other vegetative matter resulting from land clearing and landscaping for construction or land development projects.
- C. Disposal: Removal off-site of demolition and construction waste and subsequent sale, recycling, reuse, or deposit in landfill or incinerator acceptable to authorities having jurisdiction.
- D. Diversion: Avoidance of demolition and construction waste sent to landfill or incineration. Diversion does not include using materials for landfill, alternate daily cover on landfills, or materials used as fuel in waste-to-energy processes.
- E. Enforcement Agency (EA). Enforcement agency as defined in CA Public Resources Code 40130.
- F. Hazardous: Exhibiting the characteristics of hazardous substances, i.e., ignitibility, corrosivity, toxicity or reactivity.
- G. Landfill, Inert waste or Inert Disposal Facility:
1. A disposal facility that accepts only inert waste such as soil and rock, fully cured asphalt paving, uncontaminated concrete (including fiberglass or steel reinforcing rods embedded in the concrete), brick, glass, and ceramics, for land disposal.
- H. Landfill, Class III:
1. A landfill that accepts non-hazardous resources such as household, commercial, and industrial waste, resulting from construction, remodeling, repair, and demolition operations.
 2. A Class III landfill must have a solid waste facilities permit from the California Integrated Waste Management Board (CIWMB) and is regulated by the Enforcement Agency (EA).
- I. Mixed Debris: Loads that include commingled recyclable and non-recyclable materials generated at the construction site.
- J. Mixed Debris Recycling Facility: A processing facility that accepts loads of commingled construction and demolition debris for the purpose of recovering re-usable and recyclable materials and disposing the non-recyclable residual materials.
- K. Nonhazardous: Exhibiting none of the characteristics of hazardous substances, i.e., ignitibility, corrosivity, toxicity, or reactivity.
- L. Nontoxic: Neither immediately poisonous to humans nor poisonous after a long period of exposure.
- M. Recyclable: The ability of a product or material to be recovered at the end of its life cycle and remanufactured into a new product for reuse by others.
- N. Recycle: To remove a waste material from the project site to another site for remanufacture into a new product for reuse by others.

FOR REFERENCE ONLY

- O. Recycling: The process of sorting, cleansing, treating and reconstituting solid waste and other discarded materials for the purpose of using the altered form. Recycling does not include burning, incinerating, or thermally destroying waste.
- P. Recycling Center: A facility that receives only C&D material that has been separated for reuse prior to receipt, in which the residual (disposed) amount of waste in the material is less than 10% of the amount separated for reuse by weight.
- Q. Return: To give back reusable items or unused products to vendors for credit.
- R. Reuse: To reuse a construction waste material in some manner on the project site.
- S. Salvage: To remove a waste material from the project site to another site for resale or reuse by others.
- T. Sediment: Soil and other debris that has been eroded and transported by storm or well production run-off water.
- U. Separated for Reuse:
 - 1. Materials, including commingled recyclables.
 - 2. Separated or kept separate from the solid waste stream for the purpose of:
 - a. Additional sorting or processing those materials for reuse or recycling.
 - 1) In order to return them to the economic mainstream in the form of raw material for new, reused, or reconstituted products.
 - b. Products shall meet the quality standards necessary to be used in the marketplace.
 - c. Includes materials that have been "source separated".
- V. Solid Waste:
 - 1. All putrescible and nonputrescible solid, semisolid, and liquid wastes, including:
 - a. Garbage, trash, refuse, paper, rubbish, ashes, industrial wastes, demolition and construction wastes.
 - b. Abandoned vehicles and parts thereof.
 - c. Discarded home and industrial appliances.
 - d. Dewatered, treated, or chemically fixed sewage sludge which is not hazardous waste.
 - e. Manure, vegetable or animal solid and semisolid wastes.
 - f. Other discarded solid and semisolid wastes.
 - 2. "Solid waste" does not include hazardous waste, radioactive waste, or medical waste as defined or regulated by State law.
- W. Source Separation: The act of keeping different types of waste materials separate beginning from the first time they become waste.
 - 1. Materials, including commingled recyclables, that have been separated or kept separate from the solid waste stream at the point of generation, for the purpose of additional sorting or processing of those materials for reuse or recycling in order to return them to the economic mainstream in the form of raw materials for new, reused, or reconstituted products which meet the quality standards necessary to be used in the marketplace.
- X. Toxic: Poisonous to humans either immediately or after a long period of exposure.

- Y. Trash: Any product or material unable to be reused, returned, recycled, or salvaged.
- Z. Waste: Extra material or material that has reached the end of its useful life in its intended use. Waste includes salvageable, returnable, recyclable, and reusable material.
- AA. Waste Hauler: A company that possesses a valid permit from the local waste management authority to collect and transport solid wastes from individuals or businesses for the purpose of recycling or disposal in the locality.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Submit Waste Management Plan within 30 calendar days after receipt of Notice to Proceed, or prior to any trash or waste removal, whichever occurs sooner; submit projection of all trash and waste that will require disposal and alternatives to landfilling.
 - 1. Submit four copies of CWMP for review.
 - a. Contractor's Construction Waste and Recycling Plan must be approved by the Architect and Construction Manager prior to the start of Work.
 - 2. Approval of the Contractor's CWMP shall not relieve the Contractor of responsibility for adequate and continuing control of pollutants and other environmental protection measures.
- C. Waste Management Plan: Include the following information:
 - 1. Analysis of the trash and waste projected to be generated during the entire project construction cycle, including types and quantities.
 - 2. Landfill Options: The name, address, and telephone number of the landfill(s) where trash/waste will be disposed of, the applicable landfill tipping fee(s), and the projected cost of disposing of all project trash/waste in the landfill(s).
 - 3. Landfill Alternatives: List all waste materials that will be diverted from landfills by reuse, salvage, or recycling.
 - a. List each material proposed to be salvaged, reused, or recycled.
 - b. List the local market for each material.
 - c. State the estimated net cost, versus landfill disposal.
 - 4. Meetings: Describe regular meetings to be held to address waste prevention, reduction, recycling, salvage, reuse, and disposal.
 - 5. Materials Handling Procedures: Describe the means by which materials to be diverted from landfills will be protected from contamination and prepared for acceptance by designated facilities; include separation procedures for recyclables, storage, and packaging.
 - 6. Transportation: Identify the destination and means of transportation of materials to be recycled; i.e. whether materials will be site-separated and self-hauled to designated centers, or whether mixed materials will be collected by a waste hauler.
 - 7. Recycling Incentives: Describe procedures required to obtain credits, rebates, or similar incentives.

FOR REFERENCE ONLY

- D. Waste Disposal Reports: Submit at specified intervals, with details of quantities of trash and waste, means of disposal or reuse, and costs; show both totals to date and since last report.
1. Submit updated Report with each Application for Progress Payment; failure to submit Report will delay payment.
 - a. Inert materials shall achieve a construction waste diversion rate of at least 95 percent.
 - 1) These materials include, but are not limited to, concrete, asphalt and rock.
 - 2) Earthwork is not included.
 - 3) Excavated soil shall not be included in any of the calculations used to ensure compliance with this specification section.
 - b. The overall diversion rate must be based on weight.
 - c. The diversion rate of individual materials can be measured in either weight or volume, but the rate shall be converted into the units selected for calculating the overall diversion rate.
 - 1) All individual material diversions must be converted to a consistent set of units when calculating the overall diversion rate for the all reports and submittals required for the Work.
 - d. Base conversion rate numbers on standard conversion rate data for construction projects provided by the California Integrated Waste Management Board (CIWMB). This data is available at the following internet location, www.calrecycle.ca.gov/LGCentral/Library/Guidance.
 2. Submit Report on a form acceptable to District.
 3. Landfill Disposal: Include the following information:
 - a. Identification of material.
 - b. Amount, in tons or cubic yards, of trash/waste material from the project disposed of in landfills.
 - c. State the identity of landfills, total amount of tipping fees paid to landfill, and total disposal cost.
 - d. Include manifests, weight tickets, receipts, and invoices as evidence of quantity and cost.
 4. Recycled and Salvaged Materials: Include the following information for each:
 - a. Identification of material, including those retrieved by installer for use on other projects.
 - b. Amount, in tons or cubic yards, date removed from the project site, and receiving party.
 - c. Transportation cost, amount paid or received for the material, and the net total cost or savings of salvage or recycling each material.
 - d. Include manifests, weight tickets, receipts, and invoices as evidence of quantity and cost.
 - e. Certification by receiving party that materials will not be disposed of in landfills or by incineration.

5. Material Reused on Project: Include the following information for each:
 - a. Identification of material and how it was used in the project.
 - b. Amount, in tons or cubic yards.
 - c. Include weight tickets as evidence of quantity.
6. Other Disposal Methods: Include information similar to that described above, as appropriate to disposal method.

PART 2 PRODUCTS

2.01 PRODUCT SUBSTITUTIONS

- A. See Section 01 60 00 - Product Requirements for substitution submission procedures.
- B. For each proposed product substitution, submit the following information in addition to requirements specified in Section 01 60 00:
 1. Relative amount of waste produced, compared to specified product.
 2. Cost savings on waste disposal, compared to specified product, to be deducted from the Contract Sum.
 3. Proposed disposal method for waste product.
 4. Markets for recycled waste product.

PART 3 EXECUTION

3.01 WASTE MANAGEMENT PROCEDURES

- A. See Section 01 30 00 for additional requirements for project meetings, reports, submittal procedures, and project documentation.
- B. See Section 01 50 00 for additional requirements related to trash/waste collection and removal facilities and services.
- C. See Section 01 60 00 for waste prevention requirements related to delivery, storage, and handling.
- D. See Section 01 70 00 for trash/waste prevention procedures related to demolition, cutting and patching, installation, protection, and cleaning.

3.02 WASTE MANAGEMENT PLAN IMPLEMENTATION

- A. Manager: Designate an on-site person or persons responsible for instructing workers and overseeing and documenting results of the Waste Management Plan.
- B. Communication: Distribute copies of the Waste Management Plan to job site foreman, each subcontractor, District, and Architect.
- C. Instruction: Provide on-site instruction of appropriate separation, handling, and recycling, salvage, reuse, and return methods to be used by all parties at the appropriate stages of the project.
- D. Meetings: Discuss trash/waste management goals and issues at project meetings.
 1. Prebid meeting.

2. Preconstruction meeting.
 3. Regular job-site meetings.
- E. Facilities: Provide specific facilities for separation and storage of materials for recycling, salvage, reuse, return, and trash disposal, for use by all contractors and installers.
1. As a minimum, provide:
 - a. Separate area for storage of materials to be reused on-site, such as wood cut-offs for blocking.
 - b. Separate dumpsters for each category of recyclable.
 - c. Recycling bins at worker lunch area.
 2. Provide containers as required.
 3. Provide temporary enclosures around piles of separated materials to be recycled or salvaged.
 4. Provide materials for barriers and enclosures that are nonhazardous, recyclable, or reusable to the maximum extent possible; reuse project construction waste materials if possible.
 5. Locate enclosures out of the way of construction traffic.
 6. Provide adequate space for pick-up and delivery and convenience to subcontractors.
 7. If an enclosed area is not provided, clearly lay out and label a specific area on-site.
 8. Keep recycling and trash/waste bin areas neat and clean and clearly marked in order to avoid contamination of materials.
- F. Hazardous Wastes: Separate, store, and dispose of hazardous wastes according to applicable regulations.
- G. Recycling: Separate, store, protect, and handle at the site identified recyclable waste products in order to prevent contamination of materials and to maximize recyclability of identified materials. Arrange for timely pickups from the site or deliveries to recycling facility in order to prevent contamination of recyclable materials.
- H. Reuse of Materials On-Site: Set aside, sort, and protect separated products in preparation for reuse.
- I. Salvage: Set aside, sort, and protect products to be salvaged for reuse off-site.

3.03 DISPOSAL OPERATIONS AND WASTE HAULING

- A. Remove waste materials from Project Site and legally dispose of them in a landfill or incinerator acceptable to authorities having jurisdiction.
1. Except for items or materials to be salvaged, recycled, or otherwise reused.
 2. Except as otherwise specified, do not allow waste materials that are to be disposed of to accumulate on site.
 3. Use a permitted waste hauler or Contractor's trucking services and personnel. To confirm valid permitted status of waste haulers, contact the local solid waste authority.
 4. Become familiar with the conditions for acceptance of new construction, excavation and demolition materials at recycling facilities, prior to delivering materials.

FOR REFERENCE ONLY

5. Deliver to facilities that can legally accept new construction, excavation and demolition materials for purpose of re-use, recycling, composting, or disposal.
6. Remove and transport debris in a manner that will prevent spillage on adjacent surfaces and areas.
7. Do not burn or bury waste materials on or off site. Appropriate on-site topical application of ground gypsum or wood, or use of site paving as granulated fill is considered reuse, not waste.

3.04 PLAN AND REPORT FORMS

- A. See suggested forms on the following pages.

END OF SECTION

CONTRACTOR'S CONSTRUCTION WASTE AND RECYCLING PLAN
 (Submit After Award of Contract and Prior to Start of Work)

FOR REFERENCE ONLY

Project Title:						
Contract or Work Order No.:						
Contractor's Name:						
Street Address:						
City:			State:		Zip:	
Phone: ()			Fax: ()			
E-Mail Address:						
Prepared by: (Print Name)						
Date Submitted:						
Project Period:		From:			TO:	
Reuse, Recycling or Disposal Processes To Be Used						
Describe the types of recycling processes or disposal activities that will be used for material generated in the project. Indicate the type of process or activity by number, types of materials, and estimated quantities that will be recycled or disposed in the sections below:						
01 - Reuse of building materials or salvage items on site (i.e. crushed base or red clay brick)						
02 - Salvaging building materials or salvage items at an offsite salvage or re-use center (i.e. lighting, fixtures)						
03 - Recycling source separated materials on site (i.e. crushing asphalt/concrete for reuse or grinding for mulch)						
04 - Recycling source separated materials at an offsite recycling center (i.e. scrap metal or green materials)						
05 - Recycling commingled loads of C&D materials at an offsite mixed debris recycling center or transfer station						
06 - Recycling material as Alternative Daily Cover at landfills						
07 - Delivery of soils or mixed inerts to an inert landfill for disposal (inert fill).						
08 - Disposal at a landfill or transfer station.						
09 - Other (please describe) _____						
Types of Material To Be Generated						
Use these codes to indicate the types of material that will be generated on the project						
A = Asphalt		C = Concrete		M = Metals		I = Mixed Inert
D = Drywall		P/C=Paper/Cardboard		W/C = Wire/Cable		S= Soils (Non Hazardous)
M/C = Miscellaneous Construction Debris		R = Reuse/Salvage		W = Wood		O = Other (describe)
Facilities Used: Provide Name of Facility and Location (City)						
Total Truck Loads: Provide Number of Trucks Hauled from Site During Reporting Period						
Total Quantities: If scales are available at sites, report in tons. If not, quantify by cubic yards. For salvage/reuse items, quantify by estimated weight (or units).						
SECTION I - RE-USED/RECYCLED MATERIALS						
Include all recycling activities for source separated or mixed material recycling centers where recycling will occur.						
Type of Material	Type of Activity	Facility to be Used/Location	Total Truck Loads	Total Quantities		
				Tons	Cubic YD	Other Wt.
(ex.) M	04	ABC Metals, Los Angeles	24	355		
a. Total Diversion						

CONTRACTOR'S CONSTRUCTION WASTE AND RECYCLING PLAN
Continued

FOR REFERENCE ONLY

SECTION II - DISPOSED MATERIALS						
Include all disposal activities for landfills, transfer stations, or inert landfills where no recycling will occur.						
Type of Material	Type of Activity	Facility to be Used/Location	Total Truck Loads	Total Quantities		
				Tons	Cubic YD	Other Wt.
(ex.) D	08	DEF Landfill, Los Angeles	2	35		
b. Total Disposal				0	0	0

SECTION III - TOTAL MATERIALS GENERATED			
This section calculates the total materials to be generated during the project period (Reuse/Recycle + Disposal = Generation)			
	Tons	Cubic YD	Other Wt.
a. Total Reused/Recycled	0	0	0
b. Total Disposed	0	0	0
c. Total Generated	0	0	0

SECTION IV - CONTRACTOR'S LANDFILL DIVERSION RATE CALCULATION			
Add totals from Section I + Section II			
	Tons	Cubic YD	Other Wt.
a. Materials Re-Used and Recycled	0		
b. Materials Disposed	0		
c. Total Materials Generated (a. + b. = c.)	0	0	0
d. Landfill Diversion Rate (Tonnage Only)*			

* Use tons only to calculate recycling percentages: Tons Reused/Recycled/Tons Generated = % Recycled

Contractor's Comments (Provide any additional information pertinent to planned reuse, recycling, or disposal activities):

- Notes:
- | | |
|---|---|
| <p>1. Suggested Conversion Factors: From Cubic Yards to Tons (Use when scales are not available)</p> <p>a. Asphalt: .61 (ex. 1000 CY Asphalt = 610 tons. Applies to broken chunks of asphalt)</p> <p>b. Concrete: .93 (ex. 1000 CY Concrete = 930 tons. Applies to broken chunks of concrete)</p> | <p>c. Ferrous Metals: .22 (ex. 1000 CY Ferrous Metal = 220 tons)</p> <p>d. Non-Ferrous Metals: .10 (ex. 1000 CY Non-Ferrous Metals = 100 tons)</p> <p>e. Drywall Scrap: .20</p> <p>f. Wood Scrap: .16</p> |
|---|---|

CONTRACTOR'S REUSE, RECYCLING, AND DISPOSAL REPORT
(Submit With Each Progress Payment)

FOR REFERENCE ONLY

Project Title:		
Contract or Work Order No.:		
Contractor's Name:		
Street Address:		
City:	State:	Zip:
Phone: ()	Fax: ()	
E-Mail Address:		
Prepared by: (Print Name)		

Date Submitted:		
Project Period:	From:	TO:

Reuse, Recycling or Disposal Processes to Be Used

Describe the types of recycling processes or disposal activities that will be used for material generated in the project. Indicate the type of process or activity by number, types of materials, and estimated quantities that will be recycled or disposed in the sections below:

01 - Reuse of building materials or salvage items on site (i.e. crushed base or red clay brick)
 02 - Salvaging building materials or salvage items at an offsite salvage or re-use center (i.e. lighting, fixtures)
 03 - Recycling source separated materials on site (i.e. crushing asphalt/concrete for reuse or grinding for mulch)
 04 - Recycling source separated materials at an offsite recycling center (i.e. scrap metal or green materials)
 05 - Recycling commingled loads of C&D materials at an offsite mixed debris recycling center or transfer station
 06 - Recycling material as Alternative Daily Cover at landfills
 07 - Delivery of soils or mixed inerts to an inert landfill for disposal (inert fill).
 08 - Disposal at a landfill or transfer station.
 09 - Other (please describe) _____

Types of Material To Be Generated

Use these codes to indicate the types of material that will be generated on the project

A = Asphalt C = Concrete M = Metals I = Mixed Inert G = Green Materials
 D = Drywall P/C=Paper/Cardboard W/C = Wire/Cable S= Soils (Non-Hazardous)
 M/C = Miscellaneous Construction Debris R = Reuse/Salvage W = Wood O = Other (describe)

Facilities Used: Provide Name of Facility and Location (City)
 Total Truck Loads: Provide Number of Trucks Hauled from Site During Reporting Period

Total Quantities: If scales are available at sites, report in tons. If not, quantify by cubic yards. For salvage/reuse items, quantify by estimated weight (or units).

SECTION I - RE-USED/RECYCLED MATERIALS

Include all recycling activities for source separated or mixed material recycling centers where recycling will occur.

Type of Material	Type of Activity	Facility to be Used/Location	Total Truck Loads	Total Quantities		
				Tons	Cubic YD	Other Wt.
(ex.) M	04	ABC Metals, Los Angeles	24	355		
a. Total Diversion						

CONTRACTOR'S REUSE, RECYCLING, AND DISPOSAL REPORT
Continued



SECTION II - DISPOSED MATERIALS						
Include all disposal activities for landfills, transfer stations, or inert landfills where no recycling will occur.						
Type of Material	Type of Activity	Facility to be Used/Location	Total Truck Loads	Total Quantities		
				Tons	Cubic YD	Other Wt.
(ex.) D	08	DEF Landfill, Los Angeles	2	35		
b. Total Disposal						

SECTION III - TOTAL MATERIALS GENERATED			
This section calculates the total materials to be generated during the project period (Reuse/Recycle + Disposal = Generation)			
	Tons	Cubic YD	Other Wt.
a. Total Reused/Recycled			
b. Total Disposed			
c. Total Generated			

SECTION IV - CONTRACTOR'S LANDFILL DIVERSION RATE CALCULATION			
Add totals from Section I + Section II			
	Tons	Cubic YD	Other Wt.
a. Materials Re-Used and Recycled			
b. Materials Disposed			
c. Total Materials Generated (a. + b. = c.)			
d. Landfill Diversion Rate (Tonnage Only)*			

* Use tons only to calculate recycling percentages: Tons Reused/Recycled/Tons Generated = % Recycled

Contractor's Comments (Provide any additional information pertinent to planned reuse, recycling, or disposal activities):

- Notes:
- | | |
|---|--|
| 1. Suggested Conversion Factors: From Cubic Yards to Tons (Use when scales are not available) | c. Ferrous Metals: .22 (ex. 1000 CY Ferrous Metal = 220 tons) |
| a. Asphalt: .61 (ex. 1000 CY Asphalt = 610 tons. Applies to broken chunks of asphalt) | d. Non-Ferrous Metals: .10 (ex. 1000 CY Non-Ferrous Metals = 100 tons) |
| b. Concrete: .93 (ex. 1000 CY Concrete = 930 tons. Applies to broken chunks of concrete) | e. Drywall Scrap: .20 |
| | f. Wood Scrap: .16 |

SECTION 01 76 10 TEMPORARY PROTECTIVE COVERINGS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Temporary protective coverings for installed floors, walls, and other surfaces.

1.02 RELATED REQUIREMENTS

- A. Section 01 70 00 - Execution and Closeout Requirements: Coordination of requirements for materials specified in this section.

1.03 REFERENCE STANDARDS

- A. ANSI A135.4 - Basic Hardboard.
- B. ASTM C208 - Standard Specification for Cellulosic Fiber Insulating Board.
- C. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials.
- D. ASTM E96/E96M - Standard Test Methods for Gravimetric Determination of Water Vapor Transmission Rate of Materials.
- E. NFPA 701 - Standard Methods of Fire Tests for Flame Propagation of Textiles and Films.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide data on specified products, describing physical and performance characteristics; including sizes available; and installation instructions.
- C. Shop Drawings: Indicate existing finished surfaces to be protected.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Temporary Protective Coverings:
 - 1. Fortifiber Building Systems Group: fortifiber.com.
 - 2. Protex Products: www.protex-products.com.
 - 3. Surface Shields, Inc: www.surfaceshields.com.
- B. Substitutions: See Section 01 60 00 - Product Requirements.

2.02 GENERAL

- A. Provide materials that are easily removed without damage to the surfaces covered and with the following characteristics:
 - 1. Water resistant.
 - 2. Vapor permeable.

3. Impact resistant.
4. Slip resistant.
5. Flame retardant.

2.03 MATERIALS

A. Sheet Materials:

1. Corrugated polypropylene sheet.
2. Recycled paperboard/plastic composite sheet.
3. Recycled paperboard sheet.
4. Wood Hardboard: ANSI A135.4, tempered, 1/4 inch thick nominal.
5. Plywood, 1/2 inch thick nominal.
6. Fiberboard: ASTM C208, 1/2 inch thick nominal.
7. Water Vapor Permeability: Greater than 0.1 perms when tested in accordance with ASTM E96/E96M.
8. Flame Retardance: Meet requirements of NFPA 701.
9. Surface Burning Characteristics: Maximum flame spread index of 25 and smoke developed index of 450; when system tested in accordance with ASTM E84.

B. Rolled Materials:

1. Self-adhering polyethylene film.
2. Recycled cellulose fiberboard paper.
3. Laminated glass fiber reinforced kraft paper.
4. Rosin coated paper.
5. Water Vapor Permeability: Greater than 0.1 perms when tested in accordance with ASTM E96/E96M.
6. Flame Retardance: Meet requirements of NFPA 701.
7. Surface Burning Characteristics: Maximum flame spread index of 25 and smoke developed index of 450; when system tested in accordance with ASTM E84.

C. Corner and Door Jamb Protection Materials:

1. Cardboard, shaped specifically for application.
2. PVC plastic.

D. Tape: Type recommended by protective covering material manufacturer.

PART 3 EXECUTION

3.01 PREPARATION

- A. Remove dirt and debris from surfaces to be protected.

3.02 INSTALLATION

- A. Install in accordance with manufacturer's instructions.

FOR REFERENCE ONLY

- B. Trim or overlap sheet materials to fit area to be covered.
- C. Roll out and cut rolled materials to fit area to be covered.
- D. Tape seams. Avoid taping directly to finished surfaces.
- E. Stretch self-adhering film materials to completely cover surface.
- F. Install door jamb protection to full height of opening.
- G. Position corner protection 4 inches above finished floor to 96 inches high.

3.03 REMOVAL

- A. Remove protective coverings prior to Date of Final Inspection. Reuse or recycle materials if possible.

END OF SECTION

SECTION 01 78 00 CLOSEOUT SUBMITTALS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Project record documents.
- B. Operation and maintenance data.
- C. Warranties and bonds.

1.02 RELATED REQUIREMENTS

- A. District issued Bidding Instructions and Contract General Conditions: Performance bond and labor and material payment bonds, warranty, and correction of work.
- B. Section 01 30 00 - Administrative Requirements: Submittals procedures, shop drawings, product data, and samples.
- C. Section 01 45 33 - Code-Required Special Inspections: Construction oversight procedures by DSA regarding the execution, approval, and closeout of this building project.
- D. Section 01 70 00 - Execution and Closeout Requirements: Contract closeout procedures.
- E. Section 01 78 39 - Project Record Documents: Detailed requirements.
- F. Individual Product Sections: Specific requirements for operation and maintenance data.
- G. Individual Product Sections: Warranties required for specific products or Work.
 - 1. Special Project warranty requirements for specific products or elements of the Work; commitments and agreements for continuing services to District.

1.03 DEFINITIONS

- A. Warranty: Assurance to District by Contractor, installer, supplier, manufacturer or other party responsible as warrantor, for the quantity, quality, performance and other representations of a product, system service of the Work, in whole or in part, for the duration of the specified period of time.
- B. Guarantee: Assurance to District by Contractor or product manufacturer or other specified party, as guarantor, that the specified warranty will be fulfilled by the guarantor in the event of default by the warrantor.
- C. Standard Product Warranty: Preprinted, written warranty published by product manufacturer for particular products and specifically endorsed by the manufacturer to the District.
- D. Special Project Warranty: Written warranty required by or incorporated into Contract Documents, to extend time limits provided by standard warranty or to provide greater rights for District.
- E. Correction Period: As defined in the Conditions of the Contract, Correction Period shall be synonymous with "warranty period", "guarantee period" and similar terms used in the Contract Specifications.

1.04 SUBMITTALS

- A. Advance Submittals: For equipment and systems, or component parts of systems, put into service during construction and operated by District, submit documents within ten days of start of operation by District.
- B. Final Completion Submittals: Prior to application for final payment, Contractor shall submit 3 copies the following:
 - 1. Agency Document Submittals: Submit to District all documents required by authorities having jurisdiction, including serving utilities and other agencies. Submit original versions of all permit cards, with final sign-off by inspectors. Submit all certifications of inspections and tests.
 - a. Complete all required Contractor forms and obtain DSA approval of these same forms. Comply with "Final Certification of Construction" per Title 24 Part 1 section 4-339.
 - 1) Form-6.C: Verified Report – Contractor: From each Contractor having a contract with the District.
 - 2. Final Specifications Submittals: Submit to District all documents and products required by Specifications to be submitted, including the following:
 - a. Project record drawings and specifications.
 - b. Operating and maintenance data.
 - c. Guarantees, warranties and bonds.
 - d. Keys and keying schedule.
 - e. Spare parts and extra stock.
 - f. Test reports and certificates of compliance.
 - 3. Certificates of Compliance and Test Report Submittals: Submit to District certificates and reports as specified and as required by authorities having jurisdiction, including the following:
 - a. Sterilization of water systems.
 - b. Sanitary sewer system tests.
 - c. Gas system tests.
 - d. Lighting, power and signal system tests.
 - e. Ventilation equipment and air balance tests.
 - f. Fire sprinkler system tests.
 - g. Fire detection system, smoke alarms and dampers.
 - h. Roofing inspections and tests.
 - 4. Lien and Bonding Company Releases: Submit to District, with copy to Architect, evidence of satisfaction of encumbrances on Project by completion and submission of The American Institute of Architects Forms:
 - a. G706 - Contractor's Affidavit of Payment of Debts and Claims;
 - b. G706A - Contractor's Affidavit of Release of Liens;
 - c. (if applicable) G707 - Consent of Surety;
 - d. or forms as as agreed to by the District.
 - e. Comply also with other requirements of District, as directed.

- f. All signatures shall be notarized.
- 5. Subcontractor List: Submit to two copies to District and two copies to Architect of updated Subcontractor and Materials Supplier List.
- 6. Warranty Documents: Prepare and submit to District all warranties and bonds as specified in Contract General Conditions and this Section.
- C. Project Record Documents: Submit final progress markup PDF documents by uploading via Bluebeam to Architect with claim for final Application for Payment.
- D. Operation and Maintenance Data:
 - 1. Submit two copies of preliminary draft or proposed formats and outlines of contents before start of Work. Architect will review draft and return one copy with comments.
 - 2. For equipment, or component parts of equipment put into service during construction and operated by District, submit completed documents within ten days after acceptance.
 - 3. Submit one copy of completed documents 15 days prior to final inspection. This copy will be reviewed and returned after final inspection, with Architect comments. Revise content of all document sets as required prior to final submission.
 - 4. Submit two sets of revised final documents in final form within 10 days after final inspection.
- E. Warranties and Bonds:
 - 1. For equipment or component parts of equipment put into service during construction with District's permission, submit documents within 10 days after acceptance.
 - 2. Make other submittals within 10 days after Date of Final Inspection, prior to final Application for Payment.
 - 3. For items of Work for which acceptance is delayed beyond Date of Final Inspection, submit within 10 days after acceptance, listing the date of acceptance as the beginning of the warranty period.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION

3.01 PROJECT RECORD DOCUMENTS

- A. See also Section 01 78 39 - Project Record Documents.
- B. Record Documents are to be maintained and submitted in searchable live electronic format (PDF), unflattened.
 - 1. Develop in compliance with Section 01 30 00 - Administrative Requirements.
 - 2. Acceptable markup software:
 - a. Adobe Acrobat Professional.
 - b. Bluebeam Revu.
- C. Maintain on site one set of the following record documents; record actual revisions to the Work:
 - 1. Contract Drawings.

FOR REFERENCE ONLY

2. Project Manual with Specifications.
 3. Addenda.
 4. Change Orders and other modifications to the Contract.
 5. Reviewed shop drawings, product data, and samples.
 6. Manufacturer's instruction for assembly, installation, and adjusting.
- D. Ensure entries are complete and accurate, enabling future reference by District.
- E. Store record documents separate from documents used for construction.
- F. Record information concurrent with construction progress.
- G. Specifications: Legibly mark and record at each product section description of actual products installed, including the following:
1. Manufacturer's name and product model and number.
 2. Product substitutions or alternates utilized.
 3. Changes made by Addenda and modifications.
 4. Provide copies of all approved addenda, directives, corrections, and change orders affecting the associated project.
 - a. These copies shall be included with the "Bid Set" and/or "Record Set" listed above and formatted as detailed above.
- H. Record Drawings and Shop Drawings: Legibly mark each item to record actual construction including:
1. Reproducible (PDF) set of Contract Drawings will be provided to Contractor by District through Architect or Construction Manager.
 2. Measured depths of foundations in relation to finish first floor datum.
 3. Measured horizontal and vertical locations of underground utilities and appurtenances, referenced to permanent surface improvements.
 4. Measured locations of internal utilities and appurtenances concealed in construction, referenced to visible and accessible features of the Work.
 5. Field changes of dimension and detail.
 6. Details not on original Contract drawings.
 - a. Application of copies of details produced and provided by Architect during construction will be accepted.
 7. Sketches, clarifications (RFI's), Field Orders, Supplemental Instructions, Construction Change Documents, and Approved Change Orders
- I. Submission: Submit by uploading, Record Documents to Architect prior to each Application for Payment.
1. Provide, by email, to the Architect, a download link the Record Documents consisting of an unflattened PDF format with live text and redline mark-ups, not scanned.
 2. Maintain one additional paper copy and one in PDF format (on CD) of the fire suppression and fire protection detection system drawings and specifications at the building premises.

- a. One copy is to be kept on site for a period of three years to comply with CFC section 901.6.2.

3.02 OPERATION AND MAINTENANCE DATA

- A. Source Data: For each product or system, list names, addresses and telephone numbers of Subcontractors and suppliers, including local source of supplies and replacement parts.
- B. Product Data: Mark each sheet to clearly identify specific products and component parts, and data applicable to installation. Delete inapplicable information.
- C. Drawings: Supplement product data to illustrate relations of component parts of equipment and systems, to show control and flow diagrams. Do not use Project Record Documents as maintenance drawings.
- D. Typed Text: As required to supplement product data. Provide logical sequence of instructions for each procedure, incorporating manufacturer's instructions.

3.03 OPERATION AND MAINTENANCE DATA FOR MATERIALS AND FINISHES

- A. For Each Product, Applied Material, and Finish:
 - 1. Product data, with catalog number, size, composition, and color and texture designations.
 - 2. Information for re-ordering custom manufactured products.
- B. Instructions for Care and Maintenance: Manufacturer's recommendations for cleaning agents and methods, precautions against detrimental cleaning agents and methods, and recommended schedule for cleaning and maintenance.
- C. Moisture protection and weather-exposed products: Include product data listing applicable reference standards, chemical composition, and details of installation. Provide recommendations for inspections, maintenance, and repair.
- D. Additional information as specified in individual product specification sections.
- E. Where additional instructions are required, beyond the manufacturer's standard printed instructions, have instructions prepared by personnel experienced in the operation and maintenance of the specific products.

3.04 OPERATION AND MAINTENANCE DATA FOR EQUIPMENT AND SYSTEMS

- A. For Each Item of Equipment and Each System:
 - 1. Description of unit or system, and component parts.
 - 2. Identify function, normal operating characteristics, and limiting conditions.
 - 3. Include performance curves, with engineering data and tests.
 - 4. Complete nomenclature and model number of replaceable parts.
- B. Where additional instructions are required, beyond the manufacturer's standard printed instructions, have instructions prepared by personnel experienced in the operation and maintenance of the specific products.
- C. Panelboard Circuit Directories: Provide electrical service characteristics, controls, and communications; by label machine.
- D. Include color coded wiring diagrams as installed.

FOR REFERENCE ONLY

- E. Operating Procedures: Include start-up, break-in, and routine normal operating instructions and sequences. Include regulation, control, stopping, shut-down, and emergency instructions. Include summer, winter, and any special operating instructions.
- F. Maintenance Requirements: Include routine procedures and guide for preventative maintenance and trouble shooting; disassembly, repair, and reassembly instructions; and alignment, adjusting, balancing, and checking instructions.
 - 1. Include HVAC outdoor and exhaust air damper calibration strategy.
 - a. Include provisions which ensure that full closure of dampers can be achieved.
 - 2. Include Carbon Dioxide Monitoring Protocol.
- G. Provide servicing and lubrication schedule, and list of lubricants required.
- H. Include manufacturer's printed operation and maintenance instructions.
- I. Include sequence of operation by controls manufacturer.
- J. Provide original manufacturer's parts list, illustrations, assembly drawings, and diagrams required for maintenance.
- K. Provide control diagrams by controls manufacturer as installed.
- L. Provide Contractor's coordination drawings, with color coded piping diagrams as installed.
- M. Provide charts of valve tag numbers, with location and function of each valve, keyed to flow and control diagrams.
- N. Provide list of original manufacturer's spare parts, current prices, and recommended quantities to be maintained in storage.
 - 1. Parts Data:
 - a. Provide original manufacturer's parts list, illustrations, assembly drawings, and diagrams as necessary for service and maintenance.
 - b. Include complete nomenclature and catalog numbers for consumable and replacement parts.
 - c. Provide list of original manufacturer's spare parts, current prices, and recommended quantities to be maintained in stock by the District or operator.
- O. Include test and balancing reports.
- P. Additional Requirements: As specified in individual product specification sections.

3.05 ASSEMBLY OF OPERATION AND MAINTENANCE MANUALS

- A. Assemble operation and maintenance data into durable manuals for District's personnel use, with data arranged in the same sequence as, and identified by, the specification sections.
 - 1. Provide duplicate electronic formatted (PDF) versions of the O&M binder for record purposes. Organize the same as the printed versions.
- B. Where systems involve more than one specification section, provide separate tabbed divider for each system.
- C. Binders: Commercial quality, 8-1/2 by 11 inch three D side ring binders with durable plastic covers; 2 inch maximum ring size. When multiple binders are used, correlate data into related consistent groupings.

FOR REFERENCE ONLY

- D. Cover: Identify each binder with typed or printed title OPERATION AND MAINTENANCE INSTRUCTIONS; identify title of Project; identify subject matter of contents.
- E. Project Directory: Title and address of Project; names, addresses, and telephone numbers of Architect, Consultants, Contractor and subcontractors, with names of responsible parties.
- F. Tables of Contents: List every item separated by a divider, using the same identification as on the divider tab; where multiple volumes are required, include all volumes Tables of Contents in each volume, with the current volume clearly identified.
- G. Dividers: Provide tabbed dividers for each separate product and system; identify the contents on the divider tab; immediately following the divider tab include a description of product and major component parts of equipment.
- H. Text: Manufacturer's printed data, or typewritten data on 20 pound paper.
- I. Drawings: Provide with reinforced punched binder tab. Bind in with text; fold larger drawings to size of text pages.
- J. Arrangement of Contents: Organize each volume in parts as follows:
 - 1. Project Directory.
 - 2. Table of Contents, of all volumes, and of this volume.
 - 3. Operation and Maintenance Data: Arranged by system, then by product category.
 - a. Source data.
 - b. Product data, shop drawings, and other submittals.
 - c. Operation and maintenance data.
 - d. Field quality control data.
 - e. Photocopies of warranties and bonds.
 - 4. Design Data: To allow for addition of design data furnished by Architect or others, provide a tab labeled "Design Data" and provide a binder large enough to allow for insertion of at least 20 pages of typed text.

3.06 WARRANTIES AND BONDS

- A. General:
 - 1. Provide all warranties and guarantees with District named as beneficiary.
 - 2. For equipment and products, or components thereof, bearing a manufacturer's warranty or guarantee that extends for a period of time beyond the Contractor's warranty and guarantee, so state in the warranty or guarantee.
- B. General Warranty and Guarantee Requirements:
 - 1. Warranty shall be an agreement to repair or replace, without cost and undue hardship to District, Work performed under the Contract which is found to be defective during the Correction Period (warranty or guarantee) period.
 - 2. Repairs and replacements due to improper maintenance or operation, or due to normal wear, usage and weathering are excluded from warranty requirements unless otherwise specified.
- C. Provisions for Special Warranties: Refer to Conditions of the Contract for terms of the Contractor's special warranty of workmanship and materials.

FOR REFERENCE ONLY

- D. Specific Warranty and Guarantee Requirements: Specific requirements are included in product Specifications Technical Sections, including content and limitations.
- E. Disclaimers and Limitations:
 - 1. Manufacturer's disclaimers and limitations on product warranties and guarantees shall not relieve Contractor of responsibility for warranty and guarantee requirements.
 - 2. This applies to the Work that incorporates such products, nor shall they relieve suppliers, manufacturers, and installers required to countersign special warranties with Contractor.
- F. Related Damages and Losses: When correcting warranted Work that has been found defective, remove and replace other Work that has been damaged as a result of such defect or that must be removed and replaced to provide access for correction of warranted Work.
- G. Reinstatement of Warranty:
 - 1. When Work covered by a warranty has been found defective and has been corrected by replacement or rebuilding, reinstate the warranty by written endorsement.
 - 2. The reinstated warranty shall be equal to the original warranty with an equitable adjustment for depreciation.
- H. Replacement Cost:
 - 1. Upon determination that Work covered by a warranty has been found to be defective, replace or reconstruct the Work to a condition acceptable to District, complying with applicable requirements of the Contract Documents.
 - 2. Contractor is responsible for all costs for replacing or reconstructing defective Work regardless of whether District has benefited from use of the Work through a portion of its anticipated useful service life.
- I. District's Recourse:
 - 1. Written warranties made to the District are in addition to implied warranties, and do not limit the duties, obligations, rights and remedies otherwise available under law, nor shall warranty periods be interpreted as limitations on time in which the District can enforce such other duties, obligations, rights, or remedies.
 - 2. Rejection of Warranties:
 - a. The District reserves the right to reject warranties and to limit selections to products with warranties not in conflict with requirements of the Contract Documents.
- J. Warranty as Condition of Acceptance:
 - 1. District reserves the right to refuse to accept Work for the Project where a special warranty, certification, or similar commitment shall be required on such Work or part of the Work, until evidence is presented that entities required to countersign such commitments are willing to do so.
- K. Obtain warranties and bonds, executed in duplicate by responsible Subcontractors, suppliers, and manufacturers, within 10 days after completion of the applicable item of work. Except for items put into use with District's permission, leave date of beginning of time of warranty until Date of Final Acceptance is determined.
- L. Project Warranty and Guarantee Forms:

FOR REFERENCE ONLY

1. Example forms for special Project warranties and guarantees are included at the end of this Section.
 2. Prepare written documents utilizing the appropriate form, ready for execution by the Contractor, or the Contractor and subcontractor, supplier or manufacturer.
 - a. Submit a draft to District through Architect for approval prior to final execution.
 3. Refer to product Technical Specifications Sections for specific content requirements, and particular requirements for submittal of special warranties.
 4. Prepare standard warranties and guarantees, excepting manufacturers' standard printed warranties and guarantees, on Contractor's, subcontractor's, material supplier's, or manufacturer's own letterhead, addressed to District.
 5. Warranty and guarantee letters shall be signed by all responsible parties and by Contractor in every case, with modifications only as approved in advance by District to suit the conditions pertaining to the warranty or guarantee.
- M. Manufacturer's Guarantee Form:
1. Manufacturer's guarantee form may be used in lieu of special Project form included at the end of this Section.
 2. Manufacturer's guarantee form shall contain appropriate terms and identification, ready for execution by the required parties.
 3. If proposed terms and conditions restrict guarantee coverage or require actions by District beyond those specified, submit draft of guarantee to District through Architect for review and acceptance before performance of the Work.
 4. In other cases, submit draft of guarantee to District through Architect for approval prior to final execution of guarantee.
- N. Verify that documents are in proper form, contain full information, and are notarized.
1. Provide all warranties and guarantees with District named as beneficiary.
 2. Signatures: By person authorized to sign warranties, guarantees and bonds on behalf of entity providing such warranty, guarantee or bond.
 3. Co-Signature: All installer's warranties and bonds shall be co-signed by Contractor. Manufacturer's guarantees will not require co-signature.
- O. Co-execute submittals when required.
- P. Retain warranties and bonds until time specified for submittal.
- Q. Manual: Bind in commercial quality 8-1/2 by 11 inch three D side ring binders with durable plastic covers.
- R. Cover: Identify each binder with typed or printed title WARRANTIES AND BONDS, with title of Project; name, address and telephone number of Contractor and equipment supplier; and name of responsible company principal.
1. If more than one volume of warranties, guarantees and bonds is produced, identify volume number on binder.
- S. Table of Contents: Neatly typed, in the sequence of the Table of Contents of the Project Manual, with each item identified with the number and title of the specification section in which specified, and the name of product or work item.

- T. Separate each warranty or bond with index tab sheets keyed to the Table of Contents listing. Provide full information, using separate typed sheets as necessary. List Subcontractor, supplier, and manufacturer, with name, address, and telephone number of responsible principal.
- U. Form of Warranty and Bond Submittals:
 - 1. Prior to final Application and Certificate for Payment, compile two copies of each required warranty, guarantee and bond, properly executed by Contractor, or jointly by Contractor, subcontractor, supplier, or manufacturer.
 - 2. Collect and assemble all written warranties and guarantees into binders and deliver binders to District for final review and acceptance.
 - 3. Include Table of Contents for binder, neatly typed, following order and Section numbers and titles as used in the Project Manual.
 - 4. Provide heavy paper dividers with celluloid or plastic covered tabs for each separate warranty.
 - a. Mark tabs to identify products or installation, and Section number and title.
 - 5. Include on separate typed sheet, if information is not contained in warranty or guarantee form, a description of the product or installation, and the name, address, telephone number and responsible person for applicable installer, supplier and manufacturer.
 - 6. When operating and maintenance data manuals are required for warranted construction, include additional copies of each required warranty and guarantee in each required manual.
 - a. Coordinate with requirements listed in the prior articles for operating and maintenance data manuals.

3.07 TIME OF WARRANTY AND BOND SUBMITTALS

- A. Submission of Preliminary Copies:
 - 1. Unless otherwise specified, obtain preliminary copies of warranties, guarantees and bonds within ten days of completion of applicable item or Work.
 - 2. Prepare and submit preliminary copies for review as specified herein.
- B. Submission of Final Copies:
 - 1. Submit fully executed copies of warranties, guarantees and bonds within ten days of date identified in Certificate of Completion but no later than three days prior to date of final Application for Payment.
- C. Date of Warranties and Bonds:
 - 1. Unless otherwise directed or specified, commencement date of warranty, guarantee and bond periods shall be the date established in the Certificate of Completion.
 - 2. Warranties for Work accepted in advance of date stated in Certificate of Completion:
 - a. When a designated system, equipment, component parts or other portion of the Work is completed and occupied or put to beneficial use by District:

FOR REFERENCE ONLY

- 1) By separate agreement with Contractor, prior to completion date established in the Certificate of Completion, submit properly executed warranties to District within ten days of completion of that designated portion of the Work.
- 2) List date of commencement of warranty, guarantee or bond period as the date established in the Certificate of Completion.
3. Warranties for Work not accepted as of date established in the Certificate of Completion:
 - a. Submit documents within ten days after acceptance, listing date of acceptance as beginning of warranty, guarantee or bond period.
- D. Duration of Warranties and Guarantees:
 1. Unless otherwise specified or prescribed by law, warranty and guarantee periods shall be not less than the Correction Period required by the Conditions of the Contract.
 2. In no case, the period is to be less than one year from the date established for completion of the Project in the Certificate of Completion.
 3. See product Specifications Sections of the Project Manual for extended warranty and guarantee beyond the minimum one year duration.

END OF SECTION

FOR REFERENCE ONLY

**SECTION 01 78 00.01
WARRANTY FORM LETTER**

FOR CONTRACTOR'S / SUBCONTRACTOR'S / MANUFACTURER'S WARRANTY

CONTRACTOR'S/SUBCONTRACTOR'S/SUPPLIER'S LETTERHEAD

SPECIAL LIMITED PROJECT WARRANTY FOR _____ WORK.

We, the undersigned, do hereby warrant that the portion of the Work described above which we have provided for Kitchen Upgrades at Madison ES is in accordance with the Contract Documents and that all such Work as installed will fulfill or exceed all minimum warranty requirements. We agree to repair or replace Work installed by us, together with any adjacent Work which is displaced or damaged by so doing, that proves to be defective in workmanship, material, or function within a period of (years), commencing (date identified in Certificate of Completion, unless otherwise directed) and terminating (date).

The following terms and conditions apply to this warranty (obtain District 's approval before submission):

In the event of our failure to comply with the above-mentioned conditions within a reasonable time period determined by the District , after notification in writing, we, the undersigned, all collectively and separately, hereby authorize the District to have said defective Work repaired or replaced to be made good, and agree to pay to the District upon demand all moneys that the District may expend in making good said defective Work, including all collection costs and reasonable attorney fees.

LOCAL REPRESENTATIVE: FOR WARRANTY MAINTENANCE, REPAIR, OR REPLACEMENT SERVICE, CONTACT:

(Name) _____
(Address) _____
(City) _____ (State) _____ (ZIP) _____
(Phone) _____ / _____
(signed) _____
(Typed Name) _____ (Date) _____
(Title) _____ (Firm) _____

CONTRACTOR:

State License No: _____
(signed) _____
(Date) _____ (Typed Name) _____
(Title) _____ (Firm) _____

FOR REFERENCE ONLY

FORM LETTER

FOR CONTRACTOR'S / MANUFACTURER'S GUARANTEE

CONTRACTOR'S / MANUFACTURER'S LETTERHEAD

SPECIAL LIMITED PROJECT [__WARRANTY__] [__GUARANTEE__] FOR _____ WORK.

We, the undersigned, do hereby [__warranty__] [__guarantee__] that the portion of the Work described above which [__we have provided__] [__was provided by (Installer or Subcontractor's Name)__] for Kitchen Upgrades at Madison ES in accordance with the Contract Documents and that all such Work as installed will fulfill or exceed all minimum warranty requirements. We agree to repair or replace Work installed by [__us,__] [__(Installer or Subcontractor's Name)__] together with any adjacent Work which is displaced or damaged by so doing, that proves to be defective in workmanship, material, or function within a period of (years), commencing (date indicated in Certificate of Completion, unless otherwise directed) and terminating (date).

The following terms and conditions apply to this [__warranty__] [__guarantee__] (obtain District's approval before submission):

In the event of our failure to comply with the above-mentioned conditions within a reasonable time period determined by the District, after notification in writing, we, the undersigned, all collectively and separately, hereby authorize the District to have said defective Work repaired or replaced to be made good, and agree to pay to the District upon demand all moneys that the District may expend in making good said defective Work, including all collection costs and reasonable attorney fees.

LOCAL REPRESENTATIVE: FOR WARRANTY MAINTENANCE, REPAIR, OR REPLACEMENT SERVICE, CONTACT:

(Name) _____
(Address) _____
(City) _____ (State) _____ (ZIP) _____
(Phone) _____ / _____
(signed) _____
(Date) _____ (Typed Name) _____
(Title) _____ (Firm) _____

CONTRACTOR:

State License No: _____
(signed) _____
(Date) _____ (Typed Name) _____
(Title) _____ (Firm) _____

FORM LETTER

SECTION 01 78 39 PROJECT RECORD DOCUMENTS

PART 1 - GENERAL

1.01 SUMMARY

- A. Record Drawings.
- B. Record Specifications.
- C. Record Product Data.
- D. Record Samples.
- E. Record Photos and Video.
- F. Miscellaneous record submittals.

1.02 RELATED REQUIREMENTS:

- A. Section 01 20 00 - Price and Payment Procedures: Schedule of Values.
- B. Section 01 30 00 - Administrative Requirements: Project Coordination.
- C. Section 01 78 00 - Closeout Submittals: General Closeout.

1.03 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Project Record Documents: Recorded actual locations.

PART 2 -PRODUCTS - NOT USED

PART 3 - EXECUTION

3.01 RECORD DRAWINGS

- A. Record Documents: Maintain one set of marked-up PDF copies of the Contract Drawings and Shop Drawings, incorporating new and revised drawings as modifications are issued.
 - 1. Preparation: Mark record prints to show the actual installation where installation varies from that shown originally. Require individual or entity who obtained record data, whether individual or entity is Installer, subcontractor, or similar entity, to provide information for preparation of corresponding marked-up record prints.
 - a. Give particular attention to information on concealed elements that would be difficult to identify or measure and record later.
 - b. Accurately record information in an acceptable drawing technique.
 - c. Record data as soon as possible after obtaining it.
 - d. Record and check the markup before enclosing concealed installations.
 - e. Cross-reference record prints to corresponding archive photographic documentation.

FOR REFERENCE ONLY

2. Content: Types of items requiring marking include, but are not limited to, the following:
 - a. Field changes of dimensions from Drawings.
 - b. Revisions to details shown on Drawings.
 - 1) Details not on original Contract Drawings. Application of copies of details produced and provided by Architect during construction will be accepted.
 - c. Depths of foundations and footing, measured in relation to finish First Floor datum.
 - d. Measured horizontal and vertical locations of underground utilities and appurtenances, referenced to permanent ground improvements.
 - e. Revisions to routing of piping and conduits.
 - f. Revisions to electrical circuits.
 - g. Actual equipment locations and sizes.
 - h. Duct size and routing.
 - i. Locations of concealed internal utilities.
 - j. Permanent Room names and Room numbers.
 - k. Changes made by Change Order or Construction Change Directive.
 - l. Changes made following written orders by District or Construction Manager.
 - m. Changes made following Architect's written orders.
 - n. Note clarifications from RFI's.
 - o. Field records for variable and concealed conditions.
 - p. Record information on the Work that is shown only schematically.
 3. Mark the Contract Drawings and Shop Drawings completely and accurately. Use personnel proficient at recording graphic information in production of marked-up record prints.
 4. Mark record sets with erasable, red-colored pencil. Use other colors to distinguish between changes for different categories of the Work at same location.
 5. Mark important additional information that was either shown schematically or omitted from original Drawings.
 6. Note Construction Change Directive numbers, alternate numbers, Change Order numbers, and similar identification, where applicable.
- B. Record Digital Data Files: Immediately before inspection for Certificate of Substantial Completion, review marked-up record prints with Architect. When authorized, prepare a full set of corrected digital data files of the Contract Drawings, as follows:
1. Format: Same digital data software program, version, and operating system as the original Contract Drawings.
 - a. Format: DWG, Version, Microsoft Windows operating system.
 2. Incorporate changes and additional information previously marked on record prints. Delete, redraw, and add details and notations where applicable.
 3. Refer instances of uncertainty to Architect and Construction Manager for resolution.

FOR REFERENCE ONLY

4. Architect will furnish Contractor one set of digital data files of the Contract Drawings for use in recording information.
 - a. See Section 01 35 50 - Requests for Electronic Files for requirements related to use of Architect's digital data files.
 - b. Architect will provide data file layer information. Record markups in separate layers.
- C. Newly Prepared Record Drawings: Prepare new Drawings instead of preparing record Drawings where Architect determines that neither the original Contract Drawings nor Shop Drawings are suitable to show actual installation.
 1. New Drawings may be required when a Change Order is issued as a result of accepting an alternate, substitution, or other modification.
 2. Consult Architect and Construction Manager for proper scale and scope of detailing and notations required to record the actual physical installation and its relation to other construction. Integrate newly prepared record Drawings into record Drawing sets; comply with procedures for formatting, organizing, copying, binding, and submitting.
- D. Format: Identify and date each record Drawing; include the designation "PROJECT RECORD DRAWING" in a prominent location.
 1. Record Prints: Organize record prints and newly prepared record Drawings into manageable sets. Bind each set with durable paper cover sheets. Include identification on cover sheets.
 2. Format: Annotated PDF electronic file with comment function enabled.
 3. Record Digital Data Files: Organize digital data information into separate electronic files that correspond to each sheet of the Contract Drawings. Name each file with the sheet identification. Include identification in each digital data file.
 4. Identification:
 - a. Project name and number.
 - b. Date.
 - c. Designation "PROJECT RECORD DRAWINGS."
 - d. Name of Architect and Construction Manager.
 - e. Name of Contractor.

3.02 RECORD SPECIFICATIONS

- A. Preparation: Mark Specifications in PART 2 to indicate the actual product installation where installation varies from that indicated in Specifications, addenda, and contract modifications.
 1. Give particular attention to information on concealed products and installations that cannot be readily identified and recorded later.
 2. Mark copy with the proprietary name and model number of products, materials, and equipment furnished, including substitutions and product options selected.
 3. Record the name of manufacturer, supplier, Installer, and other information necessary to provide a record of selections made.
 4. For each principal product, indicate whether record Product Data has been submitted in operation and maintenance manuals instead of submitted as record Product Data.

5. Note related Change Orders, record Product Data, and Record Drawings, where applicable.
- B. Format: Submit record Specifications as annotated PDF electronic file.

3.03 RECORD DESIGN AND ENGINEERING DATA

- A. Fire Systems:
1. Provide updated SDU files at each:
 - a. One flash drive placed inside fire panel cabinet.
 - b. One flash drive turned over to District.
 - c. One file copy emailed Operations and Facilities Director or District.

3.04 RECORD PRODUCT DATA

- A. Preparation: Mark Product Data to indicate the actual product installation where installation varies substantially from that indicated in Product Data submittal.
1. Give particular attention to information on concealed products and installations that cannot be readily identified and recorded later.
 2. Include significant changes in the product delivered to Project site and changes in manufacturer's written instructions for installation.
 3. Note related Change Orders, record Specifications, and record Drawings where applicable.
- B. Format: Submit record Product Data as annotated PDF electronic file.
1. Include record Product Data directory organized by Specification Section number and title, electronically linked to each item of record Product Data.

3.05 RECORD SAMPLES

- A. Immediately before date of Substantial Completion, meet with District or Construction Manager at Project site to determine which Samples maintained during the construction period are to be transmitted to District or Construction Manager for record purposes.
- B. Comply with District or Construction Manager's instructions for packaging, identification, marking, and delivery to District or Construction Manager's Sample storage space. Dispose of other Samples in the manner specified for disposing surplus and waste materials

3.06 RECORD PHOTOS AND VIDEO

- A. Photograph all work before covering up, including:
1. All open trenches and manholes shall be photographed.
 2. All exposed utilities should be identified in the photos.
 3. Show photograph locations and dates on Record Drawings.
- B. Interior video recording of all underground sewer and storm drain lines, under the building and outside to and including the on-site or utility connection.

3.07 MISCELLANEOUS RECORD SUBMITTALS

- A. Assemble miscellaneous records required by other Specification Sections for miscellaneous record keeping and submittal in connection with actual performance of the Work. Bind or file miscellaneous records and identify each, ready for continued use and reference.
 - 1. Field records on excavations and foundations.
 - 2. Field records on underground construction and similar work.
 - 3. Surveys showing locations and elevations of underground lines.
 - 4. Invert elevations of drainage piping.
 - 5. Surveys establishing building lines and levels.
 - 6. Authorized measurements using unit prices or allowances.
 - 7. Records of plant treatment.
 - 8. Ambient and substrate condition tests.
 - 9. Certifications received in lieu of labels on bulk products.
 - 10. Batch mixing and bulk delivery records.
 - 11. Testing and qualification of trade persons.
 - 12. Documented qualification of installation firms.
 - 13. Load and performance testing.
 - 14. Inspections and certifications by governing authorities.
 - 15. Leakage and water-penetration tests.
 - 16. Fire-resistance and flame-spread test results.
 - 17. Final inspection and correction procedures.
- B. Format: Submit miscellaneous record submittals as PDF electronic file.
 - 1. Include miscellaneous record submittals directory organized by Specification Section number and title, electronically linked to each item of miscellaneous record submittals.

3.08 SUBMISSION

- A. Keep Project Record Documents current, as they will be reviewed for completeness by Architect, Engineer, Project Inspector, and Construction Manager; as a condition of certification for each Progress Payment Application.
- B. Prior to the date of the Notice of Completion, submit marked Record Documents to Architect and Construction Manager for review, approval and further processing.

3.09 RECORDING AND MAINTENANCE

- A. Recording: Maintain one copy of each submittal during the construction period for project record document purposes. Post changes and revisions to project record documents as they occur; do not wait until end of Project.
- B. Review of documents by Architect, Engineer, Project Inspector, or Construction Manager to be in concert with approval of the monthly Application for Payment.
- C. Maintenance of Record Documents and Samples:

FOR REFERENCE ONLY

1. Store record documents and Samples in the field office apart from the Contract Documents used for construction.
2. Do not use project record documents for construction purposes.
3. Maintain record documents in good order and in a clean, dry, legible condition, protected from deterioration and loss.
4. Provide access to project record documents for Architect and Construction Manager reference during normal working hours.

END OF SECTION

SECTION 01 79 00 DEMONSTRATION AND TRAINING

PART 1 GENERAL

1.01 SUMMARY

- A. Demonstration of products and systems to be commissioned and where indicated in specific specification sections.
- B. Training of District personnel in operation and maintenance is required for:
 - 1. All software-operated systems.
 - 2. HVAC systems and equipment.
 - 3. Plumbing equipment.
 - 4. Electrical systems and equipment.
 - 5. Landscape irrigation.
 - 6. Items specified in individual product Sections.
- C. Training of District personnel in care, cleaning, maintenance, and repair is required for:
 - 1. Roofing, waterproofing, and other weather-exposed or moisture protection products.
 - 2. Finishes, including flooring, wall finishes, ceiling finishes.
 - 3. Fixtures and fittings.
 - 4. Items specified in individual product Sections.

1.02 RELATED REQUIREMENTS

- A. Section 01 78 00 - Closeout Submittals: Operation and maintenance manuals.
- B. Section 01 91 13 - General Commissioning Requirements: Additional requirements applicable to demonstration and training.
- C. Other Specification Sections: Additional requirements for demonstration and training.

1.03 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures; except:
 - 1. Make all submittals specified in this section, and elsewhere where indicated for commissioning purposes, directly to the Commissioning Authority.
 - 2. Submit one copy to the Commissioning Authority, not to be returned.
 - 3. Make commissioning submittals on time schedule specified by Commissioning Authority.
 - 4. Submittals indicated as "Draft" are intended for the use of the Commissioning Authority in preparation of overall Training Plan; submit in editable electronic format, Microsoft Word preferred.
- B. Draft Training Plans: District will designate personnel to be trained; tailor training to needs and skill-level of attendees.

FOR REFERENCE ONLY

1. Each Sub, Design-Builder SubContractor and vendor responsible for training submits a written training plan to the Architect, District, Construction Manager, and Commissioning Authority for review and approval prior to training.
 2. Submit to Architect for transmittal to District.
 3. Submit to Commissioning Authority for review and inclusion in overall training plan.
 4. Submit not less than four weeks prior to start of training.
 5. Revise and resubmit until acceptable.
 6. Provide an overall schedule showing all training sessions.
 7. Include at least the following for each training session:
 - a. Identification, date, time, and duration.
 - b. Description of products and/or systems to be covered.
 - 1) Equipment list
 - c. Name of firm and person conducting training; include qualifications.
 - d. Intended audience, such as job description.
 - e. Objectives of training and suggested methods of ensuring adequate training.
 - 1) Agenda and subjects (design intent, equipment inspections, modes of operation, system interactions, troubleshooting, preventative maintenance, etc.)
 - f. Methods to be used, such as classroom lecture, live demonstrations, hands-on, etc.
 - g. Media to be used, such a slides, hand-outs, etc.
 - 1) The approved O&M manuals shall be used during the training for equipment specific references.
 - h. Training equipment required, such as projector, projection screen, etc., to be provided by Contractor.
- C. Training Manuals: Provide training manual for each attendee; allow for minimum of two attendees per training session.
1. Include applicable portion of O&M manuals.
 2. Include copies of all hand-outs, slides, overheads, video presentations, etc., that are not included in O&M manuals.
 3. Provide one extra copy of each training manual to be included with operation and maintenance data.
- D. Training Reports:
1. Identification of each training session, date, time, and duration.
 2. Sign-in sheet showing names and job titles of attendees.
 3. List of attendee questions and written answers given, including copies of and references to supporting documentation required for clarification; include answers to questions that could not be answered in original training session.
 4. Include Commissioning Authority's formal acceptance of training session.

- E. Video Recordings: Submit digital video recording of each demonstration and training session for District's subsequent use.
 - 1. Format: DVD Disc.
 - 2. Label each disc and container with session identification and date.

1.04 QUALITY ASSURANCE

- A. Instructor Qualifications: Familiar with design, operation, maintenance and troubleshooting of the relevant products and systems.
 - 1. Provide as instructors the most qualified trainer of those contractors and/or installers who actually supplied and installed the systems and equipment.
 - 2. Where a single person is not familiar with all aspects, provide specialists with necessary qualifications.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION

3.01 TRAINING OF OWNER PERSONNEL

- A. The Contractor and Design-Builder SubContractors shall be responsible for training coordination and scheduling and for ensuring that training is completed.
- B. The Commissioning Authority (CA) shall be responsible for reviewing and approving the content of the training of Owner personnel for commissioned equipment.
- C. The specific training requirements of District personnel by Subs, Design-Builder SubContractors and vendors is specified in the Division in which the equipment is specified.
- D. For primary HVAC equipment, the Controls Contractor shall provide a short discussion of the control of the equipment during the mechanical or electrical training conducted by others.
- E. All training on Commissioned equipment or systems shall be documented for LEED requirements by filling out "Training Verification Forms" provided by CA. Design-Builder SubContractors and Controls Contractor to fill out forms and submit to CxC for inclusion in Cx Report by CA

3.02 DEMONSTRATION - GENERAL

- A. Demonstrations conducted during system start-up do not qualify as demonstrations for the purposes of this section, unless approved in advance by District.
- B. Demonstrations conducted during Functional Testing need not be repeated unless District personnel training is specified.
- C. Demonstration may be combined with District personnel training if applicable.
- D. Operating Equipment and Systems: Demonstrate operation in all modes, including start-up, shut-down, seasonal changeover, emergency conditions, and troubleshooting, and maintenance procedures, including scheduled and preventive maintenance.
 - 1. Perform demonstrations not less than two weeks prior to Final Inspection.

2. For equipment or systems requiring seasonal operation, perform demonstration for other season within six months.
- E. Non-Operating Products: Demonstrate cleaning, scheduled and preventive maintenance, and repair procedures.
 1. Perform demonstrations not less than two weeks prior to Final Inspection.

3.03 TRAINING - GENERAL

- A. Commissioning Authority will prepare the Training Plan based on draft plans submitted.
- B. Conduct training on-site unless otherwise indicated.
- C. District will provide classroom and seating at no cost to Contractor.
- D. Do not start training until Functional Testing is complete, unless otherwise specified or approved by the Commissioning Authority.
- E. Provide training in minimum two hour segments.
- F. The Commissioning Authority is responsible for determining that the training was satisfactorily completed and will provide approval forms.
- G. Training schedule will be subject to availability of District's personnel to be trained; re-schedule training sessions as required by District; once schedule has been approved by District failure to conduct sessions according to schedule will be cause for District to charge Contractor for personnel "show-up" time.
- H. Review of Facility Policy on Operation and Maintenance Data: During training discuss:
 1. The location of the O&M manuals and procedures for use and preservation; backup copies.
 2. Typical contents and organization of all manuals, including explanatory information, system narratives, and product specific information.
 3. Typical uses of the O&M manuals.
- I. Product- and System-Specific Training:
 1. Review the applicable O&M manuals.
 2. For systems, provide an overview of system operation, design parameters and constraints, and operational strategies.
 3. Review instructions for proper operation in all modes, including start-up, shut-down, seasonal changeover and emergency procedures, and for maintenance, including preventative maintenance.
 4. Provide hands-on training on all operational modes possible and preventive maintenance.
 5. Emphasize safe and proper operating requirements; discuss relevant health and safety issues and emergency procedures.
 6. Discuss common troubleshooting problems and solutions.
 7. Discuss any peculiarities of equipment installation or operation.
 8. Discuss warranties and guarantees, including procedures necessary to avoid voiding coverage.

FOR REFERENCE ONLY

9. Review recommended tools and spare parts inventory suggestions of manufacturers.
 10. Review spare parts and tools required to be furnished by Contractor.
 11. Review spare parts suppliers and sources and procurement procedures.
- J. Be prepared to answer questions raised by training attendees; if unable to answer during training session, provide written response within three days.

END OF SECTION

SECTION 02 41 00 DEMOLITION

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Selective demolition of built site elements.
 - 1. Demolition and removal of existing site improvements within Project area, as indicated on Drawings and as necessary to accomplish the Work, including:
 - a. Asphaltic concrete and portland cement concrete paving.
 - b. Abandoned underground utility lines outside of utility easement.
 - c. Pavement cutting and removal.
 - d. Debris removal.
 - 2. Handling and disposal of removed materials.
 - 3. Dewatering of excavations as necessary to control surface and sub-surface water.
- B. Selective demolition of building elements for alteration purposes.
- C. Abandonment and removal of existing utilities and utility structures.

1.02 RELATED REQUIREMENTS

- A. Section 00 31 00 - Available Project Information: Existing building survey conducted by District; information about known hazardous materials.
- B. Section 01 10 00 - Summary: Limitations on Contractor's use of site and premises.
- C. Section 01 10 00 - Summary: Description of items to be removed by District.
- D. Section 01 10 00 - Summary: Description of items to be salvaged or removed for re-use by Contractor.
- E. Section 01 50 00 - Temporary Facilities and Controls: Site fences, security, protective barriers, and waste removal.
- F. Section 01 57 13 - Temporary Erosion and Sediment Control.
- G. Section 01 60 00 - Product Requirements: Handling and storage of items removed for salvage and relocation.
- H. Section 01 70 00 - Execution and Closeout Requirements: Project conditions; protection of bench marks, survey control points, and existing construction to remain; reinstallation of removed products; temporary bracing and shoring.
- I. Section 01 74 19 - Construction Waste Management and Disposal: Limitations on disposal of removed materials; requirements for recycling.
- J. Section 31 10 00 - Site Clearing: Vegetation and existing debris removal.
- K. Section 31 22 00 - Grading: Topsoil removal.
- L. Section 31 22 00 - Grading: Fill material for filling holes, pits, and excavations generated as a result of removal operations.

- M. Section 31 23 23 - Fill: Filling holes, pits, and excavations generated as a result of removal operations.
- N. Section 32 93 00 - Planting: Relocation of existing trees, shrubs, and other plants.
- O. Section 32 93 00 - Planting: Pruning of existing trees to remain.

1.03 DEFINITIONS

- A. Class III Landfill: A landfill that accepts non-hazardous materials such as household, commercial, and industrial waste, resulting from construction, remodeling, repair, and demolition operations. A Class III landfill must have a solid waste facilities permit from the State of California.
- B. Demolition: Dismantle, raze, destroy or wreck any building or structure or any part thereof.
 - 1. Demolition Waste: Building materials and solid waste resulting from construction, remodeling, repair, cleanup, or demolition operations that are not hazardous. This term includes, but is not limited to, asphalt concrete, Portland cement concrete, brick, lumber, gypsum wallboard, cardboard and other associated packaging, roofing material, ceramic tile, carpeting, plastic pipe, and steel. The materials may include rock, soil, tree stumps, and other vegetative matter resulting from land clearing and landscaping for construction or land development projects.
- C. Environmental Pollution and Damage: The presence of chemical, physical, or biological elements or agents which adversely affect human health or welfare; unfavorably alter ecological balances of importance to human or animal life; affect other species of importance to humanity; or degrade the utility of the environment for aesthetic, cultural or historical purposes.
- D. Inert Fill: A permitted facility that accepts inert waste such as asphalt and concrete exclusively for the purpose of disposal.
 - 1. Inert Solids/Inert Waste: Non-liquid solid waste including, but not limited to, soil and concrete, that does not contain hazardous substances or soluble pollutants at concentrations in excess of water-quality standards established by a regional water board and does not contain significant quantities of decomposable solid waste.
- E. Recycling: The process of sorting, cleansing, treating and reconstituting materials for the purpose of using the altered form in the manufacture of a new product. Recycling does not include burning, incinerating or thermally destroying solid waste.
- F. Remove: Detach or dismantle items from existing construction and dispose of them off site, unless items are indicated to be salvaged or reinstalled.
- G. Remove and Salvage: Detach or dismantle items from existing construction in a manner to prevent damage. Clean, package, label and deliver salvaged items to District in ready-for-reuse condition.
- H. Remove and Reinstall: Detach or dismantle items from existing construction in a manner to prevent damage. Clean and prepare for reuse and reinstall where indicated.
- I. Reuse: The use, in the same or similar form as it was produced, of a material which might otherwise be discarded.
- J. Existing to Remain: Designation for existing items that are not to be removed and that are not otherwise indicated to be salvaged or reinstalled.

K. Waste:

1. Chemical Waste: Includes petroleum products, bituminous materials, salts, acids, alkalis, herbicides, pesticides, organic chemicals and inorganic wastes.
2. Solid Waste: All putrescible and nonputrescible solid, semisolid, and liquid wastes, including garbage, trash, refuse, paper, rubbish, ashes, industrial wastes, demolition and construction wastes, abandoned vehicles and parts thereof, discarded home and industrial appliances, dewatered, treated, or chemically fixed sewage sludge which is not hazardous waste, manure, vegetable or animal solid and semisolid wastes, and other discarded solid and semisolid wastes. "Solid waste" does not include hazardous waste, radioactive waste, or medical waste as defined or regulated by State law.

1.04 REFERENCE STANDARDS

- A. 29 CFR 1926 - Safety and Health Regulations for Construction.
- B. CFC Ch. 33 - Fire Safety During Construction and Demolition.
- C. NFPA 241 - Standard for Safeguarding Construction, Alteration, and Demolition Operations.

1.05 ADMINISTRATIVE REQUIREMENTS

- A. Pre-Construction Conference: Conduct a pre-construction conference one week prior to the start of the work of this section; require attendance by all affected trades.
- B. Convene a conference at the Project site 3 days prior to starting demolition to review the Drawings and Specifications, requirements of authorities having jurisdiction, instructions and requirements of serving utilities, sequencing and interface considerations and project conditions.
- C. Conference shall be attended by Construction Manager, supervisory and quality control personnel of Contractor and all subcontractors performing this and directly-related Work.
- D. Submit minutes of meeting to District, Project Inspector and Architect, for Project record purposes.
- E. Sequencing: Ensure that utility connections are achieved in an orderly and expeditious manner.

1.06 MATERIALS OWNERSHIP

- A. Except for items or materials indicated to be reused, salvaged, reinstalled, or otherwise indicated to remain property of Twin Rivers Unified School District, demolished materials shall become the Contractor's property and shall be removed, recycled, or disposed from Project site in an appropriate and legal manner.
 1. Arrange a meeting no less than ten (10) days prior to demolition with the District or Construction Manager and other designated representatives to review any salvageable items to determine if District wants to retain ownership, and discuss Contractor's Waste Management and Recycling Plan.
- B. Storage or sale of removed items or materials on-site will not be permitted without advance written approval from Construction Manager.

1.07 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Site Plan: Indicate:
 - 1. Vegetation to be protected.
 - 2. Areas for temporary construction and field offices.
 - 3. Areas for temporary and permanent placement of removed materials.
- C. Demolition Plan: Submit demolition plan as required by OSHA and local AHJs.
 - 1. Indicate extent of demolition, removal sequencing, bracing and shoring, and location and construction of barricades and fences.
 - 2. Demolition firm qualifications.
- D. Demolition phase:
 - 1. Proposed dust-control measures.
 - 2. Proposed noise-control measures.
 - 3. Schedule of demolition activities indicating the following:
 - a. Detailed sequence of demolition and removal work, including start and end dates for each activity.
 - b. Dates for shutoff, capping, and continuation of utility services.
 - 4. If hazardous materials are encountered and disposed of, landfill records indicating receipt and acceptance of hazardous wastes by a landfill facility licensed to accept hazardous wastes.
 - 5. Contractor's Waste Management and Recycling Plan: See Section 01 74 19 - Construction Waste Management and Disposal.
 - a. This plan will not otherwise relieve the Contractor of responsibility for adequate and continuing control of pollutants and other environmental protection measures.
 - 6. Contractor's Reuse, Recycling, and Disposal Report: See Section 01 74 19 - Construction Waste Management and Disposal.
- E. Project Record Documents: Accurately record actual locations of capped and active utilities and subsurface construction.
 - 1. Record drawings: Identify and accurately locate capped utilities and other subsurface structural, electrical, or mechanical conditions.

1.08 SUBMITTALS

- A. Demolition and Removal Procedures and Schedule: Submit for Project record only.
- B. Project Record Drawings: Submit in accordance with provisions specified in Section 01 78 00 - Closeout Submittals. Indicate verified locations of underground utilities and storm drainage system on project record drawings.

1.09 QUALITY ASSURANCE

- A. Demolition Firm Qualifications: Company specializing in the type of work required.
 - 1. Minimum of 5 years of documented experience.

1.10 SCHEDULING

- A. Schedule Work to precede new construction.
- B. Describe demolition removal procedures and schedule.
- C. Perform work between the hours of 8am and 5pm, subject to noise abatement regulations and District's approval for noise considerations.

PART 2 PRODUCTS -- NOT USED

PART 3 EXECUTION

3.01 DEMOLITION

- A. Remove paving and curbs required to accomplish new work.
- B. Remove all other paving and curbs within construction limits indicated on drawings.
- C. Within area of new construction, remove foundation walls and footings to minimum 2 feet below finished grade.
 - 1. Below-Grade Construction: Demolish foundation walls and other below-grade construction:
 - a. Completely remove below-grade construction, including foundation walls and footings, unless indicated otherwise on Drawings.
 - b. Break up and completely remove below-grade concrete slabs, in small sizes, suitable for acceptance at recycling or disposal facilities.
 - c. Below-Grade Areas: Completely fill below-grade areas and voids resulting from building demolition operations to street level with satisfactory soil materials.
- D. Remove concrete slabs on grade within construction limits indicated on drawings.
- E. Remove manholes and manhole covers, curb inlets and catch basins.
- F. Remove fences and gates.
- G. Remove other items indicated, for salvage, relocation, and recycling.

3.02 GENERAL PROCEDURES AND PROJECT CONDITIONS

- A. Conform to the relevant Article of the General Conditions, South Coast Air Quality Management District and other applicable regulatory procedures when discovering hazardous or contaminated materials.
- B. Selective Demolition of Site and Building Elements:
 - 1. Use techniques acceptable to authorities having jurisdiction and which will achieve intended results and provide protection of surrounding features to remain.
 - 2. Some items may have been demolished prior to Work of this Contract. Verify existing conditions prior to start of demolition. If items are or have been demolished contact the Architect.
 - 3. Some items may require postponement of demolition until late in Contract Time period.
 - 4. Phase demolition as necessary to provide adequate interfacing of related Work.

FOR REFERENCE ONLY

5. Demolish in an orderly and careful manner. Protect existing foundations, retaining walls, utility structures, other structures and finish materials to remain.
- C. Field Measurements and Conditions:
1. Survey existing conditions and correlate with requirements indicated to determine extent of demolition and recycling required.
 2. In addition to provisions of the Conditions of the Contract, verify dimensions and field conditions prior to construction. Verify condition of substrate and adjoining Work before proceeding with demolition Work. If conflict is found notify Construction Manager, Project Inspector and Architect.
- D. Comply with requirements in Section 01 70 00.
- E. Comply with governing EPA notification regulations before starting demolition. Comply with hauling and disposal regulations of authorities having jurisdiction. Obtain and pay for all permits required.
- F. Environmental Controls
1. Comply with federal, state and local regulations pertaining to water, air, solid waste, recycling, chemical waste, sanitary waste, sediment and noise pollution.
 2. Protection of Natural Resources: Preserve the natural resources within the project boundaries or restore to an equivalent condition.
 3. Confine demolition activities to areas defined by public roads, easements, and work area limits indicated on the drawings.
 4. Temporary Construction: Remove indications of temporary construction facilities, such as haul roads, work areas, structures, stockpiles or waste areas.
 5. Water Resources: Comply with applicable regulations concerning the direct or indirect discharge of pollutants to underground and natural surface waters.
 - a. Oily Substances: Prevent oily or other hazardous substances from entering the ground, drainage areas, or local bodies of water in such quantities as to affect normal use, aesthetics, or produce a measurable ecological impact on the area.
 - 1) Store and service construction equipment at areas designated for collection of oil wastes.
 6. Dust Control, Air Pollution, and Odor Control: Prevent creation of dust, air pollution and odors.
 - a. Use temporary enclosures and other appropriate methods to limit dust and dirt rising and scattering in air to lowest practical level.
 - b. Store volatile liquids, including fuels and solvents, in closed containers.
 - c. Properly maintain equipment to reduce gaseous pollutant emissions.
 7. Noise Control: Perform demolition operations to minimize noise.
 - a. Repetitive, high level impact noise will be permitted only during the times indicated in Section 01 70 00 - Execution and Closeout Requirements.
- G. Comply with applicable codes and regulations for demolition operations and safety of adjacent structures and the public.
1. Obtain required permits.

FOR REFERENCE ONLY

2. Comply with applicable requirements of NFPA 241 and CFC Ch. 33.
 3. Use of explosives is not permitted.
 4. Take precautions to prevent catastrophic or uncontrolled collapse of structures to be removed; do not allow worker or public access within range of potential collapse of unstable structures.
 - a. Survey condition of the building to determine whether removing any element might result in a structural deficiency or unplanned collapse of any portion of the structure or adjacent structures during demolition.
 - 1) Retain a licensed and qualified civil or structural engineer to provide analysis, including calculations, necessary to ensure the safe execution of the demolition work.
 - b. Prevent movement or settlement of adjacent structures. Provide bracing and shoring.
 - c. Perform surveys as the Work progresses to detect hazards resulting from demolition activities.
 5. Provide, erect, and maintain temporary barriers and security devices.
 - a. Provide, erect, and maintain temporary barriers, safety and security devices , for protection of streets, sidewalks, curbs, adjacent property and the public.
 - b. Protection: Protect existing construction and adjacent areas with temporary barriers and security devices in accordance with requirements specified in Section 01 50 00 - Temporary Facilities and Controls.
 - 1) Review location and type of construction of temporary barriers with District and/or the Construction Manager.
 - 2) Barriers shall control dust, debris and provide protection for persons occupying and using adjacent facilities.
 - 3) Maintain protected egress and access at all times, in accordance with requirements of authorities having jurisdiction and with permission of DSA (AHJ having jurisdiction).
 6. Use physical barriers to prevent access to areas that could be hazardous to workers or the public.
 7. Conduct operations to minimize effects on and interference with adjacent structures and occupants.
 8. Do not close or obstruct roadways or sidewalks without permits from authority having jurisdiction.
 9. Conduct operations to minimize obstruction of public and private entrances and exits. Do not obstruct required exits at any time. Protect persons using entrances and exits from removal operations.
 10. Obtain written permission from owners of adjacent properties when demolition equipment will traverse, infringe upon, or limit access to their property.
- H. Do not begin removal until receipt of notification to proceed from District.
- I. Do not begin removal until built elements to be salvaged or relocated have been removed.

FOR REFERENCE ONLY

- J. Do not begin removal until vegetation to be relocated has been removed and vegetation to remain has been protected from damage.
- K. Protect existing structures and other elements to remain in place and not removed.
 - 1. Provide bracing and shoring.
 - 2. Prevent movement or settlement of adjacent structures.
 - 3. Stop work immediately if adjacent structures appear to be in danger.
 - 4. Protect existing landscaping materials, appurtenances, structures and items that are not to be demolished, or are on adjacent property.
 - 5. Mark location of utilities.
- L. Minimize production of dust due to demolition operations. Do not use water if that will result in ice, flooding, sedimentation of public waterways or storm sewers, or other pollution.
- M. Hazardous Materials:
 - 1. Hazardous Materials: Comply with 29 CFR 1926 and state and local regulations.
- N. Remove materials to be re-installed or retained in manner to prevent damage. Store and protect in accordance with requirements of Section 01 60 00 - Product Requirements.
- O. Perform demolition in a manner that maximizes salvage and recycling of materials.
 - 1. Comply with requirements of Section 01 74 19 - Construction Waste Management and Disposal.
 - 2. Dismantle existing construction and separate materials.
 - 3. Set aside reusable, recyclable, and salvageable materials; store and deliver to collection point or point of reuse.
- P. Damages: Promptly repair damages to adjacent facilities caused by demolition operations.
- Q. Partial Removal of Paving and Curbs: Neatly saw cut at right angle to surface.

3.03 EXISTING UTILITIES

- A. Coordinate work with utility companies. Notify utilities before starting work, comply with their requirements, and obtain required permits.
- B. Protect existing utilities to remain from damage.
- C. Do not disrupt public utilities without permit from authority having jurisdiction.
- D. Do not close, shut off, or disrupt existing life safety systems that are in use without at least 7 days prior written notification to District.
- E. Do not close, shut off, or disrupt existing utility branches or take-offs that are in use without at least 3 days prior written notification to District.
- F. Locate and mark utilities to remain; mark using highly visible tags or flags, with identification of utility type; protect from damage due to subsequent construction, using substantial barricades if necessary.
- G. Remove exposed piping, valves, meters, equipment, supports, and foundations of disconnected and abandoned utilities.

- H. Prepare building demolition areas by disconnecting and capping utilities outside the demolition zone. Identify and mark, in same manner as other utilities to remain, utilities to be reconnected.

3.04 SELECTIVE DEMOLITION FOR ALTERATIONS

- A. Existing construction and utilities indicated on drawings are based on casual field observation and existing record documents only.
 - 1. Verify construction and utility arrangements are as indicated.
 - 2. Report discrepancies to Architect before disturbing existing installation.
 - 3. Beginning of demolition work constitutes acceptance of existing conditions that would be apparent upon examination prior to starting demolition.
- B. Separate areas in which demolition is being conducted from areas that remain occupied.
 - 1. Provide, erect, and maintain temporary dustproof partitions of construction specified in Section 01 50 00 in locations indicated on drawings.
 - 2. Provide sound retardant partitions of construction and in locations indicated on drawings.
- C. Maintain weatherproof exterior building enclosure, except for interruptions required for replacement or modifications; prevent water and humidity damage.
- D. Remove existing work as indicated and required to accomplish new work.
 - 1. Remove rotted wood, corroded metals, and deteriorated masonry and concrete; replace with new construction indicated.
 - 2. Remove items indicated on drawings.
 - 3. Remove structural framing members and lower to ground by method suitable to avoid free fall and to prevent ground impact or dust generation.
- E. Services including, but not limited to, HVAC, Plumbing, Fire Protection, Electrical, and Telecommunications: Remove existing systems and equipment as indicated.
 - 1. Maintain existing active systems to remain in operation, and maintain access to equipment and operational components.
 - 2. Where existing active systems serve occupied facilities but are to be replaced with new services, maintain existing systems in service until new systems are complete and ready for service.
 - 3. See Section 01 10 00 - Summary for limitations on outages and required notifications.
 - 4. Verify that abandoned services serve only abandoned facilities before removal.
 - 5. Remove abandoned pipe, ducts, conduits, and equipment, including those above accessible ceilings. Remove back to source of supply where possible, otherwise cap stub and tag with identification.
- F. Protect existing work to remain.
 - 1. Prevent movement of structure. Provide shoring and bracing as required.
 - 2. Perform cutting to accomplish removal work neatly and as specified for cutting new work.
 - 3. Repair adjacent construction and finishes damaged during removal work.

FOR REFERENCE ONLY

4. Patch to match new work.

3.05 DEBRIS AND WASTE REMOVAL

- A. Remove debris, junk, and trash from site.
- B. Remove materials not to be reused on site; comply with requirements of Section 01 74 19 - Waste Management.
- C. Remove temporary work.
- D. Leave site in clean condition, ready for subsequent work.
- E. Clean up spillage and wind-blown debris from public and private lands.

END OF SECTION

SECTION 03 10 00 CONCRETE FORMING AND ACCESSORIES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Formwork for cast-in-place concrete, with shoring, bracing and anchorage.
- B. Openings for other work.
- C. Form accessories.
- D. Form stripping.

1.02 RELATED REQUIREMENTS

- A. Section 03 20 00 - Concrete Reinforcing.
- B. Section 03 30 00 - Cast-in-Place Concrete.
- C. Section 04 20 00 - Unit Masonry: Reinforcement for masonry.
- D. Section 05 12 00 - Structural Steel Framing: Placement of embedded steel anchors and plates in cast-in-place concrete.
- E. Section 05 31 00 - Steel Decking: Placement of steel anchors in composite decking.
- F. Section 05 50 00 - Metal Fabrications: Placement of embedded steel anchors and plates in cast-in-place concrete.
- G. Section 31 23 16 - Excavation: Shoring and underpinning for excavation.
- H. Section 32 13 13 - Site Concrete: Sidewalks, curbs and gutters.

1.03 REFERENCE STANDARDS

- A. ACI 117 - Specification for Tolerances for Concrete Construction and Materials.
- B. ACI 301 - Specifications for Concrete Construction.
- C. ACI 318 - Building Code Requirements for Structural Concrete.
- D. ACI 347R - Guide to Formwork for Concrete.
- E. ASTM D695 - Standard Test Method for Compressive Properties of Rigid Plastics.
- F. PS 1 - Structural Plywood.
- G. CBC Chapter 19A.

1.04 DEFINITIONS

- A. Unexposed Finish: A general-use finish, with no appearance criteria, applicable to all formed concrete concealed from view after completion of construction.
- B. Exposed Finish: A general-use finish applicable to all formed concrete exposed to view and including surfaces which may receive a paint coating (if any).

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.

- B. Product Data: Provide data on void form materials and installation requirements.
 - 1. Form release agent.
- C. Shop Drawings: Indicate pertinent dimensions, materials, bracing, and arrangement of joints and ties.

1.06 QUALITY ASSURANCE

- A. Industry Standard: Formwork design and construction shall be in accordance with ACI 301, ACI 318, and ACI 347R.
- B. Maintain one copy of each installation standard on site throughout the duration of concrete work.
- C. Regulatory Requirements: Conform to formwork construction requirements of the California Building Code (CBC) Title 24, Part 2, Chapter 19A as amended and adopted by authorities having jurisdiction.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Deliver prefabricated forms and installation instructions in manufacturer's packaging.
- B. Store prefabricated forms off ground in ventilated and protected manner to prevent deterioration from moisture.

PART 2 PRODUCTS

2.01 FORMWORK - GENERAL

- A. Provide concrete forms, accessories, shoring, and bracing as required to accomplish cast-in-place concrete work.
- B. Design and construct concrete that complies with design with respect to shape, lines, and dimensions.
- C. Chamfer outside corners of beams, joists, columns, and walls.
- D. Comply with applicable state and local codes with respect to design, fabrication, erection, and removal of formwork.
- E. Comply with relevant portions of ACI 301, ACI 318, and ACI 347R.
- F. Provide materials for contact with concrete which impart suitable surface quality to completed concrete. Use the following form types:
 - 1. Forms for Exposed Finish Concrete:
 - a. Plywood, metal, metal-framed plywood faced, or other acceptable panel-type materials to provide continuous, straight, smooth, exposed surfaces.
 - b. Furnish in largest practical sizes to minimize number of joints and to conform to joint system shown on the Drawings.
 - 2. Forms for Unexposed Finish Concrete:
 - a. Plywood, lumber, metal, or another acceptable material.
 - b. Provide lumber dressed on at least two edges and one side for tight fit.

- c. When unexposed concrete is intended to receive waterproofing, provide form as for exposed finish concrete.
- G. Provide materials to construct formwork to support forming materials in contact with concrete, of sufficient capacity to withstand pressures of concrete placement and to support concrete in place until cured, without distortion.

2.02 WOOD FORM MATERIALS

- A. Plywood for Architectural Concrete: Marine Grade, APA B-B Plyform Class 1.
 - 1. APA proprietary concrete form panels designed for high reuse.
 - 2. HDO for very smooth concrete finish, in Structural I, and with special overlays.
 - 3. Bond Classification: Exterior. Common Performance Categories: 19/32, 5/8, 11/16, 23/32, 3/4.
- B. Softwood Plywood for Concealed Surfaces: PS 1, undamaged face C Grade, Group 2 Plugged EXT or APA Structural I Sheathing.
- C. Hardboard: For curved surfaces, tempered hardboard, Masonite Corp., or equal.
- D. Lumber: Douglas fir or douglas fir-larch species; appropriate for intended use grade; with grade stamp clearly visible.
 - 1. Sound and undamaged straight edges, and solid knots, to maintain principal shores to support concrete until minimum strength is achieved as approved by Structural Engineer.
- E. Embedded Nailers: Clear all heart redwood or pressure preservative-treated (PPTDF) douglas fir, edges reverse beveled to key into concrete.

2.03 FORMWORK ACCESSORIES

- A. Form Ties: Removable, adjustable-length or snap-off type, galvanized metal, fixed length, cone type, with waterproofing washer, free of defects that could leave holes larger than 1 inch in concrete surface.
- B. Form Release Agent: Capable of releasing forms from hardened concrete without staining or discoloring concrete or forming bugholes and other surface defects, compatible with concrete and form materials, and not requiring removal for satisfactory bonding of coatings to be applied.
 - 1. Do not use materials containing diesel oil or petroleum-based compounds.
 - 2. Does not impair subsequent treatments of concrete surfaces or bond of applied coatings.
 - 3. Products:
 - a. Nox-Crete Inc; BIO-NOX: www.nox-crete.com/#sle.
 - b. SpecChem, LLC; Bio Strip WB (water-based): www.specchemllc.com/#sle.
 - c. W. R. Meadows, Inc; Duogard II (water-based): www.wrmeadows.com/#sle.
 - d. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- C. Dowel Sleeves: Plastic sleeve and nailable plastic base for smooth, round, steel load-transfer dowels.
 - 1. Thickness: 0.125 inch
 - 2. Compression Resistance, ASTM D695: 5,500-8,000 PSI.

3. Products:
 - a. BoMetals, Inc: www.bometals.com/#sle.
 - b. Sika Corporation; Speed Dowel: usa.sika.com
 - c. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- D. Nails, Spikes, Lag Bolts, Through Bolts, Anchorages: Sized as required, of sufficient strength and character to maintain formwork in place while placing concrete.
- E. Embedded Anchor Shapes, Plates, Angles and Bars: As specified in Section 05 50 00.
- F. Screed Pins and Chairs:
 1. Provide units that leave no metal closer than 1-1/2 inch to the plane of the exposed concrete surface.
 2. Manufacturers:
 - a. Grann Adjustable Quick Screed (800/554-7266).
 - b. Dayton Richmond (800/745-3700).
 - c. Aztek (877/531-3344).
 - d. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify lines, levels and centers before proceeding with formwork. Ensure that dimensions agree with drawings.

3.02 SYSTEM REQUIREMENTS

- A. Formwork Design Requirements: Formwork products and execution specified herein are for finish surface quality only.
 1. Design, layout and construction of formwork shall be solely the responsibility of the Contractor.
 2. Design and construct formwork, shoring and bracing to conform to California Building Code (CBC), Title 24, Part 2, Chapter 19A requirements and ACI 318.
 3. Resulting concrete shall conform to shapes, lines and dimensions indicated and required.
- B. Coordination:
 1. Coordinate Work specified in this Section with other Sections which require placement of embedded products and provision of openings and recesses.
 2. If formwork is placed after reinforcement, resulting in insufficient concrete cover over reinforcement, request instructions from the Architect before proceeding.

3.03 EARTH FORMS

- A. Earth (Soil) Forms, General: Except as otherwise indicated on Drawings, conform to ACI 301, ACI 347R and California Building Code (CBC) requirements. Refer also to notes on Structural Drawings.
- B. Hand trim sides and bottom of earth forms. Remove loose soil prior to placing concrete.

3.04 ERECTION - FORMWORK

- A. Erect formwork, shoring and bracing to achieve design requirements, in accordance with requirements of ACI 301, ACI 347R and California Building Code (CBC) Title 24, Part 2 requirements.
- B. Provide bracing to ensure stability of formwork. Shore or strengthen formwork subject to overstressing by construction loads.
 - 1. Use form ties of sufficient strength and sufficient quantities to prevent formwork spreading.
 - 2. Maintain principal shores to support concrete until minimum required strength is achieved.
- C. Arrange and assemble formwork to permit dismantling and stripping. Do not damage concrete during stripping. Permit removal of remaining principal shores.
 - 1. Design and fabricate forms for easy removal, without impact, shock, or damage to concrete surfaces or other portions of the work.
 - 2. Design to support all applied loads until concrete is adequately cured, within allowable tolerances and deflection limits.
- D. Align joints and make watertight. Keep form joints to a minimum. Make forms watertight to prevent leakage of concrete mortar. Locate form joints, at exposed concrete, to be symmetrical about center of panel, unless otherwise noted. Align joints symmetrically at exposed conditions.
- E. Permanent openings: Provide openings to accommodate Work specified in other Sections. Size and locate openings accurately. Securely support items built into forms; provide additional bracing at openings and discontinuities in formwork.
- F. Temporary openings: Provide temporary openings for cleaning and inspection. Provide drain openings at bottoms of formwork to allow water to drain. Locate temporary openings in most inconspicuous locations at base of forms, closed with tight-fitting panels designed to minimize appearance of joints in finished concrete Work.
- G. Obtain approval before framing openings in structural members that are not indicated on drawings.
- H. Coordinate this section with other sections of work that require attachment of components to formwork.
- I. If formwork is placed after reinforcement, resulting in insufficient concrete cover over reinforcement, request instructions from Architect before proceeding.
- J. Inspection: Before placing of concrete, and after placement of reinforcing steel in the forms, provide notification so that proper inspection can be made. Make such notification at least 2 working days in advance of placing concrete.
- K. Rejection of Defective Work: Any movement or bellying of forms during construction or variations in excess of the tolerances specified shall be considered just cause for the removal of such forms and, in addition, the concrete construction so affected. Reconstruct forms, place new concrete and required reinforcing steel at no additional cost to the District.

3.05 APPLICATION - FORM RELEASE AGENT

- A. Form Release Agent: Provide either form materials with factory applied non-absorptive liner or field applied form coating to comply with applicable air quality regulations for VOC. If field applied coating is employed, thoroughly clean and recondition formwork and reapply coating before each use. Rust on form surfaces is not acceptable.
- B. Apply form release agent on formwork in accordance with manufacturer's recommendations.
- C. Apply prior to placement of reinforcing steel, anchoring devices, and embedded items.
- D. Do not apply form release agent where concrete surfaces to receive special finishes or applied coverings that are affected by agent. Soak inside surfaces of untreated forms with clean water. Keep surfaces coated prior to placement of concrete.

3.06 INSERTS, EMBEDDED PARTS, AND OPENINGS

- A. Provide formed openings where required for items to be embedded in passing through concrete work.
 - 1. Install accessories in accordance with manufacturer's instructions and referenced standards, level, straight and plumb.
- B. Locate and set in place items that are cast directly into concrete.
- C. Coordinate with work of other sections in forming and placing openings, slots, reglets, recesses, sleeves, bolts, anchors, other inserts, and components of other work.
 - 1. Openings: Size and locate formed openings, depressions, recesses and chases to accommodate products to be applied to, built into and pass through concrete Work. Coordinate size, location and placement of inserts, embedded products, openings and recesses with Work specified in other Sections.
 - 2. Anchors and Other Devices: Set and build into concrete formwork anchorage devices and other embedded products required for Work to be attached to or supported by concrete elements.
 - 3. Locating Embedded Products and Openings: Use setting drawings, diagrams, instructions and templates to set embedded products.
 - 4. Screeds: Set screeds and establish level for tops of concrete slabs and leveling for finish surfaces. Shape surfaces as indicated on the Drawings. Provide cradle, pad or base type screed supports for concrete over waterproof membranes and vapor retarders.
- D. Install accessories in accordance with manufacturer's instructions, so they are straight, level, and plumb. Ensure items are not disturbed during concrete placement.
- E. Provide temporary ports or openings in formwork where required to facilitate cleaning and inspection. Locate openings at bottom of forms to allow flushing water to drain.
- F. Close temporary openings with tight fitting panels, flush with inside face of forms, and neatly fitted so joints are not apparent in exposed concrete surfaces.

3.07 FORM CLEANING

- A. Clean forms as erection proceeds, to remove foreign matter within forms.
- B. Clean formed cavities of debris prior to placing concrete.

FOR REFERENCE ONLY

1. At above grade forms, flush with water or use compressed air to remove remaining foreign matter. Ensure that water and debris drain to exterior through clean-out ports.
 2. During cold weather, remove ice and snow from within forms. Do not use de-icing salts. Do not use water to clean out forms, unless formwork and concrete construction proceed within heated enclosure. Use compressed air or other means to remove foreign matter.
- C. Formwork Reuse: Do not reuse wood and plywood forming materials which contact concrete, except as follows:
1. High density plywood may be cleaned and reused for exposed concrete.
 2. Unfaced plywood may be reused for concealed concrete.
 3. Steel and fiberglass forming materials may be cleaned and reused.
- D. Patching and Repairs: Patch tie holes with sheet metal patches and restore forms to like new condition prior to reuse.

3.08 FORMWORK TOLERANCES

- A. Construct formwork to maintain tolerances required by ACI 117, unless otherwise indicated.
1. Also as specified in ACI 301, ACI 318, and ACI 347R, unless otherwise specified or indicated.
- B. Camber slabs and beams in accordance with ACI 301.

3.09 FIELD QUALITY CONTROL

- A. An independent testing agency will perform field quality control tests, as specified in Section 01 40 00 - Quality Requirements.
- B. Inspect erected formwork, shoring, and bracing to ensure that work is in accordance with formwork design, and to verify that supports, fastenings, wedges, ties, and items are secure.
1. Comply with CBC Table 1705A.3, item 12.
- C. Do not reuse wood formwork more than 3 times for concrete surfaces to be exposed to view. Do not patch formwork.

3.10 FORM REMOVAL

- A. Do not remove forms or bracing until concrete has gained sufficient strength to carry its own weight and imposed loads.
1. Comply with California Building Code (CBC) requirements.
 2. Formwork supporting weight of concrete may not be removed until concrete has reached a minimum of specified 28-day compressive strength and no earlier than 21 days after pour.
 3. Removal of Load Bearing Formwork:
 - a. Do not remove shoring and forms supporting weight of concrete, such as beam soffits, joists, slabs, and other structural elements, until concrete has attained its 28 day specified compressive strength, unless otherwise specified or permitted by the Structural Engineer of Record.

- b. Determine the actual compressive strength has attained is adequate to support the weight of the concrete and superimposed loads.
- c. Maintain curing and protection operations after form removal.
- 4. Removal of Non Load Bearing Formwork After Superimposed Loads or as Approved by Engineer:
 - a. Provided that concrete has hardened sufficiently, that it is not damaged, and has achieved sufficient strength to support its own weight and all imposed construction and design loads, forms not actually supporting weight of concrete or weight of soffit forms may be removed after concrete has cured at not less than 50 degrees F for 24 hours.
 - b. Maintain curing and protection operations after form removal.
- B. Loosen forms carefully. Do not wedge pry bars, hammers, or tools against finish concrete surfaces scheduled for exposure to view.
 - 1. Remove formwork progressively so no unbalanced loads are imposed on structure. Remove formwork without damaging concrete surfaces.
 - 2. Remove or snap off metal spreader ties inside wall surface. Cut nails and form ties off flush and leave surfaces level and clean.
- C. Store removed forms to prevent damage to form materials or to fresh concrete. Discard damaged forms.

3.11 PATCHING

- A. Schedule: Patch forming and tie holes immediately after form removal.
- B. Cleaning: Clean surface of all loose materials and soiling.
- C. Patching: Patch all holes and depressions with grouting gun and grout mix of one part cement and 2-1/2 parts mortar sand.

3.12 FORMWORK SCHEDULE

- A. Footings and Walls, Not Exposed to View: Site fabricated plywood or lumber, coated with form release agent.
- B. Footings and Walls, Exposed to View: Site fabricated plywood, coated with form release agent compatible with applied finish coatings.

END OF SECTION

FOR REFERENCE ONLY

SECTION 03 20 00 CONCRETE REINFORCING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Reinforcing steel for cast-in-place concrete.
- B. Supports and accessories for steel reinforcement.

1.02 RELATED REQUIREMENTS

- A. Section 03 10 00 - Concrete Forming and Accessories.
- B. Section 03 30 00 - Cast-in-Place Concrete.
- C. Section 04 20 00 - Unit Masonry: Reinforcement for masonry.
- D. Division 26 - Electrical: Grounding connection to concrete reinforcement.

1.03 REFERENCE STANDARDS

- A. ASTM A615/A615M - Standard Specification for Deformed and Plain Carbon-Steel Bars for Concrete Reinforcement.
- B. ASTM A706/A706M - Standard Specification for Deformed and Plain Low-Alloy Steel Bars for Concrete Reinforcement.
- C. ASTM A996/A996M - Standard Specification for Rail-Steel and Axle-Steel Deformed Bars for Concrete Reinforcement.
- D. ASTM A1064/A1064M - Standard Specification for Carbon-Steel Wire and Welded Wire Reinforcement, Plain and Deformed, for Concrete.
- E. AWS B2.1/B2.1M - Specification for Welding Procedure and Performance Qualification.
- F. AWS A5.5/A5.5M - Specification for Low-Alloy Steel Electrodes for Shielded Metal Arc Welding.
- G. AWS D1.4/D1.4M - Structural Welding Code - Steel Reinforcing Bars.
- H. CRSI (DA4) - Manual of Standard Practice.
- I. CRSI (P1) - Placing Reinforcing Bars, 10th Edition.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data:
 - 1. Reinforcement supporting and spacing devices at exposed concrete only, to demonstrate non-corroding and non-staining characteristics.
 - 2. Adhesive compounds.
- C. Manufacturer's Certificate: Certify that reinforcing steel and accessories supplied for this project meet or exceed specified requirements.

FOR REFERENCE ONLY

- D. Welders' Qualification Statement: Welders' certificates in accordance with AWS B2.1/B2.1M and dated no more than 12 months before start of scheduled welding work.
- E. Reports: Submit certified copies of mill test report of reinforcement materials analysis.
- F. Quality Control Submittals: Submit the following information related to quality assurance requirements specified:
 - 1. Certifications: Submit to the testing laboratory mill test certificates for all reinforcing steel, showing physical and chemical analysis. If steel is to be welded, include in chemical analysis the percentages of carbon, manganese, copper, nickel, and chromium, and optionally the percentages of molybdenum and vanadium.
 - 2. Certifications: If steel is to be welded, submit certifications to the testing laboratory signed by AWS Certified Welding Inspector (CWI) of prequalified welding procedures, qualifications of welding procedures unless prequalified, qualification of welding operators, and qualification of welders.
- G. Welding Procedure Specification Submittal: Submit to Testing Laboratory written Welding Procedure Specifications (WPS) as defined by AWS D1.4/D1.4M. The WPS shall be prepared by the Fabricator for review and approval by the Architect (Structural Engineer) and Testing Laboratory as complying with specified criteria, and shall be readily available to the welding inspector.

1.05 QUALITY ASSURANCE

- A. Perform work of this section in accordance with ACI 318, CRSI (DA4), and CRSI (P1).
 - 1. Maintain one copy of each document on project site.
- B. Regulatory Requirements: Conform to California Building Code (CBC) Title 24 Part 2, Chapter 19A requirements as amended and adopted by authorities having jurisdiction, for details of reinforcement.
- C. Provide Architect, Project Inspector, and Special Inspector with access to fabrication plant to facilitate inspection of reinforcement. Provide notification of commencement and duration of shop fabrication in sufficient time to allow inspection.
- D. Welder Qualifications: Welding processes and welding operators qualified in accordance with AWS D1.4/D1.4M and no more than 12 months before start of scheduled welding work.
 - 1. Only AWS Certified Welding Inspectors shall be used for tests and qualifications associated with welding of reinforcing steel.
 - 2. Only AWS qualified welders or welding operators shall perform welding of reinforcing steel.
- E. Coordinate Work specified in this Section with other Sections which require placement of embedded products and provision of openings and recesses.
- F. If formwork is placed after reinforcement, resulting in insufficient concrete cover over reinforcement, request instructions from Architect (Structural Engineer) before proceeding.

1.06 DELIVERY, STORAGE AND HANDLING

- A. Delivery: Deliver reinforcement bars new and free from rust and mill scale in original bundles marked with durable identification tags.

- B. Storage: Store reinforcement to avoid excessive rusting or fouling with grease, oil, dirt or other bond-weakening coatings.
- C. Handling: Take precautions to maintain reinforcement identification after bundles are broken.

PART 2 PRODUCTS

2.01 REINFORCEMENT

- A. Reinforcing Steel: ASTM A615/A615M, Grade 60 (60,000 psi).
 - 1. Deformed billet-steel bars.
 - 2. Unfinished.
- B. Reinforcing Steel: ASTM A706/A706M, Grade 60 (60,000 psi), deformed low-alloy steel bars.
 - 1. Unfinished.
 - 2. Carbon Content: 0.55 % maximum.
- C. Reinforcing Steel: #3 Deformed bars, ASTM A615/A615M Grade 40 (280), Type A.
- D. Tie Wire: ASTM A1064/A1064M steel wire, unfinished.
- E. Reinforcement Accessories:
 - 1. Tie Wire: Annealed, minimum 16 gauge, 0.0508 inch.
 - 2. Chairs, Bolsters, Bar Supports, Spacers: Wire-bar-type devices, complying with CRSI (DA4), for spacing, supporting and fastening reinforcing bars and welded wire reinforcement in place. Sized and shaped for adequate support of reinforcement during concrete placement.
 - a. Supports at Slab on Grade: Provide devices with load-bearing pads or horizontal runners where base material does not support chair legs, to prevent puncture of vapor retarder/barrier or provide precast concrete block bar supports of equal or greater strength to specified concrete.
 - b. Corrosion Resistance:
 - 1) Provide stainless steel or plastic components for placement within 1-1/2 inches of weathering surfaces.
 - (a) Provide plastic coated, plastic-tipped (CRSI, Class 1) or stainless steel types at exposed-to-view concrete surfaces.
 - (b) Provide only stainless steel (CRSI Class 2) at exterior exposed surfaces to be painted.
 - 3. Welding Electrodes: AWS A5.5/A5.5M E80XX, low hydrogen, with a minimum yield point of 80,000 psi, for welding grade 60 reinforcing steel.

2.02 RE-BAR SPLICING:

- A. Coupler Systems: Mechanical devices for splicing reinforcing bars; capable of developing 160% of steel reinforcing design strength in tension and compression.
- B. Dowel Bar Splicer with Dowel-Ins: Mechanical devices for connecting dowels; Type II capable of developing 160% of steel reinforcing design strength in tension and compression.

- C. Grout: Cementitious, non-metallic, non-shrink grout for use with manufacturer's grout sleeve reinforcing bar coupler system.

2.03 FABRICATION

- A. Fabricate concrete reinforcing in accordance with CRSI (DA4) - Manual of Standard Practice.
- B. Welding of reinforcement is permitted only with the specific approval of Architect. Perform welding in accordance with AWS D1.4/D1.4M.
- C. Fusion welded reinforcing steel assemblies are not permitted.
- D. Locate reinforcing splices not indicated on drawings at point of minimum stress. See Structural Drawings,
 - 1. Review locations of splices with Architect (Structural Engineer) before fabrication and placement. .

PART 3 EXECUTION

3.01 PREPARATION

- A. Cleaning: Clean reinforcement to remove loose rust and mill scale, soil, and other materials which may reduce or destroy bond with concrete.
- B. Adjustment and Inspection: Do not bend or straighten reinforcement in a manner injurious to material. Do not use bars with kinks or bends not shown on Drawings and reviewed shop drawings, or bars with reduced cross-section due to corrosion or other cause.
- C. Do not bend bars No. 5 and larger in the field.
- D. Do not bend bars more than once in the same location.

3.02 PLACEMENT

- A. General: Place and secure reinforcement as specified herein, as indicated and noted on Drawings and in compliance with recommended details and methods of reinforcement placement and support specified in CRSI Placing Reinforcing Bars.
- B. Place, support and secure reinforcement against displacement. Do not deviate from required position.
 - 1. Set wire ties so ends are directed into concrete, not toward exposed concrete surfaces.
- C. Do not displace or damage vapor barrier.
- D. Accommodate placement of formed openings.
- E. Maintain concrete cover around reinforcing as indicated on Structural Drawings:
- F. Comply with applicable code for concrete cover over reinforcement.
 - 1. If not otherwise indicated on Drawings or specified herein, provide concrete cover in compliance with ACI 318.
- G. Bond and ground all reinforcement to requirements of Division 26.
- H. Coordination: Locate reinforcement to accommodate embedded products and formed openings and recesses.

FOR REFERENCE ONLY

- I. Slab on Grade Reinforcement: Do not displace or damage vapor retarder/barrier at slab on grade.
- J. Wire Reinforcement Placement: Place reinforcement in sheets as long as practicable, lapping adjoining pieces at least one full mesh and lace splices with 16 gage wire. Offset end laps in adjacent widths to prevent continuous laps. Extend reinforcement to within 1-inch of edge at slabs on grade. Cut mesh at expansion joints and full depth control joints.
- K. Dowels: Secure tie dowels in place before depositing concrete. Provide No. 3 bars for securing dowels where no other reinforcement is provided.
- L. Reinforcement Splices, General: Provide standard reinforcement splices by lapping ends, placing bars in contact and tightly wire tying. Comply with details and requirements of ACI 318 for minimum lap of spliced bars and criteria indicated on the Drawings.
 - 1. Clearances for Splices: Wherever possible, provide minimum 1-1/2 inch clearance between sets of splices. Stagger horizontal bars so that adjacent splices are minimum 48 inches apart.
- M. Reinforcement Supports: Support reinforcement on metal chairs, spacers or metal hangers to provide required coverage and to properly locate reinforcement. Do not use wood. Avoid cutting or puncturing vapor retarder/barrier during reinforcement placement and concreting operations. Repair damages before placing concrete.
 - 1. Support Spacing: Space chairs and accessories in conformance with CRSI Placing Reinforcing Bars.
- N. Welding of Reinforcement Steel
 - 1. Welding: Perform welding under continuous inspection and supervision of a qualified Registered Deputy Inspector employed by testing and inspection agency. Weld reinforcement as indicated on Drawings.
 - 2. Carbon Equivalent (CE): CE of reinforcing bars or splice materials shall be calculated from chemical composition as indicated in mill report by following formula:
 - a. ASTM A615/A615M Bars:
$$CE = \%C + (\%Mn/6)$$
 - b. ASTM A706/A706M Bars:
 - 1) $CE = \%C + (\%Mn/6) + (\%Cu/40) + (\%Ni/20) + (\%CR/10) - (\%Mo/50) - (\%V/10)$
Where: C = Carbon; MN = Manganese; CU = Copper; NI = Nickel; CR = Chromium; MO = Molybdenum; V = Vanadium
 - 3. If mill test report is not available, make chemical analysis of bars representative of bars to be welded. Bars with CE above 0.75 shall not be welded.
 - 4. No welds shall be made at bends in reinforcing bars. Welds to be 1 inch minimum from bends
- O. Corrections During Concrete Placement: Maintain reinforcing steel workers on-site during placement of concrete for resetting reinforcement displaced by runways, workers and other causes.

3.03 FIELD QUALITY CONTROL

- A. An independent testing agency, as specified in Section 01 40 00 - Quality Requirements, will inspect installed reinforcement for compliance with contract documents before concrete placement.
 - 1. Concrete floor slabs on grade are to be continuously inspected as recommended in the geotechnical report.
- B. Inspector of Record, as specified in Section 01 45 33 - Code-Required Special Inspections, will inspect installed reinforcement for conformance to contract documents before concrete placement.
 - 1. Concrete floor slabs on grade are to be continuously inspected as recommended in the geotechnical report.
- C. Defective Reinforcement Work: The following shall be considered defective and may be ordered to be removed and reconstructed at no change in Contract Time or Sum.
 - 1. Bars with kinks or bends not shown on Drawings.
 - 2. Bars injured due to bending or straightening.
 - 3. Bars heated or bent.
 - 4. Reinforcement not placed in accordance with Drawings and Specifications.
 - 5. Rusty or oily bars.
 - 6. Bars exposed in surface of concrete or without adequate concrete cover.

END OF SECTION

FOR REFERENCE ONLY

SECTION 03 30 00 CAST-IN-PLACE CONCRETE

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Floors and slabs on grade.
- B. Joint devices associated with concrete work.
- C. Miscellaneous concrete elements, including equipment pads and thrust blocks.
- D. Concrete curing.

1.02 RELATED REQUIREMENTS

- A. Section 03 10 00 - Concrete Forming and Accessories: Forms and accessories for formwork.
- B. Section 03 20 00 - Concrete Reinforcing.
- C. Section 03 35 11 - Concrete Floor Finishes: Densifiers, hardeners, applied coatings, and polishing.
- D. Section 07 92 00 - Joint Sealants: Products and installation for sealants and joint fillers for saw cut joints and isolation joints in slabs.
- E. Section 32 13 13 - Site Concrete: Sidewalks, curbs and gutters.

1.03 REFERENCE STANDARDS

- A. ACI CODE-318 - Building Code Requirements for Structural Concrete and Commentary.
- B. ACI PRC-211.1 - Selecting Proportions for Normal-Density and High Density-Concrete - Guide.
- C. ACI 302.2R - Guide for Concrete Slabs that Receive Moisture-Sensitive Flooring Materials.
- D. ACI 318 - Building Code Requirements for Structural Concrete.
- E. ACI PRC-302.1 - Guide to Concrete Floor and Slab Construction.
- F. ACI PRC-302.2 - Concrete Slabs that Receive Moisture-Sensitive Flooring Materials - Guide.
- G. ACI PRC-304 - Guide for Measuring, Mixing, Transporting, and Placing Concrete.
- H. ACI PRC-305 - Guide to Hot Weather Concreting.
- I. ACI PRC-306 - Guide to Cold Weather Concreting.
- J. ACI PRC-308 - Guide to External Curing of Concrete.
- K. ACI SPEC-301 - Specifications for Concrete Construction.
- L. ASTM C33/C33M - Standard Specification for Concrete Aggregates.
- M. ASTM C39/C39M - Standard Test Method for Compressive Strength of Cylindrical Concrete Specimens.
- N. ASTM C94/C94M - Standard Specification for Ready-Mixed Concrete.
- O. ASTM C109/C109M - Standard Test Method for Compressive Strength of Hydraulic Cement Mortars (Using 2-in. or [50 mm] Cube Specimens).

FOR REFERENCE ONLY

- P. ASTM C111/C111M - Standard Test Methods for Sampling and Testing Fly Ash or Natural Pozzolans for Use in Portland-Cement Concrete.
- Q. ASTM C143/C143M - Standard Test Method for Slump of Hydraulic-Cement Concrete.
- R. ASTM C150/C150M - Standard Specification for Portland Cement.
- S. ASTM C171 - Standard Specification for Sheet Materials for Curing Concrete.
- T. ASTM C309 - Standard Specification for Liquid Membrane-Forming Compounds for Curing Concrete.
- U. ASTM C494/C494M - Standard Specification for Chemical Admixtures for Concrete.
- V. ASTM C579 - Standard Test Methods for Compressive Strength of Chemical-Resistant Mortars, Grouts, Monolithic Surfacing, and Polymer Concretes.
- W. ASTM C618 - Standard Specification for Coal Ash and Raw or Calcined Natural Pozzolan for Use in Concrete.
- X. ASTM C827/C827M - Standard Test Method for Change in Height at Early Ages of Cylindrical Specimens of Cementitious Mixtures.
- Y. ASTM C881/C881M - Standard Specification for Epoxy-Resin-Base Bonding Systems for Concrete.
- Z. ASTM C979/C979M - Standard Specification for Pigments for Integrally Colored Concrete.
- AA. ASTM C1059/C1059M - Standard Specification for Latex Agents for Bonding Fresh to Hardened Concrete.
- BB. ASTM C1107/C1107M - Standard Specification for Packaged Dry, Hydraulic-Cement Grout (Nonshrink).
- CC. ASTM C1240 - Standard Specification for Silica Fume Used in Cementitious Mixtures.
- DD. ASTM C1315 - Standard Specification for Liquid Membrane-Forming Compounds Having Special Properties for Curing and Sealing Concrete.
- EE. ASTM C1602/C1602M - Standard Specification for Mixing Water Used in the Production of Hydraulic Cement Concrete.
- FF. ASTM D695 - Standard Test Method for Compressive Properties of Rigid Plastics.
- GG. ASTM D1709 - Standard Test Methods for Impact Resistance of Plastic Film by the Free-Falling Dart Method.
- HH. ASTM D2103 - Standard Specification for Polyethylene Film.
- II. ASTM E1643 - Standard Practice for Selection, Design, Installation, and Inspection of Water Vapor Retarders Used in Contact with Earth or Granular Fill Under Concrete Slabs.
- JJ. ASTM E1745 - Standard Specification for Plastic Water Vapor Retarders Used in Contact with Soil or Granular Fill under Concrete Slabs.
- KK. ASTM F1869 - Standard Test Method for Measuring Moisture Vapor Emission Rate of Concrete Subfloor Using Anhydrous Calcium Chloride.
- LL. ASTM F2170 - Standard Test Method for Determining Relative Humidity in Concrete Floor Slabs Using in situ Probes.
- MM. {RSTEMP#10005050}
- NN. DSA IR 19-3 - Fly Ash and Natural Pozzolans Used in Concrete.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Submit manufacturers' data on manufactured products showing compliance with specified requirements and installation instructions.
 - 1. For curing compounds, provide data on method of removal in the event of incompatibility with floor covering adhesives.
 - 2. For membrane-forming, moisture emission-reducing, curing and sealing compound, provide manufacturer's installation instructions,.
- C. Mix Design: Submit proposed concrete mix design.
 - 1. Indicate proposed mix design complies with requirements of ACI SPEC-301, Section 4 - Concrete Mixtures.
 - 2. Indicate proposed mix design complies with requirements of ACI CODE-318, Chapter 19 - Concrete: Design and Durability Requirements, and Chapter 26 - Construction Documents and Inspection.
 - a. Reports must include all the data as required to verify conformance with ACI CODE-318, Section 26.4.2.2, and the following:
 - 1) Mix design identification number.
 - 2) Cement certification.
 - 3) Fly ash certification of compliance or test data.
 - 4) Admixture data.
 - 5) Aggregate test data.
 - 3. Mix Designs Utilizing 15% Or More Fly Ash: Proportioning conform to ACI CODE-318, Section 26.4.3. Based on field experience or trial mixtures, or both, per ACI 318, Section 26.4. Proportioning per ACI 318, Section 26.4.2.2 (without field experience or trial mixtures) is not permitted.
 - 4. Mix Design Review and Approval Process: An engineer from a DSA approved (LEA) testing laboratory shall review the mix design report and the design professional in responsible charge of the project shall approve the mix design.
 - a. Review by LEA Engineer: A qualified civil engineer associated with a DSA approved (LEA) testing laboratory shall review the report for conformance with ACI CODE-318, Sections 26.4.2.2. Issue an evaluation report of findings and recommendation for either acceptance or rejection and forward his report to the design professional in responsible charge of the project.
 - b. Approval by the Project Engineer in Responsible Charge: Based on the findings and recommendation of the LEA engineer's evaluation report, the project design professional in responsible charge decides whether to accept or reject the mix design. He will issue a letter stating his acceptance or rejection. The letter shall be sent to DSA, and copied to the project inspector, the LEA laboratory, and the mix design engineer.

- c. Documentation by the Concrete Supplier: The concrete supplier shall submit copies of the cement certification, fly ash certification of compliance or test data, admixture data, aggregate test data, and mix design identification number to the project inspector and the LEA engineer who reviewed the mix design report.
- 5. Indicate proposed mix design complies with admixture manufacturer's written recommendations.
- 6. Mix Design: Submit mix designs prepared, stamped and signed by a Civil Engineer licensed in the State of California.
- D. Samples: Submit samples of underslab vapor retarder to be used.
- E. Samples: Submit two, 12 inch long samples of waterstops and construction joint devices.
- F. Quality Control Submittals:
 - 1. Field tests: Submit reports of all slump, strength and air content tests as required by authorities having jurisdiction and as indicated on the Drawings and specified herein.
 - 2. Delivery tickets: Have available copies of delivery tickets complying with ASTM C94/C94M for each load of concrete delivered to site. Include on the tickets the additional information specified in the ASTM document.
- G. Test Reports: Submit report for each test or series of tests specified.
- H. Manufacturer's Installation Instructions: For concrete accessories, indicate installation procedures and interface required with adjacent construction.
- I. Sustainable Design Submittal: If any fly ash, ground granulated blast furnace slag, silica fume, rice hull ash, or other waste material is used in mix designs to replace Portland cement, submit the total volume of concrete cast in place, mix design(s) used showing the quantity of portland cement replaced, reports showing successful cylinder testing, and temperature on day of pour if cold weather mix is used.
- J. Project Record Documents: Accurately record actual locations of embedded utilities and components that will be concealed from view upon completion of concrete work.
- K. Warranty: Submit manufacturer warranty and ensure forms have been completed in District's name and registered with manufacturer.

1.05 QUALITY ASSURANCE

- A. Perform work of this section in accordance with ACI SPEC-301 and ACI CODE-318.
 - 1. Maintain one copy of each document on site.
- B. Follow recommendations of ACI PRC-305(305R) when concreting during hot weather.
- C. Follow recommendations of ACI PRC-306(306R) when concreting during cold weather.
- D. For slabs required to include moisture vapor reducing admixture (MVRA), do not proceed with placement unless manufacturer's representative is present for every day of placement.
- E. For slabs indicated to receive membrane-forming, moisture emission-reducing, curing and sealing compound, do not proceed with application unless manufacturer's representative is present for every day of placement.
- F. Regulatory Requirements:

FOR REFERENCE ONLY

1. Conform to California Building Code (CBC) Chapter 19A requirement, as amended and adopted by authorities having jurisdiction.
2. Chemical products field-applied to concrete shall comply with applicable air quality requirements of authorities having jurisdiction.
 - a. Comply with Section 01 61 16 - Volatile Organic Compound (VOC) Content Restrictions, CALGreen Section 5.504.4 Finish material pollutant control; 5.504.4.1 Adhesives, sealants and caulks; 5.504.4.3 Paints and coatings.
 - b. Comply with CALGreen Section A5.405.4 Recycled content.
 - c. Comply with CALGreen Section A5.406 Enhanced Durability and Reduced Maintenance.
- G. Testing Agency Services: District will engage an independent testing and inspection agency to conduct tests and perform other services specified for quality control during construction, as required by Section(s) 01 40 00 - Quality Requirements and 01 45 33 - Code-Required Special Inspections.
- H. Coordination: Coordinate the placement of joint devices with erection of concrete formwork and placement of form accessories. Coordinate concrete requirements with Work specified for underground utilities and mechanical and electrical equipment pads and bases.

1.06 MOCK-UPS

- A. Construct and erect mock-up panel for architectural concrete surfaces indicated to receive special treatment or finish as result of formwork.
 1. Panel Size: Sufficient to illustrate full range of treatment.
 2. Number of Panels: Two.
 3. Locate as indicated on drawings.
- B. Accepted mock-up panel is considered basis of quality for the finished work. Keep mock-up exposed to view for duration of concrete work.
- C. Mock-up may not remain as part of the Work.

1.07 DELIVERY AND HANDLING

- A. Protection During Concrete Placement: Provide protective coverings and runways, and use appropriate equipment and means of access to Work areas to avoid soiling or damage to existing conditions.
- B. Runoff: Prevent run off of water contaminated by construction agents and chemicals from soiling existing surfaces and from contaminating existing and future landscape areas.

1.08 WARRANTY

- A. See Section 01 78 00 - Closeout Submittals for additional warranty requirements.
- B. Slabs with Porosity Inhibiting Admixture (PIA) or Moisture Vapor Reducing Admixture (MVRA): Provide warranty to cover cost of flooring failures due to moisture migration from slabs for life of the concrete.
 1. Include cost of repair or removal of failed flooring, placement of topical moisture remediation system, and replacement of flooring with comparable flooring system.

2. Provide warranty by admixture manufacturer matching terms of flooring adhesive or primer manufacturer's material defect warranty.
- C. Moisture Emission-Reducing Curing and Sealing Compound, Membrane-Forming: Provide warranty to cover cost of flooring delamination failures for 10 years.
 1. Include cost of repair or removal of failed flooring, remediation with a moisture vapor impermeable surface coating, and replacement of flooring with comparable flooring system.
 2. Provide warranty by manufacturer of MVRA matching terms of flooring adhesive or primer manufacturer's material defect warranty.
- D. Moisture Emission-Reducing Curing and Sealing Compound, Penetrating: Provide non-prorated warranty to cover cost of flooring delamination failures for 20 years.
 1. Include cost of repair or removal of failed flooring, remediation with a moisture vapor impermeable surface coating, and replacement of flooring with comparable flooring system.
 2. See Section 09 05 61 - Common Work Results for Flooring Preparation.

PART 2 PRODUCTS

2.01 FORMWORK

- A. Comply with requirements of Section 03 10 00.

2.02 REINFORCEMENT MATERIALS

- A. Comply with requirements of Section 03 20 00.

2.03 CONCRETE MATERIALS

- A. Cement: ASTM C150/C150M, Type II - Moderate Portland type.
 1. Cement used in contact with soil shall be Type V - Sulfate Resistant.
 2. Acquire cement for entire project from same source.
- B. Fine and Coarse Aggregates: ASTM C33/C33M.
 1. Acquire aggregates for entire project from same source.
 2. Fine and coarse aggregates, {RS#10005050} Title 24, Part 2, 1903A.5, ACI CODE-318 Section 26.4.
 3. Concrete indicated to receive abrasive blast or retarded finish: Design mix with uniform fine to coarse gradation of aggregates to produce evenly textured finish surface.
 4. Other than Structural Concrete: Conform to requirements for structural concrete.
- C. Fly ash and raw or calcined natural pozzolans to conform to ASTM C618 for Class N or F (Class C fly ash is not permitted). Per ASTM C618, sampling and testing of fly ash in accordance with ASTM C111/C111M.
 1. Conform to ACI CODE-318 Section 26.4.2.2 and DSA IR 19-3 for the use of fly ash or natural pozzolan.
 2. Fly Ash: ASTM C618, Class N or F.

- a. Supply fly ash by an experienced producer that complies with all applicable standards above.
 - b. Provide fly ash from one source for the duration of the project, unless additional physical testing of the changed mix is performed; per Concrete Mix Design.
3. Calcined Pozzolan: ASTM C618, Class N.
- D. Silica Fume: ASTM C1240, proportioned in accordance with ACI PRC-211.1.
 - E. Water: ASTM C1602/C1602M; clean, potable, and not detrimental to concrete.

2.04 ADMIXTURES

- A. The use of any chemical admixture is subject to prior approval by DSA.
- B. Use no admixtures not included in mix design. Products of the following manufacturers are specified and will be acceptable provided they comply with referenced standards all other requirements of the Contract Documents:
- C. Do not use chemicals that will result in soluble chloride ions in excess of 0.1 percent by weight of cement.
- D. Water Reducing and Accelerating Admixture: ASTM C494/C494M Type E.
 1. Products:
 - a. Euclid Chemical Company; ACCELGUARD 80: www.euclidchemical.com/#sle.
 - b. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- E. Water Reducing and Retarding Admixture: ASTM C494/C494M Type D.
 1. Provide pigmented type, with ASTM C979/C979M inorganic pigments.
- F. Water Reducing Admixture: ASTM C494/C494M Type A.
 1. Products:
 - a. Euclid Chemical Company; EUCON NW: www.euclidchemical.com/#sle.
 - b. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- G. Moisture Vapor Reducing Admixture (MVRA): Liquid, inorganic admixture free of volatile organic compounds (VOCs). Closes capillary systems formed during concrete curing to reduce moisture vapor emission and transmission. Reduces concrete shrinkage with no adverse effect on concrete properties or applied flooring.
 1. Provide admixture in slabs to receive adhesively applied flooring or roofing.
 2. Provide admixture in concrete for elevator pits, retaining walls, water-retaining structures, underground structures, roads, dams, and bridges.
 3. VOC Content: Zero.
 4. Installed admixture to meet or exceed Modified ASTM F1869 or ASTM F2170 testing to performance of moisture vapor emission rate (MVER) of 4 lbs/1,000 ft²/24 hours or lower.
 - a. Alternative test methods shall be acceptable to the finish flooring manufacturer and installer.

FOR REFERENCE ONLY

5. The concrete ready mix supplier must coordinate with the admixture manufacturer before designing and testing any new mix designs, to receive guidance on achieving proper water absorption characteristics.
6. Products:
 - a. AVECS, LLC; PRO-ACT: www.avecs.build/#sle.
 - b. Barrier One Concrete Admixtures; MVRA-CPS: www.barrierone.com/#sle.
 - c. Hycrete, Inc: www.hycrete.com/#sle.
 - d. ISE Logik Industries, Inc; MVRA 900: www.iselogik.com/#sle.
 - e. Specialty Products Group; Vapor Lock 20/20: www.spggogreen.com/#sle.
 - f. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.

2.05 ACCESSORY MATERIALS

A. Underslab Vapor Retarder:

1. Sheet Material: ASTM E1745, Class A; stated by manufacturer as suitable for installation in contact with soil or granular fill under concrete slabs. Single-ply polyethylene is prohibited.
 2. Performance Requirements:
 - a. Comply with ACI PRC-302.1 and ACI PRC-302.2.
 - b. Water Vapor Permeance: Not more than 0.010 perms, maximum.
 - 1) Permeance as tested after conditioning (ASTM E1745).
 - c. Comply with ASTM E1745 Class A.
 - d. Puncture Resistance, ASTM D1709: 2,300 gms.
 3. Accessory Products: Vapor retarder manufacturer's recommended tape, adhesive, mastic, prefabricated boots, etc., for sealing seams and penetrations.
 4. Products:
 - a. Henry Company; Moistop Ultra 15: www.henry.com/#sle.
 - b. ISI Building Products; Viper VaporCheck II 15-mil (Class A): www.isibp.com/#sle.
 - c. Raven Industries; VaporBlock VB15, 15 mils thick (0.01 perms), Class A, unreinforced polyolefin: ravenefd.com,
 - d. Reef Industries, Inc.; Vaporguard, 15 mil (E-96 0.000 perms), Class B: www.reefindustries.com
 - e. Stego Industries, LLC; Stego Wrap Vapor Barrier, 15 mils:: www.stegoindustries.com/#sle.
 - f. W. R. Meadows, Inc; PERMINATOR Class A - 15 mils (0.38 mm): www.wrmeadows.com/#sle.
 - g. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Non-Shrink Cementitious Grout: Premixed compound consisting of nonmetallic aggregate, cement, water reducing and plasticizing agents.
1. Grout: Comply with ASTM C1107/C1107M.

FOR REFERENCE ONLY

2. Height Change, Plastic State; when tested in accordance with ASTM C827/C827M:
 - a. Maximum: Plus 4 percent.
 - b. Minimum: Plus 1 percent.
 3. Minimum Compressive Strength at 48 Hours: 2,000 pounds per square inch.
 4. Minimum Compressive Strength at 28 Days: 8,000 pounds per square inch.
 5. Products containing aluminum powder are not permitted.
 6. Flowable Products:
 - a. Dayton Superior Corporation: www.daytonsuperior.com/#sle.
 - b. LATICRETE International, Inc; DURAGROUT: www.laticrete.com/#sle.
 - c. SpecChem, LLC; SC Precision Grout: www.specchemllc.com/#sle.
 - d. W. R. Meadows, Inc; 588-10K: www.wrmeadows.com/#sle.
 - e. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
 7. Low-Slump, Dry Pack Products:
 - a. Dayton Superior Corporation: www.daytonsuperior.com/#sle.
 - b. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- C. Non-Shrink Epoxy Grout: Moisture-insensitive, two-part; consisting of epoxy resin, nonmetallic aggregate, and activator.
1. Composition: High solids content material exhibiting positive expansion when tested in accordance with ASTM C827/C827M.
 - a. Maximum Height Change: Plus 4 percent.
 - b. Minimum Height Change: Plus 1 percent.
 2. Minimum Compressive Strength at 7 days, ASTM C579: 12,000 pounds per square inch.
 3. Minimum Compressive Strength at 7 days, ASTM D695: 12,000 pounds per square inch.
 4. Products:
 - a. Euclid Chemical Company; E3-DEEP POUR: www.euclidchemical.com/#sle.
 - b. Dayton Superior Corporation; ____: www.daytonsuperior.com/#sle.
 - c. Five Star Products, Inc; Five Star DP Epoxy Grout: www.fivestarproducts.com/#sle.
 - d. W. R. Meadows, Inc; REZI-WELD 3/2: www.wrmeadows.com/#sle.
 - e. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.

2.06 BONDING AND JOINTING PRODUCTS

- A. Latex Bonding Agent: Non-redispersable acrylic latex, complying with ASTM C1059/C1059M, Type II.
1. Products:
 - a. Euclid Chemical Company; AKKRO-7T: www.euclidchemical.com/#sle.
 - b. SpecChem, LLC; Strong Bond Acrylic Bonder: www.specchemllc.com/#sle.
 - c. W. R. Meadows, Inc; ACRY-LOK: www.wrmeadows.com/#sle.
 - d. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.

FOR REFERENCE ONLY

- B. Epoxy Bonding System:
1. Complying with ASTM C881/C881M and of Type required for specific application.
 2. Products:
 - a. Adhesives Technology Corporation; CRACKBOND 2100 MV: www.atcepoxy.com/#sle.
 - b. Euclid Chemical Company; DURAL FAST SET LV: www.euclidchemical.com/#sle.
 - c. Euclid Chemical Company; DURALFLEX GEL: www.euclidchemical.com/#sle.
 - d. Euclid Chemical Company; DURALFLEX LV: www.euclidchemical.com/#sle.
 - e. Euclid Chemical Company; DURAL 452 GEL, DURAL 452 LV, or DURAL 452 MV: www.euclidchemical.com/#sle.
 - f. Dayton Superior Corporation: www.daytonsuperior.com/#sle.
 - g. Mapei Corporation; Planibond AE: www.mapei.com/#sle.
 - h. Mapei Corporation; Planibond 3C: www.mapei.com/#sle.
 - i. SpecChem, LLC; SpecPoxy 1000, SpecPoxy 2000, SpecPoxy 3000, or SpecPoxy 3000FS: www.specchemllc.com/#sle.
 - j. W. R. Meadows, Inc; Rezi-Weld Gel Paste, Rezi-Weld Gel Paste State, Rezi-Weld 1000: www.wrmeadows.com/#sle.
 - k. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- C. Slab Isolation Joint Filler: 1/2-inch thick, height equal to slab thickness, with removable top section forming 1/2-inch deep sealant pocket after removal.
1. Material: Closed-cell, non-absorbent, compressible polymer foam in sheet form.
 2. Products:
 - a. W. R. Meadows, Inc; Deck-O-Foam Joint Filler with pre-scored top strip: www.wrmeadows.com/#sle.
 - b. W. R. Meadows, Inc; X-Foam: www.wrmeadows.com/#sle.
 - c. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- D. Slab Contraction Joint Device: Preformed linear strip intended for pressing into wet concrete to provide straight route for shrinkage cracking.
1. Products:
 - a. W. R. Meadows, Inc; Speed-E-Joint: www.wrmeadows.com/#sle.
 - b. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- E. Slab Construction Joint Devices: Combination keyed joint form and screed, galvanized steel, with rectangular or round knockout holes for conduit or rebar to pass through joint form at 6 inches on center; ribbed steel stakes for setting.
1. Provide removable plastic cap strip that forms wedge-shaped joint for sealant installation.
 2. Height: To suit slab thickness.
- F. Dowel Sleeves: Plastic sleeve for smooth, round, steel load-transfer dowels.

2.07 CURING MATERIALS

- A. Evaporation Reducer: Liquid thin-film-forming compound that reduces rapid moisture loss caused by high temperature, low humidity, and high winds; intended for application immediately after concrete placement.
 - 1. Products:
 - a. Dayton Superior Corporation: www.daytonsuperior.com/#sle.
 - b. Euclid Chemical Company ; EUCOBAR: www.euclidchemical.com/#sle.
 - c. Nox-Crete Inc; Monofilm: www.nox-crete.com/#sle.
 - d. SpecChem, LLC; SpecFilm Concentrate or SpecFilm: www.specchemllc.com/#sle.
 - e. W. R. Meadows, Inc; Evapre or Evapre-RTU: www.wrmeadows.com/#sle.
 - f. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
 - B. Curing and Sealing Compound, Moisture Emission-Reducing, Membrane-Forming: Clear, liquid sealer for application to newly-placed concrete; capable of providing adequate bond for flooring adhesives, initially and over the long term; with sufficient moisture vapor impermeability to prevent deterioration of flooring adhesives due to moisture emission.
 - 1. CONC-2.
 - 2. Comply with ASTM C309 and ASTM C1315 Type I Class A.
 - 3. VOC Content: Less than 100 g/L.
 - 4. Solids Content: 25 percent, minimum.
 - 5. Products:
 - a. Floor Seal Technology, Inc; VaporSeal 309 System: www.floorseal.com/#sle.
 - b. Forta Corporation; _____: www.forta-ferro.com/#sle.
 - c. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
 - C. Curing and Sealing Compound, High Gloss: Liquid, membrane-forming, clear, nonyellowing acrylic; complying with ASTM C1315 Type 1 Class A.
 - 1. Vehicle: Water-based.
 - 2. Solids by Mass: 25 percent, minimum.
 - 3. VOC Content: Ozone Transport Commission (OTC) compliant.
 - 4. Products:
 - a. LATICRETE International, Inc; LUMISEAL FX: www.laticrete.com/#sle.
 - b. Mapei Corporation; Mapecure UV WB: www.mapei.com/#sle.
 - c. W. R. Meadows, Inc; VOCOMP-30: www.wrmeadows.com/#sle.
 - d. Substitutions: See Section 01 60 00 - Product Requirements.
 - D. Moisture-Retaining Sheet: ASTM C171.
 - 1. Curing paper, regular.
 - 2. Polyethylene film, white opaque, minimum nominal thickness of 4 mil, 0.004 inch.
 - E. Polyethylene Film: ASTM D2103, 4 mil, 0.004 inch thick, clear.

- F. Water: Potable, not detrimental to concrete. ASTM C1602/C1602M per ACI CODE-318 Sec. 26.4.3.1

2.08 CONCRETE MIX DESIGN

- A. Proportioning Normal Weight Concrete: Comply with ACI PRC-211.1 recommendations and ACI CODE-318.
 - 1. Replace as much Portland cement as possible with fly ash, ground granulated blast furnace slag, silica fume, or rice hull ash as is consistent with ACI recommendation.
- B. Concrete Strength: Establish required average strength for each type of concrete on the basis of field experience or trial mixtures, as specified in ACI SPEC-301.
 - 1. For trial mixtures method, employ independent testing agency acceptable to Architect for preparing and reporting proposed mix designs.
- C. Admixtures: Add acceptable admixtures as recommended in ACI PRC-211.1 and at rates recommended or required by manufacturer.
- D. Normal Weight Concrete:
 - 1. Compressive Strength, when tested in accordance with ASTM C39/C39M at 28 days: As indicated on drawings.
 - 2. Fly Ash Content: Maximum 15 percent of cementitious materials by weight.
 - 3. Calcined Pozzolan Content: Maximum 10 percent of cementitious materials by weight.
 - 4. Silica Fume Content: Maximum 5 percent of cementitious materials by weight.
 - 5. Water-Cement Ratio: As indicated on Structural Drawings.
 - 6. Maximum Slump: As indicated on Structural Drawings.
 - 7. Maximum Aggregate Size: 1 inch.
 - a. Structural Concrete: Maximum size not larger than 1/5 of narrowest dimension between forms, 1/3 depth of slab nor 3/4 of minimum clear spacing between individual reinforcing bars.
 - b. Other than Structural Concrete: Conform to requirements for structural concrete.

2.09 MIXING

- A. Transit Mixers: Comply with ASTM C94/C94M.
- B. Adding Water: If concrete arrives on-site with slump less than suitable for placement, do not add water that exceeds the maximum water-cement ratio or exceeds the maximum permissible slump.
- C. Do not use shrinkage-reducing admixture (SRA) in same concrete batch with MVRA or PIA.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify lines, levels, and dimensions before proceeding with work of this section.
- B. Layout construction and control joints according to the drawing details and plans following these guidelines:

FOR REFERENCE ONLY

1. Finished exposed concrete floors are critical for aesthetics.
 2. Layout joints on exposed concrete floors to allow for installation of utilities without sawcutting or concrete placement of different production batches subject to different colors. Staining and integral color concrete is not exempt from this requirement.
 3. Architect to review joint pattern submittal each floor.
 4. No lengthwise joints in corridors; place cross-corridor, if required.
 5. Place joint at 90 degree wall corners.
 6. Place joints at center line of columns.
 7. Equally space all joints.
- C. Verify that concrete cover requirements are met in formwork construction and reinforcement placement.
- D. Examine areas to receive reinforced vapor retarders. Notify Architect if areas are not acceptable. Do not begin installation until unacceptable conditions have been corrected.
- E. Subbase: Per ACI PRC-302.1.
1. As indicated on Drawings and approved by the Geotechnical Engineer.
 - a. Minimum 4 inch thick (or larger) base of 1/2 inch or larger clean aggregate, per CA Green Code 4.505.2.1 and CBC 1907A.1.
- F. Verify that base material (sand, gravel or natural as specified or indicated on Drawings) level, vapor barrier/retarder properly placed and that required clearances to reinforcing steel have been maintained.
- G. Verify that all embedded products and formed openings and recesses are correctly placed.
- H. At slabs on grade, verify that vapor retarder/barrier is properly placed and free of damage.

3.02 PREPARATION

- A. Verify that forms are clean and free of rust before applying release agent.
- B. Prepare previously placed concrete by cleaning with hydro-blasting or wet sand blasting to provide suitable surface for bonding. Provide minimum aggregate exposure of 1/4 inch.
- C. Coordinate placement of embedded items with erection of concrete formwork and placement of form accessories.
- D. Where new concrete is to be bonded to previously placed concrete, prepare existing surface by cleaning and applying bonding agent in according to bonding agent manufacturer's instructions.
1. Use epoxy bonding system for bonding to damp surfaces, for structural load-bearing applications, and where curing under humid conditions is required.
 2. Use latex bonding agent only for non-load-bearing applications.
- E. Interior Slabs on Grade: Install vapor retarder under interior slabs on grade. Comply with ASTM E1643. Lap joints minimum 6 inches. Seal joints, seams and penetrations watertight with manufacturer's recommended products and follow manufacturer's written instructions. Repair damaged vapor retarder before covering.
1. Vapor Retarder Over Granular Fill: Install compactible granular fill before placing vapor retarder as indicated on drawings. Do not use sand.

FOR REFERENCE ONLY

- a. Install total thickness indicated on Drawings. Provide crushed rock, 1/2 inch grading, clean washed, complying with ASTM C33/C33M.
- b. Minimum 4 inch thick (or larger) base of 1/2 inch or larger clean aggregate, per CA Green Code 4.505.2.1 and CBC 1907A.1.
- c. Seam and Lap Sealing: With adhesive mastic and adhesive sealing tape, seal all seams, edges and penetrations of vapor retarder/barrier.
 - 1) For adhesive mastic seal, apply adhesive to both surfaces, allow approximately 10 minutes to set up and then press together smoothly and evenly, without gaps or fishmouths, for full contact bond.
 - 2) For adhesive tape seal, comply with manufacturer's instructions and recommendations.
 - 3) Seal all penetrations with both adhesive sealing tape and adhesive mastic.
 - 4) Seal sheets to concrete footing faces and penetrating components with adhesive mastic or double sided tape as recommended by membrane manufacturer.
2. Repair underslab vapor retarder damaged during placement of concrete reinforcing. Repair with vapor retarder material; lap over damaged areas minimum 6 inches and seal watertight.

3.03 CONCRETE MIXING

- A. Concrete Mixing, General: Comply with ACI CODE-318 as adopted by CBC, Title 24, Part 2, Chapter 19A and ACI PRC-304 - Guide for Measuring, Mixing, Transporting, and Placing Concrete. Introduce and mix admixtures in compliance with manufacturer's instructions and recommendations.

3.04 PLACING CONCRETE

- A. Notify District's Inspector and at least 2 working days in advance of placing concrete.
- B. Place concrete in accordance with ACI PRC-304.
 1. General: Comply with ACI CODE-318, as adopted by CBC, Title 24, Part 2, Chapter 19A and as follows:
 - a. Schedule continuous placement of concrete to prevent the formation of cold joints.
 - b. Deliver ready mix concrete in accordance with ASTM C94/C94M. Place concrete within 90 minutes after start of mixing.
 - c. Provide construction joints if concrete for a particular element or component cannot be placed in a continuous operation.
 - 1) Submit for review, proposed locations of joints prior to pouring. See Structural Drawings for additional requirements.
 - d. Deposit concrete as close as possible to its final location, to avoid segregation.
 2. Placement in Forms: Limit horizontal layers to depths which can be properly consolidated, but in no event greater than 24 inches.

FOR REFERENCE ONLY

- a. Consolidate concrete by means of mechanical vibrators, inserted vertically in freshly placed concrete in a systematic pattern at close intervals. Penetrate previously placed concrete to ensure that separate concrete layers are knitted together.
 - b. Vibrate concrete sufficiently to achieve consistent consolidation without segregation of coarse aggregates.
 - c. Do not use vibrators to move concrete laterally.
- C. Hot Weather Placement: Comply with recommendations of ACI PRC-305 when ambient temperature before, during, or after concrete placement is expected to exceed 90 deg F or when combinations of high air temperature, low relative humidity, and wind speed are such that the rate of evaporation from freshly poured concrete would otherwise exceed 0.2 lbs./SF/Hr..
1. Use evaporation reducer.
 2. Do not add water to approved concrete mixes under any conditions.
 3. Provide mixing water at lowest feasible temperature, and provide adequate protection of poured concrete to reduce rate of evaporation.
 4. Use fog nozzle to cool formwork and reinforcing steel immediately prior to placing concrete.
- D. Cold-Weather Placement: Comply with provisions of ACI PRC-306 when air temperature has fallen to or is expected to fall below 40 deg F. Protect concrete work from physical damage or reduced strength that could be caused by frost, freezing actions, or low temperatures.
1. Uniformly heat water and aggregates before mixing to obtain a concrete mixture temperature of not less than 50 deg F and not more than 80 deg F at point of placement.
 2. Do not use frozen materials or materials containing ice or snow. Do not place concrete on frozen subgrade or on subgrade containing frozen materials.
 3. Do not use calcium chloride, salt, or other materials containing antifreeze agents or chemical accelerators unless otherwise accepted in mix designs.
- E. Place concrete for floor slabs in accordance with ACI PRC-302.1.
1. Schedule continuous placement and consolidation of concrete within planned construction joints.
 2. Place concrete in linear pattern, with control joints at slab on grade conditions only, with joints located as indicated on the Drawings.
 3. Thoroughly consolidate concrete without displacing reinforcement or embedded items, using internal vibrators, vibrating screeds, roller pipe screeds or vibrating laser screed as described below.
 4. Screeding Procedures: Strike off and level concrete slab surfaces before bleed water can collect on surface. Do not work concrete further until finishing operations are commenced.
 - a. Typical Slabs: Strike off and level surface using highway straight edges, darbies or bull floats.
 - b. Create control and construction joints true to line and profile. Do not radius the joints. Refer to the Drawings for structural requirements of joints.

FOR REFERENCE ONLY

- c. Locate joints as indicated on the Drawings but in no case shall joint spacing exceed 15 feet or 36 times the slab thickness in both directions and maximum area between joints shall not exceed 200 square feet. Locate joints on column centers and at re-entrant corners where possible.
- d. Sawcut control joints to one-quarter of slab depth, immediately after slab has achieved initial set and not longer than 8 hours. "Soff-Cut" method is preferred.
- e. Alternate control and construction joint products and procedures will be considered in accordance with substitution provision specified in Section 01 60 00 - Product Requirements.
- F. Notify Architect not less than 24 hours prior to commencement of placement operations.
- G. Maintain records of concrete placement. Record date, location, quantity, air temperature, and test samples taken.
- H. Ensure reinforcement, inserts, and waterstops will not be disturbed during concrete placement.
- I. Place concrete continuously without construction (cold) joints wherever possible; where construction joints are necessary, before next placement prepare joint surface by removing laitance and exposing the sand and sound surface mortar, by sandblasting or high-pressure water jetting.
- J. Finish floors level and flat, unless otherwise indicated, within the tolerances specified below.

3.05 SLAB JOINTING

- A. Locate joints as indicated on drawings.
 - 1. Place joint filler in floor slab pattern placement sequence. Set top to required elevations. Secure to resist movement by wet concrete.
- B. Anchor joint fillers and devices to prevent movement during concrete placement.
 - 1. Extend joint filler from bottom of slab to within 1/2 inch of finished slab surface. Conform to Section 07 92 00 for finish joint sealer requirements.
- C. Isolation Joints: Use preformed joint filler with removable top section for joint sealant, total height equal to thickness of slab, set flush with top of slab.
 - 1. Install where indicated and required on Structural Drawings, to separate slab from other building members, including columns, walls, equipment foundations, footings, stairs, manholes, sumps, and drains.
 - 2. Separate slabs on grade from vertical surfaces with joint filler.
 - 3. Isolation Joints in Slabs-on-Grade: Construct isolation joints in slabs-on-grade at points of contact between slabs-on-grade and vertical surfaces, such as column pedestals, foundation walls, grade beams, and other locations, or as indicated.
 - a. Structural slab contact at foundation walls and grade beams shall be doweled as detailed.
- D. Load Transfer Construction and Contraction Joints: Install load transfer devices as indicated; saw cut joint at surface as indicated for contraction joints.

- E. Saw Cut Contraction Joints: Saw cut joints before concrete begins to cool, within 4 to 8 hours after placing; use 1/4 inch thick blade and cut at least 1 inch deep but not less than one quarter (1/4) the depth of the slab.
- F. Construction Joints: Where not otherwise indicated, use metal combination screed and key form, with removable top section for joint sealant.

3.06 FLOOR FLATNESS AND LEVELNESS TOLERANCES

- A. An independent testing agency, as specified in Section 01 40 00, will inspect finished slabs for compliance with specified tolerances.
- B. Maximum Variation of Surface Flatness:
 - 1. Exposed Concrete Floors: 1/4 inch in 10 feet.
 - 2. Under Seamless Resilient Flooring: 1/8 inch in 10 feet.
 - 3. Under Carpeting: 1/4 inch in 10 feet.
- C. For the following applications, depressions in slab floors between high spots shall be a maximum 1/8 inch in 10 ft., using a metal straight edge placed at any location on slab, and measured within 72 hours of pour.
 - 1. Slabs receiving resilient athletic flooring as specified in Section 09 65 66 - Resilient Athletic Flooring.
- D. Curbs:
 - 1. Top of Curb: 1/4 inch in 10 ft, non-cumulative.
 - 2. Side of Curb: 1/8 inch in 10 ft, non-cumulative, vertical and horizontal.
- E. Correct the slab surface if tolerances are less than specified.
- F. Correct defects by grinding or by removal and replacement of the defective work. Areas requiring corrective work will be identified. Re-measure corrected areas by the same process.

3.07 CONCRETE FINISHING

- A. Repair surface defects, immediately after removing formwork.
 - 1. Remove honeycombed areas and other defective concrete down to sound concrete, cutting perpendicular to surface or slightly undercutting without damaging reinforcement. Dampen patch location and area immediately surrounding it prior to applying bonding compound or patching mortar.
 - 2. Before bonding compound has dried, apply patching mixture matching original concrete in materials and mix except for omission of coarse aggregate, and using a blend of white and normal portland cement as necessary to achieve color match. Consolidate thoroughly and strike off slightly higher than surrounding surface.
- B. Exposed Form Finish: Rub down or chip off and smooth fins or other raised areas 1/4 inch or more in height. Provide finish as follows:
 - 1. Grout Cleaned Finish: Wet areas to be cleaned and apply grout mixture by brush or spray; scrub immediately to remove excess grout. After drying, rub vigorously with clean burlap, and keep moist for 36 hours.
- C. Concrete Slabs: Finish to requirements of ACI PRC-302.1 and as follows:

FOR REFERENCE ONLY

1. Surfaces to Receive Thin Floor Coverings: "Steel trowel" as described in ACI PRC-302.1; thin floor coverings include resilient flooring.
2. Other Surfaces to Be Left Exposed: Trowel as described in ACI PRC-302.1, minimizing burnish marks and other appearance defects.

3.08 CURING AND PROTECTION

- A. Comply with requirements of ACI PRC-308. Immediately after placement, protect concrete from premature drying, excessively hot or cold temperatures, and mechanical injury.
- B. Maintain concrete with minimal moisture loss at relatively constant temperature for period necessary for hydration of cement and hardening of concrete.
 1. Normal concrete: Not less than seven days.
- C. Formed Surfaces: Cure by moist curing with forms in place for full curing period.
- D. Surfaces Not in Contact with Forms:
 1. Initial Curing: Start as soon as free water has disappeared and before surface is dry. Keep continuously moist for not less than three days by water ponding, water-saturated sand, water-fog spray, or saturated burlap.
 - a. Spraying: Spray water over floor slab areas and maintain wet.
 - b. Saturated Burlap: Saturate burlap-polyethylene and place burlap-side down over floor slab areas, lapping ends and sides; maintain in place.
 2. Final Curing: Begin after initial curing but before surface is dry.
 - a. Moisture-Retaining Sheet: Lap strips not less than 3 inches and seal with waterproof tape or adhesive; secure at edges.
 - b. Curing Compound: Apply in two coats at right angles, using application rate recommended by manufacturer.

3.09 MISCELLANEOUS CONCRETE ITEMS

- A. Filling In: Fill in holes and openings left in concrete structures for passage of Work specified in other Sections, after such Work is in place. Mix, place, and cure concrete as specified to blend with in-place construction. Provide other miscellaneous concrete filling shown or required to complete Work. Use non-shrink grout where required or indicated.
- B. Curbs: Provide monolithic finish to interior curbs by stripping forms while concrete is still green and by steel-troweling surfaces to a hard, dense finish with corners, intersections, and terminations slightly rounded.
- C. Equipment Bases and Foundations: Provide machine and equipment bases and foundations as shown on drawings. Set anchor bolts for machines and equipment to template at correct elevations, complying with diagrams or templates of manufacturer furnishing machines and equipment.

3.10 FIELD QUALITY CONTROL

- A. An independent testing agency will perform field quality control tests, as specified in Section 01 40 00 - Quality Requirements.

FOR REFERENCE ONLY

- B. Maintain records of concrete placement. Record date, location, quantity, air temperature, and test samples taken.
- C. Provide free access to concrete operations at project site and cooperate with appointed firm.
- D. Submit proposed mix design of each class of concrete to inspection and testing firm for review prior to commencement of concrete operations.
- E. Field Certifications: For all concrete, provide signed copy of batch plant's certificate stating quantity of each material, amount of water, admixtures, departure time and date accompanying each load of materials or concrete.
- F. Field Tests of Concrete: Perform tests in accordance with applicable California Building Code requirements, ACI SPEC-301 and requirements of authorities having jurisdiction.
- G. Tests of concrete and concrete materials may be performed at any time to ensure compliance with specified requirements.
- H. Compressive Strength Tests: ACI CODE-318, 26.12.2.1(a), ASTM C39/C39M, for each test, mold and cure a minimum of four concrete test cylinders. Project Inspector to obtain test samples each day, for every 50 cubic yards, 2,000 sq. ft. of slab or wall surface area, or less of each class of concrete placed. CBC 1905A.1.15
 1. Take additional samples for 7-day compressive strength tests for of each class of concrete at the beginning of of concrete work or whenever the mix or aggregate is changed.
 2. Test one cylinder at 7 days and two at 28 days after placement.
 3. Maintain fourth cylinder to be tested at 56 days only if 28-day test fails to meet strength requirement.
 4. Take one additional test cylinder during cold weather concreting and cure it at job site under same conditions as concrete it represents. Test cold weather cylinder at 28 days.
 5. Comply with ACI CODE-318, 26.12.3 Acceptance Criteria for Standard-Cured Specimens.
 - a. Strength level of a concrete mixture shall be acceptable if (1) and (2) are satisfied:
 - 1) Every average of any three consecutive strength tests equals or exceeds f_c' .
 - 2) No strength test falls below f_c' by more than 500 psi if f_c' is 5000 psi or less; or by more than $0.10f_c'$ if f_c' exceeds 5000 psi.
 - b. If either of the requirements of 26.12.3.1(a) is not satisfied, steps shall be taken to increase subsequent strength tests.
 - c. Requirements of 26.12.6 for investigating strength tests shall apply if the requirements of 26.12.3.1(a)(2) are not met.
- I. Take one additional test cylinder during cold weather concreting, cured on job site under same conditions as concrete it represents.
- J. Perform one slump test for each set of test cylinders taken, following procedures of ASTM C143/C143M.
- K. Slab Testing: Cooperate with manufacturer of specified moisture vapor reducing admixture (MVRA) to allow access for sampling and testing concrete for compliance with warranty requirements.

3.11 DEFECTIVE CONCRETE

- A. Test Results: The testing agency shall report test results in writing to Architect and Contractor within 24 hours of test.
- B. Defective Concrete: Concrete not complying with required lines, details, dimensions, tolerances or specified requirements.
- C. Repair or replacement of defective concrete will be determined by the Architect. The cost of additional testing shall be borne by Contractor when defective concrete is identified.
 - 1. Obtain repair details from Architect (Structural Engineer) and approved by DSA before proceeding.
- D. Do not patch, fill, touch-up, repair, or replace exposed concrete except upon express direction of Architect for each individual area.

3.12 PROTECTION

- A. Do not permit traffic over unprotected concrete floor surface until fully cured.
- B. Protect concrete from marring and damage due to weather and construction activities.
 - 1. Protective measures shall include providing temporary coverings, and be in accordance with Section 01 50 00 - Temporary Facilities and Controls, and shall prohibit all non-essential construction activities, including cleaning and maintenance of construction equipment.
 - 2. In particular, protect concrete floor slabs from oil, paint and other products that might penetrate and degrade concrete surface.

END OF SECTION

SECTION 03 35 11 CONCRETE FLOOR FINISHES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Surface treatments for concrete floors and slabs.
- B. Liquid densifiers and hardeners.
- C. Clear coatings.
- D. Clear penetrating sealers.

1.02 RELATED REQUIREMENTS

- A. Section 03 30 00 - Cast-in-Place Concrete: Finishing of concrete surface to tolerance; floating, troweling, and similar operations; curing.

1.03 REFERENCE STANDARDS

- A. ADA Standards - 2010 ADA Standards for Accessible Design.
- B. ANSI A137.1 - American National Standard Specifications for Ceramic Tile.
- C. ANSI/NFSI B101.3 - Test Method for Measuring the Wet DCOF of Hard Surface Walkways.
- D. ASTM C156 - Standard Test Method for Water Loss [from a Mortar Specimen] Through Liquid Membrane-Forming Curing Compounds for Concrete.
- E. ASTM D4039 - Standard Test Method for Reflection Haze of High-Gloss Surfaces.
- F. ASTM D5767 - Standard Test Method for Instrumental Measurement of Distinctness-of-Image (DOI) Gloss of Coated Surfaces.
- G. ASTM F609 - Standard Test Method for Using a Horizontal Pull Slipmeter (HPS).
- H. {RSTEMP#10005085}
- I. ICRI 310.2R - Selecting and Specifying Concrete Surface Preparation for Sealers, Coatings, Polymer Overlays, and Concrete Repair.
- J. SCAQMD 1113 - Architectural Coatings.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordinate the work with concrete floor placement and concrete floor curing.
- B. Pre-Concrete Placement Meeting:
 - 1. Prior to the start of concrete placement Contractor shall conduct a meeting to review the required methods and procedures to achieve the required finish. Contractor shall send a meeting agenda to all attendees 20 days prior to the scheduled date of the meeting
 - 2. The Contractor shall require responsible representatives of every party concerned with the concreting work to attend the meeting, including but not limited to the following: Contractor's superintendent, ready-mix company, testing lab, topping and coating applicator, and Construction Manager.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Manufacturer's published data on each finishing product, including information on compatibility of different products and limitations.
- C. Maintenance Data: Provide data on maintenance and renewal of applied finishes.
- D. Warranty Documentation: Manufacturer warranty; ensure that forms have been completed in District's name and registered with manufacturer.
- E. Specimen Warranty: Manufacturer warranty.
- F. Certification: Submit manufacturer's certificate that all materials supplied conform to applicable Federal regulations and to applicable State and Local air pollution emission ordinances and regulations.

1.06 QUALITY ASSURANCE

1.07 MOCK-UP

- A. For coatings, construct mock-up area under conditions similar to those that will exist during application, with coatings applied.
- B. Mock-Up Size: 10 feet square.
 - 1. Demonstrate typical joints, surface finish, texture, color, and standard of workmanship.
- C. Locate where directed.
- D. Mock-up may not remain as part of the work.

1.08 DELIVERY, STORAGE, AND HANDLING

- A. Deliver materials in manufacturer's sealed packaging, including application instructions.

1.09 FIELD CONDITIONS

- A. Maintain light level equivalent to a minimum 200 W light source at 8 feet above the floor surface over each 20 foot square area of floor being finished.
- B. Do not finish floors until interior heating system is operational.
- C. Maintain ambient temperature of 50 degrees F minimum.

1.10 WARRANTY

- A. See Section 01 78 00 - Closeout Submittals for additional warranty requirements.
- B. Correct defective work within a two-year period commencing on the Date of Final Inspection.
- C. Manufacturer Warranty: Provide two-year manufacturer warranty for non-slip, color and fading, commencing on the Date of Final Inspection.
- D. Installer Warranty: Provide two-year manufacturer warranty for adhesion, alligating, and flaking commencing on the Date of Final Inspection.
- E. Finish Warranty: Provide five-year manufacturer warranty against excessive degradation of finish. Include provision for replacement of units with excessive fading, chalking, or flaking.

PART 2 PRODUCTS

2.01 REGULATORY REQUIREMENTS

- A. All products used shall meet VOC requirements listed in Section 01 61 16 - Volatile Organic Compound (VOC) Content Restrictions.
- B. Requirements for persons with disabilities: Provide flooring meeting slip-resistant requirements of California Code of Regulations (CCR), Title 24, Part 2, {RS#10005085} and ADA Standards, latest amendment.
 - 1. Flooring demonstrating a coefficient meeting the intent of slip resistance; {RS#10005085}-302 Floor or Ground Surfaces, {RS#10005085}-403 Walking Surfaces, and ADA Standards.
 - a. Also acceptable: A dynamic coefficient of friction of at least 0.42 per DCOF AcuTest ANSI A137.1 Section 9.6 or ASTM F609.
 - 2. Flooring surface shall be stable, firm, and slip resistant. {RS#10005085}-302.1 General.
 - 3. Flooring surface demonstrating a dynamic coefficient of friction of at least 0.42 wet per DCOF AcuTest ANSI A137.1 Section 9.6 and ANSI/NFSI B101.3 (using a BOT-3000 testing unit) will be accepted as meeting the intent of slip resistance; {RS#10005085}-302 Floor or Ground Surfaces and ADA Standards.
 - a. Ramp surface: Provide DCOF value of 0.46 wet.

2.02 CONCRETE FLOOR FINISH APPLICATIONS

- A. Unless otherwise indicated, all concrete floors are to be finished using liquid densifier/hardener.
- B. Liquid Densifier and Hardener:
 - 1. Use at following locations: concrete floors on grade.
- C. Penetrating Clear Sealer:
 - 1. Use at following locations: Concrete floors with sealer.
- D. Clear Coating:
- E. Slip Resistant Coating: Finely-ground aggregates added to coatings.
 - 1. Use at following locations: _____.

2.03 SURFACE TREATMENTS

- A. Troweling Aid, Densifier and Curing Agent: Liquid reactive colloidal silica-based topical treatment, spray-applied to wet concrete and floated or troweled into the surface.
- B. Surface Etching: A water-based liquid or gel compound to remove the concrete surface by chemically etching to produce a certain profile.
 - 1. VOC Compliance: Less than 40 g/L. Conform to SCAQMD 1113 requirements.
 - 2. Concrete Surface Profile: CSP-1 Acid Etched.
 - 3. Products:
 - a. Ameripolish Inc.; EZ Etch-Concrete Surface Etching Agent: www.ameripolish.com.

- b. Eco Safety Products; Ecoprocote-EcoEtch Pro Concrete Etcher & Cleaner: www.ecosafetyproducts.com.
- c. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.

2.04 DENSIFIERS AND HARDENERS

- A. Liquid Densifier and Hardener: Penetrating chemical compound that reacts with concrete, filling the pores, hardening, and dustproofing.
 - 1. Composition: Lithium silicate.
 - a. Products:
 - 1) Dayton Superior Corporation; Densifier J13: www.daytonsuperior.com/#sle.
 - 2) Euclid Chemical Company; ULTRASIL LI+: www.euclidchemical.com/#sle.
 - 3) PROSOCO, Inc; ColorHard used with Consolideck LS or LS/CS: www.prosoco.com/consolideck/#sle.
 - 4) Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
 - 2. Composition: Sodium silicate.
 - a. Products:
 - 1) Curecrete Distribution, Inc; Ashford Formula: www.curecrete.com/#sle.
 - 2) Euclid Chemical Company; EUCOSIL: www.euclidchemical.com/#sle.
 - 3) L&M Construction Chemicals, Inc; SEAL HARD: www.lmcc.com/#sle.
 - 4) Nox-Crete Inc; Duro-Nox: www.nox-crete.com/#sle.
 - 5) Paul M. Wolff Co.; SHUR-HARD: www.paulwolffco.com.
 - 6) SpecChem, LLC; Cure Hard: www.specchemllc.com/#sle.
 - 7) W. R. Meadows, Inc; Liqui-Hard: www.wrmeadows.com/#sle.
 - 8) Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
 - 3. Composition: Hybrid silicate.
 - a. Products:
 - 1) Ameripolish, Inc; 3D HS Hybrid Silicate Densifier: www.ameripolish.com/#sle.
 - 2) Or Equal Substitutions: See Section 01 60 00 - Product Requirements.

2.05 COATINGS

- A. Matte Gloss Clear Coating: Transparent, nonyellowing, acrylic polymer-based coating.
- B. Penetrating Sealer: Transparent, nonyellowing, water-based coating.
 - 1. USDA approved for use with Food and Beverage.
 - 2. Composition: Hybrid.
 - a. Products:
 - 1) Ameripolish, Inc; 3D SP Concrete Sealer: www.ameripolish.com/#sle.
 - 2) Aqua-Mix; Sealer's Choice Gold: www.custombuildingproducts.com.
 - 3) Curecrete Distribution, Inc; Ashford Formula: www.curecrete.com/#sle.

FOR REFERENCE ONLY

- 4) Glaze N' Seal; Glaze N' Seal Multi-Purpose Sealer : www.glaze-n-seal.com.
 - 5) L&M Construction Chemicals, Inc, a subsidiary of Laticrete International, Inc; L&M Permaguard SPS: www.lmcc.com/#sle.
 - 6) Paul Wolff Co.; Royal-Sheen: www.paulwolff.com
 - 7) Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
3. Composition: Epoxy.
- a. Products:
 - 1) Arizona Polymer Flooring; Epoxy 100 : www.apfepoxy.com.
 - 2) Rustoleum Corporation; Product - Water Based Epoxy 6010 System : www.rustoleum.com. Also available through Vista Paint, www.vistapaint.com.
 - 3) Tnemec; Enviro-Pox Series 287 Base Coat / Everthane Series 248 Top-Coat : www.tnemec.com.
 - (a) System: 287/248 EverThane – Low Sheen* Clea+r, UV Stable, WB Epoxy/MC Urethane.
 - (b) Surface Preparation: Light Shot Blast or Mechanically Abrade (CSP 2-3).
 - (c) Primer: Series 287 Enviro-Pox. DFT 2.0 to 4.0 Mils.
 - (d) Intermediate Coat: Series 287 Enviro-Pox. DFT 2.0 to 4.0 Mils.
 - (e) Finish Coat: Series 248 EverThane*. DFT 2.0 to 3.0 Mils.
 - (f) Total DFT: 6.0 to 11.0 Mils.
 - 4) Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- C. Plastic Aggregate: Finely ground polymer for addition to coatings for slip resistance.
1. Products:
 - a. Dayton Superior Corporation: www.daytonsuperior.com/#sle.
 - b. Euclid Chemical Company; EUACO GRIP: www.euclidchemical.com/#sle.
 - c. SpecChem, LLC; Surface Grip: www.specchemllc.com/#sle.
 - d. W. R. Meadows, Inc; Sure-Step: www.wrmeadows.com/#sle.
 - e. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that floor surfaces are acceptable to receive the work of this section.
- B. Concrete Substrate: Structurally sound.
- C. Concrete Age: Minimum 28 days old.
- D. Verify that flaws in concrete have been patched and joints filled with methods and materials suitable for further finishes.

3.02 PREPARATION

- A. Blow clean using unoled air or vacuum clean.

- B. Surface profile shall be CSP 2-5 per ICRI 310.2R.

3.03 GENERAL

- A. Apply materials in accordance with manufacturer's instructions.

3.04 CONCRETE FINISHING

- A. Decorative Exposed Surfaces: Trowel as described in ACI PRC-302.1; take measures necessary to avoid black-burnish marks; decorative exposed surfaces include surfaces to be polished, pigmented concrete, surfaces to receive liquid hardeners, and surfaces to receive dry-shake hardeners.
- B. Curing: Water retention 0.0006 psi in accordance with ASTM C156.

3.05 COATING APPLICATION

- A. Verify that surface is free of previous coatings, sealers, curing compounds, water repellents, laitance, efflorescence, fats, oils, grease, wax, soluble salts, residues from cleaning agents, and other impediments to adhesion.
- B. Verify that water vapor emission from concrete and relative humidity in concrete are within limits established by coating manufacturer.
- C. Protect adjacent non-coated areas from drips, overflow, and overspray; immediately remove excess material.
- D. Apply coatings in accordance with manufacturer's instructions, matching approved mock-ups for color, special effects, sealing and workmanship.
- E. Broadcast system:
 - 1. Apply first layer of coating with non-slip aggregate as recommended by manufacturer.
 - 2. Apply topcoat as recommended by manufacturer.

3.06 SURFACE DENSIFIER/SEALER APPLICATION

- A. New Concrete: Apply cure-seal-hardener to new concrete as soon as the concrete is firm enough to work on after troweling; with colored concrete, wait a minimum of 30 days before application.
- B. Existing Concrete: Apply cure-seal-hardener only to clean bare concrete.
 - 1. Thoroughly remove previous treatments, laitance, oil and other contaminants.
 - 2. Saturate surface with cure-seal-hardener; re-spray or broom excess onto dry spots.
 - 3. Keep surface wet with cure-seal-hardener for a minimum soak-in period of 30 - 40 minutes.
 - 4. If most of the material has been absorbed after the 30 minute soak-in period, remove all excess material, especially from low spots, using broom or squeegee.
 - 5. If most of the material remains on the surface after the 30 minute soak-in period, wait until the surface becomes slippery and then flush with water, removing all cure-seal-hardener residue. Squeegee completely dry, flushing any remaining slippery areas until no residue remains.
 - 6. If water is not available, remove residue using squeegee.

3.07 FIELD QUALITY CONTROL

- A. Defective Concrete: Repair or replace concrete not complying with required lines, details, dimensions, tolerances, or specified requirements at no additional cost to District.
- B. Slip Resistance: Minimum 0.43 in accordance with ANSI A326.3 after polishing.
- C. Final Polished Concrete Appearance: Test image clarity value and haze index prior to application of sealer at a rate of three tests per 1000 sq ft of polished concrete.
 - 1. Image clarity: Test with Image Clarity Meter in accordance with ASTM D5767.
 - 2. Haze index: Test with Glossmeter in accordance with ASTM D4039.
 - 3. Match approved mock-ups.

3.08 PROTECTION

- A. Do not permit traffic over unprotected concrete floor surface until fully cured.
- B. Protect finished surface as required and as recommended by manufacturer of polishing system until after final inspection.

END OF SECTION

SECTION 04 01 00 MAINTENANCE OF MASONRY

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Repointing mortar joints.
- B. Repair of damaged masonry.

1.02 RELATED REQUIREMENTS

1.03 REFERENCE STANDARDS

- A. TMS 402/602 - Building Code Requirements and Specification for Masonry Structures.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Preinstallation Meeting: Convene one week prior to commencing work of this section.
 - 1. Require attendance of parties directly affecting work of this section.
 - 2. Review conditions of installation, installation procedures, and coordination with related work.
- B. Scheduling:
 - 1. Perform cleaning and washing of masonry between the hours of 7 am to 11 pm only.
 - 2. Perform blast cleaning of masonry between the hours of 7 am to 11 pm only.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Shop Drawings: Indicate setting details of stone. Detail shoring.
- C. Product Data: Provide data on cleaning compounds.
- D. Manufacturer's Instructions: For cleaning materials, indicate special procedures, conditions requiring special attention.

1.06 QUALITY ASSURANCE

- A. Comply with provisions of TMS 402/602, except where exceeded by requirements of Contract Documents.
 - 1. Maintain one copy of each document on project site.
- B. Restorer: Company specializing in masonry restoration with minimum three years of documented experience.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Store restoration cleaner materials in manufacturer's packaging.

1.08 FIELD CONDITIONS

- A. Cold and Hot Weather Requirements: Comply with requirements of TMS 402/602 or applicable building code, whichever is more stringent.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Restoration and Cleaning Chemicals:
 1. Diedrich Technologies, Inc; ____: www.diedrichtechnologies.com/#sle.
 2. HMK Stone Care System; ____: www.hmkstonecare.com/#sle.
 3. PROSOCO; ____: www.prosoco.com/#sle.

2.02 CLEANING MATERIALS

- A. Cleaning Agent: Detergent type.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that surfaces to be cleaned are ready for work of this section.

3.02 PREPARATION

- A. Protect surrounding elements from damage due to restoration procedures.
- B. Carefully remove and store removable items located in areas to be restored, including fixtures, fittings, finish hardware, and accessories; reinstall upon completion.
- C. Separate areas to be protected from restoration areas using means adequate to prevent damage.
- D. Mask immediately adjacent surfaces with material that will withstand cleaning and restoration procedures.
- E. Close off adjacent occupied areas with dust proof and weatherproof partitions.
- F. Protect roof membrane and flashings from damage with 1/2 inch plywood laid on roof surfaces over full extent of work area and traffic route.
- G. When using cleaning methods that involve water or other liquids, install drainage devices to prevent runoff over adjacent surfaces unless those surfaces are impervious to damage from runoff.
- H. Do not allow cleaning runoff to drain into sanitary or storm sewers.

3.03 REBUILDING

- A. Cut out damaged and deteriorated masonry with care in a manner to prevent damage to any adjacent remaining materials.
- B. Support structure as necessary in advance of cutting out units.
- C. Cut away loose or unsound adjoining masonry as directed.

- D. Build in new units following procedures for new work specified in other section(s).
- E. Mortar Mix: Colored and proportioned to match existing work.
- F. Ensure that anchors are correctly located and built in.
- G. Install built in masonry work to match and align with existing, with joints and coursing true and level, faces plumb and in line. Build in all openings, accessories and fittings.

3.04 REPOINTING

- A. Perform repointing prior to cleaning masonry surfaces.
- B. Cut out loose or disintegrated mortar in joints to minimum 1/2 inch depth or until sound mortar is reached.
- C. Use power tools only after test cuts determine no damage to masonry units will result.
- D. Do not damage masonry units.
- E. When cutting is complete, remove dust and loose material by brushing.
- F. Premoisten joint and apply mortar. Pack tightly in maximum 1/4 inch layers. Form a smooth, compact concave joint to match existing.
- G. Moist cure for 72 hours.

3.05 CLEANING EXISTING MASONRY

- A. Cleaning Detergent: Brush clean masonry surfaces at all work locations with cleaning agent in accordance with the manufacturer's instructions. Saturate masonry with clean water and flush loose mortar and dirt.

3.06 RESTORATION CLEANING

- A. Clean surfaces and remove large particles with wood scrapers or non-ferrous wire brush.
- B. Spray coat masonry with restoration cleaner, mixed into solution in accordance with manufacturer's instructions.
- C. Provide a second application if required to match mock-up area.
- D. Allow sufficient time for solution to remain on masonry and agitate with soft fiber brush or sponge.
- E. Rinse from the bottom up with potable water applied at 400 psi and at a rate of 4 gal/min.

3.07 AGING

- A. After each application, dust off surplus and wash down with low pressure hose. Allow surface to dry before proceeding with succeeding applications.
- B. Continue process until acceptance.

3.08 CLEANING

- A. Immediately remove stains, efflorescence, or other excess resulting from the work of this section.
- B. Remove excess mortar, smears, and droppings as work proceeds and upon completion.

FOR REFERENCE ONLY

C. Clean surrounding surfaces.

END OF SECTION

SECTION 04 05 11 MASONRY MORTARING AND GROUTING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Mortar for masonry.
- B. Grout for masonry.

1.02 RELATED REQUIREMENTS

- A. Section 04 20 00 - Unit Masonry: Installation of mortar and grout.

1.03 REFERENCE STANDARDS

- A. ASTM C91/C91M - Standard Specification for Masonry Cement.
- B. ASTM C94/C94M - Standard Specification for Ready-Mixed Concrete.
- C. ASTM C270 - Standard Specification for Mortar for Unit Masonry.
- D. ASTM C387/C387M - Standard Specification for Packaged, Dry, Combined Materials for Concrete and High Strength Mortar.
- E. ASTM C476 - Standard Specification for Grout for Masonry.
- F. ASTM C780 - Standard Test Methods for Preconstruction and Construction Evaluation of Mortars for Plain and Reinforced Unit Masonry.
- G. ASTM C979/C979M - Standard Specification for Pigments for Integrally Colored Concrete.
- H. ASTM C1019 - Standard Test Method for Sampling and Testing Grout for Masonry.
- I. ASTM C1142 - Standard Specification for Extended Life Mortar for Unit Masonry.
- J. TMS 402/602 - Building Code Requirements and Specification for Masonry Structures.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Include design mix and indicate whether the Proportion or Property specification of ASTM C270 is to be used. Also include required environmental conditions and admixture limitations.
- C. Samples: Submit two samples of mortar, illustrating mortar color and color range.
- D. Reports: Submit reports on mortar indicating compliance of mortar to property requirements of ASTM C270 and test and evaluation reports per ASTM C780.
- E. Reports: Submit reports on grout indicating compliance of component grout materials to requirements of ASTM C476 and test and evaluation reports to requirements of ASTM C1019.
- F. Manufacturer's Certificate: Certify that products meet or exceed specified requirements.
- G. Manufacturer's Installation Instructions: Submit packaged dry mortar manufacturer's installation instructions.

1.05 QUALITY ASSURANCE

- A. Comply with provisions of TMS 402/602, except where exceeded by requirements of Contract Documents.
 - 1. Maintain one copy of each document on project site.

1.06 PRECONSTRUCTION TESTING

- A. Testing will be conducted by an independent test agency, in accordance with provisions of Section 01 40 00 - Quality Requirements.
- B. Mortar Mixes: Test mortars prebatched by weight in accordance with ASTM C780 recommendations for preconstruction testing.
 - 1. Test results will be used to establish optimum mortar proportions and establish quality control values for construction testing.
- C. Grout Mixes: Test grout batches in accordance with ASTM C1019 procedures.
 - 1. Test results will be used to establish optimum grout proportions and establish quality control values for construction testing.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Maintain packaged materials clean, dry, and protected against dampness, freezing, and foreign matter.

1.08 FIELD CONDITIONS

- A. Cold and Hot Weather Requirements: Comply with requirements of TMS 402/602 or CBC Chapter 21A building code, whichever is more stringent.

PART 2 PRODUCTS

2.01 MORTAR AND GROUT APPLICATIONS

- A. Use only factory premixed packaged dry materials for mortar and grout, with addition of water only at project site.
 - 1. Exception: If a specified mix design is not available in a premixed dry package, provide equivalent mix design using standard non-premixed materials.
- B. Mortar Color: Natural gray unless otherwise indicated.
- C. Mortar Mix Designs: ASTM C270, Proportion Specification.
 - 1. Masonry below grade and in contact with earth: Type S.
 - 2. Exterior, Non-loadbearing Masonry: Type S.
 - 3. Interior, Loadbearing Masonry: Type S.
- D. Grout Mix Designs:
 - 1. Comply with CBC 2103A.3.1.
 - 2. Bond Beams and Lintels: 3,000 psi strength at 28 days; 8-10 inches slump; provide premixed type in accordance with ASTM C 94/C 94M.
 - a. Fine grout for spaces with smallest horizontal dimension of 2 inches or less.

- b. Coarse grout for spaces with smallest horizontal dimension greater than 2 inches.
- 3. Engineered Masonry: Compressive strength at 28 days: as indicated on Drawings; 8-10 inches slump; provide premixed type in accordance with ASTM C 94/C 94M.
 - a. Fine grout for spaces with smallest horizontal dimension of 2 inches or less.
 - b. Coarse grout for spaces with smallest horizontal dimension greater than 2 inches.

2.02 MATERIALS

- A. All materials to conform to CBC, Section 2103A.2 and 2103A.3.
- B. Packaged Dry Material for Mortar for Unit Masonry: Premixed Portland cement, hydrated lime, and sand; complying with ASTM C387/C387M and capable of producing mortar of the specified strength in accordance with ASTM C270 with the addition of water only.
 - 1. Type: Type S.
 - 2. Color: Standard gray.
- C. Packaged Dry Material for Grout for Masonry: Premixed cementitious materials and dried aggregates; capable of producing grout of the specified strength in accordance with ASTM C476 with the addition of water only.
 - 1. Type: Fine.
- D. Pigments for Colored Mortar: Pure, concentrated mineral pigments specifically intended for mixing into mortar and complying with ASTM C979/C979M.
- E. Water: Clean and potable.
- F. Bonding Agent: Latex type.

2.03 MORTAR MIXING

- A. Ready Mixed Mortar: ASTM C1142, Type equivalent to that specified according to ASTM C270.
- B. Thoroughly mix mortar ingredients using mechanical batch mixer, in accordance with ASTM C270 and in quantities needed for immediate use.
- C. Maintain sand uniformly damp immediately before the mixing process.
- D. Colored Mortar: Proportion selected pigments and other ingredients to match Architect's sample, without exceeding manufacturer's recommended pigment-to-cement ratio; mix in accordance with manufacturer's instructions, uniform in coloration.
- E. Do not use anti-freeze compounds to lower the freezing point of mortar.
- F. If water is lost by evaporation, re-temper only within two hours of mixing.

2.04 GROUT MIXING

- A. Mix grout in accordance with ASTM C94/C94M.
- B. Thoroughly mix grout ingredients in quantities needed for immediate use in accordance with ASTM C476 for fine and coarse grout.
 - 1. Concrete Masonry High Lift Grouting Per DSA IR 21-2, revised 3/3/16:
 - a. The grout mix shall comply with the requirements of CBC, Section 2103A.3.
 - 1) All cells shall be solidly filled with grout in reinforced hollow unit masonry per CBC Section 2104A.1.3.

- 2) A coarse grout shall be used in grout spaces 2 inches or more in width and in all grouted cells of hollow unit masonry, per CBC Section 2103A.3.
 - b. Sufficient water may be added to make a workable mix that will flow into all voids of the masonry without separation or segregation.
 - 1) The slump of the grout shall be 8 to 11 inches per TMS 402/602, Article 2.6 B.2 and ASTM C476, Section 4.2.2.
 - c. Grout mixes shall contain an approved admixture conforming to the requirements of this specification. Admixture shall be used in strict accordance with the manufacturer's instructions and appropriate listing from ICC-ES or other acceptable evaluation agency per IR A-5.
- C. Add admixtures in accordance with manufacturer's instructions; mix uniformly.
1. Basis of Design Product: Grout Aid as manufactured by Sika, or approved equal.
 2. Admixtures shall meet the requirements of CBC Section 2103A.5 and have an evaluation report meeting the requirements of IR A-5.
 3. The approval of the Architect or structural engineer and DSA is required for the use of any admixture.

PART 3 EXECUTION

3.01 PREPARATION

- A. Apply bonding agent to existing concrete surfaces.
- B. Plug clean-out holes for grouted masonry with block masonry units. Brace masonry to resist wet grout pressure.

3.02 INSTALLATION

- A. Install mortar and grout to requirements of section(s) in which masonry is specified.
- B. Do not install grout in lifts greater than 16 inches without consolidating grout by rodding.

3.03 GROUTING

- A. Perform all grouting by means of low-lift technique. Do not employ high-lift grouting.
- B. Low-Lift Grouting:
 1. Conform to CBC 2104A.1.3.1.
 2. Limit height of pours to 48 inches.
 3. Limit height of masonry to 16 inches above each pour.
 4. Pour grout only after vertical reinforcing is in place; horizontal reinforcing to be in place prior to grout being poured. Prevent displacement of bars as grout is poured.
 5. Place grout for each pour continuously and consolidate immediately; do not interrupt pours for more than 1-1/2 hours.
- C. When grouting is stopped for more than one hour, terminate grout minimum 1-1/2 inch, 2 inches maximum below top of upper masonry unit to form a positive key for subsequent grout placement.

- D. Solid grout all cells and courses, no exceptions. Consolidate with 3/4 inch diameter mechanical vibrator inserted into each and every cell.
 - 1. Reconsolidate after the block has absorbed some of the water in the grout, but before the grout has lost plasticity.

3.04 FIELD QUALITY CONTROL

- A. An independent testing agency will perform field tests, in accordance with provisions of Section 01 40 00 - Quality Requirements.
- B. Testing of mortar and grout: Conform to the requirements of CBC, Section 2105A.3.
- C. Test and evaluate mortar in accordance with ASTM C780 procedures.
 - 1. Test with same frequency as specified for masonry units.
- D. Test and evaluate grout in accordance with ASTM C1019 procedures.
 - 1. Test with same frequency as specified for masonry units.

END OF SECTION

SECTION 04 20 00 UNIT MASONRY

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Concrete block.
 - 1. Applications: Trash Enclosure and Site Walls.
- B. Mortar and grout.
- C. Reinforcement and anchorage.
- D. Accessories.

1.02 RELATED REQUIREMENTS

- A. Section 03 20 00 - Concrete Reinforcing: Reinforcing steel for grouted masonry.
- B. Section 04 05 11 - Masonry Mortaring and Grouting.
- C. Section 07 62 00 - Sheet Metal Flashing and Trim: Through-wall masonry flashings.
- D. Section 07 92 00 - Joint Sealants: Sealing control and expansion joints.

1.03 REFERENCE STANDARDS

- A. ASTM C90 - Standard Specification for Loadbearing Concrete Masonry Units.
- B. ASTM C129 - Standard Specification for Nonloadbearing Concrete Masonry Units.
- C. ASTM C1072 - Standard Test Methods for Measurement of Masonry Flexural Bond Strength.
- D. ASTM C1314 - Standard Test Method for Compressive Strength of Masonry Prisms.
- E. ASTM E514/E514M - Standard Test Method for Water Penetration and Leakage Through Masonry.
- F. TMS 402/602 - Building Code Requirements and Specification for Masonry Structures.
- G. DSA, Interpretation of Regulations Document IR 21-2 - Concrete Masonry High Lift Grouting Method.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Preinstallation Meeting: Convene a preinstallation meeting one week before starting work of this section; require attendance by all relevant installers.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide data for masonry units and masonry accessories.
- C. Samples: Submit four samples of decorative block units to illustrate color, texture, and extremes of color range.
- D. Manufacturer's Certificate: Certify that masonry units meet or exceed specified requirements.

- E. Manufacturer's Certificate: Certify that water repellent admixture manufacturer has certified masonry unit manufacturer as an approved user of water repellent admixture in the manufacture of concrete block.
- F. Test Reports: Concrete masonry manufacturer's test reports for units with integral water repellent admixture.
- G. Installer's Qualification Statement.
- H. Maintenance Materials: Furnish the following for District's use in maintenance of project.
 - 1. See Section 01 60 00 - Product Requirements, for additional provisions.

1.06 QUALITY ASSURANCE

- A. Comply with provisions of TMS 402/602, except where exceeded by requirements of Contract Documents.
 - 1. Maintain one copy of each document on project site.
- B. Regulatory Requirements: Except as modified by the requirements specified herein or the details indicated, reinforced concrete unit masonry construction shall conform to the California Building Code (CBC), Title 24, Part 2, Chapter 21A - Masonry.
- C. Manufacturer Qualifications: Company specializing in manufacturing the type of products specified in this section with minimum three years of documented experience.
- D. Installer Qualifications: Company specializing in performing work of the type specified and with at least three years of documented experience.
- E. Single-Source Responsibility for Masonry Units: Obtain exposed masonry units of uniform texture and color, or a uniform blend within the ranges accepted for these characteristics, from one manufacturer for each different product required for each continuous surface or visually related surfaces.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Deliver, handle, and store masonry units by means that will prevent mechanical damage and contamination by other materials.
 - 1. Store and handle masonry units off the ground, under cover, and in a dry location to prevent their deterioration or damage due to moisture, temperature changes, contaminants, corrosion, and other causes. If units become wet, do not place until units are in an air-dried condition.

PART 2 PRODUCTS

2.01 CONCRETE MASONRY UNITS

- A. Acceptable Manufacturers:
 - 1. Basis of Design Product: Precision as manufactured by Basalite, or approved equal.
 - 2. Angeles Block Co., Inc.: www.angelusblock.com.
 - 3. Orco Block Co.: www.orco.com.
 - 4. RCP Block and Brick: www.rcpblock.com.
 - 5. Substitutions: See Section 01 60 00 - Product Requirements.

FOR REFERENCE ONLY

- B. Concrete Block: Comply with referenced standards and as follows:
1. Size: Standard units with nominal face dimensions of 16 x 8 inches or as indicated and nominal depths as indicated on the Drawings for specific locations.
 2. Special Shapes: Provide nonstandard blocks configured for corners.
 3. Load-Bearing Units: ASTM C90, medium weight.
 - a. Hollow block, as indicated.
 - b. Exposed Faces: Manufacturer's standard color and texture where indicated.
 - c. Pattern: As indicated on Drawings.
 - 1) CMU-1: Precision; Color: As indicated on Drawings
 - d. Unit Compressive Strength: Where indicated, provide units with minimum average net area compressive strength of 2,000 psi (Type M or S) and not less than the unit compressive strengths required to produce concrete unit masonry construction of compressive strength indicated.
 - e. Nonloadbearing Units: ASTM C129.
 - 1) Hollow block, as indicated.
 - 2) Medium weight.
 - f. Solid Cap Unit: Nominal unit size, texture and color to match adjacent wall, unless specified otherwise.
 4. Units with Integral Water Repellent: Concrete block units as specified in this section with polymeric liquid admixture added to concrete masonry units at the time of manufacture.
 - a. Only required where concrete block units are exposed to the exterior.
 - b. Performance of Units with Integral Water Repellent:
 - 1) Water Permeance: When tested per ASTM E514/E514M and for a minimum of 72 hours.
 - (a) No water visible on back of wall above flashing at the end of 24 hours.
 - (b) No flow of water from flashing equal to or greater than 0.032 gallons per hour at the end of 24 hours.
 - (c) No more than 25 percent of wall area above flashing visibly damp at end of test.
 - 2) Flexural Bond Strength: ASTM C1072; minimum 10 percent increase.
 - 3) Compressive Strength: ASTM C1314; maximum 5 percent decrease.
 - c. Use only in combination with mortar that also has integral water repellent admixture.
 - d. Use water repellent admixtures for masonry units and mortar by a single manufacturer.
 - e. Mortar and grout must still meet required strengths as indicated on drawings.

2.02 MORTAR AND GROUT MATERIALS

- A. Mortar and Grout: As specified in Section 04 05 11.

2.03 REINFORCEMENT AND ANCHORAGE

- A. Reinforcing Steel: Type specified in Section 03 20 00; size as indicated on drawings; uncoated finish.

2.04 ACCESSORIES

- A. Preformed Control Joints: Neoprene material. Provide with corner and tee accessories, fused joints.
 - 1. Manufacturers:
 - a. Blok-Lok Limited: www.blok-lok.com/#sle.
 - b. Dur-O-Wal: www.dur-o-wal.com.
 - c. Hohmann & Barnard, Inc: www.h-b.com.
 - d. WIRE-BOND: www.wirebond.com/#sle.
 - e. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Joint Filler: Closed cell polyurethane; oversized 50 percent to joint width; self expanding; 3/8 inch wide by maximum lengths available.
 - 1. Manufacturers:
 - a. Hohmann & Barnard, Inc: www.h-b.com.
 - b. WIRE-BOND: www.wirebond.com/#sle.
 - c. Substitutions: See Section 01 60 00 - Product Requirements.
- C. Cleaning Solution: Non-acidic, not harmful to masonry work or adjacent materials.
 - 1. Job-Mixed Detergent Solution: Solution of trisodium phosphate (1/2-cup dry measure) and laundry detergent (1/2-cup dry measure) dissolved in one gallon of water.
 - 2. Basis of Design Product: Enviro Klean as manufactured by ProSoCo, Inc., www.prosoco.com, or equal.
- D. Proprietary Acidic Cleaners: Standard-strength cleaners designed for removing mortar/grout stains, efflorescence, and other new construction stains from new masonry surfaces of type indicated below.
 - 1. Do not discolor or damage masonry surfaces.
 - 2. Cleaners shall be expressly approved for intended use by manufacturer of masonry units being cleaned.
 - 3. Comply with applicable occupational safety and hazardous and toxic materials regulations in handling and disposing of solutions.
 - 4. General Purpose Cleaner: For removal and control of efflorescence, removal of excess mortar, grout and common construction soiling from new masonry not subject to metallic oxidation stains.
 - a. Basis of Design Product: Sure Klean No. 600 as manufactured by ProSoCo, Inc., www.prosoco.com, or equal.
 - 5. Cleaner for Asphalt and Tar: For removing asphalt, tar, grease, hydraulic oil, motor oil and similar materials from porous masonry.

FOR REFERENCE ONLY

- a. Basis of Design Product: Sure Klean Asphalt & Tar Remover as manufactured by ProSoCo, Inc., www.prosoco.com, or equal.
- 6. Cleaner for Lime Putty Stains: For removing excess mortar, heavy lime deposits and normal construction stains from new masonry surfaces where high-strength lime putty mortar mixes have been used.
 - a. Basis of Design Product: Sure Klean 101 Lime Solvent as manufactured by ProSoCo, Inc., www.prosoco.com, or equal.
- E. Water Repellent: Water-based silane or siloxane masonry water repellent.
 - 1. See Section 07 19 00 - Water Repellents.
 - 2. Use a non-sacrificial product list in Section 09 96 23 - Graffiti-Resistant Coatings.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that field conditions are acceptable and are ready to receive masonry.
- B. Verify that related items provided under other sections are properly sized and located.
- C. Verify that built-in items are in proper location, and ready for roughing into masonry work.

3.02 PREPARATION

- A. Direct and coordinate placement of metal anchors supplied for installation under other sections.
- B. Comply with CBC Section 2104A in addition to referenced unit masonry standard and other requirements indicated applicable to each type of installation included in Project.
- C. Leave openings for equipment to be installed before completion of masonry. After installation of equipment, complete masonry to match construction immediately adjacent to the opening.
- D. Cut or trim interior of face shells or cross webs of masonry units, where necessary, to provide a minimum clearance of 1/2 inch or one bar diameter, whichever is greater, to reinforcing bars.
- E. Protection of Unit Masonry: During erection, cover tops of walls, projections, and sills with waterproof sheeting at end of each workday. Cover partially completed unit masonry when construction is not in progress.
 - 1. Extend cover a minimum of 24-inches down both sides and hold cover securely in place.
- F. Stain Prevention: Prevent grout, mortar, and soil from staining the face of unit masonry to be left exposed or painted. Remove immediately any grout, mortar, and soil that come in contact with such masonry.
- G. Stopping and Resuming Work: In each course, rack back 1/2-unit length for one-half running bond; do not tooth. Clean exposed surfaces of set masonry, and remove loose masonry units and mortar prior to laying fresh masonry.

3.03 COLD AND HOT WEATHER REQUIREMENTS

- A. Comply with requirements of TMS 402/602 or applicable building code, whichever is more stringent.

3.04 COURSING

- A. Establish lines, levels, and coursing indicated. Protect from displacement.
- B. Maintain masonry courses to uniform dimension. Form vertical and horizontal joints of uniform thickness.
- C. Concrete Masonry Units:
 - 1. Bond: Running.
 - 2. Coursing: One unit and one mortar joint to equal 8 inches.
 - 3. Mortar Joints: Concave.

3.05 PLACING AND BONDING

- A. Lay out walls in advance for accurate spacing of surface bond patterns with uniform joint widths and for accurate locating of openings, movement-type joints, returns, and offsets. Avoid the use of less-than-half-size units at corners, jambs, and where possible at other locations.
- B. Lay solid masonry units in full bed of mortar, with full head joints, uniformly jointed with other work.
 - 1. Bed webs in mortar in starting course on footings and in all courses of piers, columns, and pilasters, and where adjacent to cells or cavities to be filled with grout.
 - 2. For starting course on footings where cells are not grouted, spread out full mortar bed including areas under cells.
- C. Lay hollow masonry units with face shell bedding on head and bed joints.
- D. Buttering corners of joints or excessive furrowing of mortar joints is not permitted.
- E. Remove excess mortar and mortar smears as work progresses.
- F. Interlock intersections and external corners, except for units laid in stack bond.
- G. Do not shift or tap masonry units after mortar has achieved initial set. Where adjustment must be made, remove mortar and replace.
- H. Perform job site cutting of masonry units with proper tools (motor-driven saws) to provide straight, clean, unchipped edges. Prevent broken masonry unit corners or edges. Use full-size units without cutting where possible.

3.06 REINFORCEMENT AND ANCHORAGE - GENERAL AND SINGLE WYTHE MASONRY

- A. Place continuous joint reinforcement in first and second joint below top of walls.
- B. Embed longitudinal wires of joint reinforcement in mortar joint with at least 5/8 inch mortar cover on each side.
- C. Lap joint reinforcement ends as indicated on Drawings, minimum 6 inches.
- D. Reinforce joint corners and intersections with strap anchors 16 inches on center.
- E. Fasten anchors to structural framing and embed in masonry joints as masonry is laid. Unless otherwise indicated on drawings or closer spacing is indicated under specific wall type, space anchors at maximum of 16 inches horizontally and 16 inches vertically.

3.07 CONTROL AND EXPANSION JOINTS

- A. Control Joints: As indicated on Drawings.
- B. Control Joints: Locate control joints maximum 24 feet on center or as indicated. If not shown, provide submittal to Architect with proposed locations for approval.
- C. Expansion Joints: As indicated on Drawings.
- D. Do not continue horizontal joint reinforcement through control or expansion joints.
- E. Install preformed control joint device in continuous lengths. Seal butt and corner joints in accordance with manufacturer's instructions.
- F. Size control joints as indicated on drawings; if not indicated, 3/4 inch wide and deep.
- G. Comply with Section 07 92 00 for sealant performance.
- H. Form expansion joint as detailed on drawings.

3.08 BUILT-IN WORK

- A. As work progresses, install built-in fabricated metal frames and other items to be built into the work and furnished under other sections.
- B. Install built-in items plumb, level, and true to line.
- C. Bed anchors of metal door and glazed frames in adjacent mortar joints. Fill frame voids solid with grout.
 - 1. Fill adjacent masonry cores with grout minimum 12 inches from framed openings.
- D. Do not build into masonry construction organic materials that are subject to deterioration.

3.09 TOLERANCES

- A. Install masonry within the site tolerances found in TMS 402/602.
- B. Verify tolerances prior to placing next course. If the unit placed does not meet the tolerances listed below, it shall be removed and reinstalled to meet specified tolerances at no additional cost to District.
- C. Maximum Variation from Alignment of Columns: 1/4 inch.
- D. Maximum Variation From Unit to Adjacent Unit: 1/16 inch.
- E. Maximum Variation from Plane of Wall: 1/4 inch in 10 ft and 1/2 inch in 20 ft or more.
- F. Maximum Variation from Plumb: 1/4 inch per story non-cumulative; 1/2 inch in two stories or more.
- G. Maximum Variation from Level Coursing: 1/8 inch in 3 ft and 1/4 inch in 10 ft; 1/2 inch in 30 ft.
- H. Maximum Variation of Mortar Joint Thickness: Head joint, minus 1/4 inch, plus 3/8 inch.
- I. Maximum Variation from Cross Sectional Thickness of Walls: 1/4 inch.

3.10 CUTTING AND FITTING

- A. Cut and fit for chases and sleeves. Coordinate with other sections of work to provide correct size, shape, and location.

- B. Obtain approval prior to cutting or fitting masonry work not indicated or where appearance or strength of masonry work may be impaired.

3.11 FIELD QUALITY CONTROL

- A. An independent testing agency will perform field quality control tests, as specified in Section 01 40 00 - Quality Requirements.
- B. Inspection and Core Tests shall be per CBC 1705A.4 and 2105A.4.

3.12 REPAIRING AND POINTING

- A. Repairing: Remove and replace masonry units that are loose, chipped, broken, stained, or otherwise damaged or if units do not match adjoining units. Install new units to match adjoining units and in fresh mortar or grout, pointed to eliminate evidence of replacement.
- B. Pointing: During the tooling of joints, enlarge any voids or holes, except weep holes, and completely fill with mortar. Point-up all joints including corners, openings, and adjacent construction to provide a neat, uniform appearance, prepared for application of sealants.

3.13 CLEANING

- A. Remove excess mortar and mortar droppings.
- B. Replace defective mortar. Match adjacent work.
- C. Clean soiled surfaces with cleaning solution.
- D. Use non-metallic tools in cleaning operations.
- E. Final Cleaning: After mortar is thoroughly set and cured, clean exposed masonry as follows:
 1. Remove large mortar particles by hand with wooden paddles and nonmetallic scrape hoes or chisels.
 2. Test cleaning methods on sample wall panel; leave 1/2 panel uncleaned for comparison purposes. Obtain Architect's approval of sample cleaning before proceeding with cleaning of masonry.
 3. Wet wall surfaces with water prior to application of cleaners; remove cleaners promptly by rinsing thoroughly with clear water.
 4. Clean concrete unit masonry by means of cleaning method indicated in NCMA TEK 45 applicable to type of stain present on exposed surfaces.

3.14 PROTECTION

- A. Without damaging completed work, provide protective boards at exposed external corners that are subject to damage by construction activities.

END OF SECTION

SECTION 05 12 00 STRUCTURAL STEEL FRAMING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Structural steel framing members.
- B. Grouting under base plates.

1.02 RELATED REQUIREMENTS

- A. Section 05 31 00 - Steel Decking: Support framing for small openings in deck.
- B. Section 05 50 00 - Metal Fabrications: Steel fabrications affecting structural steel work.

1.03 REFERENCE STANDARDS

- A. AISC (MAN) - Steel Construction Manual.
- B. AISC 201 - AISC Certification Program for Structural Steel Fabricators, Standard for Steel Building Structures.
- C. AISC 303 - Code of Standard Practice for Steel Buildings and Bridges.
- D. AISC 341 - Seismic Provisions for Structural Steel Buildings.
- E. AISC 360 - Specification for Structural Steel Buildings.
- F. ASTM A36/A36M - Standard Specification for Carbon Structural Steel.
- G. ASTM A53/A53M - Standard Specification for Pipe, Steel, Black and Hot-Dipped, Zinc-Coated, Welded and Seamless.
- H. ASTM A108 - Standard Specification for Steel Bar, Carbon and Alloy, Cold-Finished.
- I. ASTM A123/A123M - Standard Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products.
- J. ASTM A500/A500M - Standard Specification for Cold-Formed Welded and Seamless Carbon Steel Structural Tubing in Rounds and Shapes.
- K. ASTM A563/A563M - Standard Specification for Carbon and Alloy Steel Nuts (Inch and Metric).
- L. ASTM A780/A780M - Standard Practice for Repair of Damaged and Uncoated Areas of Hot-Dip Galvanized Coatings.
- M. ASTM A992/A992M - Standard Specification for Structural Steel Shapes.
- N. ASTM A1008/A1008M - Standard Specification for Steel, Sheet, Cold-Rolled, Carbon, Structural, High-Strength Low-Alloy, High-Strength Low-Alloy with Improved Formability, Required Hardness, Solution Hardened, and Bake Hardenable.
- O. ASTM A1011/A1011M - Standard Specification for Steel, Sheet and Strip, Hot-Rolled, Carbon, Structural, High-Strength Low-Alloy, High-Strength Low-Alloy with Improved Formability, and Ultra-High Strength.
- P. ASTM C827/C827M - Standard Test Method for Change in Height at Early Ages of Cylindrical Specimens of Cementitious Mixtures.

FOR REFERENCE ONLY

- Q. ASTM E94/E94M - Standard Guide for Radiographic Examination Using Industrial Radiographic Film.
- R. ASTM E164 - Standard Practice for Contact Ultrasonic Testing of Weldments.
- S. ASTM E165/E165M - Standard Practice for Liquid Penetrant Testing for General Industry.
- T. ASTM E329 - Standard Specification for Agencies Engaged in Construction Inspection, Testing, or Special Inspection.
- U. ASTM E709 - Standard Guide for Magnetic Particle Testing.
- V. ASTM F436/F436M - Standard Specification for Hardened Steel Washers Inch and Metric Dimensions.
- W. ASTM F959/F959M - Standard Specification for Compressible-Washer-Type Direct Tension Indicators for Use with Structural Fasteners, Inch and Metric Series.
- X. ASTM F1554 - Standard Specification for Anchor Bolts, Steel, 36, 55, and 105-ksi Yield Strength.
- Y. ASTM F3125/F3125M - Standard Specification for High Strength Structural Bolts and Assemblies, Steel and Alloy Steel, Heat Treated, Inch Dimensions 120 ksi and 150 ksi Minimum Tensile Strength, and Metric Dimensions 830 MPa and 1040 MPa Minimum Tensile Strength.
- Z. AWS A2.4 - Standard Symbols for Welding, Brazing, and Nondestructive Examination.
- AA. AWS B2.1/B2.1M - Specification for Welding Procedure and Performance Qualification.
- BB. AWS D1.1/D1.1M - Structural Welding Code - Steel.
- CC. IAS AC172 - Accreditation Criteria for Fabricator Inspection Programs for Structural Steel AC172.
- DD. RCSC (HSBOLT) - Specification for Structural Joints Using High-Strength Bolts; Research Council on Structural Connections.
- EE. SSPC-Paint 15 - Steel Joist Shop Primer/Metal Building Primer.
- FF. SSPC-Paint 20 - Zinc-Rich Coating (Type I - Inorganic, and Type II - Organic).
- GG. SSPC-SP 2 - Hand Tool Cleaning.
- HH. SSPC-SP 3 - Power Tool Cleaning.
- II. SSPC-SP 13 - Surface Preparation of Concrete.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Shop Drawings:
 - 1. Indicate profiles, sizes, spacing, locations of structural members, openings, attachments, and fasteners.
 - 2. Indicate cambers and loads.
 - 3. Indicate welded connections with AWS A2.4 welding symbols. Indicate net weld lengths.
- C. Manufacturer's Mill Certificate: Certify that products meet or exceed specified requirements.
- D. Mill Test Reports: Indicate structural strength, destructive test analysis and non-destructive test analysis.

- E. Fabricator Test Reports: Comply with ASTM A1011/A1011M.
- F. Materials Test Reports: Submit independent test results or engineered performance analysis of structural thermal-break pad performance in bearing or slip-critical connections where shear and moment loads are applied.
- G. Welders' Qualification Statement: Welders' certificates in accordance with AWS B2.1/B2.1M and dated no more than 12 months before start of scheduled welding work.
- H. Fabricator's Qualification Statement: Provide documentation showing steel fabricator is accredited under the International Accreditation Service (IAS) Fabricator Inspection Program for Structural Steel in accordance with IAS AC172, AISC 201, or City of Los Angeles Certified Fabricator.

1.05 QUALITY ASSURANCE

- A. Fabricate structural steel members in accordance with AISC (MAN) "Steel Construction Manual."
- B. Maintain one copy of each document on site.
- C. Fabricator: Company specializing in performing the work of this section with minimum five years of documented experience.
- D. Welder Qualifications: Welding processes and welding operators qualified in accordance with AWS D1.1/D1.1M and no more than 12 months before start of scheduled welding work.
- E. Fabricator Qualifications: A qualified steel fabricator that is accredited by the International Accreditation Service (IAS) Fabricator Inspection Program for Structural Steel in accordance with IAS AC172, AISC 201, or City of Los Angeles Certified Fabricator.
- F. Erector: Company specializing in performing the work of this section with minimum five years of documented experience.
- G. Inspection: The District will employ a special inspector during all welding, and high-strength bolt installations and tightening operations, in accordance with California Building Code (CBC) requirements and other requirements of authorities having jurisdiction
 - 1. Testing Agency Qualifications: An independent agency qualified according to ASTM E329 and Section 01 45 33 for testing indicated.
 - a. Special Inspector: AWS-CWI qualified inspector approved by DSA for all welding.

PART 2 PRODUCTS

2.01 REGULATORY REQUIREMENTS

- A. Comply with applicable provisions of the following building codes, including special inspection provisions:
 - 1. California Building Code (CBC), Chapters 17A and 22A.
- B. Comply with applicable provisions of the following specifications and documents as modified by the building codes:
 - 1. AISC 341 and Supplement No. 1.
 - 2. AISC 358.
 - 3. AISC 360 including high-seismic applications.

4. AWS D1.1/D1.1M, "Structural Welding Code-Steel".
5. AWS D1.8/D1.8M, "Structural Welding Code-Seismic Supplement".
6. RCSC (HSBOLT).

2.02 MATERIALS

- A. Steel Angles, Plates, and Channels: ASTM A36/A36M.
 1. Unless indicated as Grade 50 on Drawings.
- B. Steel W Shapes and Tees: ASTM A992/A992M.
- C. Rolled Steel Structural Shapes: ASTM A992/A992M.
- D. Cold-Formed Structural Tubing: ASTM A500/A500M, Grade B.
- E. Steel Bars: ASTM A108.
- F. Steel Sheet: ASTM A1011/A1011M, Designation SS, Grade 30 hot-rolled, or ASTM A1008/A1008M, Designation SS, Grade 30 cold-rolled.
- G. Pipe: ASTM A53/A53M, Grade B, Finish black.
- H. Structural Bolts and Nuts: As indicated on Structural Drawings.
- I. High-Strength Structural Bolts, Nuts, and Washers: ASTM F3125/F3125M, Type 1, with matching compatible ASTM A563/A563M nuts and ASTM F436/F436M washers.
- J. Tension Control Bolts: Twist-off type; ASTM F3125/F3125M.
- K. Unheaded Anchor Rods: ASTM F1554, Grade 36, plain, with matching ASTM A563/A563M nuts and ASTM F436/F436M Type 1 washers.
- L. Headed Anchor Rods: ASTM F1554 Grade 36, plain.
- M. Load Indicator Washers: Provide washers complying with ASTM F959/F959M at connections requiring high-strength bolts.
- N. Welding Materials: AWS D1.1/D1.1M and AWS D1.8/D1.8M; type required for materials being welded.
 1. Provide E70XX-low hydrogen electrodes for shielded metal arc welding.
 2. Provide E71TXX wire type for flux-cored arc welding.
 3. The filler metal used for the welding of members of the lateral load resisting system, shall have a notch toughness not less than 20 ft.-lbs. at 20F. as measured by a standard Charpy V-notch test, ASTM E23, in accordance with the applicable filler metal specification referenced in [AWS D1.1/D1.1M](#).
- O. Grout: ASTM C1107/C1107M; Non-shrink; premixed compound consisting of non-metallic aggregate, cement, water reducing and plasticizing agents.
 1. Provide minimum compressive strength as indicated on Drawings.
 2. Height Change, Plastic State; when tested according to ASTM C827/C827M:
 - a. Maximum: Plus 4 percent.
 - b. Minimum: Plus 1 percent.
- P. Shop and Touch-Up Primer: Fabricator's standard, complying with VOC limitations of authorities having jurisdiction.

1. SSPC-Paint 15, standard color.
 2. Low-Emitting Materials: Paints and coatings shall comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."
- Q. Touch-Up Primer for Galvanized Surfaces: SSPC-Paint 20 Type I - Inorganic, complying with VOC limitations of authorities having jurisdiction.

2.03 FABRICATION

- A. Shop fabricate to greatest extent possible.
- B. Continuously seal joined members by continuous welds. Grind exposed welds smooth.
- C. Fabricate connections for bolt, nut, and washer connectors.
- D. Develop required camber for members.

2.04 FINISH

- A. General: Materials and fabrication procedures shall be subject to inspection and tests in mill, shop, and field, conducted by a qualified inspection agency, as specified in Section 01 40 00 - Quality Requirements and Section 01 45 33 - Code-Required Special Inspections.
 1. Such inspections and tests do not relieve Contractor of responsibility for providing materials and fabrication procedures in compliance with specified requirements.
 2. Promptly remove and replace materials or fabricated components that do not comply.
- B. Prepare structural component surfaces in accordance with SSPC-SP 3.
- C. Shop prime structural steel members. Do not prime surfaces that will be fireproofed, field welded, in contact with concrete, or high strength bolted.
- D. Galvanize all exterior structural steel members to comply with ASTM A123/A123M. Provide minimum 1.7 oz/sq ft galvanized coating.

2.05 SOURCE QUALITY CONTROL

- A. Provide shop testing and analysis of structural steel.
- B. High-Strength Bolts: Provide testing and verification of shop-bolted connections in accordance with RCSC (HSBOLT) "Specification for Structural Joints Using High-Strength Bolts", testing at least 100 percent of bolts at each connection.
- C. Welded Connections: Visually inspect continuously or periodically per the DSA Form 103 all shop-welded connections and test at least 100 percent of welds using one of the following:
 1. Radiographic testing performed in accordance with ASTM E94/E94M.
 2. Ultrasonic testing performed in accordance with ASTM E164.
 3. Liquid penetrant inspection performed in accordance with ASTM E165/E165M.
 4. Magnetic particle inspection performed in accordance with ASTM E709.
 - a. Performed on root pass and on finished weld.
 - b. Cracks or zones of incomplete fusion or penetration not acceptable.
- D. See also part 3 article "Field Quality Control".

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that conditions are appropriate for erection of structural steel and that the work may properly proceed.

3.02 ERECTION

- A. Erect structural steel in compliance with AISC 303.
- B. Allow for erection loads and provide sufficient temporary bracing to maintain structure in safe condition, plumb, and in true alignment until completion of erection and installation of permanent bracing.
- C. Field weld components indicated on shop drawings.
- D. Use carbon steel bolts only for temporary bracing during construction, unless otherwise specifically permitted on drawings. Install high-strength bolts in accordance with RCSC (HSBOLT) "Specification for Structural Joints Using High-Strength Bolts".
- E. Do not field cut or alter structural members without approval of Architect.
- F. After erection, prime welds, abrasions, and surfaces not shop primed, except surfaces to be in contact with concrete.
- G. Grout solidly between column plates and bearing surfaces, complying with manufacturer's instructions for nonshrink grout. Trowel grouted surfaces smooth, splaying neatly to 45 degrees.

3.03 TOLERANCES

- A. Level and plumb individual members of structure within specified AISC tolerances.
- B. Maximum Variation From Plumb: 1/4 inch per story, non-cumulative.
- C. Maximum Offset From True Alignment: 1/4 inch.

3.04 FIELD QUALITY CONTROL

- A. An independent testing agency will perform field quality control tests, as specified in Section 01 40 00 - Quality Requirements.
 - 1. Special Inspector: AWS-CWI qualified inspector to inspect all welds.
- B. High-Strength Bolts: Provide testing and verification of field-bolted connections in accordance with RCSC (HSBOLT) "Specification for Structural Joints Using High-Strength Bolts."
- C. Welded Connections: Visually inspect continuously or periodically per the DSA Form 103 all field-welded connections and test at least 100 percent of welds using one of the following:
 - 1. Radiographic testing performed in accordance with ASTM E94/E94M.
 - 2. Ultrasonic testing performed in accordance with ASTM E164.
 - 3. Liquid penetrant inspection performed in accordance with ASTM E165/E165M.
 - 4. Magnetic particle inspection performed in accordance with ASTM E709.

FOR REFERENCE ONLY

- D. Report: AWS-CWI Welding inspector will submit a signed report to the Architect, Structural Engineer, Project Inspector, and Authority Having Jurisdiction (Division of the State Architect) verifying that welding was performed in compliance with specified and Code-mandated requirements and that adequate methods were used to determine the quality of the welding.
- E. Re-Inspection: After correction of deficiencies in structural steel work which inspections and test reports indicate, additional inspections and tests will be performed to confirm that structural steel complies with specified requirements. Costs of re-inspections shall be paid in accordance with Conditions of the Contract.

3.05 CLEANING AND TOUCH-UP

- A. Cleaning: Perform initial cleaning immediately after completion of installation. Prepare surfaces for finish painting.
- B. Galvanizing Touch-Up: Touch up galvanizing immediately after installation, including field welding.
 - 1. Prepare surface and apply cold galvanizing compound in compliance with ASTM A780/A780M and the manufacturer's instructions and recommendations.
- C. Primer Paint Touch-Up: Touch up shop paint immediately after erection. Use products compliant with Section(s) 09 91 13 - Exterior Painting and 09 91 23 - Interior Painting.
 - 1. Clean exposed areas of rust, field welds, bolted joints, and areas where primer is damaged by SSPC-SP 2 hand tool cleaning or SSPC-SP 3 power-tool cleaning.
 - 2. Paint with applicable SSPC-Paint 15 (interior) or SSPC-Paint 20 (exterior) compliant material used for shop painting, minimum 3 mils dry film thickness.

END OF SECTION

SECTION 05 50 00 METAL FABRICATIONS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Shop fabricated steel items.
- B. Requirements for materials and equipment for post-installed mechanical and adhesive anchors in concrete.

1.02 RELATED REQUIREMENTS

- A. Section 03 30 00 - Cast-in-Place Concrete: Placement of metal fabrications in concrete.
- B. Section 05 12 00 - Structural Steel Framing: Structural steel column anchor bolts.
- C. Section 09 91 13 - Exterior Painting: Paint finish.
- D. Section 09 91 23 - Interior Painting: Paint finish.
- E. Divisions 10 - Specialties, 22 - Plumbing, 23 - Heating, Ventilating, and Air-Conditioning (HVAC), 26 - Electrical, 27 - Communications, and 28 - Electronic Safety and Security: Mounting of equipment and components.

1.03 REFERENCE STANDARDS

- A. ACI 318 - Building Code Requirements for Structural Concrete.
- B. ACI 355.4 - Qualification of Post-Installed Adhesive Anchors in Concrete.
- C. ACI 440.2R - Guide for the Design and Construction of Externally Bonded FRP Systems for Strengthening Concrete Structures.
- D. AISC 201 - AISC Certification Program for Structural Steel Fabricators, Standard for Steel Building Structures.
- E. ASTM A193/A193M - Standard Specification for Alloy-Steel and Stainless Steel Bolting for High Temperature or High Pressure Service and Other Special Purpose Applications.
- F. ASTM A36/A36M - Standard Specification for Carbon Structural Steel.
- G. ASTM A53/A53M - Standard Specification for Pipe, Steel, Black and Hot-Dipped, Zinc-Coated, Welded and Seamless.
- H. ASTM A123/A123M - Standard Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products.
- I. ASTM A500/A500M - Standard Specification for Cold-Formed Welded and Seamless Carbon Steel Structural Tubing in Rounds and Shapes.
- J. ASTM A615/A615M - Standard Specification for Deformed and Plain Carbon-Steel Bars for Concrete Reinforcement.
- K. ASTM A653/A653M - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process.

FOR REFERENCE ONLY

- L. ASTM A1011/A1011M - Standard Specification for Steel, Sheet and Strip, Hot-Rolled, Carbon, Structural, High-Strength Low-Alloy, High-Strength Low-Alloy with Improved Formability, and Ultra-High Strength.
- M. ASTM B633 - Standard Specification for Electrodeposited Coatings of Zinc on Iron and Steel.
- N. ASTM E329 - Standard Specification for Agencies Engaged in Construction Inspection, Testing, or Special Inspection.
- O. ASTM F594 - Standard Specification for Stainless Steel Nuts.
- P. AWS A2.4 - Standard Symbols for Welding, Brazing, and Nondestructive Examination.
- Q. AWS B2.1/B2.1M - Specification for Welding Procedure and Performance Qualification.
- R. AWS D1.1/D1.1M - Structural Welding Code - Steel.
- S. AWS D1.2/D1.2M - Structural Welding Code - Aluminum.
- T. IAS AC172 - Accreditation Criteria for Fabricator Inspection Programs for Structural Steel AC172.
- U. SSPC-PA 1 - Shop, Field, and Maintenance Coating of Metals.
- V. SSPC-Paint 15 - Steel Joist Shop Primer/Metal Building Primer.
- W. SSPC-Paint 20 - Zinc-Rich Coating (Type I - Inorganic, and Type II - Organic).
- X. SSPC-SP 3 - Power Tool Cleaning.
- Y. SSPC-SP 5 - White Metal Blast Cleaning.
- Z. SSPC-SP 6 - Commercial Blast Cleaning.
- AA. SSPC-SP 10 - Near-White Metal Wet Abrasive Blast Cleaning.
- BB. SSPC-SP 2 - Hand Tool Cleaning.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. ICC ES Reports: If requested, ICC Evaluation Service report indicating conformance with ICC-ES Acceptance Criteria.
- C. Shop Drawings: Indicate profiles, sizes, connection attachments, reinforcing, anchorage, size and type of fasteners, and accessories. Include erection drawings, elevations, and details where applicable.
 - 1. Indicate welded connections using standard AWS A2.4 welding symbols. Indicate net weld lengths.
- D. Welders' Qualification Statement: Welders' certificates in accordance with AWS B2.1/B2.1M and dated no more than 12 months before start of scheduled welding work.
- E. Fabricator's Qualification Statement: Provide documentation showing steel fabricator is accredited under IAS AC172 or AISC 201.

1.05 QUALITY ASSURANCE

- A. Welder Qualifications: Welding processes and welding operators qualified in accordance with AWS D1.1/D1.1M and AWS D1.2/D1.2M and dated no more than 12 months before start of scheduled welding work.

FOR REFERENCE ONLY

- B. Fabricator Qualifications: A qualified steel fabricator that is accredited by IAS AC172, AISC 201, or City of Los Angeles Certified Fabricator.
- C. Testing Agency Qualifications: An independent agency qualified according to ASTM E329 and Section 01 45 33 for testing indicated.
- D. Installer Training: Prior to beginning the work, manufacturer or manufacturer's representative shall provide on-site training for all contractor's personnel who will be installing anchors.

PART 2 PRODUCTS

2.01 REGULATORY REQUIREMENTS

- A. Conform to applicable requirements of California Building Code (CBC), Title 24, Part 2, as amended and adopted by authorities having jurisdiction.
 - 1. Comply with Title 24, Part 9, California Fire Code Chapter 35 "Welding and Other Hot Work."

2.02 MATERIALS - STEEL

- A. Steel Sections: ASTM A36/A36M, for channels, angles and plates.
- B. Steel Tubing: ASTM A500/A500M Grade B cold-formed structural tubing.
- C. Pipe: ASTM A53/A53M, Grade B Schedule 40, black finish.
- D. Slotted Channel Framing: ASTM A653/A653M, Grade 33.
- E. Slotted Channel Fittings: ASTM A1011/A1011M.
- F. Mechanical Fasteners: Same material as or compatible with materials being fastened; type consistent with design and specified quality level.
- G. Bolts, Nuts, and Washers: As indicated on Drawings.
- H. Welding Materials: AWS D1.1/D1.1M; type required for materials being welded.
- I. Shop and Touch-Up Primer: SSPC-Paint 15, complying with VOC limitations of authorities having jurisdiction.
 - 1. Comply with SSPC-PA 1. Coordinate with requirements specified in Section 09 91 13 - Exterior Painting and 09 91 23 - Interior Painting .
 - a. Coordinate primer with finish paint and coating, as applicable, to provide sound foundation for field-applied topcoats despite prolonged exposure during construction.
- J. Galvanize all exterior steel members to comply with ASTM A123/A123M. Provide minimum 1.7 oz/sq ft galvanized coating.
- K. Touch-Up Primer for Galvanized Surfaces: SSPC-Paint 20, Type I - Inorganic, complying with VOC limitations of authorities having jurisdiction.

2.03 FABRICATION

- A. Ferrous Metal Surfaces, General:

FOR REFERENCE ONLY

1. For metal fabrications exposed to view upon completion of the Work: Provide ferrous metals materials selected for their surface flatness, smoothness, and freedom from surface blemishes.
2. Do not use materials whose exposed surfaces exhibit pitting, seam marks, roller marks, rolled trade names, roughness, and, for steel sheet, variations in flatness exceeding those permitted by reference standards for stretcher-leveled sheet.
- B. Hot-dip galvanize fabricated ferrous items, indicated as remaining unpainted, after fabrication. Field connections shall be bolted or screwed where possible. Avoid field cutting and welding which damage galvanized coating.
- C. Fit and shop assemble items in largest practical sections, for delivery to site.
- D. Fabricate items with joints tightly fitted and secured.
- E. Gas cutting of non-structural steel items may be acceptable where stress is not transmitted through flame-cut surfaces.
 1. Make cuts clean and to contour.
 2. Deduct 1/8 inch from effective width of members cut by torch.
- F. Continuously seal joined members by intermittent welds and plastic filler.
- G. Joints Exposed to Weather or Water: Fabricate to keep water out, or provide adequate drainage of water that penetrates.
- H. Steel Tubing and Piping Fabrication: Unless otherwise indicated, close ends with plate stock so no exposed ends of tubing and piping. Grind all edges.
- I. Connections, General:
 1. Component parts of built-up members shall be well-pinned with closely-fitted contact.
 2. Conceal connections where possible.
 3. Otherwise, make countersinks for concealment after fabrication, except where noted.
- J. Welding: Conform to AWS D1.1/D1.1M recommendations.
 1. Do not field weld galvanized components to remain unfinished.
 2. Provide continuous welds at welded corners and seams.
 3. Grind exposed welds smooth and flush with base material.
 4. Re-weld to fill holes. Putties and fillers are not acceptable.
- K. Grind exposed joints flush and smooth with adjacent finish surface. Make exposed joints butt tight, flush, and hairline. Ease exposed edges to small uniform radius.
- L. Exposed Mechanical Fastenings: Flush countersunk screws or bolts; unobtrusively located; consistent with design of component, except where specifically noted otherwise.
 1. Bolted and Screwed Connections:
 - a. Provide holes and connections for work specified in other Sections.
 - b. Use bolts for field connections only.
 - c. Provide washers under heads and nuts bearing on wood.
 - d. Draw all nuts tight and nick threads of permanent connections.
 - e. Use beveled washers where bearing is on sloped surfaces.

- f. Where screws must be used for permanent connections in ferrous metal, use flat head type, countersunk, with screw slots filled and finished smooth and flush.
- M. Furnish components required for anchorage of fabrications. Fabricate anchors and related components of same material and finish as fabrication, except where specifically noted otherwise.

2.04 FABRICATED ITEMS

- A. Rough Hardware
 - 1. Provide bent or otherwise custom fabricated bolts, plates, anchors, hangers, dowels, and other miscellaneous steel and iron shapes as indicated on Drawings.
- B. Other Products and Fabrications
 - 1. Other Products and Fabrications: Provide all materials not specifically described but required for a complete and proper installation, as selected by the Contractor, subject to review and acceptance by Construction Manager and Architect.
- C. Lintels: As detailed; prime paint finish.
- D. Slotted Channel Framing: Fabricate channels and fittings from structural steel complying with the referenced standards; electro-galvanized per ASTM B633 Type III, SC 1 finish.

2.05 POST INSTALLED CONCRETE ANCHORS

- A. Manufacturers:
 - 1. Manufacturers: Provide products as indicated on the approved Structural Drawings.
 - 2. Substitutions: Substitutions of products from manufacturer's not listed are not permitted.
 - a. Substitution of structural anchors requires structural calculations and DSA approval.
- B. Materials:
 - 1. Conform to ACI 355.4 and ICC ER Report.
 - 2. Interior Use: For use in conditioned environments free from potential moisture, provide zinc plated carbon steel anchors.
 - 3. Exterior Use:
 - a. In exposed or potentially wet environments, and for attachment of exterior cladding materials, provide stainless steel anchors.
 - b. Stainless steel nuts and washers shall be of matching alloy group of equal or greater strength than the rod.
 - c. Avoid installing stainless steel anchors in contact with galvanically dissimilar metals.
 - 4. Deformed Reinforcing Bars: Deformed steel rebar conforming to ASTM A615/A615M Grade 60. Permissible sizes as described in each adhesive products ICC report.
- C. Mechanical Anchors:
 - 1. Expansion, screw or undercut anchors having current ICC approval for use in cracked and uncracked concrete, with a published ICC Evaluation Service report.
 - a. Type and size as indicated on drawings.

2. Basis of Design Approved Products conforming to this specification are acceptable for anchoring to concrete are as indicated on Drawings:
 - a. Hilti, Inc. Tulsa, OK; Hilti Kwik Bolt TZ2 Carbon and Stainless Steel Anchors in Cracked and Uncracked Concrete (ICC Report ESR-4266); www.us.hilti.com.
- D. Adhesive Anchors:
 1. Cartridge Injection Adhesive Anchors: Threaded carbon steel rod, inserts, or reinforcing dowels complete with required nuts, washers, adhesive system and manufacturer's installation instructions.
 - a. Type and size as indicated on drawings.
 - b. Current ICC approval for use in cracked and uncracked concrete with a published ICC Evaluation Service report required.
 2. Interior Use: Unless otherwise indicated on the Drawings, provide:
 - a. Carbon steel threaded rods conforming to specification as indicated on structural drawings. Where no specification and grade are indicated, provide: ASTM A193/A193M Type B7 with zinc plating in accordance with ASTM B633, Type III Fe/Zn 5 (SC1).
 3. Exterior Use: As indicated on the Drawings, provide stainless steel anchors.
 - a. Stainless steel anchors shall be AISI Type 304 and Type 316 stainless steel provided with stainless steel nuts and washers of matching alloy group and minimum proof stress equal to or greater than the specified minimum full-size tensile strength of the externally threaded fastener.
 - b. All nuts shall conform to ASTM F594, unless otherwise specified.
 4. Basis of Design Approved Products conforming to this specification are acceptable for anchoring to concrete are as indicated on Drawings:

2.06 FINISHES - STEEL

- A. Mechanical Finishes: Complete finishing prior to fabrication wherever possible.
 1. After fabrication, finish all joints, bends, abrasions, and other surface blemishes to match finish.
 2. Protect finish on exposed surfaces by using temporary protective covering.
- B. Prime paint steel items.
 1. Exceptions: Galvanize items to be embedded in concrete.
 2. Exceptions: Do not prime surfaces in direct contact with concrete, where field welding is required, and items to be covered with sprayed fireproofing.
- C. Prepare surfaces to be primed in accordance with SSPC-SP2.
 1. Exterior fabrications: Clean in accordance with SSPC-SP 5, SSPC-SP 6, 8, or SSPC-SP 10.
 2. Interior fabrications: Clean in accordance with SSPC-SP 2, SSPC-SP 3, SSPC-SP 5, SSPC-SP 6, 8, or SSPC-SP 10.
- D. Clean surfaces of rust, scale, grease, and foreign matter prior to finishing.
- E. Prime Painting: One coat.

FOR REFERENCE ONLY

- F. Galvanizing of Structural Steel Members: Galvanize all exterior steel members after fabrication to ASTM A123/A123M requirements. Provide minimum 1.7 oz/sq ft galvanized coating.
- G. Galvanizing of Non-structural Items: Galvanize all exterior steel members after fabrication to ASTM A123/A123M requirements.

2.07 FABRICATION TOLERANCES

- A. Squareness: 1/8 inch maximum difference in diagonal measurements.
- B. Maximum Offset Between Faces: 1/16 inch.
- C. Maximum Misalignment of Adjacent Members: 1/16 inch.
- D. Maximum Bow: 1/8 inch in 48 inches.
- E. Maximum Deviation From Plane: 1/16 inch in 48 inches.
- F. Punch, drill and reaming in manner to leave clean, true lines and surfaces.
 - 1. Oversize hole 1/16 inch by punching, when material thickness is equal to or less than bolt diameter plus 1/8 inch.
 - 2. Sub-punch 1/16 inch smaller than bolt and drill or ream to oversize by 1/16 inch, when material thickness is thicker than bolt diameter plus 1/8 inch.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that field conditions are acceptable and are ready to receive work.
- B. Field Inspection of Fabricated Products: Prior to installation, inspect products for damage and verify markings and dimensions against reviewed submittals.
- C. Environmental Conditions: Do not install products intended for interior locations when spaces are uncovered and unprotected from inclement weather.
- D. Coordination: Coordinate metal fabrications Work with Work specified in other Sections so that related Work shall be accurately and properly joined.
- E. Post Installed Anchors
 - 1. Verification of Conditions
 - a. Base Material Strength: Unless otherwise specified, do not drill holes in concrete until concrete has achieved full design strength.
 - b. Temperature of concrete surface and ambient air temperature must meet manufacturer's requirements prior to use of adhesive anchor products.
 - c. Embedded Items:
 - 1) Identify position of reinforcing steel and other embedded items prior to drilling holes for anchors.
 - 2) Exercise care in coring or drilling to avoid damaging existing reinforcing or embedded items.

- 3) Take precautions as necessary to avoid damaging anything embedded in the concrete including electrical/telecommunications conduit, gas pipes, and plumbing pipes.
 - 4) Notify the Architect if reinforcing steel or other embedded items are encountered during drilling.
- d. Beginning of installation indicates acceptance of existing conditions.

3.02 PREPARATION

- A. Clean and strip primed steel items to bare metal where site welding is required.
- B. Supply setting templates to the appropriate entities for steel items required to be cast into concrete.
- C. Make provision for erection loads with temporary bracing. Keep work in alignment.
- D. Obtain Architect's review prior to site cutting or making adjustments not indicated on Drawings and reviewed shop drawings.

3.03 INSTALLATION

- A. Install items plumb and level, accurately fitted, free from distortion or defects.
- B. Provide for erection loads, and for sufficient temporary bracing to maintain true alignment until completion of erection and installation of permanent attachments.
- C. Field weld components as indicated on drawings.
- D. Perform field welding in accordance with AWS D1.1/D1.1M.
- E. Obtain approval prior to site cutting or making adjustments not scheduled.
- F. After erection, prime welds, abrasions, and surfaces not shop primed, except surfaces to be in contact with concrete.
 1. Touch up galvanized steel with cold galvanizing compound.

3.04 INSTALLATION OF POST-INSTALLED ANCHORS

- A. Installation shall comply with all manufacturer's instructions and current ICC ESR report.
- B. Post-Installed Anchors in Hardened Concrete.
 1. Drilled-in anchors and/or powder driven pins in existing non-prestressed reinforced concrete: use care and caution to avoid cutting or damaging the existing reinforcing bars.
 2. Maintain a minimum clearance of one inch between the reinforcement and the drilled-in anchor and/or pin.
- C. Manufacturer shall provide on-site training for all personnel who will be installing post-installed adhesive anchors at the beginning of the work. Installation of anchors must be performed by a certified installer.
- D. Where manufacturer recommends use of special tools for installation of anchors, such tools shall be used, unless otherwise permitted specifically by the Engineer.
- E. Drill holes with rotary impact hammer drills using carbide-tipped bits. Bits must be of type required and permitted by ICC ESR report.

FOR REFERENCE ONLY

1. Drill holes with rotary impact hammer drills using carbide-tipped bits or core drills using diamond core bits.
 2. Drill bits shall be of diameters as specified by the anchor manufacturer.
 3. Unless otherwise shown on the Drawings, all holes shall be drilled perpendicular to the concrete surface.
 4. Where anchors are to be installed in cored holes, use core bits with matched tolerances as specified by the manufacturer.
 5. Cored holes may only be used if acceptable to the Engineer and in compliance with ICC ESR report.
- F. Holes shall be cleared of debris after holes are drilled per manufacturer's instructions.
1. For adhesive installations, at a minimum, holes shall be blown out with oil-free compressed air and shall be brushed with a wire or nylon brush.
 2. Holes shall than be blown out one additional time with oil-free compressed air.
 3. Additional hole cleaning requirements may be required by manufacturer and ICC ESR Report.
- G. During adhesive curing time period, the temperature of the substrate shall be kept above the minimum substrate temperature as defined by the manufacturer. Contractor shall determine the appropriate means and methods to ensure that the temperature is kept above the required minimum temperature required before adhesive installation is begun.

3.05 TOLERANCES

- A. Maximum Variation From Plumb: 1/4 inch per story, non-cumulative.
- B. Maximum Offset From True Alignment: 1/4 inch.
- C. Maximum Out-of-Position: 1/4 inch.

3.06 FIELD QUALITY CONTROL

- A. An independent testing agency will perform field quality control tests, as specified in Section 01 45 33 - Code-Required Special Inspections.
- B. Inspection: Special inspection of post-installed anchors shall be provided as required by the ICC-ES report for that anchor and not less than the requirements of the Structural Drawings and the following (whichever is the most restrictive):
 1. Continuously observe the installation of all anchors, or as specified in the ICC report.
 - a. Minimum anchor embedments, proof loads and torques shall be as shown on the Drawings.
 - b. Load Testing: Per Structural General Notes on Drawings.
 - c. Verify anchor type, anchor dimensions, hole dimensions, anchor spacing, edge distances, anchor embedment and adherence to the manufacturer's published installation instructions.
 - d. For adhesive anchors also verify hole cleaning technique, adhesive expiration date and proper mixing and dispensing.

FOR REFERENCE ONLY

2. Subsequent inspection of installation will be required when there is a change of personnel doing the installation. Change is defined as any one or more persons drilling or preparing holes, or installing anchors.
 3. Visually inspect 100% of all installed anchors.
- C. Reporting:
1. Daily reports shall reference the applicable ICC-ES report number, indicate that all specified criteria were complied with and provide itemized verification of all inspected items.
 2. Special Inspector shall immediately report any deviations from the requirements to the Architect.
- D. Defective Work:
1. Installations that are not accepted by the Special Inspector shall be considered defective.
 2. Provide additional testing and inspection to determine acceptability of defective work, as directed by the Architect at Contractor's expense.

3.07 REPAIR OF DEFECTIVE WORK

- A. Remove and replace misplaced, defective or malfunctioning anchors at Contractor's expense. Replacement of anchors requires signed structural detail, unless otherwise noted.
- B. Fill empty anchor holes and patch failed anchor locations with high-strength, non-shrink non-metallic grout.

END OF SECTION

SECTION 05 52 13 PIPE AND TUBE RAILINGS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Free-standing railings at steps or ramps.

1.02 RELATED REQUIREMENTS

- A. Section 03 30 00 - Cast-in-Place Concrete: Placement of anchors in concrete.
- B. Section 05 50 00 - Metal Fabrications: Embedded items, welding and shop painting. Placement of anchors in concrete.
- C. Section 09 21 16 - Gypsum Board Assemblies: Placement of backing plates in stud wall construction.

1.03 REFERENCE STANDARDS

- A. ADA Standards - 2010 ADA Standards for Accessible Design.
- B. AISC 201 - AISC Certification Program for Structural Steel Fabricators, Standard for Steel Building Structures.
- C. ASTM A53/A53M - Standard Specification for Pipe, Steel, Black and Hot-Dipped, Zinc-Coated, Welded and Seamless.
- D. ASTM A123/A123M - Standard Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products.
- E. ASTM A500/A500M - Standard Specification for Cold-Formed Welded and Seamless Carbon Steel Structural Tubing in Rounds and Shapes.
- F. AWS A2.4 - Standard Symbols for Welding, Brazing, and Nondestructive Examination.
- G. AWS B2.1/B2.1M - Specification for Welding Procedure and Performance Qualification.
- H. AWS D1.1/D1.1M - Structural Welding Code - Steel.
- I. NAAMM AMP 521 - Pipe Railing Systems Manual.
- J. SSPC-PA 1 - Shop, Field, and Maintenance Coating of Metals.
- K. SSPC-Paint 20 - Zinc-Rich Coating (Type I - Inorganic, and Type II - Organic).

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Shop Drawings: Indicate profiles, sizes, connection attachments, anchorage, size and type of fasteners, and accessories.
 - 1. Indicate welded connections using standard AWS A2.4 welding symbols. Indicate net weld lengths.
 - 2. Prepare shop drawings for all railing systems, including attachment.

3. Conform to AISC Standards, except provisions for approval/responsibility for dimensions by Architect and structural engineer shall not apply.
 4. Include erection drawings, elevations, and details where applicable.
 5. Indicate welded connections using standard AWS welding symbols. Indicate net weld lengths.
- C. Welders' Qualification Statement: Welders' certificates in accordance with AWS B2.1/B2.1M and dated within the previous 12 months.
- D. Fabricator's Qualification Statement.

1.05 QUALITY ASSURANCE

- A. Welder Qualifications: Welding processes and welding operators qualified within previous 12 months.
- B. Fabricator Qualifications:
1. A qualified steel fabricator that is certified by the City of Los Angeles.
 2. A company specializing in manufacturing products specified in this section, with not less than ten years of documented experience.
- C. Coordination: Provide templates and sleeves for incorporation of embedded items into the work specified elsewhere herein.

1.06 DELIVERY, STORAGE AND HANDLING

- A. Delivery, Storage and Handling, General: Protect products from deformation, marring, discoloration, soiling and corrosion.
- B. Storage: Store products in enclosed, well-ventilated spaces, not in contact with soil or vegetation and not subject to inclement weather.

PART 2 PRODUCTS

2.01 RAILINGS - GENERAL REQUIREMENTS

- A. Regulatory Requirements: Conform to California Building Code (CBC), Title 24, Part 2, Section 11B-505 and 11B-405.8 as amended and adopted by authorities having jurisdiction.
1. Top of gripping surfaces of handrails shall be 34 inches minimum and 38 inches maximum vertically above walking surfaces, stair nosings, and ramp surfaces. Handrails shall be at a consistent height above such surfaces.
 2. Clearance between handrail gripping surfaces and adjacent surfaces shall be 1-1/2 inches minimum.
 - a. Handrail may be located in a recess if the recess is 3 inches maximum deep and 18 inches minimum clear above the top of the handrail.
 3. Handrail gripping surfaces shall be continuous along their length and shall not be obstructed along their tops or sides. The bottoms of handrail gripping surfaces shall not be obstructed for more than 20% of their length.
 - a. Where provided, horizontal projections shall occur 1-1/2 inches minimum below the bottom of the handrail gripping surfaces.

FOR REFERENCE ONLY

4. Handrail gripping surfaces with a circular cross section shall have an outside diameter of 1-1/4 inch minimum and 2 inches maximum.
 5. Handrail gripping surfaces with a non-circular cross section shall have an outside dimension of 4 inches minimum and 6-1/4 inches maximum, and a cross-sectional dimension of 2-1/4 inches maximum.
 6. Handrail gripping surfaces and any surfaces adjacent to them shall be free of sharp or abrasive elements and shall have rounded edges.
 7. Handrails shall not rotate within their fittings.
 8. Handrail gripping surfaces shall extend beyond and in the same direction of stair flights and ramp runs in accordance with CBC Section 11B-505.10.
 - a. Such extensions are not required for continuous handrails at the inside turn of switchback or dogleg stairs and ramps.
 9. A 2 inch minimum high curb or a barrier shall be provided to prevent the passage of a 4 inch diameter sphere rolling off the sides of a ramp surface.
 - a. Such a curb or barrier shall be continuous and uninterrupted along the length of a ramp. CBC Section 11B-405.9.2
- B. Design, fabricate, and test railing assemblies in accordance with the most stringent requirements of applicable local code.
- C. Allow for expansion and contraction of members and building movement without damage to connections or members.
- D. Dimensions: See drawings for configurations and heights.
 1. Top Rails and Wall Rails: 1-1/2 inches outside diameter, round.
 2. Intermediate Rails: 1-1/2 inches diameter, round.
- E. Provide anchors and other components as required to attach to structure, made of same materials as railing components unless otherwise indicated; where exposed fasteners are unavoidable provide flush countersunk fasteners.
 1. For anchorage to concrete, provide inserts to be cast into concrete, for welding anchors.
 2. For anchorage to stud walls, provide backing plates, for bolting anchors.
- F. Provide welding fittings to join lengths, seal open ends, and conceal exposed mounting bolts and nuts, including but not limited to elbows, T-shapes, splice connectors, flanges, escutcheons, and wall brackets.

2.02 STEEL RAILING SYSTEM

- A. Steel Tube: ASTM A500/A500M, Grade B cold-formed welded or seamless structural tubing.
- B. Steel Pipe: ASTM A 53/A 53M, Grade B Schedule 40, black and galvanized finish, as indicated, seamless or welded.
- C. Welding Fittings: Factory- or shop-welded from matching pipe or tube; seams continuously welded; joints and seams ground smooth.
- D. Exposed Fasteners: No exposed bolts or screws.
- E. Straight Splice Connectors: Steel concealed spigots.
- F. Galvanizing: In accordance with requirements of ASTM A123/A123M.

1. Touch-Up Primer for Galvanized Surfaces: SSPC-Paint 20 Type I - Inorganic.

2.03 FABRICATION

- A. Fabricate railings in accordance with NAAMM AMP 521 and as required for specified design requirements. Provide stock and tubing and manufactured components sized and arranged as indicated on Drawings and specified herein.
- B. Accurately form components to suit specific project conditions and for proper connection to building structure.
 1. Prior to fabrication, field verify dimensions and details of construction. Immediately report variances in writing to Architect.
- C. Fit and shop assemble components in largest practical sizes for delivery to site.
- D. Fabricate components with joints tightly fitted and secured. Provide spigots and sleeves to accommodate site assembly and installation.
- E. Welded Joints:
 1. Exterior Components (Type 2): Continuously seal joined pieces by continuous welds. Drill condensate drainage holes at bottom of members at locations that will not encourage water intrusion.
 2. Interior Components (Type 1): Continuously seal joined pieces by continuous welds.
 3. Grind exposed joints flush and smooth with adjacent finish surface. Make exposed joints butt tight, flush, and hairline. Ease exposed edges to small uniform radius (1/8 inch).

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that field conditions are acceptable and are ready to receive work.
- B. Coordination: Coordinate fabrication and installation of steel pipe and tube railings so that related Work accurately and properly join.

3.02 PREPARATION

- A. Obtain Architect's review prior to site cutting or making adjustments not indicated on shop drawings.
- B. Supply items required to be cast into concrete with setting templates, for installation as work of other sections.

3.03 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Install components plumb and level, accurately fitted, free from distortion or defects, with tight joints.
- C. Install railings in compliance with CBC 11B and ADA Standards for accessible design at applicable locations.
- D. Anchor railings securely to structure.

FOR REFERENCE ONLY

- E. Field weld anchors as indicated on drawings. Touch-up welds with primer. Grind welds smooth.
- F. Conceal anchor bolts and screws whenever possible. Where not concealed, use flush countersunk fastenings.
- G. Guardrails Installation: Install railings plumb and level, accurately fitted, free from distortion or defects.
 - 1. Plumb posts in each direction.
 - 2. Temporarily install sections and align before securing sections together.
 - 3. Fully weld all joints and grind smooth as for shop welding.
 - 4. Perform field welding in accordance with AWS D1.1/D1.1M.
- H. Wall Railings Installation, General: Secure handrails to wall with wall brackets and end return fittings.
 - 1. Provide brackets with 1-1/2 inch clearance from inside face of handrail and finished wall surface.
 - 2. Locate brackets as indicated, or if not indicated, at spacing required to support structural loads.
 - 3. Secure wall brackets to building construction as specified below.
 - a. Secure railing to bracket with pre-drilled hole for exposed bolt anchorage.
 - b. Railing ends: None. Return railings to within 1/4 inch of wall face and provide handrail bracket within 12 inches of end of railing.
 - c. Securing Railings to Metal Stud Framed Walls: Anchor brackets and fittings directly to steel framing or to concealed sheet steel backing or to concealed anchors, using self-tapping screws of size and type necessary to support structural loads.

3.04 TOLERANCES

- A. Code required dimensions indicated on Drawings as minimum or maximum are absolute. No tolerances are allowed less or more than this dimension.
- B. Maximum Variation From Plumb: 1/4 inch per floor level, non-cumulative.
- C. Maximum Offset From True Alignment: 1/4 inch.
- D. Maximum Out-of-Position: 1/4 inch.

3.05 CLEANING AND PROTECTION

- A. Galvanizing Repair Compound:
 - 1. If finish is to be painted or is otherwise not visible, field repair with premixed cold galvanizing compound for field touch-up of galvanized coatings.
 - 2. Where the finish is galvanized, resend to galvanizing for reapplication, if practical (e.g.; bolted components) and accepted by Architect.
- B. Finish Touch-Up:
 - 1. Immediately after installation, clean field welds, bolted connections, and abraded areas of shop paint, and paint exposed areas with same material as used for shop painting to comply with SSPC-PA 1 requirements for touch-up of field painted surfaces.

FOR REFERENCE ONLY

2. Apply paint by brush or spray to provide a minimum dry film thickness of 2.0 mils.
- C. Cleaning:
1. Clean and dress all field welds, bolted connections, and abraded areas of galvanizing or shop paint on miscellaneous metal.

END OF SECTION

SECTION 05 59 20 TUBE STEEL ENCLOSURE AND GATES

PART1 GENERAL

1.01 SECTION INCLUDES

- A. Tube steel enclosure. MWP-1
- B. Pedestrian gates.
- C. Vehicle and equipment access gates.
- D. Excavation for post bases; concrete foundation for posts.

1.02 RELATED REQUIREMENTS

- A. Section 03 30 00 - Cast-in-Place Concrete: Concrete footings
- B. Section 08 11 13 - Hollow Metal Doors and Frames: Non-insulated exterior doors.
- C. Section 09 96 00 - High-Performance Coatings: Field applied exterior metal coatings
- D. Section 31 23 16 - Excavation: Excavation for footings.

1.03 REFERENCE STANDARDS

- A. AAMA 2605 - Voluntary Specification, Performance Requirements and Test Procedures for Superior Performing Organic Coatings on Aluminum Extrusions and Panels (with Coil Coating Appendix).
- B. ADA Standards - 2010 ADA Standards for Accessible Design.
- C. ASCE 7 - Minimum Design Loads and Associated Criteria for Buildings and Other Structures.
- D. ASTM B209M - Standard Specification for Aluminum and Aluminum-Alloy Sheet and Plate (Metric).
- E. ASTM B209 - Standard Specification for Aluminum and Aluminum-Alloy Sheet and Plate.
- F. ASTM B221 - Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes.
- G. ASTM B221M - Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes (Metric).
- H. AWS D1.2/D1.2M - Structural Welding Code - Aluminum.
- I. SSPC-Paint 15 - Steel Joist Shop Primer/Metal Building Primer.

1.04 SUBMITTALS

- A. Product data in the form of manufacturer's technical data, specifications, and installation instructions for fence and gate posts, fabric, gates, hardware and accessories specified in the section.
 - 1. Fence and gate posts, rails, and fittings.
 - 2. Gates and hardware, including accessible gate lever lockset.

3. Welder certificates signed by Contractor certifying that welders comply with requirements specified under the "Quality Assurance" Article.
- B. Shop Drawings:
 1. Indicate plan layout, spacing of components, post foundation dimensions, hardware anchorage, gates, and schedule of components.
 2. Provide templates for anchors and bolts specified for installation under other Sections.
- C. Welders' Certificates: Submit certification for welders employed on the project, verifying AWS qualification within the previous 12 months.

1.05 QUALITY ASSURANCE

- A. Regulatory Requirements: Conform to applicable requirements of California Building Code (CBC), Title 24, Part 2, as amended and adopted by authorities having jurisdiction.
 1. Comply with Title 24, Part 9, California Fire Code Chapter 35 "Welding and Other Hot Work."
- B. Coordination: Provide templates and sleeves for incorporation of embedded items into the Work specified in other Sections.
- C. Field-Verified Dimensions: Prior to fabrication, field verify dimensions and details of construction. Immediately report variances in writing to Construction Manager and Architect.
- D. Fabricator Qualifications: A qualified steel fabricator that is accredited by the International Accreditation Service (IAS) Fabricator Inspection Program for Structural Steel or equal.
- E. Welder's Qualifications:
 1. Welding shall be performed by certified welders qualified in accordance with procedures specified in applicable referenced AWS standard, using materials, procedures and equipment of the type required for the Work.
 2. Certify that each welder has satisfactorily passed AWS qualification tests for welding processes involved and, if pertinent, has undergone re-certification.

1.06 PROJECT CONDITIONS

- A. Field Measurements: Verify layout information for fences and gates shown on the Drawings in relation to the property survey and existing structures. Verify dimensions by field measurements.

PART 2 PRODUCTS

2.01 REGULATORY REQUIREMENTS

- A. Provide fences and gates meeting life safety and accessibility requirements of California Building Code (CBC) Title 24, Part 2, Chapters 10 and 11B; and ADA Standards, per latest amendments.
 1. Gates that are part of the accessible route shall meet all the requirements of an accessible door in compliance with CBC Section 11B-404 and 11B-206.5.
 2. Gate Hardware: Meet the requirements of CBC 11B-206.5 and 11B-404.2.9.

FOR REFERENCE ONLY

- a. Latch: Latch, including padlock eye as integral part of latch, mounted 40 inches above finish grade. Comply with California Fire Code.
 - b. Hardware shall comply with local Fire Authority, California Building Code (CBC) Title 24, Section 1008.2, and California Fire Code (CFC) Section 503.5.2.
 - c. The lever of lever actuated latches or locks for an accessible gate shall be curved with a return to within 1/2 inch of the (face of) gate to prevent catching on the clothing or persons. California Referenced Standards Code T-24 Part 12, Section 12-10-202, Item (F).
 - d. Hand activated opening hardware, handles, pulls, latches, locks, and other operating devices for and accessible gate shall have a shape that is easy to grasp with one hand and does not require tight grasping, tight pinching, or twisting of the wrist to operate. CBC Section 11B-404.2.7 and 11B-309.4.
3. Swing doors and gate surfaces within 10 inches of the finish floor or ground shall have a smooth surface on the push side extending the full width of the door or gate. Parts creating horizontal or vertical joints in these surfaces within 1/16 inch of the same plane as the other and be free of sharp or abrasive edges. Cavities created by added kick plates shall be capped. CBC Section 11B-404.2.10
 4. The bottom of the gate shall be within 3 inches of the finish surface of the path of travel. The maximum effort to operate a gate shall not exceed 5 lbf. CBC Section 11B-404.2.9.

2.02 DESIGN CRITERIA

- A. Metal Plate Wall Panels System: Factory fabricated prefinished metal panel system, site assembled.
 1. Provide exterior wall panels and subgirt framing assembly.
 2. Design and size components to support assembly dead loads, and to withstand live loads caused by positive and negative wind pressure acting normal to plane of wall.
 3. Design Pressure: In accordance with ASCE 7.
 4. Intermediate Panel Stiffeners: Provide as required by design loads applied to panels, and secured to rear face of panel by welding per AWS D1.2/D1.2M; of size and strength to maintain panel flatness.
 5. Movement: Accommodate movement within system without damage to components or deterioration of seals, movement between system and perimeter components when subject to 100 degrees F seasonal temperature cycling; dynamic loading and release of loads; and deflection of structural support framing.
 6. Fabrication: Formed true to shape, accurate in size, square, and free from distortion or defects; pieces of longest practical lengths.

2.03 MANUFACTURED METAL PANELS

- A. Basis of Design Product: Profile #MFP120 as manufactured by Hendrick Architectural, or approved equal.
- B. Metal Plate Wall Panels:
 1. Orientation: Vertical and horizontal; style as indicated.
 2. Joint Layout: As indicated on Drawings.

3. Material: Aluminum, 0.125 inch minimum thickness.
4. Perforation Pattern:
 - a. Hole Size: 0.188 inch diameter.
 - b. Hole Spacing: 3/4 inch. staggered centers.
 - c. Open Area: 40 percent.
5. Panel Width: As indicated on drawings.
- C. Fasteners: Provide of aluminum, galvanized steel, or stainless steel material.

2.04 MATERIALS

- A. Aluminum Plate: ASTM B209 (ASTM B209M), 3003 alloy, H14 temper.
 1. Surface Texture: Smooth.
- B. Shop and Touch-Up Primer: SSPC-Paint 15, complying with VOC limitations of authorities having jurisdiction.

2.05 ENCLOSURE GATES

- A. Gates: Located as shown on the Drawings.
- B. Gate Posts: As indicated on Drawings.
- C. Gate Frame and Brace: As indicated on Drawings.

2.06 HARDWARE

- A. All gate drop rod assemblies are to use a 5/8 inch diameter solid steel center stop.
 1. Provide a 4 inch deep steel sleeve/receiver.
 2. In asphalt areas secure sleeve in a 12 inch diameter by 18 inch deep concrete footing.
- B. Gate Hinges: Size as required for weight of gate, plus 20 percent. Each hinge to be capable of the entire weight of the gate panel.
 1. Basis of Design Product: Series 1200 Sealed Bearing Hinge as manufactured by DoorKing, www.doorking.com; or approved equal.

2.07 FINISHES

- A. Tubular Steel Framework: Paint per Section 09 96 00 - High-Performance Coatings.
- B. Aluminum Panels:
 1. Superior Performing Organic Coatings: AAMA 2605 multiple coat, thermally cured polyvinylidene fluoride (PVDF) system.
 - a. Polyvinylidene fluoride (PVDF) multi-coat thermoplastic fluoropolymer coating system, including minimum 70 percent PVDF color topcoat and minimum total dry film thickness of 0.9 mil; color and gloss as indicated on drawings.
 - 1) Manufacturers:
 - (a) PPG Metal Coatings; Duranar: www.ppgmetalcoatings.com/#sle.
 - (b) Sherwin-Williams Company; SHER-NAR 5000: oem.sherwin-williams.com/#sle.
 - (c) Valspar; Fluropon: www.valsparcoilextrusion.com/#sle.

(d) Substitutions: See Section 01 60 00 - Product Requirements.

2. Back Side Coating: Same as front face.
- C. Touch-Up Materials: As recommended by coating manufacturer for field application.

2.08 ACCESSORIES

- A. Gaskets: Manufacturer's standard type suitable for use with system, permanently resilient; ultraviolet and ozone resistant.
- B. Extruded Aluminum: Comply with ASTM B221 (ASTM B221M).
- C. Fasteners: Manufacturer's standard type to suit application; galvanized metal with soft neoprene washers.
 1. Metal-to-Metal Fasteners: Self-drilling, self-tapping screws.
- D. Field Touch-up Paint: As recommended by panel manufacturer.
- E. Bituminous Paint: Asphalt based.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Examine areas and conditions, with Installer present, for compliance with requirements for site clearing, earthwork, pavement work, and other conditions affecting performance.
 1. Do not begin installation before final grading is completed, unless otherwise permitted by Architect.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

3.02 PREPARATION

- A. Stake locations of gates and ensure footings will not conflict with any utilities, easements, or footings.
- B. If conflict occurs immediately alert General Contractor.

3.03 ON THE JOB SITE

- A. After the gate has been erected and is mechanically complete, wire brush field welds, dry wipe off all loose residue, spot prime with the Zinc Chromate all bare metal, bare spots and chips, and unpainted surfaces.

3.04 FABRICATION AND INSTALLATION

- A. Gates shall be welded and have smoothed, clean, slag free welds. Dimensions and installation shall be in accordance with the drawings.
- B. Gates shall be set square and plumb.

3.05 POST SETTING

- A. General: Comply with ACI 301 for cast-in-place concrete.
- B. Materials: Portland cement complying with ASTM C 150, aggregates complying with ASTM C 33, and potable water for ready-mixed concrete complying with ASTM C 94.

1. Concrete Mixes: Normal-weight concrete with not less than 3000-psi (20.7- MPa) compressive strength (28 days), 3-inch (75-mm) slump, and 1-inch (25-mm) maximum size aggregate.
- C. All posts to be set in concrete as detailed on the drawings.

3.06 GROUT AND ANCHORING CEMENT

- A. Nonshrink, Nonmetallic Grout: Premixed, factory-packaged, nonstaining, noncorrosive, nongaseous grout complying with ASTM C 1107. Provide grout, recommended in writing by manufacturer, for exterior applications.
- B. Erosion-Resistant Anchoring Cement: Factory-packaged, nonshrink, nonstaining, hydraulic-controlled expansion cement formulation for mixing with potable water at Project site to create pourable anchoring, patching, and grouting compound. Provide formulation that is resistant to erosion from water exposure without needing protection by a sealer or waterproof coating and that is recommended by the manufacturer in writing for exterior applications.

3.07 SITE CLEAN UP

- A. The construction site shall be cleaned up and all accumulated debris removed by the Contractor.

END OF SECTION

SECTION 06 05 73 WOOD TREATMENT

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Site applied termiticide for wood materials.
- B. Site applied termiticide for other building materials.
- C. Site applied mildewcide for wood materials.
- D. Site applied fire-retardant treatment for wood materials.
- E. Site applied fire retardant for wood materials.

1.02 RELATED REQUIREMENTS

- A. Section 01 61 16 - Volatile Organic Compound (VOC) Content Restrictions .
- B. Section 03 30 00 - Cast-in-Place Concrete.
- C. Section 06 17 33 - Wood I-Joists: Factory treatment for wood products.
- D. Section 06 18 00 - Glued-Laminated Construction: Factory treatment for wood products.

1.03 REFERENCE STANDARDS

- A. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials.
- B. AWWA U1 - Use Category System: User Specification for Treated Wood.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide technical data on insulated sheathing, wood preservative materials, and application instructions.
- C. Warranty: Submit manufacturer warranty and ensure that forms have been completed in District's name and registered with manufacturer.

1.05 DELIVERY, STORAGE, AND HANDLING

- A. General: Cover wood products to protect against moisture. Support stacked products to prevent deformation and to allow air circulation.
- B. Fire Retardant Treated Wood: Prevent exposure to precipitation during shipping, storage, or installation.

1.06 WARRANTY

- A. See Section 01 78 00 - Closeout Submittals, for additional warranty requirements.
- B. Site Applied Termiticide and Mildewcide: Correct defective Work within a twenty-five year period after Date of Final Inspection.

PART 2 PRODUCTS

2.01 SITE-APPLIED WOOD TREATMENT

- A. Manufacturers:
 - 1. Arch Wood Protection, Inc: www.wolmanizedwood.com.
 - 2. Green Products Company; Copper Green: greenproductsco.net.
 - 3. Nisus Corporation: www.nisuscorp.com/#sle.
 - 4. Osmose, Inc: www.osmose.com.
 - 5. Viance, LLC: www.treatedwood.com.
 - 6. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- B. Site Applied Termiticide for Wood: Borate mineral salt based, spray applied, penetrating termiticide.
 - 1. Products:
 - a. Nisus Corporation; Bora-Care: www.nisuscorp.com/#sle.
 - b. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- C. Site Applied Termiticide and Mildewcide: Borate mineral salt based, spray applied termiticide, mildewcide and mold growth preventative.
 - 1. Products:
 - a. Nisus Corporation; Bora-Care: www.nisuscorp.com/#sle.
 - b. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- D. Site Applied Termiticide for Wood, Steel and Concrete: Borate mineral salt based, spray applied termiticide formulated for use on wood, steel, concrete and other building materials.
 - 1. Active Ingredient: 40% minimum disodium octaborate tetrahydrate (DOT).
 - 2. Carrier and Penetrant: Proprietary glycol solution.
 - 3. Products:
 - a. Nisus Corporation; Bora-Care with Mold-Care: www.nisuscorp.com/#sle.
 - b. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- E. Site Applied Mold Cleaner: Non-bleaching, oxidizer based formula with high-pH tolerant surfactant. Contains no sodium hydroxide or sodium hypochlorite.
 - 1. Products:
 - a. Nisus Corporation; Mold Clean: www.nisuscorp.com/#sle.
 - b. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- F. Surface-Applied Wood Preservative: Pressure treatment in accordance with AWPA U1, using water borne preservative.
- G. Surface-Applied Fire-Retardant:
 - 1. Fire Retardant and Preservative Treatment: Dip- or brush-type, non-discoloring.
 - a. Number of Coats: Two.

- b. Surface Burning Characteristics: Class A; Flame spread index of 25 or less, smoke developed index of 26 or less, when tested in accordance with ASTM E84.
- c. Recommended Reapplication Period: Five years.
- 2. Basis of Design Product: Fire-Kote 100 manufactured by Universal Fire-Shield; www.firechemicals.com.
- 3. Other Acceptable Manufacturers:
 - a. Flame Stop, Inc.; Flame Stop II: www.flamestop.com.
 - b. Universal Fire-Shield; Fire-Kote 100: www.firechemicals.com.
 - c. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.

PART 3 EXECUTION

3.01 PREPARATION

- A. Remove dust, dirt and other contaminants from treatment surfaces. Remove tarpaulins, dropcloths, strippable protective films, etc., from areas to be treated. Move equipment and stored materials that block or prevent product application.

3.02 INSTALLATION - GENERAL

- A. Provide temporary ventilation during and immediately after installation sufficient to remove indoor air contaminants.

3.03 SITE APPLIED WOOD TREATMENT

- A. Comply with manufacturers written mixing and installation instructions.
- B. Termiticide: Apply to foundations, structure and other items as listed.
 - 1. All structural wood and sill plates within 24 inches, minimum, of point of contact with foundation.
 - 2. All wood, wood based and cellulosic sheathing within 24 inches, minimum, of point of contact with foundation.
 - 3. Concrete foundations 2 inches, minimum, from sill plate.
 - 4. All pipe and plumbing penetrations up to 24 inches, minimum, above slab and slab surface within 6 inches, minimum, of pipe or penetration.
 - 5. Six inches, minimum, on either side of control joints and construction joints in slabs and joints between slabs and abutting material.
- C. Mildewcide: Apply to wood and wood based building materials as listed.
 - 1. All structural wood and sill plates within 24 inches, minimum, of point of contact with foundation.
 - 2. All wood, wood based and cellulosic sheathing within 24 inches, minimum, of point of contact with foundation.
- D. Fire-Retardant:
 - 1. Apply fire-retardant and preservative treatment in accordance with manufacturer's instructions.

FOR REFERENCE ONLY

- a. Verify materials do not exceed the specified percent moisture content before applying wood treatment.
- b. Brush apply two coats of fire-retardant and preservative treatment.
2. Apply dip- or brush-type preservative to site-sawn ends of pressure preservative treated materials. Allow preservative to cure prior to erecting materials.
3. Do not install materials until site pre-finishing and back priming is complete and dry.

END OF SECTION

FOR REFERENCE ONLY

SECTION 06 10 00 ROUGH CARPENTRY

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Structural dimension lumber framing.
- B. Nonstructural dimension lumber framing.
- C. Rough opening framing for doors, windows, and roof openings.
- D. Sheathing.
- E. Roof-mounted curbs.
- F. Roofing nailers.
- G. Roofing cant strips.
- H. Preservative treated wood materials.
- I. Miscellaneous framing and sheathing.
- J. Communications and electrical room mounting boards.
- K. Concealed wood blocking, nailers, and supports.
- L. Miscellaneous wood nailers, furring, and grounds.

1.02 RELATED REQUIREMENTS

- A. Section 01 61 16 - Volatile Organic Compound (VOC) Content Restrictions.
- B. Section 03 30 00 - Cast-in-Place Concrete: Setting anchors in concrete.
- C. Section 05 12 00 - Structural Steel Framing: Prefabricated beams and columns for support of wood framing.
- D. Section 05 50 00 - Metal Fabrications: Miscellaneous steel connectors and support angles for wood framing.
- E. Section 07 25 00 - Weather Barriers: Water-resistive barrier over sheathing.
- F. Section 07 62 00 - Sheet Metal Flashing and Trim: Sill flashings.

1.03 REFERENCE STANDARDS

- A. AFPA (NDS) - National Design Specification for Wood Construction.
- B. ASTM A153/A153M - Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware.
- C. ASTM A653/A653M - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process.
- D. ASTM B695 - Standard Specification for Coatings of Zinc Mechanically Deposited on Iron and Steel.
- E. ASTM F2130 - Standard Test Method for Measuring Repellency, Retention, and Penetration of Liquid Pesticide Formulation Through Protective Clothing Materials.

FOR REFERENCE ONLY

- F. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials.
- G. ASTM E96/E96M - Standard Test Methods for Gravimetric Determination of Water Vapor Transmission Rate of Materials.
- H. AWC SDPWS - Special Design Provisions for Wind and Seismic.
- I. AWPA U1 - Use Category System: User Specification for Treated Wood.
- J. {RSTEMP#10005050}
- K. ICC-ES AC308 - Acceptance Criteria for Termite Physical Barrier Systems.
- L. PS 1 - Structural Plywood.
- M. PS 2 - Performance Standard for Wood Structural Panels.
- N. PS 20 - American Softwood Lumber Standard.
- O. WCLIB (GR) - Standard Grading Rules for West Coast Lumber No. 17.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide technical data on insulated sheathing, wood preservative materials, and application instructions.
- C. Evaluation Service Reports: Show compliance with specified requirements.
- D. Structural Composite Lumber: Submit manufacturer's published structural data including span tables, marked to indicate which sizes and grades are being used; if structural composite lumber is being substituted for dimension lumber or timbers, submit grading agency structural tables marked for comparison.
- E. Manufacturer's Certificate: Certify that wood products supplied for rough carpentry meet or exceed specified requirements.
- F. Warranty Documentation: Submit manufacturer warranty and ensure that forms have been completed in District's name and registered with manufacturer.

1.05 DELIVERY, STORAGE, AND HANDLING

- A. General: Cover wood products to protect against moisture. Support stacked products to prevent deformation and to allow air circulation.

1.06 WARRANTY

- A. See Section 01 78 00 - Closeout Submittals for additional warranty requirements.
- B. Correct defective work within a two-year period commencing on Date of Final Inspection or Final Acceptance.

PART 2 PRODUCTS

2.01 GENERAL REQUIREMENTS

- A. Dimension Lumber: Comply with PS 20 and requirements of specified grading agencies.
 - 1. Species: Douglas Fir-Larch, unless otherwise indicated.

2. If no species is specified, provide species graded by the agency specified; if no grading agency is specified, provide lumber graded by grading agency meeting the specified requirements.
3. Grading Agency: Grading agency whose rules are approved by the Board of Review, American Lumber Standard Committee at www.alsc.org, and who provides grading service for the species and grade specified; provide lumber stamped with grade mark unless otherwise indicated.
4. Lumber of other species or grades is acceptable provided structural and appearance characteristics are equivalent to or better than products specified.

2.02 DIMENSION LUMBER FOR CONCEALED APPLICATIONS

- A. Grading Agency: West Coast Lumber Inspection Bureau; WCLIB (GR).
- B. Sizes: Nominal sizes as indicated on drawings, S4S.
- C. Moisture Content: S-dry or MC19; Maximum 19%.
- D. Stud Framing (2 by 2 through 2 by 6):
 1. Species: Douglas Fir-Larch.
 2. Grade: No. 1 & Better.
- E. Joist, Rafter, and Small Beam Framing (2 by 6 through 4 by 16):
 1. Species: Douglas Fir-Larch.
 2. Grade: No. 1 and Better.
 - a. No. 1 & Better for joists and rafters;
 - b. No. 1 for beams and stringers.
- F. Miscellaneous Framing, Blocking, Nailers, Grounds, and Furring:
 1. Lumber: S4S, No. 1 or Construction Grade.
 2. Boards: No. 2 or Standard Grade.

2.03 STRUCTURAL COMPOSITE LUMBER

- A. Structural Composite Lumber: Factory fabricated beams, headers, and columns, of sizes and types indicated on drawings; structural capacity as published by manufacturer.
 1. Columns: Use laminated veneer lumber, laminated strand lumber, or parallel strand lumber with manufacturer's published modulus of elasticity, E: 1,800,000 psi, minimum.
 2. Beams: Use laminated veneer lumber, laminated strand lumber, or parallel strand lumber with manufacturer's published modulus of elasticity, E: 1,800,000 psi, minimum.
 3. Headers Not Longer Than 48 inches: Use laminated veneer lumber, laminated strand lumber, or parallel strand lumber.
 4. Basis of Design Product: RedLam LVL as manufactured by RedBuilt, LLC, or approved equal.
 5. Products:
 - a. Boise Cascade Company: www.bc.com/#sle.
 - 1) ICC ESR-1040, VAR-1017.

FOR REFERENCE ONLY

- b. RedBuilt LLC; Redbuilt Laminated Veneer Lumber: www.redbuilt.com/#sle.
 - 1) ICC ESR-2993.
- c. Pacific Woodtech Corp.: www.pacificwoodtech.com.
 - 1) ICC ESR-2403. (Formerly Louisian Pacific Corp.)
- d. Weyerhaeuser Company: www.weyerhaeuser.com/#sle.
 - 1) ICC ESR-1387, VAR-1008.
- e. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.

2.04 CONSTRUCTION PANELS

- A. Subfloor/Underlayment Combination: PS 1 or PS 2 type, rated Single Floor.
 - 1. Panel Type: Plywood.
 - 2. Bond Classification: Exposure 1.
 - 3. Span Rating: 48.
 - 4. Performance Category: 1-1/8 PERF CAT.
 - 5. Edges: Tongue and groove.
 - 6. Products:
 - a. Roseburg Forest Products; Softwood Plywood: www.roseburg.com/#sle.
 - b. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- B. Roof Sheathing: PS 1 type, rated Structural I Plywood Sheathing.
 - 1. Bond Classification: Exterior.
 - 2. Span Rating: 24.
 - 3. Performance Category: 15/32 PERF CAT.
 - 4. Edge: Square edge.
- C. Wall Sheathing: PS 2 type plywood.
 - 1. Bond Classification: Exterior.
 - 2. Grade: Structural I Sheathing.
 - 3. Span Rating: 24.
 - 4. Performance Category: 5/16 PERF CAT.
 - 5. Edge Profile: Square edge.
- D. Communications and Electrical Room Mounting Boards: PS 1 A-D plywood; 3/4 inch thick; flame spread index of 25 or less, smoke developed index of 450 or less, when tested in accordance with ASTM E84.
- E. Other Applications:
 - 1. Plywood Concealed From View But Located Within Exterior Enclosure: PS 1, C-C Plugged or better, Exterior grade.
 - 2. Plywood Exposed to View But Not Exposed to Weather: PS 1, A-D, or better.
 - 3. Other Locations: PS 1, C-D Plugged or better.

2.05 ACCESSORIES

- A. Fasteners and Anchors:
 - 1. Metal and Finish: Hot-dipped galvanized steel complying with ASTM A153/A153M for high humidity and preservative-treated wood locations, unfinished steel elsewhere. Comply with CBC 2304.10.2.1.
 - a. Exterior Wall Coverings: Provide hot dipped or mechanically deposited zinc-coated steel, stainless steel, silicon bronze or copper.
 - 1) Provide coating weights for mechanically deposited zinc coating fasteners complying with ASTM B695, minimum Class 55.
 - 2. Wood Screws: Bugle head, hardened steel, power driven type, length three times thickness of sheathing.
 - 3. Anchors: As indicated on Drawings.
- B. Die-Stamped Connectors: Hot dipped galvanized steel, sized to suit framing conditions.
 - 1. For contact with preservative treated wood in exposed locations, provide minimum G185 galvanizing complying with ASTM A653/A653M.
 - 2. Basis of Design Product: Connectors as manufactured by Simpson Strong-Tie, or approved equal.
- C. Joist Hangers: Hot dipped galvanized steel, sized to suit framing conditions.
 - 1. For contact with preservative treated wood in exposed locations, provide minimum G185 galvanizing complying with ASTM A653/A653M.
 - 2. Basis of Design Product: Connectors as manufactured by Simpson Strong-Tie, or approved equal.
- D. Sill Gasket on Top of Foundation Wall: 1/4 inch thick, plate width, closed cell plastic foam from continuous rolls.
- E. Termite Resistant Base Condition:
 - 1. Termite-Resistant Sill Plate Barrier: Self-adhesive, 4 mil film-backed 64 mil barrier with release sheet; adheres to concrete substrates and blocks termite access.
 - a. Thickness: 68 mil, 0.068 inch.
 - b. Termite Resistance: 100 percent when tested in accordance with ICC-ES AC380.
 - c. Water Vapor Permeance: 0.035 perm, maximum, when tested in accordance with ASTM E96/E96M.
 - d. Products:
 - 1) Basis of Design: Polyguard Products Inc.; TERM® Sill Barrier | Termite Barrier : www.polyguardproducts.com, or approved equal.
 - 2) Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
 - 2. Termite-Resistant Sill Flashing: Self-adhesive membrane; 4 mil polyethylene film bonded to 36 mil sealant.
 - a. Thickness: 40 mil, 0.040 inch.
 - b. Width: 12 inches, minimum.

- c. Termite Resistance: 100 percent when tested in accordance with ICC-ES AC380.
 - 1) ICC ESR 3632.
- d. Water Vapor Permeance: 0.035 perm, maximum, when tested in accordance with ASTM E96/E96M.
- e. Pesticide repellency; chlorodane, fipronil, and permethrin: 0 percent penetration, tested to ASTM F2130.
- f. Products:
 - 1) Basis of Design: Polyguard Products Inc.; TERM® Flashing Barrier | Termite Barrier : www.polyguardproducts.com, or approved equal.
 - 2) Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- 3. Accessory Sealants: indicated on details to maintain warranty.
 - a. Sill Barrier Sealant: Polygard Detail Sealant PW (California VOC Compliant), or approved equal.
 - b. Sill Flashing Sealant : Polyguard California Sealant, or approved equal.
- F. Sill Flashing: See Section 07 62 00.
- G. Water-Resistive Barrier: See Section 07 25 00.

2.06 FACTORY WOOD TREATMENT

- A. Treated Lumber and Plywood: Comply with requirements of AWPA U1 - Use Category System for wood treatments determined by use categories, expected service conditions, and specific applications.
 - 1. Preservative-Treated Wood: Provide lumber and plywood marked or stamped by an ALSC-accredited testing agency, certifying level and type of treatment in accordance with AWPA standards.
- B. Preservative Treatment:
 - 1. Products:
 - a. Lonza Group: www.wolmanizedwood.com/#sle.
 - b. Koppers Performance Chemicals, Inc: www.koppersperformancechemicals.com/#sle.
 - c. Viance, LLC; Preserve ACQ: www.treatedwood.com/#sle.
 - d. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
 - 2. Preservative Pressure Treatment of Lumber Above Grade: AWPA U1, Use Category UC3B, Commodity Specification A using waterborne preservative.
 - a. Kiln dry lumber after treatment to maximum moisture content of 19 percent.
 - b. Treat lumber in contact with roofing, flashing, or waterproofing.
 - c. Treat lumber in contact with masonry or concrete.
 - d. Treat lumber less than 18 inches above grade.
 - e. Treat lumber in other locations as indicated.

3. Preservative Pressure Treatment of Plywood Above Grade: AWPA U1, Use Category UC2 and UC3B, Commodity Specification F using waterborne preservative.
 - a. Kiln dry plywood after treatment to maximum moisture content of 19 percent.
 - b. Treat plywood in contact with roofing, flashing, or waterproofing.
 - c. Treat plywood in contact with masonry or concrete.
 - d. Treat plywood less than 18 inches above grade.
 - e. Treat plywood in other locations as indicated.

PART 3 EXECUTION

3.01 PREPARATION

- A. Install sill gasket under sill plate of framed walls bearing on foundations; puncture gasket cleanly to fit tightly around protruding anchor bolts.
- B. Coordinate installation of rough carpentry members specified in other sections.

3.02 INSTALLATION - GENERAL

- A. Select material sizes to minimize waste.
- B. Reuse scrap to the greatest extent possible; clearly separate scrap for use on site as accessory components, including: shims, bracing, and blocking.
- C. Where treated wood is used on interior, provide temporary ventilation during and immediately after installation sufficient to remove indoor air contaminants.

3.03 FRAMING INSTALLATION

- A. Set structural members level, plumb, and true to line. Discard pieces with defects that would lower required strength or result in unacceptable appearance of exposed members.
- B. Make provisions for temporary construction loads, and provide temporary bracing sufficient to maintain structure in true alignment and safe condition until completion of erection and installation of permanent bracing.
- C. Install structural members full length without splices unless otherwise specifically detailed.
- D. Comply with member sizes, spacing, and configurations indicated, and fastener size and spacing indicated, but not less than required by applicable codes, AFPA (NDS), and AWC SDPWS.
- E. Install horizontal spanning members with crown edge up and not less than 1-1/2 inches of bearing at each end.
- F. Construct double joist headers at floor and ceiling openings and under wall stud partitions that are parallel to floor joists; use metal joist hangers unless otherwise detailed.
- G. Provide bridging at joists in excess of 8 feet span as detailed. Fit solid blocking at ends of members.
- H. Frame wall openings with two or more studs at each jamb; support headers on cripple studs.

3.04 BLOCKING, NAILERS, AND SUPPORTS

- A. Provide framing and blocking members as indicated or as required to support finishes, fixtures, specialty items, and trim.
- B. In framed assemblies that have concealed spaces, provide solid wood fireblocking as required by applicable local code, to close concealed draft openings between floors and between top story and roof/attic space; other material acceptable to authorities having jurisdiction may be used in lieu of solid wood blocking.
 - 1. Comply with {RS#10005050} Section 718.2 Fireblocking.
- C. In walls, provide blocking attached to studs as backing and support for wall-mounted items, unless item can be securely fastened to two or more studs or other method of support is explicitly indicated.
- D. Where ceiling-mounting is indicated, provide blocking and supplementary supports above ceiling, unless other method of support is explicitly indicated.
- E. Provide the following specific nonstructural framing and blocking:
 - 1. Cabinets and shelf supports.
 - 2. Wall brackets.
 - 3. Handrails.
 - 4. Grab bars.
 - 5. Towel and bath accessories.
 - 6. Wall-mounted door stops.
 - 7. Chalkboards and marker boards.
 - 8. Wall paneling and trim.
 - 9. Joints of rigid wall coverings that occur between studs.
 - 10. Equipment.

3.05 ROOF-RELATED CARPENTRY

- A. Coordinate installation of roofing carpentry with deck construction, framing of roof openings, and roofing assembly installation.
- B. Provide wood curb at each roof opening except where specifically indicated otherwise; form corners by alternating lapping side members.

3.06 INSTALLATION OF CONSTRUCTION PANELS

- A. Roof Sheathing: Secure panels with long dimension perpendicular to framing members, with ends staggered and over firm bearing.
 - 1. At long edges provide solid edge blocking where joints occur between roof framing members.
 - 2. Nail panels to framing; staples are not permitted.
- B. Wall Sheathing: Secure with long dimension perpendicular to wall studs, with ends over firm bearing and staggered, using nails or screws.

FOR REFERENCE ONLY

1. Use plywood or other acceptable structural panels at building corners, for not less than 96 inches, measured horizontally.
 2. Place water-resistive barrier horizontally over wall sheathing, weather lapping edges and ends.
- C. Communications and Electrical Room Mounting Boards: Secure with screws to studs with edges over firm bearing; space fasteners at maximum 24 inches on center on all edges and into studs in field of board.
1. At fire-rated walls, install board over wall board indicated as part of the fire-rated assembly.
 2. Where boards are indicated as full floor-to-ceiling height, install with long edge of board parallel to studs.
 3. Install adjacent boards without gaps.
 4. Size and Location: As indicated on drawings.

3.07 SITE APPLIED WOOD TREATMENT

- A. Apply preservative treatment compatible with factory applied treatment at site-sawn cuts, complying with manufacturer's instructions.
- B. Allow preservative to dry prior to erecting members.

3.08 TOLERANCES

- A. Framing Members: 1/4 inch from true position, maximum.
- B. Variation from Plane, Other than Floors: 1/4 inch in 10 feet maximum, and 1/4 inch in 30 feet maximum.

3.09 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements for additional requirements.

3.10 CLEANING

- A. Waste Disposal: See Section 01 74 19 - Construction Waste Management and Disposal.
 1. Comply with applicable regulations.
 2. Do not burn scrap on project site.
 3. Do not burn scraps that have been pressure treated.
 4. Do not send materials treated with pentachlorophenol, CCA, or ACA to co-generation facilities or "waste-to-energy" facilities.
- B. Do not leave wood, shavings, sawdust, etc. on the ground or buried in fill.
- C. Prevent sawdust and wood shavings from entering the storm drainage system.

END OF SECTION

SECTION 06 83 16 FIBERGLASS REINFORCED PANELING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Fiberglass reinforced plastic panels. FRP-1
- B. Trim.

1.02 RELATED REQUIREMENTS

- A. Section 01 61 16 - Volatile Organic Compound (VOC) Content Restrictions.

1.03 REFERENCE STANDARDS

- A. ASTM D256 - Standard Test Methods for Determining the Izod Pendulum Impact Resistance of Plastics.
- B. ASTM D3273 - Standard Test Method for Resistance to Growth of Mold on the Surface of Interior Coatings in an Environmental Chamber.
- C. ASTM D5319 - Standard Specification for Glass-Fiber Reinforced Polyester Wall and Ceiling Panels.
- D. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials.
- E. FDA Food Code - Chapter 6 - Physical Facilities.
- F. ISO 846 - Plastics - Evaluation of the Action of Microorganisms.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide data on specified products, describing physical and performance characteristics; including sizes, patterns and colors available; and installation instructions.
- C. Maintenance Materials: Furnish the following for District's use in maintenance of project.
 - 1. See Section 01 60 00 - Product Requirements, for additional provisions.

1.05 DELIVERY, STORAGE, AND HANDLING

- A. Store panels flat, indoors, on a clean, dry surface. Remove packaging and allow panels to acclimate to room temperature for 48 hours prior to installation.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Basis of Design Product: Standard FRP as manufactured by Marlite, or approved equal.
- B. Fiberglass Reinforced Plastic Panels:
 - 1. Crane Composites, Inc: www.cranecomposites.com.
 - 2. Marlite: Standard FRP: www.marlite.com.

3. Nudo: www.nudo.com.
4. Panolam Industries International, Inc: www.panolam.com/#sle.
5. Parkland Performance; Plas-Tex PolyWall; www.parklandplastics.com.
6. Substitutions: See Section 01 6000 - Product Requirements.

2.02 PANEL SYSTEMS

A. Wall Panels:

1. Panel Size: 4 by 8 feet.
2. Panel Thickness: 0.075 inch.
3. Surface Design: Smooth.
4. Color: White.
5. Attachment Method: Adhesive only, with trim and sealant in joints.

2.03 MATERIALS

A. Panels: Fiberglass reinforced plastic (FRP), complying with ASTM D5319.

1. Surface Burning Characteristics: Maximum flame spread index of 25 and smoke developed index of 450; when system tested in accordance with ASTM E84.
2. Mold Resistance: Score of 10, when tested in accordance with ASTM D3273.
3. Impact Strength: Greater than 6 ft lb force per inch, when tested in accordance with ASTM D256.
4. Surface Characteristics and Cleanability: Provide products that are smooth, durable, and easily cleanable, in compliance with FDA Food Code, Chapter 6 - Physical Facilities.
5. Biological Resistance: Rating of 0, when tested in accordance with ISO 846.

B. Trim: Aluminum; color coordinating with panel.

C. Adhesive: Type recommended by panel manufacturer.

D. Sealant: Type recommended by panel manufacturer; white.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify existing conditions and substrate flatness before starting work.
- B. Verify that substrate conditions are ready to receive the work of this section.

3.02 INSTALLATION - WALLS

- A. Install panels in accordance with manufacturer's instructions.
- B. Cut and drill panels with carbide tipped saw blades, drill bits, or snips.
- C. Apply adhesive to the back side of the panel using trowel as recommended by adhesive manufacturer.
- D. Apply panels to wall with seams plumb and pattern aligned with adjoining panels.
- E. Install panels with manufacturer's recommended gap for panel field and corner joints.

FOR REFERENCE ONLY

- F. Place trim on panel before fastening edges, as required.
- G. Fill channels in trim with sealant before attaching to panel.
- H. Install trim with adhesive and screws or nails, as required.
- I. Seal gaps at floor, ceiling, and between panels with applicable sealant to prevent moisture intrusion.
- J. Remove excess sealant after paneling is installed and prior to curing.

END OF SECTION

SECTION 07 01 50.20 ROOFING, RESTORATION, PATCH, AND REPAIR

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Partial removal of existing roofing system in preparation for new penetrations.
- B. Patching and repair shall not void or reduce Contractor's and manufacturer's warranty of existing roofing. If possible, removal of existing roofing and repair is recommended to be done by the Roofing Contractor in which the roofing system was originally installed.

1.02 RELATED REQUIREMENTS

- A. Section 06 10 00 - Rough Carpentry: Wood framing, plywood sheathing, wood curbs, cants, nailers, blocking and backing.
- B. Section 07 62 00 - Sheet Metal Flashing and Trim: Counterflashings, reglets, .
- C. Section 07 72 00 - Roof Accessories: Roof-mounted units; prefabricated curbs.
- D. Division 22 - Plumbing: Roof drains, plumbing items penetrating roofing membrane.
- E. Division 23 - Heating, Ventilation and Air-Conditioning (HVAC): Roof mounted equipment, curbs, and ducts penetrating roofing membrane.
- F. Division 26 - Electrical.
 - 1. Conduit penetrating roofing membrane.
- G. ASTM C208 - Standard Specification for Cellulosic Fiber Insulating Board.
- H. ASTM E108 - Standard Test Methods for Fire Tests of Roof Coverings.
- I. UL (DIR) - Online Certifications Directory.
- J. NRCA ML104 - The NRCA Roofing and Waterproofing Manual.

1.03 ADMINISTRATIVE REQUIREMENTS

- A. Coordinate with affected mechanical and electrical work associated with roof penetrations.
- B. Preinstallation Meeting: Convene two weeks before starting work of this section.
 - 1. Attendance is mandatory at conference required in section specifying new roofing installation.
 - a. Require attendance by Contractor's superintendent and other supervisory and quality control personnel having responsibility for roofing, supervisory personnel of roofing installer and, if required for warranty provisions, representative of roofing products manufacturer.
 - b. DSA, testing and inspection agency (if engaged by District), District's insurance underwriter (if necessary, at District's option), and Architect (if authorized by District) will attend.

FOR REFERENCE ONLY

- c. At Contractor's option, installers of each component of related Work, including deck or substrate construction, rooftop equipment, penetrations of roof deck, and other Work integral with or adjacent to roofing may attend.
 - d. If required, attendance shall include Authority Having Jurisdiction (AHJ). Contractor shall verify requirement with Authority Having Jurisdiction (AHJ) and arrange for attendance.
2. Establish at pre-bid job walk, number of layers to be removed and reconfirm at pre-installation conference.
 3. See new roofing installation section for additional information.
 4. Agenda items specific to patch and repair.
 - a. Review Drawings and Specifications for suitability for application of roofing system. Review application procedures and coordination required with related Work.
 - 1) Discuss changes and deviations from Drawings and Specifications, if any, recommended or required.
 - b. Walk roof areas to review and discuss substrate preparation including repair of unacceptable surfaces, roof drainage, penetrations, equipment curbs, and work performed by other trades which requires coordination with roofing system.
 - c. Review Contract Document requirements and submittals for roofing system, including roofing schedule, inspection and testing, and environmental conditions.
 - 1) Identify which governing regulations or insurance requirements will affect roofing system installation.
 - d. Discuss anticipated weather, as well as procedures for responding to unacceptable weather, including using temporary roofing.
 - 1) Temporary roofing, if necessary, will be added to scope of the Work by contract modification (change order or construction change directive), with acceptable adjustment in Contract Time and Contract Sum.
 - e. Document discussions in writing, including actions required, and distribute copy of report to each meeting participant.
 - f. Attendance by DSA, Architect and independent testing and inspection agency shall not relieve Contractor of sole responsibility for means, methods, techniques and sequence of construction, in accordance with provisions of the Bidding and Contract Requirements.
- C. Schedule work to coincide with commencement of installation of new roofing system.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Submit for each type of material.
- C. Shop Drawings: Indicate size, configuration, and installation details.
- D. Preconstruction Test Reports.
- E. Materials Removal Company Qualification Statement.
- F. Installer's Qualification Statement.

- G. Preconstruction Testing Agency Qualification Statement.
- H. Certification required for existing buildings to be re-roofed per Chapter 3 of Part 1 of Division 2 of the Public Contract Code Section 1 Section 3006(b):
 - 1. I, _____ (Name), _____ (Name of Employer), certify that I have not offered, given, or agreed to give, received, accepted, or agreed to accept, any gift, contribution, or any financial incentive whatsoever to or from any person in connection with the roof project contract. As used in this certification, "person" means any natural person, business, partnership, corporation, union, committee, club, or other organization, entity, or group of individuals. Furthermore, I _____ (Name), _____ (Name of Employer), certify that I do not have, and throughout the duration of the contract, I will not have, any financial relationship in connection with the performance of this contract with any architect, engineer, roofing consultant, materials manufacturer, distributor, or vendor that is not disclosed below.
 - 2. I _____ (Name), _____ (Name of Employer), have the following financial relationships with an architect, engineer, roofing consultant, materials manufacturer, distributor, or vendor, or other person in connection with the following roof project contract:

_____ Name and Address of Building, Contract Date and Number
 - 3. I certify that to the best of my knowledge, the contents of this disclosure are true, or are believed to be true.

_____ (Signature) _____ (Date)

_____ (Print Name)

_____ (Print Name of Employer)
 - 4. Submit this certification to District, DSA, and Architect.

1.05 QUALITY ASSURANCE

- A. Comply with Title 24 Part 2 - California Building Code Sections 1504 Performance Requirements, 1505 Fire Classification and 1507 Requirements for Roof Coverings; and Part 6 - California Energy Code requirements
- B. Materials Removal Firm Qualifications: Company specializing in performing the work of this section with minimum five years of documented experience.
- C. Industry Standards:
 - 1. Work specified in this Section shall comply to manufacturer's product data and application instructions.
 - 2. Work shall also conform to recommended practices and details published in NRCA Roofing and Waterproofing Manual, NRCA ML104 and recommended practices and details of Western States Roofing Contractors Association (WSRCA), where such practices and details are more stringent.
- D. Testing and Inspection:

1. At District's option, services of an independent inspection and testing agency may be obtained. Costs of this service will be paid for by District.
2. Contractor shall cooperate with independent testing and inspection agency.

1.06 SCHEDULING

- A. Remove only existing roofing materials that can be replaced with new materials as the weather will permit.

1.07 FIELD CONDITIONS

- A. Do not remove existing roofing membrane when weather conditions threaten the integrity of the building contents or intended continued occupancy.
- B. Maintain continuous temporary protection prior to and during installation of new roofing system.

1.08 WARRANTY

- A. Existing Warranties: Remove, replace, patch, and repair materials and surfaces affected by reroofing, by methods and with materials acceptable to warrantor.
 1. Notify warrantor of existing roofing system before proceeding, and upon completion of reroofing.
 2. Obtain documentation verifying that existing roofing system has been inspected by manufacturer's technical representative, warrantor, and warranty remains in effect. Submit documentation at Project closeout.

PART 2 PRODUCTS

2.01 SYSTEM DESCRIPTION

- A. Roofing Assembly Requirements:
 1. External Fire Exposure Classification: ASTM E108 Class A, UL (DIR) or Warnock Hersey listed.
- B. Indicated Roof Areas: Patch and repair existing roofing, perimeter flashings, base flashings, counter flashings, vent stack flashings, roofing membrane, and insulation where required for the installation of new roof mounted equipment.
- C. Patch and repair roofing as necessary to provide complete, weathertight installation conforming to referenced industry standards and as necessary to accommodate new Work.
- D. Contract Drawings and Specifications:
 1. Contract Drawings and Specifications are diagrammatic and of a general nature only.
 2. Materials manufacturer's specifications for roofing and related flashings shall govern Work as if set forth herein, except as specifically indicated or where more stringent requirements are specified or required by Authority Having Jurisdiction (AHJ).
 3. All Work shall be completed as required to obtain specified warranty and guarantee.
- E. Design Review:

FOR REFERENCE ONLY

1. Contractor, roofing installer and manufacturer's representative of the original roofing installation (if known or identifiable) shall review Drawings and Specifications.
2. Obtain confirmation from roofing installer and manufacturer of original roofing (if known or identifiable) that selected roofing materials for patching and repair are proper, compatible and adequate for the Project and that conditions and details indicated and specified do not conflict with requirements and recommendations of manufacturer.

2.02 MATERIALS

- A. Temporary Protection: Sheet polyethylene; provide weights to retain sheeting in position.
 1. Provide thickness sufficient to prevent tearing or damage during use.
- B. Protection Board: ASTM C208 cellulose fiber board, one face finished with mineral fiber, asphalt and kraft paper.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify existing site conditions.
- B. Verify that existing roof surface is clear and ready for work of this section.
 1. Verify that roof deck is structurally sound to support live and dead load requirements of roofing system and sufficiently rigid to support construction traffic.

3.02 PREPARATION

- A. Coordination: Coordinate patching and repairs of roofing with installation of penetrations, supports and other adjoining new construction which affects existing roofing.
- B. Deck Preparation:
 1. Clean and prepare roof deck in accordance with roofing system manufacturer's instructions and recommendations.
 2. Correct substrate surfaces which are unacceptable to installer.
- C. Sweep roof surface clean of loose matter.
- D. Remove loose refuse and dispose off site.
 1. Free Fall Maximum: 8 feet, provide enclosed chutes for higher fall.
 2. Do not use District's disposal system.
- E. Deck Condition: Firm, smooth, clean and sufficiently dry to suit roofing manufacturer's requirements.
 1. Conduct moisture test of deck and surrounding roofing.
 2. Do not proceed with roofing application until deck and surrounding materials are dry.

3.03 MATERIAL REMOVAL

- A. Remove only existing roofing materials that can be replaced with new materials as the weather will permit.
- B. Remove metal counter flashings.

- C. Remove damaged portions of roofing membrane, perimeter base flashings, flashings around roof protrusions, pitch pans and pockets.
- D. Cut and lay flat any membrane blisters.
- E. Remove damaged insulation and fasteners, cant strips, blocking .
- F. Remove sheathing paper and underlay..
- G. Repair existing underlying deck surface to provide smooth working surface for new roof system.

3.04 TEMPORARY PROTECTION

- A. Provide temporary protective sheeting over uncovered deck surfaces.
- B. Turn sheeting up and over parapets and curbing. Retain sheeting in position with weights.
- C. Provide for surface drainage from sheeting to existing drainage facilities.
- D. Do not permit traffic over unprotected or repaired deck surface.

3.05 PATCHING AND REPAIRS

- A. General:
 - 1. It is intended to leave existing roofing intact as much as feasible.
 - a. Roofing Work is intended to be patching and repair of portions of existing roofing due to new:
 - 1) Structural supports.
 - 2) Penetrations.
 - 3) Heating, ventilating and air conditioning (HVAC) equipment.
 - 4) Electrical system penetrations.
 - b. Include repairs of areas damaged as result of construction activities.
 - 2. Comply with instructions and recommendations of manufacturer of existing roofing system for making patches and repairs.
 - 3. Comply also with recommended practices of referenced industry standards.
 - 4. Protect other Work from spillage of roofing materials and prevent materials from entering or clogging drains and conductors. Replace and restore other construction damaged or degraded by roofing Work.
 - 5. Apply roofing materials in accordance with NRCA Roofing and Waterproofing Manual and published details and recommendations of Western States Roofing Contractors Association (WSRCA).
 - 6. Keep roofing materials dry before and during application. Do not permit phased construction.
- B. Flashing Replacement: Entire sheet of flashing membrane is to be adhered to vertical substrate and hot-air welded to the secured field membrane.
- C. Penetrations:
 - 1. Coordinate roofing Work with plumbing, mechanical and electrical Work and other Work involving penetrations of roofing membrane.

FOR REFERENCE ONLY

2. Provide pipe and conduit penetrations as indicated on Drawings, or if more stringent, as detailed in NRCA - Roofing and Waterproofing Manual.
 3. Verify that penetrations through roof are adequately separated by a minimum of 18 inches from each other, away from curbs, platforms, sleepers and walls and are also located a minimum of 24 inches beyond all waterways.
- D. Other Roofing Accessories: Install other accessories in accordance with manufacturer's instructions and recommendations, and NRCA Construction Details, as applicable.
- E. Crickets and Tapered Areas: Install to provide positive slope at proper transitions at changes in roof plane.
- F. Flashing and Sheet Metal Work: Set and flash in integrated sheet metal.

3.06 FIELD QUALITY CONTROL

- A. Independent agency inspection and testing will be provided under provisions of Section 01 40 00.
- B. The drawings identify the approximate limits to material removal.
- C. Testing will identify the condition of existing materials and their reuse, repair or removal.
- D. Test Reports: Indicate existing insulation moisture content and existing roof system quality.

3.07 PROTECTION

- A. Provide temporary protective sheeting over uncovered deck surfaces.
- B. Turn sheeting up and over parapets and curbing. Retain sheeting in position with weights.
- C. Provide for surface drainage from sheeting to existing drainage facilities.
- D. Do not permit traffic over unprotected or repaired deck surface.

3.08 SCHEDULES

- A. Roof Areas as Indicated: Remove, where required, existing perimeter flashings, base flashings, counter flashings, vent stack flashings, roofing membrane, and insulation.
- B. Remove indicated roof mounted mechanical equipment and electrical equipment.

END OF SECTION

SECTION 07 21 00 THERMAL INSULATION

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Board insulation at underside of floor slabs and over roof deck.
- B. Batt insulation in exterior wall construction.
- C. Batt insulation for filling perimeter window and door shim spaces and crevices in exterior wall and roof.

1.02 RELATED REQUIREMENTS

- A. Section 07 27 00 - Air Barriers: Separate air barrier materials.
- B. Section 07 52 00 - Modified Bituminous Membrane Roofing: Installation requirements for board insulation over low slope roof deck.

1.03 DEFINITIONS

- A. Mineral Fiber Material Composition: Insulation referred to as mineral fiber block, board, and blanket insulation is composed of fibers from mineral based substances such as rock, slag, or glass and processed from the molten state into fibrous form.
 - 1. Based on type of insulation substance, the material will be referred to as a mineral fiber when having a rock or slag base, and glass fiber with a glass or silica sand base, also considered a mineral.
 - 2. Insulation blankets are flexible units consisting of felted, bonded, or unbonded fibers formed into rolls or flat cut pieces referred to as batts; rolls are simply longer versions of batts.
 - 3. For additional information about mineral fiber and the various classification types, refer to the following reference standards; ASTM C553, ASTM C612, ASTM C665, and ASTM C726.

1.04 REFERENCE STANDARDS

- A. ASTM C553 - Standard Specification for Mineral Fiber Blanket Thermal Insulation for Commercial and Industrial Applications.
- B. ASTM C578 - Standard Specification for Rigid, Cellular Polystyrene Thermal Insulation.
- C. ASTM C612 - Standard Specification for Mineral Fiber Block and Board Thermal Insulation.
- D. ASTM C665 - Standard Specification for Mineral-Fiber Blanket Thermal Insulation for Light Frame Construction and Manufactured Housing.
- E. ASTM C726 - Standard Specification for Mineral Wool Roof Insulation Board.
- F. ASTM E119 - Standard Test Methods for Fire Tests of Building Construction and Materials.
- G. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials.

- H. ASTM E136 - Standard Test Method for Assessing Combustibility of Materials Using a Vertical Tube Furnace at 750 Degrees C.
- I. NFPA 285 - Standard Fire Test Method for Evaluation of Fire Propagation Characteristics of Exterior Wall Assemblies Containing Combustible Components.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide data on product characteristics, performance criteria, and product limitations.
 - 1. Manufacturer and product identification for each product specified, including R-Value and fire resistance and surface burning characteristics specified herein.
- C. Manufacturer's Certificate: Certify that products meet or exceed specified requirements.
- D. Compliance Certification: Upon completion of installation of building envelope insulation, a card certifying compliance with requirements of California Code of Regulations (CCR) Title 24 for installation of insulation shall be completed, executed and delivered to local building officials, and one copy conspicuously posted at Project site.
- E. Manufacturer's Installation Instructions: Include information on special environmental conditions required for installation and installation techniques.

1.06 FIELD CONDITIONS

- A. Do not install insulation adhesives when temperature or weather conditions are detrimental to successful installation.

PART 2 PRODUCTS

2.01 REGULATORY REQUIREMENTS

- A. Fire Performance Characteristics: Where insulation is used within a fire rated wall assembly, provide insulation materials which are identical to those whose fire performance characteristics, as listed for each material or assembly of which insulation is a part, have been determined by testing, in accordance with methods specified below, by UL or other testing and inspecting agency acceptable to State Fire Marshal.
 - 1. Surface Burning Characteristics: ASTM E84.
 - a. Class A: Maximum flame-spread 0-25 and smoke developed of 0-450.
 - b. Class B: Maximum flame-spread 26-75 and smoke developed of 0-450.
 - c. Class C: Maximum flame-spread 76-200 and smoke developed of 0-450.
 - 2. Fire Resistance Ratings: ASTM E119.
 - 3. Combustibility: ASTM E136.
- B. Comply with Chapter 12-13 Standards for Insulating Materials, California Reference Standards Code (Part 12, Title 24. CCR) as published by Department of Consumer Affairs, Bureau of Home Furnishings and Thermal Insulation.
- C. Comply with California Energy Code:

FOR REFERENCE ONLY

1. Section 110.8(a): Installed insulating material shall have been certified by the manufacturer to comply with the California Code of Regulations, Title 24, Part 12, Chapters 12-13, Article 3, "Standards for Insulating Material.
2. Section 110.8(c): All Insulating Materials shall be installed in compliance with the flame spread rating and smoke density requirements of CBC Chapters 7 and 26.
3. Section 120.7(b) item 7: The opaque portions of framed demising walls in nonresidential buildings shall be insulated to meet a u-factor of:
 - a. Metal Framed Walls: Not greater than 0.151 (R-6 minimum).
- D. Certificate: As required by the California Building Code (CBC), Title 24, post a certificate containing the building permit number and the insulation manufacturer's name, material identification and R-value and stating that the insulation has been installed in accordance with the plans and specifications.
- E. Performance: Materials shall conform to Section 720, California Building Code.

2.02 APPLICATIONS

- A. Insulation Under Concrete Slabs: Extruded polystyrene (XPS) board.
- B. Insulation in Wood Framed Walls: Batt insulation with no vapor retarder.
- C. Insulation in Wood Framed Ceiling Structure: Batt insulation with no vapor retarder.
- D. Insulation in Exposed Wood Framed Ceiling Structure: Batt insulation with integral vapor retarder vapor retarder.
- E. Insulation Over Roof Deck: Polyisocyanurate board.

2.03 FOAM BOARD INSULATION MATERIALS

- A. Extruded Polystyrene (XPS) Board Insulation: Comply with ASTM C578 with either natural skin or cut cell surfaces.
 1. Type and Compressive Resistance: Type IV, 25 psi (173 kPa), minimum.
 2. Flame Spread Index (FSI): Class A - 0 to 25, when tested in accordance with ASTM E84.
 3. Smoke Developed Index (SDI): 450 or less, when tested in accordance with ASTM E84.
 4. Type and Thermal Resistance, R-value: Type IV, 5.0 (0.88), minimum, per 1 inch thickness at 75 degrees F mean temperature.
 5. Complies with fire resistance requirements indicated on drawings as part of an exterior non-load-bearing exterior wall assembly when tested in accordance with NFPA 285.
 6. Board Edges: Manufacturer's standard.
 7. Type and Water Absorption: Type XII, 0.3 percent by volume, maximum, by total immersion.
 8. Continuous Insulation at Plaster Systems: See Section 09 24 00 - Cement Plastering.
 9. Products:
 - a. Dow Chemical Company; STYROFOAM CladMate, CavityMate Ultra, or Foamular: www.dowbuildingsolutions.com/#sle.
 - b. Kingspan Insulation LLC; GreenGuard GG25-LG XPS Insulation Board: www.kingspan.com/#sle.

- c. Owens Corning Corporation; FOAMULAR Type ___ Extruded Polystyrene (XPS) Insulation: www.ocbuildingspec.com/#sle.
 - d. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Polyisocyanurate Board Insulation with Facers Both Sides: Rigid cellular foam, complying with ASTM C1289; Type I, aluminum foil both faces; Class 2, glass fiber-reinforced core.
- 1. Classifications:
 - a. Type I: Faced with aluminum foil on both major surfaces of core foam.
 - 1) Class 2 - Glass fiber reinforced or non-reinforced core foam.
 - 2) Compressive Strength: 16 psi, minimum.
 - 3) Thermal Resistance, R-value: At 1-1/2 inch thick; 9.0, minimum, at 75 degrees F.
 - 2. Flame Spread Index (FSI): Class A - 0 to 25, when tested in accordance with ASTM E84.
 - 3. Smoke Developed Index (SDI): 450 or less, when tested in accordance with ASTM E84.
 - 4. Comply with fire resistance requirements indicated on drawings as part of an exterior non-load-bearing exterior wall assembly when tested in accordance with NFPA 285.
 - 5. Board Size: 48 inch by 96 inch.
 - 6. Board Thickness: 3 inches.
 - 7. Board Edges: Square.
 - 8. Products:
 - a. Basis of Design: Rmax Inc; ECOMAXci FR: www.rmax.com/#sle.
 - b. DuPont de Nemours, Inc; Thermax XARMOR (ci): building.dupont.com/#sle.
 - c. GAF; EnergyGuard HD PLUS Polyiso Insulation: www.gaf.com/#sle.
 - d. Johns Manville; AP Foil-Faced: www.jm.com/#sle.
 - e. Rmax Inc; ECOMAXci FR: www.rmax.com/#sle.
 - f. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.

2.04 MINERAL FIBER BLANKET INSULATION MATERIALS

- A. Flexible Glass Fiber Blanket Thermal Insulation: Preformed insulation, complying with ASTM C665; friction fit.
- 1. Flame Spread Index: 25 or less, when tested in accordance with ASTM E84.
 - 2. Smoke Developed Index: 450 or less, when tested in accordance with ASTM E84.
 - 3. Combustibility: Non-combustible, when tested in accordance with ASTM E136, except for facing, if any.
 - 4. Formaldehyde Content: Zero.
 - 5. Exterior Walls: Two layers.
 - a. Thermal Resistance: Each R-value of 15. Total R-30
 - b. Thickness: Each 3-1/2 inch.
 - 6. Facing: Aluminum foil, flame spread 25 rated; one side.

7. Products:
 - a. CertainTeed Corporation: www.certainteed.com/#sle.
 - b. Johns Manville: www.jm.com/#sle.
 - c. Knauf Insulation: www.knauf.com.
 - d. Owens Corning Corporation: www.ocbuildingspec.com/#sle.
 - e. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Mineral Wool Blanket Thermal Insulation: Flexible or semi-rigid preformed insulation, complying with ASTM C665.
 1. Typical at interior walls, see section 09 21 16 - Gypsum Board Assemblies.
 2. Flame Spread Index: 25 or less, when tested in accordance with ASTM E84.
 3. Smoke Developed Index: 450 or less, when tested in accordance with ASTM E84.
 4. Products:
 - a. Johns Manville; MinWool Sound Attenuation Fire Batts: www.jm.com/#sle.
 - b. ROCKWOOL; COMFORTBATT: www.rockwool.com/#sle.
 - c. Thermafiber, Inc; SAFB FF: www.thermafiber.com/#sle.
 - d. Substitutions: See Section 01 60 00 - Product Requirements.

2.05 ACCESSORIES

- A. Insulation Fasteners: Appropriate for purpose intended and approved by roofing manufacturer.
 1. Length as required for thickness of insulation material and penetration of deck substrate.
- B. Nails or Staples: Steel wire; electroplated or galvanized; type and size to suit application.
- C. Adhesive: Type recommended by insulation manufacturer for application.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that substrate, adjacent materials, and insulation materials are dry and that substrates are ready to receive insulation.
- B. Verify substrate surfaces are flat, free of honeycomb, fins, irregularities, or materials or substances that may impede adhesive bond.

3.02 BOARD INSTALLATION UNDER CONCRETE SLABS

- A. Place insulation under slabs on grade after base for slab has been compacted.
- B. Cut and fit insulation tightly to protrusions or interruptions to the insulation plane.
- C. Prevent insulation from being displaced or damaged while placing vapor retarder and placing slab.

3.03 BOARD INSTALLATION OVER LOW SLOPE ROOF DECK

- A. Installation of board insulation over low slope roof deck, see Section 07 52 00.

B. Board Installation Over Roof Deck, General:

1. See applicable roofing specification section for specific board installation requirements.
2. Fasten insulation to deck in accordance with roofing manufacturer's written instructions and applicable Factory Mutual requirements.
3. Do not apply more insulation than can be covered with roofing on the same day.

3.04 BATT INSTALLATION

- A. Install insulation and vapor retarder in accordance with manufacturer's instructions.
- B. Install in exterior wall spaces without gaps or voids.
- C. Trim insulation neatly to fit spaces. Insulate miscellaneous gaps and voids.
- D. Fit insulation tightly in cavities and tightly to exterior side of mechanical and electrical services within the plane of the insulation.

3.05 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements for additional requirements.

3.06 PROTECTION

- A. Do not permit installed insulation to be damaged prior to its concealment.

END OF SECTION

SECTION 07 25 00 WEATHER BARRIERS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Water-resistive barriers, two layers under exterior plaster over air barrier.

1.02 RELATED REQUIREMENTS

- A. Section 07 27 00 - Air Barriers: Air barriers sheet and fluid applied.

1.03 DEFINITIONS

- A. Weather Barriers: Materials or assemblies forming water-resistive barriers, air barriers, vapor retarders, or combination of one or more assemblies.
- B. Water-Resistive Barriers: Materials or assemblies installed behind exterior wall coverings; designed to prevent liquid water from further penetration into exterior wall assembly.

1.04 REFERENCE STANDARDS

- A. AAMA 501.2 - Quality Assurance and Diagnostic Water Leakage Field Check of Installed Storefronts, Curtain Walls, and Sloped Glazing Systems.
- B. AAMA 713 - Voluntary Test Method To Determine Chemical Compatibility of Sealants & Self-Adhered Flashing.
- C. ASTM C719 - Standard Test Method for Adhesion and Cohesion of Elastomeric Joint Sealants Under Cyclic Movement (Hockman Cycle).
- D. ASTM C920 - Standard Specification for Elastomeric Joint Sealants.
- E. ASTM D779 - Standard Test Method for Determining the Water Vapor Resistance of Sheet Materials in Contact with Liquid Water by the Dry Indicator Method.
- F. ASTM D1970/D1970M - Standard Specification for Self-Adhering Polymer Modified Bituminous Sheet Materials Used as Steep Roofing Underlayment for Ice Dam Protection.
- G. ASTM D3960 - Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings.
- H. ASTM E96/E96M - Standard Test Methods for Gravimetric Determination of Water Vapor Transmission Rate of Materials.
- I. ASTM E2273 - Standard Test Method for Determining the Drainage Efficiency of Exterior Insulation and Finish Systems (EIFS) Clad Wall Assemblies.
- J. ASTM E2556/E2556M - Standard Specification for Vapor Permeable Flexible Sheet Water-Resistive Barriers Intended for Mechanical Attachment.
- K. ICC-ES AC308 - Acceptance Criteria for Water-Resistive Barriers.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.

- B. Product Data: Provide data on material characteristics.
- C. Shop Drawings: Provide drawings of special joint conditions.
- D. Manufacturer's Installation Instructions: Indicate preparation, installation methods, and storage and handling criteria.

1.06 MOCK-UPS

- A. See Section 01 40 00 - Quality Requirements for additional requirements.
- B. Construct weather barrier mock-up, 12 feet long by 8 feet wide, indicating complete assembly with two layers under exterior plaster over air barrier..
- C. Locate where directed.
- D. Mock-up may remain as part of work.

1.07 FIELD CONDITIONS

- A. Maintain temperature and humidity recommended by materials manufacturers before, during, and after installation.

PART 2 PRODUCTS

2.01 WATER-RESISTIVE BARRIERS

- A. Building Paper: Asphalt-saturated kraft Grade D type sheathing paper complying with ICC-ES AC38.
 - 1. Water Resistance: At least 60 minutes when tested in accordance with ASTM D779.
 - 2. Water Vapor Permeance: 29 perms, minimum, when tested in accordance with ASTM E96/E96M using Procedure A - Desiccant Method, at 73.4 degrees F.
 - 3. Products:
 - a. Henry Company; Super Jumbo Tex 60 Minute: www.henry.com/#sle.
 - b. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- B. Building Paper with Embossed Drainage Layer: Asphalt-saturated kraft Grade D type sheathing paper with embossed spunbond polypropylene fabric and barrier layer complying with ICC-ES AC38, CBC 1403.2, CBC 2510.6.1, and ASTM E2556/E2556M Type II.
 - 1. Water Resistance: At least 120 minutes when tested in accordance with ASTM D779.
 - 2. Water Vapor Permeance: 7.6 perms, minimum, when tested in accordance with ASTM E96/E96M using Procedure A - Desiccant Method, at 73.4 degrees F.
 - 3. Drainage Efficiency: Greater than 95 percent in accordance with ASTM E2273.
 - 4. Products:
 - a. Henry Company; HydroTex: www.henry.com/#sle.
 - 1) ICC ESR-1027 and ESR-3791.
 - b. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
 - 5. Weather-Resistive Barrier Seam Tape: Pressure sensitive tape as recommended by membrane manufacturer.

FOR REFERENCE ONLY

- a. Types: Sheathing Tape: Henry – Sheathing Tape, or equal.
 - b. Roll Dimensions: 1-7/8" x 55 yards.
 - c. Adhesive Type: Acrylic.
6. Sealant: One component, moisture curing, non-sag, gun-grade elastomeric polymer for use as a sealant or liquid applied flashing.
- a. Types: Sealant: Henry – Moistop® Sealant, or equal.
 - b. Referenced Standards: Must meet ASTM C920.
 - c. Movement Capability: ±25%; ASTM C719.
 - d. Max VOC: 9 g/L; ASTM D3960.
 - e. Compatibility: Chemically compatible with flexible flashing; AAMA 713.

2.02 ACCESSORIES

- A. Flexible Flashing: Self-adhering sheet flashing complying with ASTM D1970/D1970M; waive slip resistance requirement if not installed on roof.
1. Width: 4 inches.
 2. Ultraviolet (UV) and Weathering Resistance: Approved by manufacturer for up to 30 days of weather exposure.
 3. Products:
 - a. DuPont de Nemours, Inc; FlexWrap: www.dupont.com/building/#sle.
 - b. Henry Company; FortiFlash: www.henry.com/#sle.
 - c. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Preformed Transition Membrane: Semi-rigid silicone or polyester composition, tapered edges, and tear resistant.
1. Products:
 - a. Dow; DOWSIL Silicone Transition Strip and System: www.dow.com/en-us/#sle.
 - b. Henry Company; Moistop Corner Shield: www.henry.com/#sle.
 - c. Momentive Performance Materials, Inc/GE Silicones; RF100 Reinforcing Fabric: www.siliconeforbuilding.com/#sle.
 - d. Pecora Corporation: www.pecora.com/#sle.
 - e. Tremco Commercial Sealants & Waterproofing; ProGlaze ETA System 1: www.tremcosealants.com/#sle.
 - f. Substitutions: See Section 01 60 00 - Product Requirements.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that surfaces and conditions comply with requirements of this section.

3.02 PREPARATION

- A. Remove projections, protruding fasteners, and loose or foreign matter that might interfere with proper installation.
- B. Clean and prime substrate surfaces to receive adhesives and sealants in accordance with manufacturer's installation instructions.

3.03 INSTALLATION

- A. Install materials in accordance with manufacturer's installation instructions.
- B. Install continuous water-resistive barriers where indicated on drawings, with sheets lapped to shed water.
 - 1. At Plaster: Install two layers building paper under lath over plastic sheet per Section 07 27 00 - Air Barriers.
 - 2. Not required at metal panels.
- C. Apply sealants within recommended temperature range in accordance with manufacturer's installation instructions.
- D. Mechanically Fastened Sheets:
 - 1. Install sheets in shingle fashion to shed water; align horizontally.
 - 2. Overlap seams as recommended by manufacturer, 6 inches, minimum.
 - 3. Overlap at outside and inside corners as recommended by manufacturer, 12 inches, minimum.
 - 4. Attach to framed construction with fasteners extending through sheathing into framing, and space fasteners at 12 to 18 inches on center along each framing member supporting sheathing.
 - 5. For applications indicated to be airtight, seal seams, laps, penetrations, tears, and cuts with self-adhesive tape; use only large-headed, gasketed fasteners as recommended by manufacturer.
 - 6. Where stud framing rests on concrete or masonry substrate, extend lower edge of barrier sheets at least 4 inches below bottom of framing and seal to substrate with sealant or approved mounting tape.
 - 7. Install water-resistive barrier over jamb flashings.
 - 8. Install head flashings under water-resistive barrier.
 - 9. At framed openings with frames having nailing flanges, extend sheet into opening and over flanges; at head of opening, seal sheet over flange and flashing.
- E. Self-Adhered Sheets:
 - 1. Prepare substrate in accordance with sheet manufacturer's installation instructions; fill and tape joints in substrate and between dissimilar materials.
 - 2. Lap sheets shingle-fashion to shed water and seal laps airtight.
 - 3. Upon placement of sheets, firmly press onto substrate with resilient hand roller; ensure that laps are firmly adhered with no gaps or fishmouths.

FOR REFERENCE ONLY

4. Use same material, or other material approved by sheet manufacturer, to seal sheets to adjacent substrates, and as flashing.
 5. At expansion joints, provide transition to joint assemblies approved by sheet manufacturer.
- F. Openings and Penetrations in Exterior Water-Resistive Barriers:
1. Install flashing over sills, covering entire sill framing member, and extend at least 5 inches onto water-resistive barrier and at least 6 inches up jambs; mechanically fasten stretched edges.
 2. At openings filled with frames having nailing flanges, seal head and jamb flanges using a continuous bead of sealant compressed by flange and cover flanges with sealing tape at least 4 inches wide; do not seal sill flange.
 3. At openings filled with nonflanged frames, seal water-resistive barrier to each side of framing at opening using flashing at least 9 inches wide, and covering entire depth of framing.
 4. At head of openings, install flashing under water-resistive barrier extending at least 2 inches beyond face of jambs; seal water-resistive barrier to flashing.
 5. At interior face of openings, seal gaps between window and door frames and rough framing using appropriate joint sealant over backer rod.
 6. Service and Other Penetrations: Form flashing around penetrating items and seal to surface of water-resistive barrier.

3.04 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements for additional requirements.
- B. District's Inspection and Testing: Cooperate with District's testing agency.
 1. Allow access to work areas and staging.
 2. Notify District's testing agency in writing of schedule for work of this section to allow sufficient time for testing and inspection.
 3. Do not cover work of this section until testing and inspection is accepted.
- C. Do not cover installed water-resistive barriers until required inspections have been completed.
- D. Obtain approval of installation procedures from water-resistive barrier manufacturer based on a mock-up installed in place, prior to proceeding with remainder of installation.
- E. Envelope Water-Spray Test by Contractor: Provide water spray quality test of installed storefront components in accordance with AAMA 501.2 during construction process and before installation of interior finishes.
 1. Perform a minimum of two tests in each area as directed by Architect.
 2. Conduct tests in each area prior to 35 percent and 70 percent completion of this work.
 3. Testing: Installer to water test all weather barriers, storefront, windows, glazing, and door openings, in the presence of the Project Inspector (IOR) and Construction Manager by spraying with hose heavily for 5 minutes. Repair all leaks discovered by testing procedures and repeat test until leak-free performance is achieved.
- F. Take digital photographs of each portion of installation prior to covering up weather barriers.

FOR REFERENCE ONLY

3.05 PROTECTION

- A. Do not leave materials exposed to weather longer than recommended by manufacturer.

END OF SECTION

SECTION 07 27 00 AIR BARRIERS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Air barriers.

1.02 RELATED REQUIREMENTS

- A. Section 07 25 00 - Weather Barriers: Building paper under plaster applications and testing requirements.
- B. Section 07 62 00 - Sheet Metal Flashing and Trim: Metal flashings installed in conjunction with air barriers.

1.03 DEFINITIONS

- A. Air Barrier: Airtight barrier made of material that is virtually air impermeable but water vapor permeable, both to amount as specified, with sealed seams and sealed joints to adjacent surfaces.

1.04 REFERENCE STANDARDS

- A. ASTM C1177/C1177M - Standard Specification for Glass Mat Gypsum Substrate for Use as Sheathing.
- B. ASTM D412 - Standard Test Methods for Vulcanized Rubber and Thermoplastic Elastomers--Tension.
- C. ASTM D751 - Standard Test Methods for Coated Fabrics.
- D. ASTM D903 - Standard Test Method for Peel or Stripping Strength of Adhesive Bonds.
- E. ASTM D1970/D1970M - Standard Specification for Self-Adhering Polymer Modified Bituminous Sheet Materials Used as Steep Roofing Underlayment for Ice Dam Protection.
- F. ASTM D5034 - Standard Test Method for Breaking Strength and Elongation of Textile Fabrics (Grab Test).
- G. ASTM D6525 - Standard Test Method for Measuring Nominal Thickness of Permanent Rolled Erosion Control Products.
- H. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials.
- I. ASTM E96/E96M - Standard Test Methods for Gravimetric Determination of Water Vapor Transmission Rate of Materials.
- J. ASTM E2178 - Standard Test Method for Determining Air Leakage Rate and Calculation of Air Permeance of Building Materials.
- K. ASTM E2273 - Standard Test Method for Determining the Drainage Efficiency of Exterior Insulation and Finish Systems (EIFS) Clad Wall Assemblies.
- L. ASTM G90 - Standard Practice for Performing Accelerated Outdoor Weathering of Materials Using Concentrated Natural Sunlight.

- M. ICC-ES AC212 - Acceptance Criteria for Water-Resistive Coatings Used as Water-Resistive Barriers over Exterior Sheathing.
- N. NFPA 285 - Standard Fire Test Method for Evaluation of Fire Propagation Characteristics of Exterior Wall Assemblies Containing Combustible Components.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide data on material characteristics, performance criteria, and limitations.
- C. Shop Drawings: Provide drawings of special joint conditions.
- D. Manufacturer's Installation Instructions: Indicate preparation, installation methods, and storage and handling criteria.
- E. Manufacturer's qualification statement.
- F. Installer's qualification statement.
- G. Testing agency qualification statement.

1.06 QUALITY ASSURANCE

- A. Installer Qualifications: Company specializing in performing the work of this section with minimum three years documented experience.
- B. Manufacturer Qualification: Use evaluated materials from a single manufacturer regularly engaged in air barrier material manufacture, and use secondary materials approved in writing by primary material manufacturer.
- C. Testing Agency Qualifications: Independent firm specializing in performing testing and inspections of the type specified in this section.

1.07 MOCK-UPS

- A. See Section 01 40 00 - Quality Requirements for additional requirements.
- B. Construct air barrier mock-up, 12 feet long by 8 feet wide, indicating complete assembly under exterior cladding with two layers under exterior plaster over air barrier..
- C. Locate where directed.
- D. Mock-up may remain as part of work.

1.08 FIELD CONDITIONS

- A. Maintain temperature and humidity recommended by materials manufacturers before, during, and after installation.

PART 2 PRODUCTS

2.01 AIR BARRIER MATERIALS (AIR IMPERMEABLE AND WATER VAPOR PERMEABLE)

- A. Air Barrier Sheet, Mechanically Fastened:
 - 1. Air Permeance: 0.004 cfm/sq ft, maximum, when tested in accordance with ASTM E2178.

FOR REFERENCE ONLY

2. Water Vapor Permeance: 10 perms, minimum, when tested in accordance with ASTM E96/E96M using Procedure A - Desiccant Method, at 73.4 degrees F.
 3. Ultraviolet (UV) and Weathering Resistance: Approved by manufacturer for up to 90 days of weather exposure.
 4. Surface Burning Characteristics: Flame spread index of 25 or less, and smoke developed index of 50 or less, Class A, when tested in accordance with ASTM E84.
 5. Comply with NFPA 285 requirements for wall assembly.
 6. Seam and Perimeter Tape: Polyethylene self-adhering type, mesh reinforced, 2-1/2 inches wide, compatible with sheet material; unless otherwise indicated.
 7. Products:
 - a. Certainteed, Inc.; CertaWrap Weather-Protection Membrane: www.certainteed.com.
 - b. DuPont de Nemours, Inc; Tyvek CommercialWrap D with FlexWrap NF, StraightFlash, StraightFlash VF, Tyvek Wrap Caps, and Tyvek Tape: building.dupont.com/#sle.
 - c. Fiberweb, Inc; Typar MetroWrap: www.typar.com/#sle.
 - d. Henry Company; WeatherSmart Commercial: www.henry.com/#sle.
 - e. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- B. Air Barrier, Glass-Mat Faced Gypsum Panel: Vapor permeable; comply with ASTM C1177/C1177M physical requirements, ASTM E2178, and ICC-ES AC212.
1. Type: Fire-resistance-rated Type X, UL or WH listed.
 2. Thickness: 5/8 inch.
 3. Width and Height: 48 inches wide by 96 inches high.
 4. Edges: Square.
 5. Air Permeance: 0.004 cfm/sq ft, maximum, when tested in accordance with ASTM E2178.
 6. Water Vapor Permeance: 8 perms, minimum, when tested in accordance with ASTM E96/E96M using Procedure B - Water Method, at 73.4 degrees F.
 7. Water Penetration Resistance Around Nails: Pass, when tested in accordance with ASTM D1970/D1970M (modified).
 8. Surface Burning Characteristics: Flame spread index of 25 or less, smoke developed index of 450 or less, Class A when tested in accordance with ASTM E84.
 9. Seam and Perimeter Detailing: As recommended by manufacturer.
 10. Products:
 - a. Basis of Design Product: DensElement Barrier System as manufactured by Georgia-Pacific Gypsum, LLC, or approved equal.
 - b. Georgia- Pacific Gypsum, LLC; DensElement Barrier System: buildgp.com.
 - c. Tremco Commercial Sealants & Waterproofing; Securock ExoAir 430 Panel: www.tremcosealants.com/#sle.
 - d. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.

- C. Rainscreen, Mechanically Attached: (Drainage Mat)
 - 1. Three-dimensional, honeycomb-textured drainage mat with attached heavy-duty filter fabric. Replaces one layer of WRB required with stucco and stone.
 - a. Basis of Design Product: Tyvek® DrainVent™ Rainscreen as manufactured by building.dupont.com, or approved equal.
 - b. Composite Thickness, ASTM D6525: 0.27 inch.
 - c. Breaking Strength (Filter Fabric) MD, ASTM D5034: 427 lb/in.
 - d. Breaking Strength (Filter Fabric) CD, ASTM D5034: 32.6 lb/in
 - e. Surface Burning Characteristics: Flame spread index of 15 or less, smoke developed index of 115 or less, Class A when tested in accordance with ASTM E84.
 - f. Maximum Ultra Violet Light Exposure (UV), ASTM G90: 90 days.
 - g. Drainage Efficiency, ASTM E2273: greater than 90 percent.

2.02 ACCESSORIES

- A. Sealants, Tapes, and Accessories for Sealing Air Barrier and Adjacent Substrates: As indicated or in compliance with air barrier manufacturer's installation instructions.
- B. Sealant for Cracks and Joints In Substrates: Resilient elastomeric joint sealant compatible with substrate and air barrier materials.
 - 1. Application: Apply at 30 to 40 mil, 0.030 to 0.040 inch, nominal thickness.
 - 2. Color: Green.
 - 3. Elongation: 1,300 percent, measured in accordance with ASTM D412.
 - 4. Peel Adhesion: 28 lb/inch, minimum, when tested in accordance with ASTM D903.
 - 5. Hydrostatic Head Pressure: Resists head pressure of 57 feet, maximum, when tested in accordance with ASTM D751.
 - 6. Comply with NFPA 285 requirements for wall assembly.
- C. Flexible Flashing: Self-adhesive sheet flashing complying with ASTM D1970/D1970M, except slip resistance requirement waived if not installed on roof.
 - 1. Width: 4 inches.
 - 2. Ultraviolet (UV) and Weathering Resistance: Approved by manufacturer for up to 30 days of weather exposure.
 - 3. Products:
 - a. DuPont de Nemours, Inc; DuPont FlexWrap: www.dupont.com/building/#sle.
 - b. DuPont de Nemours, Inc; DuPont StraightFlash: www.dupont.com/building/#sle.
 - c. DuPont de Nemours, Inc; DuPont VersaFlange: www.dupont.com/building/#sle.
 - d. Henry Company; FortiFlash: www.henry.com/#sle.
 - e. Henry Company; FortiFlex Butyl: www.henry.com/#sle.
 - f. Henry Company; FortiFlash Butyl: www.henry.com/#sle.
 - g. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.

- D. Stainless Steel Flashing: Flexible flashing with 2 mil, 0.002 inch thick Type 304 stainless steel sheet, 8 mil, 0.008 inch of butyl adhesive and siliconized release liner.
 - 1. Roll Length: 50 feet long.
 - 2. Width: 6 inches wide.
 - 3. Overlap joints at least 2 inches.
 - 4. Products:
 - a. Momentive Performance Materials, Inc/GE Silicones; GE Elemax SS Flashing: www.siliconeforbuilding.com/#sle.
 - b. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- E. Thinners and Cleaners: As recommended by material manufacturer.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that surfaces and conditions are ready for work of this section.
- B. Where existing conditions are responsibility of another installer, notify Architect of unsatisfactory conditions.
- C. Do not proceed with this work until unsatisfactory conditions have been corrected.

3.02 PREPARATION

- A. Remove projections, protruding fasteners, and loose or foreign matter that might interfere with proper installation.
- B. Clean and prime substrate surfaces to receive adhesives and sealants in accordance with manufacturer's installation instructions.

3.03 INSTALLATION

- A. Install materials in accordance with manufacturer's installation instructions.
- B. Air Barriers: Install continuous airtight barrier over surfaces indicated, with sealed seams and with sealed joints to adjacent surfaces.
- C. Apply sealants and adhesives within recommended temperature range in accordance with manufacturer's installation instructions.
- D. Mechanically Fastened Sheets - On Exterior:
 - 1. Install sheets shingle fashion to shed water, with seams generally horizontal.
 - 2. Overlap seams as recommended by manufacturer, 6 inches, minimum.
 - 3. Overlap at outside and inside corners as recommended by manufacturer, 12 inches, minimum.
 - 4. Attach to framed construction with fasteners extending through sheathing into framing, and space fasteners at 12 to 18 inches on center along each framing member supporting sheathing.

FOR REFERENCE ONLY

5. For applications indicated to be airtight, seal seams, laps, penetrations, tears, and cuts with self-adhesive tape; use only large-headed, gasketed fasteners as recommended by manufacturer.
 6. Where stud framing rests on concrete or masonry substrate, extend lower edge of air barrier sheet at least 4 inches below bottom of framing and seal to substrate with sealant or approved mounting tape.
 7. Install air barrier underneath jamb flashings.
 8. At framed openings with frames having nailing flanges, extend sheet into opening and over flanges; at head of opening, seal sheet over flange and flashing.
- E. Openings and Penetrations in Exterior Air Barriers:
1. Install flashing over sills, covering entire sill frame member, extending at least 5 inches onto air barrier and at least 6 inches up jambs; mechanically fasten stretched edges.
 2. At openings with frames having nailing flanges, seal head and jamb flanges using a continuous bead of sealant compressed by flange and cover flanges with sealing tape at least 4 inches wide; do not seal sill flange.
 3. At openings with nonflanged frames, seal air barrier to each side of framing at opening using flashing at least 9 inches wide, and covering entire depth of framing.
 4. At head of openings, install flashing under air barrier extending at least 2 inches beyond face of jambs; seal air barrier to flashing.
 5. At interior face of openings, seal gap between window/door frame and rough framing, using joint sealant over backer rod.
 6. Service and Other Penetrations: Form flashing around penetrating item and seal to air barrier surface.

3.04 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements for additional requirements.
- B. District will provide testing services, and Contractor to provide temporary construction and materials for testing.
- C. Coordination of ABAA Tests and Inspections:
 1. Provide testing and inspection required by ABAA QAP.
 2. Notify ABAA in writing of schedule for air barrier work, and allow adequate time for testing and inspection.
 3. Cooperate with ABAA testing agency.
 4. Allow access to air barrier work areas and staging.
 5. Do not cover air barrier work until tested, inspected, and accepted.
- D. Do not cover installed air barriers until required inspections have been completed.
- E. Take digital photographs of each portion of installation prior to covering up air barriers.

FOR REFERENCE ONLY

3.05 PROTECTION

- A. Do not leave materials exposed to weather longer than recommended by manufacturer.

END OF SECTION

SECTION 07 42 43 COMPOSITE WALL PANELS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Fiber-cement wall panel system and accessories with drainable and back-ventilated rainscreen assembly.

1.02 RELATED REQUIREMENTS

- A. Section 07 25 00 - Weather Barriers and 07 27 00 - Air Barriers.
- B. Section 07 62 00 - Sheet Metal Flashing and Trim.
- C. Section 09 91 13 - Exterior Painting.

1.03 REFERENCE STANDARDS

- A. AAMA 509 - Voluntary Test and Classification Method for Drained and Back Ventilated Rainscreen Wall Cladding Systems.
- B. ASTM B221 - Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes.
- C. ASTM C920 - Standard Specification for Elastomeric Joint Sealants.
- D. ASTM C1186 - Standard Specification for Flat Fiber-Cement Sheets.
- E. ASTM D1929 - Standard Test Method for Determining Ignition Temperature of Plastics.
- F. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials.
- G. ASTM E119 - Standard Test Methods for Fire Tests of Building Construction and Materials.
- H. NFPA 268 - Standard Test Method for Determining Ignitability of Exterior Wall Assemblies Using a Radiant Heat Energy Source.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide manufacturer's data sheets on each product.
- C. Shop Drawings: Indicate layout, panel locations, and configuration.
 - 1. Indicate size, spacing, and location of support and attachment components, connections, and types and locations of fasteners.
 - 2. Indicate necessary provisions for structural and thermal movement between wall panel system and adjacent materials.
 - 3. Indicate locations and sizes of penetrations through wall panel system for Architect's approval.
- D. Samples: Submit two samples of each style and color panel, 12 by 12 inches in size and showing finish color, sheen, and texture.

- E. Manufacturer's Instructions: Include instructions for storage, handling, preparation, and product installation.
- F. Maintenance Data: Periodic inspection recommendations and maintenance procedures.
- G. Executed panel manufacturer's warranty.
- H. Executed installation warranty.

1.05 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing products specified in this section, with at least ten years of documented experience.
- B. Installer Qualifications: Company specializing in performing work of the type specified in this section with minimum three years of documented experience and approved by manufacturer.

1.06 MOCK-UPS

- A. See Section 01 40 00 - Quality Requirements for additional requirements.
- B. Construct mock-up of each panel type, 12 feet long by 12 feet wide. Include panel materials, flashings, weep drainage system, attachments, anchors, trim and termination accessories, and perimeter sealant.
- C. Locate where directed.
- D. Mock-up may remain as part of work.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. See Section 01 74 19 - Construction Waste Management and Disposal for packaging waste requirements.
- B. Deliver and store materials with labels intact in manufacturer's unopened packaging until ready for installation.
- C. Store products under waterproof cover, well ventilated, and elevated above grade on flat surface.
- D. Protect materials from harmful environmental elements, construction dust, direct sunlight, and other potentially detrimental conditions.

1.08 FIELD CONDITIONS

- A. Do not install panels when air temperature or relative humidity are outside manufacturer's limits.

1.09 WARRANTY

- A. See Section 01 78 00 - Closeout Submittals for additional warranty requirements.
- B. Manufacturer Warranty: Provide 2-year manufacturer warranty for panels. Complete forms in District's name and register with manufacturer.
 - 1. Product Performance: 50 YEAR LIMITED WARRANTY – The Product shall not incur structural cracking, rot or delaminate under normal use and wear and shall resist damage caused by termites for a period of 50 years under normal use.

- C. Installation Warranty for Building Rainscreen Assembly: Provide 10-year warranty including, but not limited to, defective materials and workmanship, labor, and removal of materials to effect repairs and restore to watertight conditions.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Cembrit, distributed by American Fiber Cement Corporation:
www.americanfibercement.com/#sle.
- B. EQUITONE Inc.; Fibre Cement Panels: www.equitone.com
- C. KMEW USA Inc.; CERACLAD: www.ceraclad.com.
 - 1. ICC ESR-1627.
- D. Nichiha USA, Inc: www.nichiha.com/#sle.
- E. Swisspearl: www.swisspearl.com/#sle.
- F. Substitutions: See Section 01 60 00 - Product Requirements.

2.02 COMPOSITE WALL PANELS

- A. Panels: Complying with ASTM C1186 Type A.
 - 1. Material: Fire-retardant solid phenolic panels with standard brown core comprised of kraft paper harvested from FSC certified forests and thermosetting resins. Dry Formed (DF) or Natural Fiber Core (NFC) products will not be accepted.
 - 2. Design Wind Loads: Comply with requirements of ASCE 7.
 - 3. Surface Burning Characteristics: Class A, Maximum flame spread index of 10 and maximum smoke developed index of 450 when tested in accordance with ASTM E84.
 - 4. Ignition Characteristics: Wall panel siding system shall not ignite when tested according to NFPA 268.
 - a. Ignition Temperature: Greater than 650 degrees Fahrenheit above ambient, ASTM D1929.
- B. Material: Fire-retardant solid phenolic panels with standard brown core comprised of kraft paper harvested from FSC certified forests and thermosetting resins. Dry Formed (DF) or Natural Fiber Core (NFC) products will not be accepted.
- C. Rainscreen Assembly: Ventilated cavity formed by back of panels and water-resistive barrier. Provide positive drainage to exterior from moisture entering or condensation occurring within panel system.
 - 1. Drained and Back-Ventilated Rainscreen System Classification: V1/W1 when tested in accordance with AAMA 509.
 - 2. Fire-Resistance Rating: Determined in accordance with test procedures ASTM E119.
- D. Smooth Panel Style: Simulated flat metal or phenolic panel appearance.
 - 1. Maximum Height: 48 inches.
 - 2. Maximum Length: 120 inches.
 - 3. Thickness: 5/16 inch.

4. Panel Orientation: As indicated on drawings.
5. Surface Texture: Smooth, sanded, brushed sheen.
6. Color: As indicated on drawings.
 - a. Panel Core: Brown.
7. Panels specifically designed for exterior rainscreen wall applications. Fabricated panels shall comply with all current codes and regulations for the Project. Panels shall have uniform thickness (+0.03") and flatness (maximum difference of 0.03") for a 10 foot span.
 - a. Fabricate panels with a minimum of 1mm micro bevel on the exposed face.
8. Non-porous homogenous surface and edges which do not require sealing after cutting or drilling.

2.03 ACCESSORIES

- A. Concealed Clip System: Manufacturer's standard system consisting of starter tracks, panel clips, corner clips, sealant backers, and spacers.
- B. Furring Strips: Galvanized metal channels.
- C. Trim: Same material and texture as panel.
- D. Metal Trim: Extruded aluminum, ASTM B221.
 1. Dimension and Layout: As indicated on drawings.
 2. Aluminum Joint Closures and Decorative Corner Profiles: Manufacturer's standard products as detailed. Maximum thickness of non structural finishing profile to be 0.8 mm or 21 gauge.
 3. Finish: Powder coating.
 4. Color: As selected by Architect.
- E. Perforated Insect/Vermin Screen: Manufacturer's standard.
- F. Flashing: Manufacturer's standard sheet aluminum; finish and color to match wall panels.
- G. Exterior Soffit Vents: One piece, aluminum, ASTM B221.
- H. Sealant: ASTM C920, Class 35, elastomeric, polyurethane or silyl-terminated polyether/polyurethane, and capable of being painted.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Examine substrate; clean and repair as required to eliminate conditions detrimental to proper installation.
- B. Verify that water-resistive barrier has been properly installed and approved.
- C. Do not begin installation until unacceptable conditions have been corrected.

3.02 PREPARATION

- A. Touch up field cut edges before installing.

- B. Protect surrounding areas and adjacent surfaces from damage during execution of this work.

3.03 INSTALLATION

- A. Install cladding in accordance with manufacturer's installation instructions and approved shop drawings.
- B. Wall Panels:
 - 1. Install in accordance with manufacturer's instructions.
 - 2. Install wall panels with manufacturer's recommended concealed attachment system.
 - 3. Do not install wall panels less than 6 inches above surface of ground or closer than 1 inch to surfaces where water may collect.
 - 4. Allow space for thermal movement at ends of wall panels that butt against trim; seal joint between panel and trim.
- C. Install control and expansion joints as detailed on drawings.
 - 1. Vertical Joints: Install at locations and with spacings recommended by wall panel manufacturer.
 - 2. Horizontal/Compression Joints: Install at locations and with spacings recommended by wall panel manufacturer.
 - a. Steel Framed Buildings: At walls higher than 45 feet or more than three floors, install compression joint at each floor line and spaced at not more than of 25 feet vertically.
- D. Exterior Soffit Vents: Install according to manufacturer's instructions and in locations indicated on drawings.
- E. After installation, seal joints. Include joints around penetrations and between wall panels and adjacent construction.
- F. Paint exposed cut edges.

3.04 CLEANING

- A. See Section 01 70 00 - Execution and Closeout Requirements for additional requirements.
- B. Clean exposed work upon completion of installation; remove grease and oil films, excess joint sealer, handling marks, and debris. Leave work clean, unmarked, and free from dents, creases, waves, scratch marks, or other damage to finish.

3.05 PROTECTION

- A. Protect installed products until Date of Final Inspection.

END OF SECTION

SECTION 07 54 00 THERMOPLASTIC MEMBRANE ROOFING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Adhered system with thermoplastic roofing membrane.
- B. Insulation, tapered.
- C. Flashings.
- D. Roofing stack boots and walkway pads.

1.02 RELATED REQUIREMENTS

- A. Section 06 10 00 - Rough Carpentry.
- B. Section 07 01 50.20 - Roofing, Restoration, Patch, and Repair.
- C. Division 26 - Electrical: Conduit penetrating roofing membrane.

1.03 REFERENCE STANDARDS

- A. ASTM C1289 - Standard Specification for Faced Rigid Cellular Polyisocyanurate Thermal Insulation Board.
- B. ASTM D4434/D4434M - Standard Specification for Poly(Vinyl Chloride) Sheet Roofing.
- C. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials.
- D. ASTM E1980 - Standard Practice for Calculating Solar Reflectance Index of Horizontal and Low-Sloped Opaque Surfaces.
- E. FM DS 1-28 - Wind Design.
- F. NRCA (RM) - The NRCA Roofing Manual.
- G. NRCA (WM) - The NRCA Waterproofing Manual.
- H. UL (FRD) - Fire Resistance Directory.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Preinstallation Meeting: Convene one week before starting work of this section.
 - 1. Review preparation and installation procedures and coordinating and scheduling required with related work.
 - 2. Notification: Two weeks prior to pre-application conference, inform District and Architect of scheduled roofing beginning and completion dates, such that District may arrange for independent inspection of roofing Work, and presence of independent testing and inspection agency at pre-application conference.
 - 3. Attendance: Require attendance by Contractor's superintendent and other supervisory and quality control personnel having responsibility for roofing, supervisory personnel of roofing applicator and, if required for warranty provisions, representative of roofing products manufacturer.

FOR REFERENCE ONLY

- a. DSA, Architect's insurer, independent testing and inspection agency and Architect, if authorized by District, will attend.
- b. Require attendance of installers of each component of related Work, including deck or substrate construction, rigid insulation, metal flashing, rooftop equipment, penetrations of roof deck, and other Work integral with or adjacent to roofing may attend.
- c. If required, attendance shall include authorities having jurisdiction. Contractor shall verify requirement with authorities having jurisdiction and arrange for attendance.
- d. Agenda:
 - 1) Meeting purpose is to review Drawings and Specifications for suitability for application of roofing system.
 - 2) Review application procedures and coordination required with related Work. Discuss changes and deviations from Drawings and Specifications, if any, recommended or required.
 - 3) Walk roof areas to review and discuss substrate preparation including repair of unacceptable surfaces, roof drainage, penetrations, equipment curbs, and work performed by other trades, which require coordination with roofing system installer.
 - 4) Review contract document requirements and submittals for roofing system, including roofing schedule, inspection and testing, and environmental conditions. Identify which governing regulations or insurance requirements will affect roofing system installation.
 - 5) Discuss anticipated weather, as well as procedures for responding to unacceptable weather, including using temporary roofing. Temporary roofing, if necessary, will be added to scope of the Work by contract modification (change order or construction change directive), with acceptable adjustment in Contract Time and Contract Sum.
 - 6) Document discussions in writing, including actions required, and distribute copy of report to each meeting participant.
 - 7) Attendance by DSA, Architect and independent testing and inspection agency shall not relieve Contractor of sole responsibility for means, methods, techniques and sequence of construction, in accordance with provisions of the Conditions of the Contract.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide data indicating membrane materials, flashing materials, insulation, surfacing, and fasteners.
- C. Shop Drawings: Submit drawings that indicate joint or termination detail conditions, conditions of interface with other materials, and setting plan for tapered insulation.
- D. Manufacturer's Certificate: Certify that products meet or exceed specified requirements.
- E. Manufacturer's Installation Instructions: Indicate membrane seaming precautions and perimeter conditions requiring special attention.

- F. Manufacturer's Field Reports: Indicate procedures followed, ambient temperatures, humidity, wind velocity during application, and supplementary instructions given.
- G. Manufacturer's qualification statement.
- H. Installer's qualification statement.
- I. Specimen Warranty: For approval.
- J. Warranty Documentation:
 - 1. Submit manufacturer warranty and ensure that forms have been completed in District's name and registered with manufacturer.
 - 2. Submit installer's written verification that installation complies with warranty conditions for waterproof membrane.

1.06 QUALITY ASSURANCE

- A. Contractor to review all roofing details prior to bid. Submittal of bid per contract documents shall be guarantee that roofing will be installed and warrantied as shown on contract documents. Any detail revisions initiated by roofing contractor or manufacturer will be implemented at Contractor's cost.
- B. Manufacturer Qualifications: Company specializing in manufacturing products specified in this section with minimum twenty years of documented experience.
- C. Installer Qualifications: Company specializing in performing work of this section with at least three years of documented experience.
- D. Industry Standards:
 - 1. Conform to manufacturer's product data and application instructions.
 - 2. Perform work in accordance with NRCA (RM) and NRCA (WM) and and Western States Roofing Contractors Association (WSRCA).
 - a. Maintain one copy on site.
- E. Testing and Inspection:
 - 1. District's independent inspection and testing agency will perform inspections and tests of roofing work.
 - 2. Costs of this service will be paid for by District.
 - 3. Contractor shall cooperate with independent testing and inspection agency.
 - 4. Refer to general requirements specified in Section 01 40 00 - Quality Requirements and 01 45 33 - Code-Required Special Inspections.
- F. Private label and third-party-manufactured membranes are not permitted.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. See Section 01 74 19 - Construction Waste Management and Disposal for packaging waste requirements.
- B. Deliver materials in manufacturer's original containers, dry and undamaged, with seals and labels intact, unless otherwise indicated.
- C. Store materials in weather protected environment, clear of ground and moisture.

- D. Ensure storage and staging of materials does not exceed static and dynamic load-bearing capacities of roof decking.
- E. Protect foam insulation from direct exposure to sunlight.

1.08 FIELD CONDITIONS

- A. Do not apply roofing membrane during unsuitable weather.
- B. Do not apply roofing membrane when ambient temperature is below 40 degrees F or above 95 degrees F.
- C. Do not apply roofing membrane to damp or frozen deck surface or when precipitation is expected or occurring.
- D. Do not expose materials vulnerable to water or sun damage in quantities greater than can be weatherproofed the same day.
- E. Schedule applications so that no partially completed sections of roof are left exposed at end of workday.
 - 1. Provide temporary roof membrane if necessary to protect portions of the Work before final roofing can be installed.
 - a. Record by way of change order the District's agreement to proceed with temporary roofing, along with additional costs and other changes (if any) to Contract Documents.
 - b. Remove temporary roofing before starting installation of final roofing system.
- F. Arrange work sequence to avoid use of newly constructed roofing as a walking surface or for equipment movement and storage.
 - 1. Provide all necessary protection and barriers to segregate the work area and to prevent damage to adjacent areas.
 - 2. Provide a substantial protection layer consisting of plywood over felt or plywood over insulation board for all new and existing roof areas that receive rooftop traffic during construction.

1.09 WARRANTY

- A. See Section 01 78 00 - Closeout Submittals for additional warranty requirements.
- B. System Warranty: Provide manufacturer's system warranty agreeing to repair or replace roofing that leaks or is damaged due to wind or other natural causes.
 - 1. Warranty Term: 20 years.
 - a. Provide a written guarantee signed by the manufacturer's authorized official, agreeing to correct failures in product and installation, with no dollar limit on such corrections, for the noted warranty term from date established in Notice of Completion.
 - 2. Include insulation and flashing as part of the roofing system and all other manufacturer supplied system components to be used as part of the roofing assembly..
 - 3. For repair and replacement include costs of both material and labor in warranty.
 - 4. Exceptions are not Permitted:

- a. Damage due to roof traffic.
 - b. Damage due to wind speed up 74 mph.
 - c. Damage due to ponding water; assign no time limit for any such ponding water during the warranty period.
 - d. Roof system maintenance.
- C. Applicator/Roofing Contractor Warranty:
1. Applicator to supply the District with a separate five-year workmanship warranty.
 2. In the event any work related to roofing, flashing, or associated metal is found to be within the Applicator warranty term, defective or otherwise not in accordance with the Contract Documents, the Applicator shall repair that defect at no cost to the District.
 3. The Applicator's warranty obligation shall run directly to the District, and a copy shall be sent to the manufacturer.
- D. Manufacturer Inspection Services: By manufacturer's technical representative, to report maintenance responsibilities to Owner necessary for preservation of Owner's warranty rights. The cost of manufacturer's inspections is included in the Contract Sum.
1. Inspections to occur in following years: 2, 5, 10, and 15 following completion.
 2. Inspections include rooftop housekeeping, including removal of incidental debris (such as leaves, branches, paper and similar items) from the roof membrane and drainage areas such as gutters. All debris will be disposed of at the Owner's approved on-site location.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Thermoplastic Polyolefin (TPO) Membrane Roofing Materials:
1. Tremco, Inc.: www.tremco.com.
 2. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Thermoplastic Polyvinyl Chloride (PVC) Membrane Roofing Materials:
1. District Standard Basis of Design Product: Thermoplastic PVC/TPA Roof Membrane sheet as manufactured by Tremco, or approved equal.
 2. Tremco, Inc.; TPA: www.tremco.com.
 3. Substitutions: See Section 01 60 00 - Product Requirements.
- C. Insulation:
1. Insulation manufacturer as part of the tested and warrantable roofing system membrane assembly.
 2. Substitutions: See Section 01 60 00 - Product Requirements.

2.02 PERFORMANCE REQUIREMENTS

- A. General: Provide installed roofing membrane and base flashings that remain watertight; do not permit the passage of water; and resist specified uplift pressures, thermally induced movement, and exposure to weather without failure.

- B. Material Compatibility: Provide roofing materials that are compatible with one another under conditions of service and application required, as demonstrated by roofing manufacturer based on testing and field experience.

2.03 ROOFING - UNBALLASTED APPLICATIONS

- A. Thermoplastic Membrane Roofing: One ply membrane, fully adhered, over vapor retarder and insulation.
- B. Roof Assembly: (from the top down)
 - 1. Typical assembly:
 - a. Roofing Membrane
 - b. Tapered Insulation layers for crickets.
 - c. Roof deck.
- C. Roofing Assembly Requirements:
 - 1. Solar Reflectance Index (SRI): 78, minimum, calculated in accordance with ASTM E1980.
 - a. Field applied coating may not be used to achieve specified SRI.
 - 2. Roof Covering External Fire Resistance Classification: UL (FRD) Class A.
 - 3. Factory Mutual Classification: Class 1 and windstorm resistance of 1-90, in accordance with FM DS 1-28.
- D. Acceptable Insulation Types - Tapered Application: Any of types specified.
 - 1. Tapered polyisocyanurate board.

2.04 MEMBRANE ROOFING AND ASSOCIATED MATERIALS

- A. Membrane Roofing Materials:
 - 1. PVC: Polyvinyl chloride (PVC) complying with ASTM D4434/D4434M, Type IV, sheet contains reinforcing fibers or reinforcing fabrics.
 - a. Thickness: 60 mil, 0.060 inch, minimum.
 - b. Backing: 9 oz. Feltback fabricated as part of the membrane.
 - 2. Sheet Width:
 - a. Adhered Application: Limit width to 120 inches, maximum, when ambient temperatures are less than 40 degrees F for extended period of time during installation.
 - 3. Solar Reflectance: 0.70, minimum, initial, and 0.65, minimum, 3-year, certified by Cool Roof Rating Council.
 - 4. Thermal Emissivity: 0.80, minimum, initial, and 0.79, minimum, 3-year, certified by Cool Roof Rating Council.
 - 5. Color: White, integral.
- B. Seaming Materials: As recommended by membrane manufacturer.
- C. Flexible Flashing Material: Same material as membrane.

2.05 INSULATION

- A. Comply with CBC Section 720 and Chapter 26.
 - 1. Flame Spread Index (FSI): Class A - 0 to 25, when tested in accordance with ASTM E84.
 - 2. Smoke Developed Index (SDI): 450 or less, when tested in accordance with ASTM E84.
- B. Polyisocyanurate (ISO) Board Insulation: Rigid cellular foam, complying with ASTM C1289.
 - 1. Classifications:
 - a. Type II: Faced with either cellulosic facers or glass fiber mat facers on both major surfaces of the core foam.
 - 1) Class 1 - Faced with glass fiber reinforced cellulosic facers on both major surfaces of the core foam.
 - 2) Compressive Strength: Classes 1-2-3, Grade 3, 25 psi (172 kPa), minimum.
 - 3) Thermal Resistance, R-value: At 1-1/2 inches thick; Class 1, Grades 1-2-3, 8.4 (1.48), minimum, at 75 degrees F.
 - 2. Board Size: 48 by 96 inches.
 - 3. Board Thickness: 2.0 inches maximum.
 - 4. Tapered Board: Slope as indicated; minimum thickness 1/2 inch; fabricate of fewest layers possible.
 - 5. Board Edges: Square.
 - 6. Products:
 - a. DuPont de Nemours, Inc: building.dupont.com/#sle.
 - b. GAF; EnergyGuard Polyiso Insulation: www.gaf.com/#sle.
 - c. Rmax Inc.; ECOMAXci: www.rmax.com.
 - d. Substitutions: See Section 01 60 00 - Product Requirements.

2.06 ACCESSORIES

- A. Clad Metal Flashing:
 - 1. Description: Membrane-coated, heat-weldable sheet metal capable of being formed into a variety of shapes and profiles.
 - 2. Materials: 24 gauge, G90 galvanized metal sheet with a 20 mil unsupported roofing membrane laminated on one side.
 - 3. Color: Clad metal to match roofing membrane.
- B. Stack Boots: Prefabricated flexible boot and collar for pipe stacks through membrane; same material as membrane.
- C. Insulation Joint Tape: Glass fiber reinforced type as recommended by insulation manufacturer, compatible with roofing materials; 6 inches wide; self adhering.
- D. Insulation Fasteners: Appropriate for purpose intended and approved by roofing manufacturer.
 - 1. Length as required for thickness of insulation material and penetration of deck substrate, with metal washers.

- E. Membrane Adhesive: As recommended by membrane manufacturer.
- F. Surface Conditioner for Adhesives: Compatible with membrane and adhesives.
- G. Thinners and Cleaners: As recommended by adhesive manufacturer, compatible with membrane.
- H. Insulation Adhesive: As recommended by insulation manufacturer.
- I. Strip Reglet Devices: Galvanized steel, maximum possible lengths per location, with attachment flanges.
- J. Insulation Perimeter Restraint: As required for wind rating. Stainless steel edge device configured to restrain insulation boards in position and provide top flashing over ballast.
- K. Sealants: As recommended by membrane manufacturer.
- L. Walkway Pads: Suitable for maintenance traffic, contrasting color or otherwise visually distinctive from roof membrane.
 - 1. Composition: Roofing membrane manufacturer's standard.
 - 2. Size: Manufacturer's standard size.
 - 3. Surface Color: White or Yellow.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that surfaces and site conditions are ready to receive work.
- B. Verify deck is supported and secure.
- C. Verify deck is clean and smooth, flat, free of depressions, waves, or projections, properly sloped and suitable for installation of roof system.
- D. Verify deck surfaces are dry and free of snow or ice.
- E. Verify that roof openings, curbs, and penetrations through roof are solidly set, and cant strips are in place.

3.02 PREPARATION - WOOD DECK

- A. Composition:
 - 1. FM Approved Wood Deck: Minimum 2 inch thick lumber or 3/4 inch thick treated plywood.
 - a. Conform deck to FM requirements for Class 1 fire-retardant and rot-resistant wood.
 - b. Install deck according to FM and local code requirements.
 - 2. Non-FM Approved Wood Deck: Minimum 1-1/2 inch thick lumber or 15/32 inch thick plywood.
 - a. Install deck according to local code requirements.
 - b. Contact Manufacturer's Technical support for fastening patterns and methods.
- B. Verify flatness and tightness of joints in wood decking; fill knot holes with latex filler.
- C. Confirm dry deck by moisture meter with 12 percent moisture maximum.

3.03 INSTALLATION, GENERAL

- A. Perform work in accordance with manufacturer's instructions, NRCA (RM), and NRCA (WM) applicable requirements.
- B. Do not apply roofing membrane during cold or wet weather conditions.
- C. Do not apply roofing membrane when ambient temperature is outside the temperature range recommended by manufacturer.
- D. Do not apply roofing membrane to damp or frozen deck surface or when precipitation is expected or occurring.
- E. Do not expose materials vulnerable to water or sun damage in quantities greater than can be weatherproofed the same day.
- F. Coordinate this work with installation of associated counterflashings installed by other sections as the work of this section proceeds.

3.04 INSTALLATION - INSULATION, UNDER MEMBRANE

- A. Install vapor retarder to deck surface with adhesive in accordance with manufacturer's instructions.
 - 1. Extend vapor retarder under cant strips and blocking to deck edge.
 - 2. Install flexible flashing from vapor retarder to air seal material of wall construction, lap and seal to provide continuity of the air barrier plane.
- B. Attachment of Insulation: Embed each layer of insulation in adhesive in full contact, in accordance with roofing and insulation manufacturers' instructions.
- C. Lay subsequent layers of insulation with joints staggered minimum 6 inches from joints of preceding layer.
- D. Place tapered insulation to the required slope pattern in accordance with manufacturer's instructions.
- E. Lay boards with edges in moderate contact without forcing. Cut insulation to fit neatly to perimeter blocking and around penetrations through roof.
- F. Tape joints of insulation in accordance with roofing and insulation manufacturers' instructions.
- G. At roof drains, use factory-tapered boards to slope down to roof drains over a distance of 18 inches.
- H. Do not install more insulation than can be covered with membrane in same day.

3.05 INSTALLATION - MEMBRANE

- A. Roll out membrane, free from wrinkles or tears. Place sheet into place without stretching.
- B. Shingle joints on sloped substrate in direction of drainage.
- C. Fully Adhered Application: Apply adhesive to substrate at rate of 0.69 gallons per square foot. Fully embed membrane in adhesive except in areas directly over or within 3 inches of expansion joints. Fully adhere one roll before proceeding to adjacent rolls.
- D. Overlap edges and ends and seal seams by contact adhesive, minimum 3 inches. Seal permanently waterproof. Apply uniform bead of sealant to joint edge.
- E. At intersections with vertical surfaces:

FOR REFERENCE ONLY

1. Extend membrane over cant strips and up a minimum of 8 inches onto vertical surfaces.
 2. Fully adhere flexible flashing over membrane and up to nailing strips.
 3. Secure flashing to nailing strips at 4 inches on center.
 4. Insert flashing into reglets and secure.
- F. At gravel stops, extend membrane under gravel stop and to the outside face of the wall.
- G. Around roof penetrations, seal flanges and flashings with flexible flashing.
- H. Coordinate installation of roof drains and sumps and related flashings.

3.06 TEMPORARY CUT OFF

- A. Install flashings concurrently with the roof membrane in order to maintain a watertight condition as the work progresses.
1. Construct all temporary waterstops to provide a 100% watertight seal.
 2. Make staggered insulation joints even by installing partial panels of insulation.
 3. Carry new membrane into the waterstop.
 4. Seal waterstop to the deck and/or substrate so that water will not be allowed to travel under the new or previous roofing.
 5. Seal the edge of the membrane in a continuous heavy application of sealant as described in Part 2 above.
 6. When work resumes, cut out the contaminated membrane.
 - a. Remove all sealant, contaminated membrane, insulation fillers, etc.; from the work area and properly disposed of off site.
 - b. Do not use these materials in the new work.
- B. If inclement weather occurs while a temporary waterstop is in place, provide the labor necessary to monitor the situation to maintain a watertight condition.
- C. If any water is allowed to enter under the newly-completed roofing, remove and replace the affected area at Applicator's expense

3.07 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements for additional requirements.
- B. District will provide testing services, and Contractor to provide temporary construction and materials for testing in accordance with requirements.
- C. Provide daily on-site attendance of roofing manufacturer's representative during installation of this work.
1. Provide regular daily written reports to the Contractor and Architect for every day of roofing installation work.
 2. Provide to Architect a written on-site approval by the roofing system manufacturer and sign-off on pre-roofing deck, insulation installation, membrane installation, flashing details and completed assembly.
 3. Provide to Architect a Project Closeout Report by the roofing system manufacturer upon delivery of the project warranty. This report shall include the following sections:

- a. Project Specifications.
 - b. Project Summary.
 - c. Progress reports as a result of roof inspections.
 - d. Job progress photos.
 - e. Warranty document with Maintenance Manual describing maintenance and emergency repair.
- D. Roofing Inspection and Testing Services by Independent Agency: District's independent agency will provide inspection and testing services during application of roofing system.
1. Unless otherwise directed, inspection, including test cuts and evaluation procedures, will be performed in accordance with Chapter V, "Quality Control," of The NRCA Low-Slope Roofing Manual.
 2. Independent agency will provide reports of inspections and tests to DSA and Architect. Copies of reports will also be provided to Contractor.
 3. Water Test: Conduct simulated rain storm test by indirect spray of water for 15 minutes over entire roof surface. Check area below roofing for leaks and check top surface for standing water.
 - a. Record test and inspection by video tape or digital recording.
 4. Remedial Work: Correct all defects and irregularities reported from inspections and tests, at no change in Contract Sum or Contract Time.

3.08 CLEANING

- A. See Section 01 70 00 - Execution and Closeout Requirements for additional requirements.
- B. Remove bituminous markings from finished surfaces.
- C. In areas where finished surfaces are soiled by work of this section, consult manufacturer of surfaces for cleaning advice and comply with their documented instructions.
- D. Repair or replace defaced or damaged finishes caused by work of this section.

3.09 PROTECTION

- A. Protect installed roofing and flashings from construction operations.
- B. Where traffic must continue over finished roof membrane, protect surfaces using durable materials.

END OF SECTION

SECTION 07 62 00 SHEET METAL FLASHING AND TRIM

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Fabricated sheet metal items, including flashings, counterflashings, gutters, and downspouts.
- B. Sealants for joints within sheet metal fabrications.
- C. Sheet metal splash pans.

1.02 RELATED REQUIREMENTS

- A. Section 07 25 00 - Weather Barriers: Flexible flashing.
- B. Division 7 - Thermal and Moisture Protection: Roofing system.
- C. Section 09 91 13 - Exterior Painting: Field painting.

1.03 REFERENCE STANDARDS

- A. AAMA 2605 - Voluntary Specification, Performance Requirements and Test Procedures for Superior Performing Organic Coatings on Aluminum Extrusions and Panels (with Coil Coating Appendix).
- B. ASTM A653/A653M - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process.
- C. ASTM B32 - Standard Specification for Solder Metal.
- D. ASTM C920 - Standard Specification for Elastomeric Joint Sealants.
- E. ASTM D1970/D1970M - Standard Specification for Self-Adhering Polymer Modified Bituminous Sheet Materials Used as Steep Roofing Underlayment for Ice Dam Protection.
- F. ASTM D2240 - Standard Test Method for Rubber Property--Durometer Hardness.
- G. ASTM D3161/D3161M - Standard Test Method for Wind Resistance of Steep Slope Roofing Products (Fan-Induced Method).
- H. ASTM D412 - Standard Test Methods for Vulcanized Rubber and Thermoplastic Elastomers--Tension.
- I. ASTM D4586/D4586M - Standard Specification for Asphalt Roof Cement, Asbestos-Free.
- J. ASTM D638 - Standard Test Method for Tensile Properties of Plastics.
- K. ASTM D792 - Standard Test Methods for Density and Specific Gravity (Relative Density) of Plastics by Displacement.
- L. SMACNA (ASMM) - Architectural Sheet Metal Manual.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Preinstallation Meeting: Convene one week before starting work of this section.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Shop Drawings: Indicate material profile, jointing pattern, jointing details, fastening methods, flashings, terminations, and installation details.
- C. Samples: Submit two samples 6 x 6 inch in size illustrating metal finish color.

1.06 QUALITY ASSURANCE

- A. Perform work in accordance with SMACNA (ASMM) requirements and standard details, except as otherwise indicated.
- B. Maintain one copy of each document on site.
- C. Fabricator and Installer Qualifications: Company specializing in sheet metal work with five years of documented experience.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. See Section 01 74 19 - Construction Waste Management and Disposal for packaging waste requirements.
- B. Stack material to prevent twisting, bending, and abrasion, and to provide ventilation. Slope metal sheets to ensure drainage.
- C. Prevent contact with materials that could cause discoloration or staining.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Sheet Metal Flashing and Trim:
 - 1. Hickman Edge Systems; Permashnap & Permasnap Plus:
www.hickmanedgesystems.com/#sle.
 - 2. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Exterior Penetration Flashing Panel:
 - 1. Quickflash Weatherproofing Products, Inc: www.quickflashproducts.com/#sle.

2.02 SHEET MATERIALS

- A. Galvanized Steel: ASTM A653/A653M, with G90/Z275 zinc coating; minimum 24-gauge, 0.0239-inch thick base metal.
- B. Pre-Finished Galvanized Steel: ASTM A653/A653M, with G90/Z275 zinc coating; minimum 24-gauge, 0.0239-inch thick base metal, shop pre-coated with PVDF coating.
 - 1. Polyvinylidene Fluoride (PVDF) Coating: Superior performing organic powder coating, AAMA 2605; multiple coat, thermally cured fluoropolymer finish system.
 - 2. Color: As selected by Architect from manufacturer's custom colors.

2.03 FABRICATION

- A. Form sections true to shape, accurate in size, square, and free from distortion or defects.

FOR REFERENCE ONLY

1. Coping and Cap Flashing:
 - a. Coping and caps of type and profile indicated on Drawings, 20 gage galvanized sheet metal, with integral expansion.
2. Drips at Doors and Windows:
 - a. Provide 20 gage galvanized sheet metal drips at head of all exterior doors and windows where no roof or overhang protection occurs.
 - b. Extend drips 2 inches beyond jambs, unless noted otherwise.
- B. Perimeter metal blocking system:
 1. Basis of Design Product: EdgeBox RI as manufactured by Hickman Edge Systems, or equal.
 2. Two-piece assembly shall be fabricated from 20 Ga. galvanized steel with pre-punched fastener holes. The bottom section is attached to the metal deck with the provided mechanical fasteners. No slots are necessary for use with rigid insulation. Install per manufacturer's written instructions.
- C. Fabricate cleats of same material as sheet, minimum 4 inches wide, except at continuous strips, interlocking with sheet.
 1. Typically use continuous strips.
- D. Form pieces in longest possible lengths.
- E. Hem exposed edges on underside 1/2 inch; miter and seam corners.
- F. Form material with flat lock seams, except where otherwise indicated; at moving joints, use sealed lapped, bayonet-type or interlocking hooked seams.
 1. Typical Seams: Overlapped and sealed seams.
 2. Coping Seams: Lock seams, flattened.
 3. Seams, Horizontal to Vertical Transitions: Solder joints.
 4. Soldered seams: Tin edges to be seamed, form seams, and solder.
- G. Fabricate corners from one piece with minimum 18-inch long legs; seam for rigidity, seal with sealant.
- H. Fabricate vertical faces with bottom edge formed outward 1/4 inch and hemmed to form drip.
- I. Fabricate flashings to allow toe to extend 2 inches over roofing gravel. Return and brake edges.

2.04 GUTTERS AND DOWNSPOUTS

- A. Gutters: SMACNA (ASMM) Rectangular profile.
- B. Downspouts: Profile as indicated.
 1. Steel Pipe Downspouts: See section 05 50 00 - Metal Fabrications.
 - a. Provide steel pipe downspouts where indicated. Fabricate from galvanized, Schedule 40 steel pipe or tube of sizes indicated. Weld joints and grind smooth. Shop prime with zinc-rich primer for field painting.
 - b. Provide necessary transitions from steel pipe to gage metal roof gutters and gutter outlets.

- c. Hold downspouts in position 1 inch clear of walls with galvanized steel straps at spacing indicated, securely fastened to wall.
 - 1) Provide heavy duty mounting bracket hardware for attachment to structural steel.
- C. Scuppers and Overflows: 24 gage galvanized sheet metal, as indicated on Drawings and complying with referenced SMACNA Manual Figure number. Fabricate with minimum 6 inch flanges.
- D. Gutters and Downspouts: Size indicated.
- E. Accessories: Profiled to suit gutters and downspouts.
 - 1. Anchorage Devices: In accordance with SMACNA (ASMM) requirements.
 - 2. Gutter Supports: Straps.
 - 3. Downspout Supports: Straps.
 - 4. Strainers 10 gage galvanized steel wire basket type, riveted and soldered into place.
- F. Splash Pans: Same metal type as downspouts, formed to 12 x 18 inches size; rolled sides of 1 inch high for inverted pan placement.
- G. Splash Pads: Precast concrete type, of size and profiles indicated; minimum 3,000 psi at 28 days, with minimum 5 percent air entrainment.
- H. Downspout Boots: Steel.
- I. Downspout Extenders: Same material and finish as downspouts.
- J. Seal metal joints.

2.05 EXTERIOR PENETRATION FLASHING PANELS

- A. Flashing Panels for Exterior Wall Penetrations: Premanufactured components and accessories as required to preserve integrity of building envelope; suitable for conduits and facade materials to be installed.
- B. Basis of Design Product: Quickflash Weatherproofing Flashing Panels as manufactured by Quickflash Weatherproofing Products, Inc., www.quickflashproducts.com, or equal.
- C. Coordinate with each trade to provide specific models correctly sized for each individual pipe, duct, conduit, box, or panel penetration in each application as occurs in the building envelope.
- D. Plumbing Flashing Panels:
 - 1. Materials:
 - a. Panel: Combination of high-density polyethylene (HDPE) and low-density polyethylene (LDPE).
 - 1) HDPE, Specific Gravity, ASTM D1505: 0.953 g/cm³.
 - 2) HDPE, Tensile Strength at Yield, ASTM D638: 3,100 psi.
 - 3) LDPE, Specific Gravity, ASTM D792: 0.917 g/cm³.
 - 4) LDPE, Tensile Strength at Yield, ASTM D638: 1,300 psi.
 - b. Weatherproof Seal: Thermoplastic elastomer.
 - 1) Hardness, ASTM D2240, Shore A, 10 Seconds: 46.

- 2) Specific Gravity, ASTM D792: 1.05 g/cm³.
 - 3) Tensile Strength, ASTM D412: 490 psi.
- E. Electrical Flashing Panels:
1. Material: Thermoplastic elastomer.
 - a. Hardness, ASTM D2240, Shore A, 10 Seconds: 93.
 - b. Specific Gravity, ASTM D792: 1.05 g/cm³.
 - c. Tensile Strength, ASTM D412: 1,300 psi.

2.06 ACCESSORIES

- A. Fasteners: Galvanized steel, with soft neoprene washers.
- B. Miscellaneous Metal Accessories: Provide sheet metal clips, straps, anchoring devices, and similar accessory units as required for installation of the Work, matching or compatible with material being installed, non-corrosive, size and gage required for performance.
- C. Underlayment: Self-adhesive sheet flexible flashing complying with ASTM D1970/D1970M.
 1. Adhesives: Type recommended by flexible flashing sheet manufacturer for waterproof/weather-resistant seaming and adhesive application of flashing sheet.
- D. Slip Sheet: Rosin-sized sheathing paper.
- E. Primer Type: Zinc chromate.
- F. Concealed Sealants: Non-curing butyl sealant.
- G. Exposed Sealants: ASTM C920; elastomeric sealant, with minimum movement capability as recommended by manufacturer for substrates to be sealed; color to match adjacent material.
 1. Epoxy Seam Sealer: 2-part non-corrosive metal seam cementing compound, recommended by metal manufacturer for exterior/interior non-moving joints including riveted joints.
- H. Asphalt Roof Cement: ASTM D4586/D4586M, Type I, asbestos-free.
- I. Reglets: Surface-mounted type, galvanized steel; face and ends covered with plastic tape.
 1. Reglets:
 - a. Surface-applied, Fry Springlok Flashing System Type SM, or equal.
 - b. Recessed, Fry Springlok Flashing System Type ST, or equal.
 2. Performance Requirements
 - a. Reglet and flashing manufacturer shall certify that the system to be installed has been tested to resist 110 MPH wind loads when tested in accordance with ASTM D3161/D3161M for a minimum period of two hours.
 3. Specified Manufacturer: Fry Reglet Corporation, www.fryreglet.com.
 4. Acceptable Manufacturers:
 - a. O'Keefes, Inc., www.okeefes.com.
 - b. Substitutions: See Section 01 60 00 - Product Requirements.

FOR REFERENCE ONLY

5. Reglets and Flashing, General: Springlok Flashing, as manufactured by Fry Reglet Corporation, or equal, formed metal reglet with snap-in metal counter-flashing, factory-fabricated, with a minimum opening of 1/4 inch and a depth of 1-1/4 inches.
 - a. Reglet material: 24 gage galvanized steel.
 - b. Flashing material: 0.020 inch Type 302 stainless steel.
 - c. End laps: Factory-formed, 1 inch at reglets and 3 inches at flashings.
 - d. Corners: Provide built-up mitered corner pieces for internal and external angles.
 - e. Wind clips: Provide Fry Windlok Clip, sheet metal clips to be secured to wall prior to installing flashing in reglet, and to be bent up over bottom edge of flashing.
6. Accessories:
 - a. Corners: Factory-manufactured, mitered inside and outside corners.
 - b. Splices: Factory-manufactured, integral component of reglet and flashing system.
- J. Solder: ASTM B32, Alloy Grade - Sn50 (50/50).

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify roof openings, curbs, pipes, sleeves, ducts, and vents through roof are solidly set, reglets in place, and nailing strips located.
- B. Verify roofing termination and base flashings are in place, sealed, and secure.

3.02 PREPARATION

- A. Install starter and edge strips, and cleats before starting installation.
- B. Install surface mounted reglets true to lines and levels, and seal top of reglets with sealant.
- C. Back paint concealed metal surfaces with protective backing paint to a minimum dry film thickness of 15 mil, 0.015 inch.

3.03 INSTALLATION

- A. Insert flashings into reglets to form tight fit; secure in place with lead wedges; pack remaining spaces with lead wool; seal flashings into reglets with sealant.
- B. Secure flashings in place using concealed fasteners, and use exposed fasteners only where permitted..
- C. Apply plastic cement compound between metal flashings and felt flashings.
- D. Fit flashings tight in place; make corners square, surfaces true and straight in planes, and lines accurate to profiles.
 1. Counterflashings Installation: Install counterflashing in reglets to form tight fit, either by snap-in seal arrangement or by securing in place with lead wedges spaced 18 inches on center maximum. Pack remaining spaces with lead wool.
 - a. Except where indicated or specified otherwise, insert counterflashing in reglets, extending down vertical surfaces over upturned vertical leg of base flashings not less than 3 inches.

FOR REFERENCE ONLY

- b. Form counterflashings to required shapes before installation.
 - c. Lengths of metal counterflashings shall not exceed 120 inches.
 - d. Where stepped counterflashings are required, counterflashing may be installed in short lengths or may be of the preformed one-piece type.
 - e. Provide factory- or shop-form corners not less than 12 inches from the angle.
 - f. Provide end laps in counterflashings not less than 3 inches and make laps weathertight with sealant.
 - g. Turn up concealed edge of counterflashings built into masonry or concrete walls not less than 1/4 inch and extend not less than 2 inches into wall.
 - h. Fold exposed edges of counterflashings 1/2 inch.
 - i. Install counterflashing to provide a spring action against base flashing.
2. Thru-Wall Flashing:
 - a. Start flashing 1/2 inch behind exposed face of wall and extend through wall.
 - b. Lap-seam joints and seal with sealant.
 - c. Provide sealant around penetrations through flashing.
- E. Seal metal joints watertight.
- F. Secure gutters and downspouts in place with concealed fasteners.
- G. Connect downspouts to downspout boots, and grout connection watertight.
- H. Set splash pans under downspouts. Set in place with adhesive .
- I. Scuppers and Overflows Installation:
 1. Mechanically fasten and solder joints.
 2. Fold outside edges under 1/2 inch on all sides.
 3. Join the bottom edge to closure flange, where necessary, and form ridge to act as a gravel stop around scupper inlet.
 4. Coat interior of scuppers and overflows with bituminous plastic cement.
- J. Metal Flashing at Wall and Roof Penetrations and Equipment Supports:
 1. Exception:
 - a. Roofing: Where single ply system assembly has provided flashing for penetrations.
 2. Penetrations through Single Ply (ex; PVC or TPO) membrane:
 - a. Roofing contractor is to install Single Ply (ex; PVC or TPO) cones and or flashing per roofing manufacturers standard details.
 - b. Roofing contractor is to provide sealant and stainless draw band to seal Single Ply (ex; PVC or TPO) cones and or flashings in accordance with the roofing manufacturer's standard details.
 3. Provide metal flashing for all pipes, ducts, and conduits projecting through the roof surface and for equipment supports, guy wire anchors, and similar items supported by or attached to the roof deck or walls.
 - a. Goose-necks, rainhoods, power roof ventilators, and other plumbing, HVAC and electrical products are specified as appropriate in:

- 1) Division 21 - Fire Suppression.
 - 2) Division 22 - Plumbing.
 - 3) Division 23 - Heating, Ventilating, and Air-Conditioning (HVAC).
 - 4) Division 26 - Electrical.
- b. Coordinate also with sheet metal curbs specified in Section 07 72 00.
4. Single Pipe Vents: Provide lead flashing as indicated on Drawings.
- a. Set flange of sleeve in bituminous plastic cement and nail 3 inches on centers.
 - b. Bend the top of sleeve over and extend down into the vent pipe a minimum of 2 inches.
 - c. For long runs or long rises above the deck, where it is impractical to cover the vent pipe with lead, use a two-piece formed galvanized sheet metal housing.
 - d. Set metal housing with a metal sleeve having a 4 inch roof flange in bituminous plastic cement and nailed 3 inches on center.
 - e. Extend sleeve a minimum of 8 inches above the roof deck and lapped a minimum of 3 inches by a metal hood secured to the vent pipe by a draw band.
 - f. Seal the area of hood in contact with vent pipe with specified sealant. Sealants are specified in Section 07 92 00 - Joint Sealants.
5. Roof Penetration Flashing:
- a. Base Flashing:
 - 1) Extend flange onto roof 6 inches minimum away from penetration.
 - 2) Extend flange upward around penetration to at least 8 inches above roofing felts.
 - 3) Fold back upper and side roof flange edges 1/2 inch minimum.
 - 4) Lap and solder joints.
 - b. Counterflashing: Overlap base flashing 1 inch minimum with storm collar sloped away from penetration. Secure to penetration with draw band and sealant.
6. Equipment Support and Pad Flashing:
- a. Fully cap support and pad.
 - b. Overlap base flashing 4 inches.
 - c. Lap and solder joints.
 - d. Provide sealant around penetrations through-flashing.

3.04 CLEANING AND PREPARATION FOR FIELD PAINTING

- A. Metal Preparation: As sheet metal installation progresses, neutralize excess flux with 5 to 10 percent washing soda solution, and thoroughly rinse.
- B. Repairs: Repair or replace damaged and deformed sheet metal.
- C. Cleaning: Wash down exposed surfaces and remove stains, scrap and debris such that sheet metal is ready to receive field painting and related Work.

FOR REFERENCE ONLY

1. Wash down exposed surfaces and remove soiling, dust, contamination from steel wool and drilling residue, and other scrap and debris.
2. Scrub surfaces with detergent solution as necessary to remove grease and oil films, handling marks, and stains.

3.05 FIELD PAINTING

- A. Field Painting: Field-paint exposed sheet metal for corrosion resistance and decorative purposes. Field finish painting is specified in Section 09 91 13 - Exterior Painting.

3.06 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements for field inspection requirements.
- B. Inspection will involve surveillance of work during installation to ascertain compliance with specified requirements.

3.07 SCHEDULE

- A. Fascia and Cornices: Prefinished.
- B. Gutters and Downspouts: Prefinished to match adjacent wall color.
- C. Scuppers: Thermoplastic membrane cladding, when adjacent to and a part of the roofing.
- D. Coping, Cap, Parapet, Sill and Ledge Flashings: Thermoplastic membrane cladding, when adjacent to and a part of the roofing.
- E. Flashings Associated with Roofing Tiles, including Valley, Hip, Ridge, Eave, Gutter Edge, Gable Edge, Chimney: Pre-finished
- F. Sheet Metal Roof Expansion Joint Covers, and Roof-to-Wall Joint Covers: Pre-finished to match adjacent wall color.
- G. Counterflashings at Roofing Terminations (over roofing base flashings): Thermoplastic membrane cladding.
- H. Counterflashings at Curb-Mounted Roof Items: Exposed galvanized, when behind a parapet; pre-finished otherwise
- I. Roofing Penetration Flashings, for Pipes, Structural Steel, and Equipment Supports: Exposed galvanized, when behind a parapet; pre-finished otherwise.

END OF SECTION

SECTION 07 92 00 JOINT SEALANTS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Nonsag gunnable joint sealants.
- B. Self-leveling pourable joint sealants.
- C. Joint backings and accessories.
- D. District-provided field quality control.

1.02 RELATED REQUIREMENTS

- A. Section 01 61 16 - Volatile Organic Compound (VOC) Content Restrictions: Additional requirements for sealants and primers.
- B. Section 09 30 00 - Tiling: Sealant between tile and plumbing fixtures and at junctions with other materials and changes in plane.

1.03 REFERENCE STANDARDS

- A. ASTM C661 - Standard Test Method for Indentation Hardness of Elastomeric-Type Sealants by Means of a Durometer.
- B. ASTM C794 - Standard Test Method for Adhesion-in-Peel of Elastomeric Joint Sealants.
- C. ASTM C834 - Standard Specification for Latex Sealants.
- D. ASTM C919 - Standard Practice for Use of Sealants in Acoustical Applications.
- E. ASTM C920 - Standard Specification for Elastomeric Joint Sealants.
- F. ASTM C1087 - Standard Test Method for Determining Compatibility of Liquid-Applied Sealants with Accessories Used in Structural Glazing Systems.
- G. ASTM C1193 - Standard Guide for Use of Joint Sealants.
- H. ASTM C1248 - Standard Test Method for Staining of Porous Substrate by Joint Sealants.
- I. ASTM C1311 - Standard Specification for Solvent Release Sealants.
- J. ASTM C1521 - Standard Practice for Evaluating Adhesion of Installed Weatherproofing Sealant Joints.
- K. ASTM D2240 - Standard Test Method for Rubber Property--Durometer Hardness.
- L. SCAQMD 1168 - Adhesive and Sealant Applications.
- M. SWRI (VAL) - SWR Institute Validated Products Directory.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Submit manufacturer's technical datasheets for each product to be used; include the following:

FOR REFERENCE ONLY

1. Physical characteristics, including movement capability, VOC content, hardness, cure time, and color availability.
 2. List of backing materials approved for use with the specific product.
 3. Backing material recommended by sealant manufacturer.
 4. Substrates that product is known to satisfactorily adhere to and with which it is compatible.
 5. Substrates the product should not be used on.
 6. Substrates for which use of primer is required.
 7. Substrates for which laboratory adhesion and/or compatibility testing is required.
 8. Installation instructions, including precautions, limitations, and recommended backing materials and tools.
 9. Sample product warranty.
 10. Certification by manufacturer indicating that product complies with specification requirements.
 11. SWRI Validation: Provide currently available sealant product validations as listed by SWRI (VAL) for specified sealants.
- C. Product Data for Accessory Products: Submit manufacturer's technical data sheet for each product to be used, including physical characteristics, installation instructions, and recommended tools.
- D. Color Cards for Selection: Where sealant color is not specified, submit manufacturer's color cards showing standard colors available for selection.
- E. Samples for Verification: Where custom sealant color is specified, obtain directions from Architect and submit at least two physical samples for verification of color of each required sealant.
- F. Preconstruction Laboratory Test Reports: Submit at least four weeks prior to start of installation.
- G. Installation Plan: Submit at least four weeks prior to start of installation.
- H. Preinstallation Field Adhesion Test Plan: Submit at least two weeks prior to start of installation.
- I. Field Quality Control Plan: Submit at least two weeks prior to start of installation.
- J. Preinstallation Field Adhesion Test Reports: Submit filled out Preinstallation Field Adhesion Test Reports log within 10 days after completion of tests; include bagged test samples and photographic records.
- K. Installation Log: Submit filled-out log for each length or instance of sealant installed.
- L. Field Quality Control Log: Submit filled-out log for each length or instance of sealant installed, within 10 days after completion of inspections/tests; include bagged test samples and photographic records, if any.
- M. Manufacturer's qualification statement.
- N. Installer's qualification statement.
- O. Executed warranty.

1.05 QUALITY ASSURANCE

- A. Maintain one copy of each referenced document covering installation requirements on site.
- B. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum three years documented experience.
- C. Installer Qualifications: Company specializing in performing the work of this section and with at least three years of documented experience.
- D. Preconstruction Laboratory Testing: Arrange for sealant manufacturer(s) to test each combination of sealant, substrate, backing, and accessories.
 - 1. Adhesion Testing: In accordance with ASTM C794.
 - 2. Compatibility Testing: In accordance with ASTM C1087.
 - 3. Allow sufficient time for testing to avoid delaying the work.
 - 4. Deliver sufficient samples to manufacturer for testing.
 - 5. Report manufacturer's recommended corrective measures, if any, including primers or techniques not indicated in product data submittals.
 - 6. Testing is not required if sealant manufacturer provides data showing previous testing, not older than 24 months, that shows satisfactory adhesion, lack of staining, and compatibility.
- E. Installation Plan: Include schedule of sealed joints, including the following:
 - 1. Joint width indicated in Contract Documents.
 - 2. Joint depth indicated in Contract Documents; to face of backing material at centerline of joint.
 - 3. Method to be used to protect adjacent surfaces from sealant droppings and smears, with acknowledgment that some surfaces cannot be cleaned to like-new condition and therefore prevention is imperative.
 - 4. Approximate date of installation, for evaluation of thermal movement influence.
 - 5. Installation Log Form: Include the following data fields, with known information filled out.
 - a. Unique identification of each length or instance of sealant installed.
 - b. Location on project.
 - c. Substrates.
 - d. Sealant used.
 - e. Stated movement capability of sealant.
 - f. Primer to be used, or indicate no primer is used.
 - g. Size and actual backing material used.
 - h. Date of installation.
 - i. Name of installer.
 - j. Actual joint width; provide space to indicate maximum and minimum width.
 - k. Actual joint depth to face of backing material at centerline of joint.

- I. Air temperature.
- F. Preinstallation Field Adhesion Test Plan: Include destructive field adhesion testing of one sample of each combination of sealant type and substrate, except interior acrylic latex sealants, and include the following for each tested sample.
1. Identification of testing agency.
 2. Name(s) of sealant manufacturer's field representatives who will be observing.
 3. Preinstallation Field Adhesion Test Log Form: Include the following data fields, with known information filled out.
 - a. Substrate; if more than one type of substrate is involved in a single joint, provide two entries on form, for testing each sealant substrate side separately.
 - b. Test date.
 - c. Location on project.
 - d. Sealant used.
 - e. Stated movement capability of sealant.
 - f. Test method used.
 - g. Date of installation of field sample to be tested.
 - h. Date of test.
 - i. Copy of test method documents.
 - j. Age of sealant upon date of testing.
 - k. Test results, modeled after the sample form in the test method document.
 - l. Indicate use of photographic record of test.
- G. District will employ an independent testing agency to perform the field quality control inspection and testing as referenced in PART 3 of this section and as follows, to prepare and submit the field quality control plan and log, and to provide recommendations of remedies in the case of failure.
1. Contractor shall cooperate with testing agency and repair failures discovered and destructive test location damage.
- H. Field Quality Control Plan:
1. Visual inspection of entire length of sealant joints.
 2. Nondestructive field adhesion testing of sealant joints, except interior acrylic latex sealants.
 - a. For each different sealant and substrate combination, allow for one test every 12 inches in the first 10 linear feet of joint and one test every 24 inches thereafter.
 - b. If any failures occur in the first 10 linear feet, continue testing at 12 inches intervals at no extra cost to District.
 3. Destructive field adhesion testing of sealant joints, except interior sealant joints.
 - a. For each different sealant and substrate combination, allow for one test every 100 feet in the first 1,000 linear feet, and one test per 1,000 linear feet thereafter, or once per floor on each elevation.

FOR REFERENCE ONLY

- b. If any failures occur in the first 1,000 linear feet, continue testing at frequency of one test per 500 linear feet at no extra cost to District.
 4. Field Quality Control Log Form: Show same data fields as on Preinstallation Field Adhesion Test Log, with known information filled out and lines for multiple tests per sealant/substrate combinations; include visual inspection and specified field testing; allow for possibility that more tests than minimum specified may be necessary.
- I. Field Adhesion Test Procedures:
 1. Allow sealants to fully cure as recommended by manufacturer before testing.
 2. Have a copy of the test method document available during tests.
 3. Take photographs or make video records of each test, with joint identification provided in the photos/videos; for example, provide small erasable whiteboard positioned next to joint.
 4. Record the type of failure that occurred, other information required by test method, and the information required on the Field Quality Control Log.
 5. When performing destructive tests, also inspect the opened joint for proper installation characteristics recommended by manufacturer, and report any deficiencies.
 6. Deliver the samples removed during destructive tests in separate sealed plastic bags, identified with project, location, test date, and test results, to District.
 7. If any combination of sealant type and substrate does not show evidence of minimum adhesion or shows cohesion failure before minimum adhesion, report results to Architect.
- J. Nondestructive Field Adhesion Test: Test for adhesion in accordance with ASTM C1521, using Nondestructive Spot Method.
 1. Record results on Field Quality Control Log.
 2. Repair failed portions of joints.
- K. Destructive Field Adhesion Test: Test for adhesion in accordance with ASTM C1521, using Destructive Tail Procedure.
 1. Sample: At least 18 inches long.
 2. Minimum Elongation Without Adhesive Failure: Consider the tail at rest, not under any elongation stress; multiply the stated movement capability of the sealant in percent by two; then multiply 1 inch by that percentage; if adhesion failure occurs before the 1-inch mark is that distance from the substrate, the test has failed.
 3. If either adhesive or cohesive failure occurs before minimum elongation, take necessary measures to correct conditions and retest; record each modification to products or installation procedures.
 4. Record results on Field Quality Control Log.
 5. Repair failed portions of joints.
- L. Field Adhesion Tests of Joints: Test for adhesion using most appropriate method in accordance with ASTM C1521, or another applicable method as recommended by manufacturer.

1.06 WARRANTY

- A. See Section 01 78 00 - Closeout Submittals for additional warranty requirements.
- B. Manufacturer Warranty: Provide 2-year manufacturer warranty for installed sealants and accessories that fail to achieve a watertight seal, exhibit loss of adhesion or cohesion, or do not cure. Complete forms in District's name and register with manufacturer.
- C. Extended Correction Period: Correct defective work within 2-year period commencing on Date of Substantial Completion.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Nonsag Sealants:
 - 1. Adhesives Technology Corporation: www.atcepoxy.com/#sle.
 - 2. Bostik Inc: www.bostik-us.com/#sle.
 - 3. Dow: www.dow.com/#sle.
 - 4. Franklin International, Inc: www.titebond.com/#sle.
 - 5. Henry Company: www.henry.com/#sle.
 - 6. Hilti, Inc: www.hilti.com/#sle.
 - 7. Master Builders Solutions: www.master-builders-solutions.com/en-us/#sle.
 - 8. Momentive Performance Materials, Inc (formerly GE Silicones): www.momentive.com/#sle.
 - 9. Pecora Corporation: www.pecora.com/#sle.
 - 10. QUIKRETE Companies: www.quikrete.com/#sle.
 - 11. Sherwin-Williams Company: www.sherwin-williams.com/#sle.
 - 12. Sika Corporation: www.usa.sika.com/#sle.
 - 13. Specified Technologies Inc: www.stifirestop.com/#sle.
 - 14. Tremco Commercial Sealants & Waterproofing: www.tremcosealants.com/#sle.
 - 15. W.R. Meadows, Inc: www.wrmeadows.com/#sle.
 - 16. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- B. Self-Leveling Sealants:
 - 1. Adhesives Technology Corporation: www.atcepoxy.com/#sle.
 - 2. Bostik Inc: www.bostik-us.com/#sle.
 - 3. Dayton Superior Corporation: www.daytonsuperior.com/#sle.
 - 4. Dow: www.dow.com/#sle.
 - 5. Master Builders Solutions: www.master-builders-solutions.com/en-us/#sle.
 - 6. Pecora Corporation: www.pecora.com/#sle.
 - 7. QUIKRETE Companies: www.quikrete.com/#sle.
 - 8. Sherwin-Williams Company: www.sherwin-williams.com/#sle.

9. Sika Corporation: www.usa.sika.com/#sle.
10. Tremco Commercial Sealants & Waterproofing: www.tremcosealants.com/#sle.
11. W.R. Meadows, Inc: www.wrmeadows.com/#sle.
12. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.

2.02 JOINT SEALANT APPLICATIONS

A. Scope:

1. Exterior Joints:
 - a. Do not seal exterior joints unless indicated on drawings as sealed.
 - b. Seal open joints except open joints indicated on drawings as not sealed.
2. Interior Joints:
 - a. Do not seal interior joints indicated on drawings as not sealed.
 - b. Do not seal gaps and openings in gypsum board and suspended ceilings
 - c. Do not seal through-penetrations in sound-rated assemblies that are also fire-rated assemblies.
 - d. Seal the following joints:
 - 1) Joints between door frames and window frames and adjacent construction.
 - 2) In sound-rated wall and ceiling assemblies, gaps at electrical outlets, wiring devices, and piping penetrations.
 - 3) In sound-rated wall and ceiling assemblies, seal joints between wall assemblies and ceiling assemblies; between wall assemblies and other construction; between ceiling assemblies and other construction.
3. Do Not Seal:
 - a. Intentional weep holes in masonry.
 - b. Joints indicated to be covered with expansion joint cover assemblies.
 - c. Joints where sealant is specified to be furnished and installed by manufacturer of product to be sealed.
 - d. Joints where sealant installation is specified in other sections.
 - e. Joints between suspended ceilings and walls.

B. Exterior Joints: Use nonsag nonstaining silicone sealant, unless otherwise indicated.

1. Type SM-1 - Lap Joints in Sheet Metal Fabrications: Butyl rubber, noncuring.
2. Type SM-1 - Lap Joints between Manufactured Metal Panels: Butyl rubber, noncuring.
3. Type CP-1 - Control and Expansion Joints in Concrete Paving: Self-leveling polyurethane traffic-grade sealant.
4. Type IA-1 - Wall and Ceiling Joints in Nonwet Areas: Acrylic emulsion latex sealant.
5. Type WP-1 - Wall and Ceiling Joints in Wet Areas: Nonsag polyurethane sealant for continuous liquid immersion.
6. Type WP-1 - Floor Joints in Wet Areas: Nonsag polyurethane non-traffic-grade sealant suitable for continuous liquid immersion.

7. Type FS-1 - Joints between Tile in Wet Areas and Floors, Walls, and Ceilings: Mildew-resistant silicone sealant; white.
 - a. See Section 09 30 00 for sealing between tile and plumbing fixtures.
- C. Interior Wet Areas: Bathrooms, restrooms, kitchens, food service areas, and food processing areas; fixtures in wet areas include plumbing fixtures, food service equipment, countertops, cabinets, and other similar items.

2.03 JOINT SEALANTS - GENERAL

- A. Sealants and Primers: Provide products having lower volatile organic compound (VOC) content than indicated in SCAQMD 1168.
- B. Colors: As indicated on drawings.

2.04 NONSAG JOINT SEALANTS

- A. Type NS-1 - Nonstaining Silicone Sealant: ASTM C920, Grade NS, Uses M and A; not expected to withstand continuous water immersion or traffic.
 1. Movement Capability: Plus and minus 50 percent, minimum.
 2. Nonstaining to Porous Stone: Nonstaining to light-colored natural stone when tested in accordance with ASTM C1248.
 3. Dirt Pick-Up: Reduced dirt pick-up compared to other silicone sealants.
 4. Hardness Range: 15 to 35, Shore A, when tested in accordance with ASTM C661.
 5. Color: Match adjacent finished surfaces.
 6. Service Temperature Range: Minus 20 to 180 degrees F.
 7. Products:
 - a. Dow; DOWSIL 756 SMS Building Sealant: www.dow.com/#sle.
 - b. Dow; DOWSIL 790 Silicone Building Sealant: www.dow.com/#sle.
 - c. Dow; DOWSIL 791 Silicone Weatherproofing Sealant: www.dow.com/#sle.
 - d. Dow; DOWSIL 795 Silicone Building Sealant: www.dow.com/#sle.
 - e. Momentive Performance Materials, Inc/GE Silicones; SCS9000 SilPruf NB - Non-Staining Silicone Weatherproofing Sealant: www.siliconeforbuilding.com/#sle.
 - f. Pecora Corporation; Pecora 890 NST (Non-Staining Technology): www.pecora.com/#sle.
 - g. Pecora Corporation; Pecora 864 NST (Non-Staining Technology): www.pecora.com/#sle.
 - h. Sika Corporation; Sikasil WS-290: www.usa.sika.com/#sle.
 - i. Sika Corporation; Sikasil WS-295: www.usa.sika.com/#sle.
 - j. Sika Corporation; Sikasil 728NS: www.usa.sika.com/#sle.
 - k. Tremco Commercial Sealants & Waterproofing; Spectrem 1: www.tremcosealants.com/#sle.
 - l. Tremco Commercial Sealants & Waterproofing; Spectrem 2: www.tremcosealants.com/#sle.

FOR REFERENCE ONLY

- m. Tremco Commercial Sealants & Waterproofing; Spectrem 3:
www.tremcosealants.com/#sle.
 - n. Tremco Commercial Sealants & Waterproofing; Spectrem 4-TS:
www.tremcosealants.com/#sle.
 - o. Tremco Commercial Sealants & Waterproofing; Tremsil 200:
www.tremcosealants.com/#sle.
 - p. Tremco Commercial Sealants & Waterproofing; Tremsil 400:
www.tremcosealants.com/#sle.
 - q. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- B. Silicone Sealant: ASTM C920, Grade NS, Uses M and A; not expected to withstand continuous water immersion or traffic.
- 1. Movement Capability: Plus and minus 25 percent, minimum.
 - 2. Hardness Range: 15 to 35, Shore A, when tested in accordance with ASTM C661.
 - 3. Color: To be selected by Architect from manufacturer's standard range.
 - 4. Cure Type: Single component, neutral moisture curing.
 - 5. Service Temperature Range: Minus 65 to 180 degrees F.
 - 6. Products:
 - a. Dow; DOWSIL 999-A Building and Glazing Sealant: www.dow.com/#sle.
 - b. Dow; DOWSIL 758 Silicone Weather Barrier Sealant: www.dow.com/#sle.
 - c. Henry Company; Moistop Sealant: www.henry.com/#sle.
 - d. Momentive Performance Materials, Inc/GE Silicones; SCS2000 SilPruf - Silicone Sealant and Adhesive: www.siliconeforbuilding.com/#sle.
 - e. Momentive Performance Materials, Inc/GE Silicones; SCS2700 SilPruf LM (Low Modulus) - Silicone Weatherproofing Sealant: www.siliconeforbuilding.com/#sle.
 - f. Momentive Performance Materials, Inc/GE Silicones; SSG4600 UltraGlaze - Silicone Structural Glazing Adhesive: www.siliconeforbuilding.com/#sle.
 - g. Pecora Corporation; Pecora 860: www.pecora.com/#sle.
 - h. Pecora Corporation; Pecora 890FTS (Field Tintable Smooth): www.pecora.com/#sle.
 - i. Pecora Corporation; Pecora 890FTS-TXTR (Field Tintable Textured):
www.pecora.com/#sle.
 - j. Sherwin-Williams Company; Silicone Rubber All Purpose Sealant: www.sherwin-williams.com/#sle.
 - k. Sika Corporation; Sikasil GP: www.usa.sika.com/#sle.
 - l. Sika Corporation; Sikasil WS-295: www.usa.sika.com/#sle.
 - m. Sika Corporation; Sikasil N-Plus US: www.usa.sika.com/#sle.
 - n. Sika Corporation; Sikasil 728NS: www.usa.sika.com/#sle.
 - o. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.

FOR REFERENCE ONLY

- C. Type FS-1 - Mildew-Resistant Silicone Sealant: ASTM C920, Grade NS, Uses M and A; single component, mildew resistant; not expected to withstand continuous water immersion or traffic.
1. Color: White.
 2. Products:
 - a. BASF Construction Chemicals-Building Systems; OmniPlus, by Sonneborn Building Products Div.: www.buildingsystems.basf.com.
 - b. Dow Corning Corporation; 786 Silicone Sealant: www.dowcorning.com.
 - c. Momentive Performance Materials, Inc (GE Silicones products); Silpruf SCS 1700 Sanitary: www.momentive.com.
 - d. Pecora Corporation; Pecora 898 NST (Non-Staining Technology): www.pecora.com/#sle.
 - e. Sika Corporation; Sikasil GP: www.usa.sika.com/#sle.
 - f. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- D. Type ST-1 - Hybrid Elastomeric Sealant: ASTM C920, Grade NS, Uses M and A; single component; not expected to withstand continuous water immersion or traffic.
1. Movement Capability: Plus and minus 50 percent, minimum.
 2. Hardness Range: 15 to 25, Shore A, when tested in accordance with ASTM C661.
 3. Color: To be selected by Architect from manufacturer's full range.
 4. Service Temperature Range: Minus 75 to 300 degrees F.
 5. Products:
 - a. Dow; DOWSIL Contractors Paintable Sealant - CPS: www.dow.com/#sle.
 - b. Franklin International Inc; Titebond WeatherMaster Sealant: www.titebond.com/#sle.
 - c. Master Builders Solutions; MasterSeal NP100: www.master-builders-solutions.com/en-us/#sle.
 - d. Sherwin-Williams Company; Stampede 100 Low-Modulus Hybrid Urethane Sealant: www.sherwin-williams.com/#sle.
 - e. Sherwin-Williams Company; Stampede 1H Hybrid Sealant: www.sherwin-williams.com/#sle.
 - f. Tremco Commercial Sealants and Waterproofing; Dymonic FC: www.tremcosealants.com/#sle.
 - g. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
 6. Hardness Range: 20 to 35, Shore A, when tested in accordance with ASTM C661.
 7. Color: To be selected by Architect from manufacturer's full range.
 8. Service Temperature Range: Minus 40 to 180 degrees F.
 9. Products:
 - a. Master Builders Solutions; MasterSeal NP1: www.master-builders-solutions.com/en-us/#sle.

FOR REFERENCE ONLY

- b. Pecora Corporation; DynaTrol II: www.pecora.com/#sle.
 - c. Pecora Corporation; DynaFlex: www.pecora.com/#sle.
 - d. Sherwin-Williams Company; Stampede-1/-TX Polyurethane Sealant: www.sherwin-williams.com/#sle.
 - e. Sika Corporation; Sikaflex-1a: www.usa.sika.com/#sle.
 - f. Sika Corporation; Sikaflex-15 LM: www.usa.sika.com/#sle.
 - g. Tremco Commercial Sealants & Waterproofing; Dymonic 100: www.tremcosealants.com/#sle.
 - h. Tremco Commercial Sealants & Waterproofing; Vulkem 116: www.tremcosealants.com/#sle.
 - i. W. R. Meadows, Inc; POURTHANE NS: www.wrmeadows.com/#sle.
 - j. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- E. Type WP-1 - Polyurethane Sealant for Continuous Water Immersion: ASTM C920, Grade NS, Uses M and A; single or multicomponent; explicitly approved by manufacturer for continuous water immersion; suitable for traffic exposure when recessed below traffic surface.
- 1. Movement Capability: Plus and minus 35 percent, minimum.
 - 2. Hardness Range: 20 to 35, Shore A, when tested in accordance with ASTM C661.
 - 3. Color: To be selected by Architect from manufacturer's standard range.
 - 4. Service Temperature Range: Minus 40 to 180 degrees F.
 - 5. Products:
 - a. Sika Corporation; Sikaflex-1a: www.usa.sika.com/#sle.
 - b. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- F. Nonsag Traffic-Grade Polyurethane Sealant: ASTM C920, Grade NS, Uses M and A; single or multi-component; explicitly approved by manufacturer for continuous water immersion and traffic without the necessity to recess sealant below traffic surface.
- 1. Movement Capability: Plus and minus 25 percent, minimum.
 - 2. Hardness Range: 20 to 30, Shore A, when tested in accordance with ASTM C661.
 - 3. Color: Match adjacent finished surfaces.
- G. Polysulfide Sealant: ASTM C920, Grade NS, Uses M and A; single component; not expected to withstand continuous water immersion or traffic.
- 1. Movement Capability: Plus and minus 25 percent, minimum.
 - 2. Hardness Range: 20 to 35, Shore A, when tested in accordance with ASTM C661.
 - 3. Color: To be selected by Architect from manufacturer's standard range.
 - 4. Service Temperature Range: Minus 40 to 180 degrees F.
 - 5. Products:
 - a. Pecora Corporation: www.pecora.com/#sle.
 - b. W.R. Meadows, Inc; Deck-O-Seal Gun Grade: www.wrmeadows.com/#sle.
 - c. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.

- H. Type IA-1 - Acrylic Emulsion Latex: Water-based; ASTM C834, single component, nonstaining, nonbleeding, nonsagging; not intended for exterior use.
1. Color: To be selected by Architect from manufacturer's full range.
 2. Grade: ASTM C834; Grade 0 Degrees F (Minus 18 Degrees C).
 3. Products:
 - a. Franklin International, Inc; Titebond Pro-Grade Plus Caulk: www.titebond.com/#sle.
 - b. Hilti, Inc; CP 506 Smoke and Acoustical Sealant: www.us.hilti.com/#sle.
 - c. Hilti, Inc; CP 572 Smoke and Acoustical Spray Sealant: www.us.hilti.com/#sle.
 - d. Hilti, Inc; Lightweight Smoke and Acoustic Sealant CS-S SA Light: www.us.hilti.com/#sle.
 - e. OSI Greenseries SC-175 Draft & Acoustical Sound Sealant; www.ositough.com.
 - f. Pecora Corporation; AC-20 +Silicone: www.pecora.com/#sle.
 - g. Sherwin-Williams Company; White Lightning 3006 Siliconized Acrylic Latex Caulk: www.sherwin-williams.com/#sle.
 - h. Sherwin-Williams Company; 850A Acrylic Latex Caulk: www.sherwin-williams.com/#sle.
 - i. Sherwin-Williams Company; 950A Siliconized Acrylic Latex Caulk: www.sherwin-williams.com/#sle.
 - j. Sherwin-Williams Company; Bolt Quickdry Siliconized Acrylic Latex Caulk: www.sherwin-williams.com/#sle.
 - k. Sherwin-Williams Company; Powerhouse Siliconized Acrylic Latex Sealant: www.sherwin-williams.com/#sle.
 - l. Specified Technologies Inc; Smoke N' Sound Acoustical Sealant: www.stifirestop.com/#sle.
 - m. Top Gun, a brand of PPG Architectural Coatings; Top Gun 200: www.ppgpaints.com/#sle.
 - n. Tremco Commercial Sealants & Waterproofing; Tremflex 834: www.tremcosealants.com/#sle.
 - o. Tremco Commercial Sealants & Waterproofing; Tremstop Smoke and Sound: www.tremcosealants.com/#sle.
 - p. Tremco Commercial Sealants & Waterproofing; Tremstop Smoke and Sound Spray: www.tremcosealants.com/#sle.
 - q. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.

2.05 SELF-LEVELING JOINT SEALANTS

- A. Self-Leveling Silicone Sealant: ASTM C920, Grade P, Uses M and A; single or multicomponent, explicitly approved by manufacturer for traffic exposure when recessed below traffic surface; not expected to withstand continuous water immersion.
1. Movement Capability: Plus 100 percent, minus 50 percent, minimum.
 2. Hardness Range: 0 to 15, Shore A, when tested in accordance with ASTM C661.

FOR REFERENCE ONLY

3. Color: To be selected by Architect from manufacturer's standard range.
 4. Service Temperature Range: Minus 40 to 180 degrees F.
 5. Products:
 - a. Dow; DOWSIL SL Parking Structure Sealant: www.dow.com/#sle.
 - b. Pecora Corporation; Pecora 300 SL (Self-Leveling): www.pecora.com/#sle.
 - c. Pecora Corporation; Pecora 322 FC (Fast Cure): www.pecora.com/#sle.
 - d. Sika Corporation; Sikasil 728SL: www.usa.sika.com/#sle.
 - e. Tremco Commercial Sealants & Waterproofing; Spectrem 900SL: www.tremcosealants.com/#sle.
 - f. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- B. Type P-1 - Self-Leveling Polyurethane Sealant: ASTM C920, Grade P, Uses M and A; single or multicomponent; explicitly approved by manufacturer for traffic exposure; not expected to withstand continuous water immersion .
1. Movement Capability: Plus and minus 25 percent, minimum.
 2. Hardness Range: 35 to 55, Shore A, when tested in accordance with ASTM C661.
 3. Color: To be selected by Architect from manufacturer's standard range.
 4. Service Temperature Range: Minus 40 to 180 degrees F.
 5. Products:
 - a. Pecora Corporation: www.pecora.com/#sle.
 - b. Sherwin-Williams Company; Stampede 1SL Polyurethane Sealant: www.sherwin-williams.com/#sle.
 - c. Sika Corporation; Sikaflex-1c SL: www.usa.sika.com/#sle.
- C. Type WFP-1 - Self-Leveling Polyurethane Sealant for Continuous Water Immersion: Polyurethane; ASTM C920, Grade P, Uses M and A; single component; explicitly approved by manufacturer for traffic exposure and continuous water immersion.
1. Movement Capability: Plus and minus 25 percent, minimum.
 2. Hardness Range: 35 to 55, Shore A, when tested in accordance with ASTM C661.
 3. Color: To be selected by Architect from manufacturer's standard range.
 4. Service Temperature Range: Minus 40 to 180 degrees F.
 5. Products:
 - a. Sika Corporation; Sikaflex-1c SL: www.usa.sika.com/#sle.
 - b. W. R. MEADOWS, Inc; POURTHANE SL: www.wrmeadows.com/#sle.
 - c. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- D. Self-Leveling Polysulfide Sealant: ASTM C920, Grade P, Uses M and A; multicomponent; explicitly approved by manufacturer for traffic exposure and continuous water immersion.
1. Movement Capability: Plus and minus 25 percent.
 2. Hardness Range: 30 to 55, Shore A, when tested in accordance with ASTM C661.
 3. Color: To be selected by Architect from manufacturer's standard range.

FOR REFERENCE ONLY

4. Service Temperature Range: Minus 40 to 180 degrees F.
5. Products:
 - a. W.R. Meadows, Inc; Deck-O-Seal (pourable): www.wrmeadows.com/#sle.
 - b. W.R. Meadows, Inc; Deck-O-Seal 125: www.wrmeadows.com/#sle.
 - c. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- E. Rigid Self-Leveling Polyurethane Joint Filler: Two part, low viscosity, fast setting; intended for cracks and control joints not subject to significant movement.
 1. Hardness Range: Greater than 100, Shore A, and 50 to 80, Shore D, when tested in accordance with ASTM C661.
 2. Products:
 - a. ARDEX Engineered Cements; ARDEX ARDIFIX: www.ardexamericas.com/#sle.
 - b. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- F. Type EPX-1 - Semi-Rigid Self-Leveling Epoxy Joint Filler: Epoxy or epoxy/polyurethane copolymer; intended for filling cracks and control joints not subject to significant movement; rigid enough to support concrete edges under traffic.
 1. Composition: Multicomponent, 100 percent solids by weight.
 2. Durometer Hardness: Minimum of 85 for Type A or 35 for Type D, after seven days when tested in accordance with ASTM D2240.
 3. Color: Concrete gray.
 4. Joint Width, Minimum: 1/8 inch.
 5. Joint Width, Maximum: 1/4 inch.
 6. Joint Depth: Provide product suitable for joints from 1/8 inch to 2 inches in depth including space for backer rod.
 7. Products:
 - a. Dayton Superior Corporation: www.daytonsuperior.com/#sle.
 - b. Euclid Chemical Company; EUCO 700: www.euclidchemical.com/#sle.
 - c. W.R. Meadows, Inc; Rezi-Weld Flex: www.wrmeadows.com/#sle.
 - d. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- G. Semi-Rigid Self-Leveling Polyurea Joint Filler: Two-component, 100 percent solids; intended for filling cracks and control joints not subject to significant movement; rigid enough to support concrete edges under traffic.
 1. Durometer Hardness, Type A: 75, minimum, after seven days when tested in accordance with ASTM D2240.
 2. Color: To be selected by Architect from manufacturer's standard colors.
 3. Joint Width, Minimum: 1/8 inch.
 4. Joint Width, Maximum: 1/2 inch.
 5. Joint Depth: Provide product suitable for joints from 1/8 inch to 1 inch in depth excluding space for backer rod.
 6. Products:

- a. ARDEX Engineered Cements; ARDEX ARDISEAL RAPID PLUS: www.ardexamericas.com/#sle.
- b. Euclid Chemical Company; EUCO QWIKjoint UVR: www.euclidchemical.com/#sle.
- c. Nox-Crete Inc; DynaFlex JF-85: www.nox-crete.com/#sle.
- d. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.

2.06 ACCESSORIES

- A. Sealant Backing Materials, General: Materials placed in joint before applying sealants; assists sealant performance and service life by developing optimum sealant profile and preventing three-sided adhesion; type and size recommended by sealant manufacturer for compatibility with sealant, substrate, and application.
- B. Backing Tape: Self-adhesive polyethylene tape with surface that sealant will not adhere to and recommended by tape and sealant manufacturers for specific application.
- C. Masking Tape: Self-adhesive, nonabsorbent, nonstaining, removable without adhesive residue, and compatible with surfaces adjacent to joints and sealants.
- D. Joint Cleaner: Noncorrosive and nonstaining type, type recommended by sealant manufacturer; compatible with joint forming materials.
- E. Primers: Type recommended by sealant manufacturer to suit application; nonstaining.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that joints are ready to receive work.
- B. Verify that backing materials are compatible with sealants.
- C. Preinstallation Adhesion Testing: Install a sample for each test location indicated in the test plan.
 1. Test each sample as specified in PART 1 under QUALITY ASSURANCE article.
 2. Notify Architect of date and time that tests will be performed, at least seven days in advance.
 3. Arrange for sealant manufacturer's technical representative to be present during tests.
 4. Record each test on Preinstallation Adhesion Test Log as indicated.
 5. If any sample fails, review products and installation procedures, consult manufacturer, or take other measures that are necessary to ensure adhesion; retest in a different location; if unable to obtain satisfactory adhesion, report to Architect.
 6. After completion of tests, remove remaining sample material and prepare joints for new sealant installation.

3.02 PREPARATION

- A. Remove loose materials and foreign matter that could impair adhesion of sealant.
- B. Clean joints, and prime as necessary, in accordance with manufacturer's instructions.
- C. Perform preparation in accordance with manufacturer's instructions and ASTM C1193.

- D. Mask elements and surfaces adjacent to joints from damage and disfigurement due to sealant work; be aware that sealant drips and smears may not be completely removable.

3.03 INSTALLATION

- A. Install this work in accordance with sealant manufacturer's requirements for preparation of surfaces and material installation instructions.
- B. Provide joint sealant installations complying with ASTM C1193.
- C. Measure joint dimensions and size joint backers to achieve the following, unless otherwise indicated:
 - 1. Width/depth ratio of 2:1.
 - 2. Neck dimension no greater than 1/3 of the joint width.
 - 3. Surface bond area on each side not less than 75 percent of joint width.
- D. Install bond breaker backing tape where backer rod cannot be used.
- E. Install sealant free of air pockets, foreign embedded matter, ridges, and sags, and without getting sealant on adjacent surfaces.
- F. Do not install sealant when ambient temperature is outside manufacturer's recommended temperature range, or will be outside that range during the entire curing period, unless manufacturer's approval is obtained and instructions are followed.
- G. Nonsag Sealants: Tool surface concave, unless otherwise indicated; remove masking tape immediately after tooling sealant surface.
- H. Concrete Floor Joint Filler: After full cure, shave joint filler flush with top of concrete slab.

3.04 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements for additional requirements.
- B. District will employ an independent testing agency to perform field quality control inspection and testing as specified in PART 1 under QUALITY ASSURANCE article.
- C. Non-Destructive Adhesion Testing: If there are any failures in first 100 linear feet, notify Architect immediately.
- D. Destructive Adhesion Testing: If there are any failures in first 1,000 linear feet, notify Architect immediately.
- E. Remove and replace failed portions of sealants using same materials and procedures as indicated for original installation.
- F. Repair destructive test location damage immediately after evaluation and recording of results.

3.05 POST-OCCUPANCY

- A. Post-Occupancy Inspection: Perform visual inspection of entire length of project sealant joints at a time that joints have opened to their greatest width, i.e., at low temperature in thermal cycle. Report failures immediately and repair them.

END OF SECTION

SECTION 07 95 13 EXPANSION JOINT COVER ASSEMBLIES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Expansion joint cover assemblies for roof/parapet cap, soffit, ceiling, wall, and floor surfaces.

1.02 RELATED REQUIREMENTS

- A. Section 05 50 00 - Metal Fabrications: Custom fabricated metal expansion and control joint devices.
- B. Section 07 62 00 - Sheet Metal Flashing and Trim: Roof expansion and control joint covers.
- C. Section 07 92 00 - Joint Sealants: Sealing expansion and control joints using gunnable and pourable sealants.
- D. Section 07 92 00 - Joint Sealants: Expansion and control joint finishing utilizing a sealant .
- E. Section 09 51 00 - Acoustical Ceilings: Expansion joint assemblies in suspended ceiling grids.

1.03 REFERENCE STANDARDS

- A. ASTM B221 - Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes.
- B. ASTM B221M - Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes (Metric).
- C. ASTM B308/B308M - Standard Specification for Aluminum-Alloy 6061-T6 Standard Structural Profiles.
- D. ITS (DIR) - Directory of Listed Products.
- E. UL (DIR) - Online Certifications Directory.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Installation Templates: For frames and anchors to be embedded in concrete or masonry, furnish templates to relevant installers; include installation instructions and tolerances.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide joint assembly profiles, profile dimensions, anchorage devices and available colors and finish.
- C. Shop Drawings: Indicate joint and splice locations, miters, layout of the work, effected adjacent construction and anchorage locations.
- D. Manufacturer's Installation Instructions: Indicate rough-in sizes and required tolerances for item placement.
- E. Maintenance Materials: Furnish the following for District's use in maintenance of project.
 - 1. See Section 01 60 00 for additional provisions.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Expansion Joint Cover Assemblies:
 - 1. Architectural Art Mfg., Inc: www.archart.com.
 - 2. Construction Specialties, Inc: www.c-sgroup.com.
 - 3. Inpro: www.inprocorp.com/#sle.
 - 4. MM Systems Corp: www.mmsystemscorp.com.
 - 5. Nystrom, Inc: www.nystrom.com.
 - 6. Watson Bowman Acme Corporation: www.watsonbowmanacme.com/#sle.
 - 7. Substitutions: See Section 01 60 00 - Product Requirements.

2.02 EXPANSION JOINT COVER ASSEMBLY APPLICATIONS

- A. Provide joint covers sized as required to match conditions, or as detailed on Drawings for specific conditions. Separation dimensions indicated on Drawings.
- B. Exterior Wall Joint Cover (stud framed structure): Aluminum cover and integral waterstop. Include end caps to transition with vertical joints. Coordinate moisture barrier secondary seal with parapet cap and soffit cover.
 - 1. Products:
 - a. Construction Specialties, Inc.; AFW-XXX / AFWC-XXX: www.c-sgroup.com/expansion-joint-covers/exterior-covers/esw_esc_4-16.
 - b. Substitutions: See Section 01 60 00 - Product Requirements.
- C. Exterior Wall Joints Subject to Seismic Movement:
- D. Exterior Parapet Cap to Wall Joint Cover: Aluminum frame, cover and integral waterstop. Include end caps to transition over vertical joints.
- E. Exterior Roof to Roof Joint Cover: Aluminum frame, cover and integral waterstop. Include end caps to transition over vertical joints.

2.03 EXPANSION JOINT COVER ASSEMBLIES

- A. Expansion Joint Cover Assemblies - General: Factory-fabricated and assembled; designed to completely fill joint openings, sealed to prevent passage of air, dust, water, smoke; suitable for traffic expected.
 - 1. Joint Dimensions and Configurations: As indicated on drawings.
 - 2. Joint Cover Sizes: Selected to suit joint width and configuration, based on manufacturer's published recommendations and limitations.
 - 3. Joint Cover Styles: As indicated on drawings.
 - 4. Joint Movement Capability: If not indicated, provide minimum plus/minus 25 percent joint movement capability.
 - 5. Lengths: Provide covers in full lengths required; avoid splicing wherever possible.
 - 6. Anchors, Fasteners, and Fittings: Provided by cover manufacturer.

7. Secondary Seal (Moisture Barrier): 7-ply laminate reinforced Polyethylene.
- B. Resilient Seal Type Covers: Having flat exposed surface without crevices that could collect dirt; designed to withstand expected movement without extrusion of seal from joint assembly; for floors, provide style that is flush with top of floor covering; for exterior joints, weathertight.
- C. Covers in Fire Rated Assemblies: Provide cover assembly having fire rating equivalent to that of assembly into which it is installed.
 1. Acceptable Evaluation Agencies: UL (DIR) and ITS (DIR).

2.04 MATERIALS

- A. Extruded Aluminum: ASTM B221 (ASTM B221M), 6063 alloy, T6 temper; or ASTM B308/B308M, 6061 alloy, T6 temper.
 1. Exposed Finish Outdoors: Natural anodized.
 2. Exposed Finish at Floors: Mill finish or natural anodized.
 3. Exposed Finish at Walls and Ceilings: Natural anodized.
- B. Resilient Seals:
 1. For Ceilings: Any resilient material, flush, pleated, or hollow gasket.
 2. Color: Black.
- C. Anchors and Fasteners: As recommended by cover manufacturer.
- D. Threaded Fasteners: Aluminum.
- E. Backing Paint for Aluminum Components in Contact with Cementitious Materials: Asphaltic type.
 1. Bituminous Coating: Tnemec, Inc.;46-450 Heavy H.B. Tnemecol Series 46-465, high-build mineral-filled coal tar pitch coating, or a Cold-applied asphalt mastic complying with SSPC-Paint 12, except containing no asbestos fibers.
 2. Bond Breaker Tape: Isolate dissimilar metals with Pecora 531 Bond Breaker Tape or equal.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that joint preparation and dimensions are acceptable and in accordance with manufacturer's requirements.

3.02 PREPARATION

- A. Install anchoring devices in conformance to templates.

3.03 INSTALLATION

- A. Install components and accessories in accordance with manufacturer's instructions.
- B. Align work plumb and level, flush with adjacent surfaces.
- C. Rigidly anchor to substrate to prevent misalignment.

FOR REFERENCE ONLY

3.04 PROTECTION

- A. Do not permit traffic over unprotected floor joint surfaces.
- B. Provide strippable coating to protect finish surface.

END OF SECTION

FOR REFERENCE ONLY

SECTION 08 06 71 DOOR HARDWARE SCHEDULE

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Preliminary schedule of door hardware sets for swinging as indicated on drawings.

1.02 RELATED REQUIREMENTS

- A. Section 08 71 00 - Door Hardware: Requirements to comply with in coordination with this section.

1.03 REFERENCE STANDARDS

- A. BHMA (CPD) - Certified Products Directory.
- B. BHMA A156.3 - Exit Devices.
- C. BHMA A156.5 - Cylinders and Input Devices for Locks.
- D. BHMA A156.13 - Mortise Locks & Latches Series 1000.
- E. BHMA A156.18 - Standard for Materials and Finishes.
- F. DHI (H&S) - Sequence and Format for the Hardware Schedule.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Comply with submittal requirements as indicated in Section 08 71 00.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Only manufacturers listed in Door Hardware Schedule or Section 08 71 00 are considered acceptable, unless noted otherwise.
- B. Obtain each type of door hardware as indicated from a single manufacturer and single supplier.
- C. Products are listed and certified compliant with specified standards by BHMA (CPD).
- D. Manufacturer's Abbreviations: Coordinate with manufacturers listed in Section 08 71 00.
 - 1. BAS/BES - Best Access Systems.
 - 2. GLY - Glynn Johnson, Allegion, PLC.
 - 3. IVE - Ives, Allegion, PLC.
 - 4. KNX/KNO - Knox Company.
 - 5. LCN - LCN Commercial Division, Allegion, PLC.
 - 6. SCE - Schlage Electronic Security, Allegion, PLC
 - 7. SCH/SC - Schlage Lock Company, Allegion, PLC.

8. VON - Von Duprin, Allegion, PLC..
9. ZER - Zero Industries, Inc., Allegion, PLC.
10. TBD - To be determined.
11. B/O, BYO, OT - By Other trades.

2.02 DESCRIPTION

- A. Door hardware sets provided represent the design intent, they are only a guideline and should not be considered a detailed or complete hardware schedule.
 1. Provide door hardware item(s) as required for similar purposes, even when item is not listed for a door in Door Hardware Schedule.
 2. Necessary items that are not included in a Hardware Set should be added and have the appropriate additional hardware as required for proper application and functionality.
 3. Door hardware supplier is responsible for providing proper size and hand of door for products required in accordance with Door Hardware Schedule and as indicated on drawings.
 4. Quantities listed are for each Pair (PR) of doors, or for each Single (SGL) door, as indicated in hardware sets.

2.03 LOCK FUNCTION CODES

- A. Function Codes for Cylindrical Locks: Complying with BHMA A156.5.
- B. Function Codes for Mortise Locks: Complying with BHMA A156.13.
- C. Function Codes for Exit Devices: Complying with BHMA A156.3.

2.04 FINISHES

- A. Finishes: Complying with BHMA A156.18.

PART 3 EXECUTION

3.01 DOOR HARDWARE SCHEDULE

- A. Organize listing of door hardware components within each hardware set in compliance with 10-Part scheduling sequence indicated in DHI (H&S), unless otherwise indicated.
- B. See door schedule in drawings for hardware set assignments.
- C. Do not order hardware until Finished Hardware has been reviewed and approved by Architect's hardware consultant.
- D. Provide Factory order numbers for all products supplied on this project as part of close out documents for District's warranty records.
- E. Any door count quantity shown in the HW set listings is for reference only. Verify all door quantities with the Architectural Drawings.
- F. Hardware Sets:

114473 OPT0378441 VERSION 1

FOR REFERENCE ONLY

GROUP NO. 01

3	EA	HINGE	5BB1 4.5 X 4.5	652	IVE
1	EA	OFFICE LOCK	9K3 7 AB 15D	626	BES
1	EA	FLOOR STOP	FS439	682	IVE
1	EA	GASKETING	188SBK PSA	BK	ZER

GROUP NO. 02

3	EA	HINGE	5BB1 4.5 X 4.5	652	IVE
1	EA	CLASSROOM LOCK	9K3 7 R 15D	626	BES
1	EA	SFIC CORE	1C7	626	BES
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS	630	IVE
1	EA	WALL STOP	WS406/407CCV	630	IVE
3	EA	SILENCER	SR64	GRY	IVE

GROUP NO. 03

3	EA	HINGE	5BB1 4.5 X 4.5	652	IVE
1	EA	CLASSROOM LOCK	9K3 7 R 15D	626	BES
1	EA	SFIC CORE	1C7	626	BES
1	EA	OH STOP	90S	630	GLY
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS	630	IVE
3	EA	SILENCER	SR64	GRY	IVE

GROUP NO. 04

3	EA	HINGE	5BB1HW 4.5 X 4.5	652	IVE
1	EA	CLASSROOM LOCK	9K3 7 R 15D	626	BES
1	EA	SFIC CORE	1C7	626	BES
1	EA	SURFACE CLOSER	4040XP WMS	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS	630	IVE
1	EA	WALL STOP	WS406/407CCV	630	IVE
1	EA	GASKETING	188SBK PSA	BK	ZER

GROUP NO. 05

3	EA	HINGE	5BB1 4.5 X 4.5	652	IVE
1	EA	STOREROOM LOCK	9K3 7 D 15D	626	BES
1	EA	SFIC CORE	1C7	626	BES
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS	630	IVE
1	EA	FLOOR STOP/HOLDER	FS40	626	IVE
1	EA	GASKETING	188SBK PSA	BK	ZER

FOR REFERENCE ONLY

GROUP NO. 06

3	EA	HINGE	5BB1 4.5 X 4.5	652	IVE
1	EA	PRIVACY LOCK	9K3 0 L 15D	626	BES
1	EA	SURFACE CLOSER	4040XP WMS	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS	630	IVE
1	EA	WALL STOP	WS406/407CCV	630	IVE
1	EA	GASKETING	188SBK PSA	BK	ZER

GROUP NO. 07

3	EA	HINGE	5BB1HW 5 X 4.5	652	IVE
1	EA	INTRUDOR CLASSROOM LOCK	9K3 7 IN 15D	626	BES
2	EA	SFIC CORE	1C7	626	BES
1	EA	SURFACE CLOSER	4040XP SCUSH WMS	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS	630	IVE
1	EA	GASKETING	188SBK PSA	BK	ZER

GROUP NO. 08

3	EA	HINGE	5BB1HW 4.5 X 4.5	652	IVE
1	EA	INTRUDOR CLASSROOM LOCK	9K3 7 IN 15D	626	BES
2	EA	SFIC CORE	1C7	626	BES
1	EA	SURFACE CLOSER	4040XP SCUSH WMS	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS	630	IVE
1	EA	GASKETING	188SBK PSA	BK	ZER

GROUP NO. 09

1	SET	SELF CLOSING HINGE	MAMMOTH 180		LOX
1	EA	PANIC HARDWARE	PA-AX-XP98-L-KC-06-WH	630	VON
1	EA	MORTISE CYLINDER	1E74	626	BES

GROUP NO. 10

HARDWARE BY GATE FABRICATOR

GROUP NO. 11

1	SET	SELF CLOSING HINGE	MAMMOTH 180		LOX
1	EA	PANIC HARDWARE	PA-AX-XP98-L-KC-06-WH	630	VON
1	EA	RIM CYLINDER	12E72	626	BES

FOR REFERENCE ONLY

END OF SECTION

SECTION 08 11 13 HOLLOW METAL DOORS AND FRAMES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Non-fire-rated hollow metal doors and frames.
- B. Thermally insulated hollow metal doors with frames.

1.02 RELATED REQUIREMENTS

- A. Section 08 71 00 - Door Hardware.
- B. Section 09 91 13 - Exterior Painting: Field painting.
- C. Section 09 91 23 - Interior Painting: Field painting.

1.03 ABBREVIATIONS AND ACRONYMS

- A. ANSI: American National Standards Institute.
- B. HMMA: Hollow Metal Manufacturers Association.
- C. NAAMM: National Association of Architectural Metal Manufacturers.
- D. NFPA: National Fire Protection Association.
- E. SDI: Steel Door Institute.
- F. UL: Underwriters Laboratories.

1.04 REFERENCE STANDARDS

- A. ADA Standards - 2010 ADA Standards for Accessible Design.
- B. ANSI/SDI A250.11 - Recommended Erection Instructions for Steel Frames.
- C. ANSI/SDI A250.4 - Test Procedure and Acceptance Criteria for Physical Endurance for Steel Doors, Frames and Frame Anchors.
- D. ANSI/SDI A250.6 - Recommended Practice for Hardware Reinforcing on Standard Steel Doors and Frames.
- E. ANSI/SDI A250.8 - Specifications for Standard Steel Doors and Frames (SDI-100).
- F. ANSI/SDI A250.10 - Test Procedure and Acceptance Criteria for Prime Painted Steel Surfaces for Steel Doors and Frames.
- G. ASTM A153/A153M - Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware.
- H. ASTM A653/A653M - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process.
- I. ASTM A1008/A1008M - Standard Specification for Steel, Sheet, Cold-Rolled, Carbon, Structural, High-Strength Low-Alloy, High-Strength Low-Alloy with Improved Formability, Required Hardness, Solution Hardened, and Bake Hardenable.

FOR REFERENCE ONLY

- J. ASTM A1011/A1011M - Standard Specification for Steel, Sheet and Strip, Hot-Rolled, Carbon, Structural, High-Strength Low-Alloy, High-Strength Low-Alloy with Improved Formability, and Ultra-High Strength.
- K. ASTM E283 - Standard Test Method for Determining the Rate of Air Leakage Through Exterior Windows, Curtain Walls, and Doors Under Specified Pressure Differences Across the Specimen.
- L. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials.
- M. BHMA A156.115 - Hardware Preparation in Steel Doors and Frames.
- N. NAAMM HMMA 830 - Hardware Selection for Hollow Metal Doors and Frames.
- O. NAAMM HMMA 831 - Hardware Locations for Hollow Metal Doors and Frames.
- P. NAAMM HMMA 840 - Guide Specifications For Receipt, Storage and Installation of Hollow Metal Doors and Frames.
- Q. NAAMM HMMA 861 - Guide Specifications for Commercial Hollow Metal Doors and Frames.
- R. SDI 117 - Manufacturing Tolerances for Standard Steel Doors and Frames.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Materials and details of design and construction, hardware locations, reinforcement type and locations, anchorage and fastening methods, and finishes; and one copy of referenced standards/guidelines.
- C. Shop Drawings: Details of each opening, showing elevations, glazing, frame profiles, and any indicated finish requirements.
 - 1. Show fabrication and installation of steel doors and frames. Include details of each frame type, elevations of door design types, conditions at openings, details of construction, location and installation requirements of door and frame hardware and reinforcements, and details of joints and connections. Show anchorage and accessory items.
 - 2. Provide schedule of doors and frames using same reference numbers for details and openings as those indicated on Drawings.
- D. Samples: Submit two samples of metal, 2 by 2 inches in size, showing factory finishes, colors, and surface texture.
- E. Installation Instructions: Manufacturer's published instructions, including any special installation instructions relating to this project.
- F. Manufacturer's Certificate: Certification that products meet or exceed specified requirements.
- G. Manufacturer's Qualification Statement.
- H. Installer's Qualification Statement.

1.06 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing products specified in this section, with not less than three years documented experience.

- B. Installer Qualifications: Company specializing in performing work of the type specified and with at least three years of documented experience.
- C. Maintain at project site copies of reference standards relating to installation of products specified.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Delivery: Provide packaging such as cardboard, or other containers to protect surfaces of hollow metal doors. Strap welded frames together in pairs with head of one unit inverted or provide temporary spreaders fastened to the bottom of each frame.
- B. Comply with NAAMM HMMA 840 or ANSI/SDI A250.8 (SDI-100) in accordance with specified requirements.
 - 1. Store doors and frames on platforms under cover.
 - 2. Store doors and frames in dry storage spaces, with adequate ventilation, free from dust, and which permits easy access for inspection and handling.
 - 3. Avoid using nonvented plastic or canvas shelters that create a humidity chamber.
 - 4. If the wrapper on the door becomes wet, remove the wrapper.
- C. Protect with resilient packaging; avoid humidity build-up under coverings; prevent corrosion and adverse effects on factory applied painted finish.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Hollow Metal Doors and Frames:
 - 1. DCI Hollow Metal: www.dcihollowmetal.com.
 - 2. Ceco Door, an Assa Abloy Group company: www.assaabloydss.com.
 - 3. Curries, an Assa Abloy Group company: www.assaabloydss.com.
 - 4. Republic Doors, an Allegion brand: www.republicdoor.com/#sle.
 - 5. Steelcraft, an Allegion brand: www.allegion.com/sle.
 - 6. Technical Glass Products; SteelBuilt Window & Door Systems: www.tgpamerica.com/#sle.
 - 7. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.

2.02 PERFORMANCE REQUIREMENTS

- A. Requirements for Hollow Metal Doors and Frames:
 - 1. Steel Sheet: Comply with one or more of the following requirements; galvanized steel complying with ASTM A653/A653M, cold-rolled steel complying with ASTM A1008/A1008M, or hot-rolled pickled and oiled (HRPO) steel complying with ASTM A1011/A1011M, commercial steel (CS) Type B, for each.
 - 2. Accessibility: Comply with ADA Standards and CBC Chapter 11B.
 - 3. Exterior Door Top Closures: Flush end closure channel, with top and door faces aligned.
 - 4. Door Edge Profile: Beveled, both sides.

5. Typical Door Face Sheets: Flush. Smooth .
 6. Glazed Lights: Non-removable stops on non-secure side; sizes and configurations as indicated on drawings. Style: Manufacturer's standard.
 7. Hardware Preparations, Selections and Locations: Comply with NAAMM HMMA 830 and NAAMM HMMA 831 or BHMA A156.115 and ANSI/SDI A250.8 (SDI-100) in accordance with specified requirements.
 8. Zinc Coating for Typical Interior and/or Exterior Locations: Provide metal components zinc-coated (galvanized) and/or zinc-iron alloy-coated (galvannealed) by the hot-dip process in accordance with ASTM A653/A653M, with manufacturer's standard coating thickness, unless noted otherwise for specific hollow metal doors and frames.
 - a. Based on SDI Standards: Provide at least A40/ZF120 (galvannealed) when necessary, coating not required for typical interior door applications, and at least A60/ZF180 (galvannealed) for corrosive locations.
- B. Combined Requirements: If a particular door and frame unit is indicated to comply with more than one type of requirement, comply with the specified requirements for each type; for instance, an exterior door that is also indicated as being sound-rated must comply with the requirements specified for exterior doors and for sound-rated doors; where two requirements conflict, comply with the most stringent.

2.03 HOLLOW METAL DOORS

- A. Door Finish: Factory primed and field finished.
- B. Exterior Doors: Thermally insulated.
 1. Based on SDI Standards: ANSI/SDI A250.8 (SDI-100).
 - a. Level 3 - Extra Heavy-duty.
 - b. Physical Performance Level A, 1,000,000 cycles; in accordance with ANSI/SDI A250.4.
 - c. Model 2 - Seamless.
 - d. Door Face Metal Thickness: 16 gauge, 0.053 inch, minimum.
 - e. Zinc Coating: A60/ZF180 galvannealed coating; ASTM A653/A653M.
 2. Core Material: Vertical steel stiffeners with fiberglass batts.
 - a. Foam Plastic Insulation: Manufacturer's standard board insulation with maximum flame spread index (FSI) of 75, and maximum smoke developed index (SDI) of 450 in accordance with ASTM E84, and completely enclosed within interior of door.
 3. Door Thermal Resistance: U-factor of 0.70 maximum.
 - a. Doors with no glazing or less than 50 percent glazed shall comply with the required U-factor not greater than the applicable value (0.70) in Subchapter Table 140.3-B, C, or D. California Energy Code Section 140.3 (a) 7.
 4. Door Thickness: 1-3/4 inches, nominal.
 5. Weatherstripping: Refer to Section 08 71 00.
 - a. Maximum Air Leakage, ASTM E283: 0.30cfm per square foot of static differential air pressure of 1.567 psf (equivalent to 25 mph wind velocity). California Energy Code Section 110.6(a) 1.

C. Interior Doors, Non-Fire-Rated:

1. Based on SDI Standards: ANSI/SDI A250.8 (SDI-100).
 - a. Level 2 - Heavy-duty.
 - b. Physical Performance Level B 500 000 cycles; in accordance with ANSI/SDI A250.4.
 - c. Model 2 - Seamless.
 - d. Door Face Metal Thickness: 18 gage, 0.042 inch, minimum.
 - e. Zinc Coating: A60/ZF180 galvanized coating; ASTM A653/A653M.
2. Door Core Material: Manufacturers standard core material/construction and in compliance with requirements.
3. Door Thickness: 1-3/4 inches, nominal.

2.04 HOLLOW METAL FRAMES

- A. Comply with standards and/or custom guidelines as indicated for corresponding door in accordance with applicable door frame requirements.
- B. Frame Finish: Factory primed and field finished.
 1. Provide compatible primer for Section 09 96 00 - High-Performance Coatings.
- C. Exterior Door Frames: Fully welded.
 1. Galvanizing: Components hot-dipped zinc-iron alloy-coated (galvanized) in accordance with ASTM A653/A653M, with A40/ZF120 coating.
 2. Frame Metal Thickness: 16 gage, 0.053 inch, minimum.
 3. Weatherstripping: Separate, see Section 08 71 00.
- D. Interior Door Frames, Non-Fire Rated: Full profile/continuously welded type.
 1. Frame Metal Thickness: 18 gage, 0.042 inch, minimum.

2.05 FINISHES

- A. Primer: Rust-inhibiting, complying with ANSI/SDI A250.10, door manufacturer's standard.
 1. Exterior Steel Doors and Door Frames: Comply with requirements for primer for finish coats.
 2. Interior Steel Doors and Rolled Steel Door Frames: Rust-inhibitive enamel or paint, either air-drying or baking, suitable as a base for specified finish paints.
- B. Bituminous Coating: Cold-applied asphalt mastic, compounded for 15 mil, 0.015 inch dry film thickness (DFT) per coat; provide inert-type noncorrosive compound free of asbestos fibers, sulfur components, and other deleterious impurities.
- C. Touch-Up Primer for Galvanized Surfaces: SSPC-Paint 20, Type I - Inorganic, complying with VOC limitations of authorities having jurisdiction.
- D. Field Applied Finish Painting: As specified in:
 1. Section 09 91 13 - Exterior Painting.
 2. Section 09 91 23 - Interior Painting.
 3. Exterior Doors (Abuse Resistant): Section 09 96 00 - High-Performance Coatings.

2.06 ACCESSORIES

- A. Supports and Anchors: Fabricate of not less than 16 gage sheet steel; galvanized where used with galvanized frames or at exterior, damp or wet locations.
 - 1. Anchors: Provide in accordance with ANSI/SDI A250.11.
 - a. Provide one floor anchor and the number of wall anchors listed below welded into each jamb member.
 - 1) Number of anchors at:
 - (a) Wood Stud Partitions: Typically 3, and 4 for doors over 7'-0" high.
 - b. Wall anchors shall be of type indicated for the specific wall condition and of same material specified for frames.
 - c. Provide head anchors welded into head member as recommended by the frame manufacturer.
 - d. Anchors: 16 gage minimum for galvanized frames and 16 gage minimum for cold or hot rolled steel frames.
 - e. Provide "Z" spacer type anchors for all wood studs.
 - 2. Punch and dimple jambs within 6 inches of bottom for attachment to concrete stem walls where occur.
- B. Silencers: Resilient rubber, fitted into drilled hole; provide three on strike side of single door, three on center mullion of pairs, and two on head of pairs without center mullions.
 - 1. Omit silencers where head and jamb bulb-type weatherstripping or sound seals are to be installed and omit where in violation of fire rating. Silencers are specified in Section 08 71 00 - Door Hardware.
- C. Temporary Frame Spreaders: Provide for factory- or shop-assembled frames.
- D. Inserts, Bolts, and Fasteners: Manufacturer's standard units. Where items are to be built into exterior walls, hot-dip galvanize in compliance with ASTM A153/A153M, Class C or D as applicable.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify existing conditions before starting work.
- B. Verify that opening sizes and tolerances are acceptable.
- C. Verify that finished walls are in plane to ensure proper door alignment.

3.02 PREPARATION

- A. Coat inside of frames to be installed in masonry or to be grouted, with bituminous coating, prior to installation.

3.03 INSTALLATION

- A. Install doors and frames in accordance with manufacturer's instructions and related requirements of specified door and frame standards or custom guidelines indicated.

- B. Coordinate frame anchor placement with wall construction.
- C. Install door hardware as specified in Section 08 71 00.
 - 1. Comply with recommended practice for hardware placement of doors and frames in accordance with ANSI/SDI A250.6 or NAAMM HMMA 861.
- D. Welded Steel Frames Installation:
 - 1. Install frame solid in the wall, plumb and square, with proper opening width and height.
 - a. Dry-pack void when frame set in place.
 - 2. Fasten clip angles to floor construction and brace frames so as to retain their position and clearance during construction of adjacent Work. Attach structural overhead bracing securely to structure above, as required.
 - 3. Install anchors for connection to concrete/masonry at each jamb (minimum 3 per jamb).
 - 4. Install anchors for stud partitions on hinge jamb immediately above each hinge reinforcing plate and below the top hinge reinforcement (minimum 4 per jamb) and locate anchors directly opposite on the strike jamb.
- E. Doors Installation, General: Hang doors and adjust for proper clearances and operation. Refer to Section 08 71 00 - Door Hardware for hardware requirements.
- F. Touch up damaged factory finishes.

3.04 REPAIRS

- A. Make repairs only if permitted by Architect. Otherwise, replace damaged components.
- B. Fill surface depressions with metallic paste filler, allow to thoroughly cure, sand flush, and smooth for an invisible appearance with adjacent metal surfaces.
- C. Sand smooth all rusted areas.
- D. Repair galvanized surfaces with specified repair compound.
- E. Apply touch-up paint using air drying primer compatible with shop-applied finish.

3.05 TOLERANCES

- A. Flush Steel Door Installation Tolerances: Fit hollow metal doors accurately in frames, within clearances specified in ANSI/SDI A250.8.
- B. Clearances Between Door and Frame: Comply with related requirements of specified frame standards or custom guidelines indicated in accordance with SDI 117 or NAAMM HMMA 861.
- C. Maximum Diagonal Distortion: 1/16 inch measured with straight edge, corner to corner.

3.06 ADJUSTING

- A. Adjust for smooth and balanced door movement.
- B. Test sound control doors for force to close, latch, and unlatch; adjust as necessary in compliance with requirements.

3.07 CLEANING AND PROTECTION

- A. Prime Coat Touch-up: Immediately after installation, sand smooth all corroded (rusted), damaged and deteriorated areas of prime coat and apply touch-up coat of compatible air-drying primer.
- B. Protection: Protect installed frames and doors from damage.
 - 1. Provide protective coverings and other devices as necessary, in conformance to requirements specified in Section 01 50 00 - Temporary Facilities and Controls.
 - 2. Remove protective devices from prefinished components for Substantial Completion review.
- C. Final Adjustments: Check and readjust operating hardware items, leaving steel doors and frames undamaged and in complete and proper operating condition.
- D. Cleaning: Clean doors and frames of surface contaminants detrimental to proper application of field-applied finishes.

3.08 SCHEDULE - SEE DRAWINGS

- A. Refer to Door and Frame Schedule on the drawings.

END OF SECTION

SECTION 08 14 16 FLUSH WOOD DOORS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Flush wood doors; flush configuration; fire rated and non-rated.

1.02 RELATED REQUIREMENTS

- A. Section 08 11 13 - Hollow Metal Doors and Frames.
- B. Section 08 71 00 - Door Hardware.
- C. Section 08 80 00 - Glazing.
- D. Section 09 91 23 - Interior Painting: Field finishing of doors.

1.03 REFERENCE STANDARDS

- A. AWI/AWMAC/WI (AWS) - Architectural Woodwork Standards, 2nd Edition.
- B. AWMAC/WI (NAAWS) - North American Architectural Woodwork Standards.
- C. WDMA I.S. 1A - Interior Architectural Wood Flush Doors.
- D. WI (MCP) - Monitored Compliance Program (MCP).

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Indicate door core materials and construction; veneer species, type and characteristics.
- C. Shop Drawings: Show doors and frames, elevations, sizes, types, swings, undercuts, beveling, blocking for hardware, factory machining, factory finishing, cutouts for glazing and other details.
 - 1. Provide information as required by AWMAC/WI (NAAWS).
 - 2. Include certification program label.
- D. Samples: Submit two samples of door veneer, 12 by 12 inches in size illustrating wood grain, stain color, and sheen.
- E. Certificate: Submit labels and certificates required by quality assurance and quality control programs.
- F. Test Reports: Show compliance with specified requirements for the following:
 - 1. Sound-retardant doors and frames; sealed panel tests are not acceptable.
- G. Manufacturer's Installation Instructions: Indicate special installation instructions.
- H. Manufacturer's qualification statement.
- I. Installer's qualification statement.
- J. Specimen warranty.

- K. Warranty, executed in District's name.

1.05 QUALITY ASSURANCE

- A. Maintain one copy of the specified door quality standard on site for review during installation and finishing.
- B. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section, with not less than three years of documented experience.
 - 1. Company with at least one project within past five years with value of woodwork within at least 20 percent of cost of woodwork for this project.
 - 2. Accredited participant in the specified certification program prior to the commencement of fabrication and throughout the duration of the project.
- C. Installer Qualifications: Company specializing in performing work of the type specified in this section, with not less than three years of documented experience.
- D. Woodwork Quality Assurance Program:
 - 1. Comply with WI (MCP) woodwork association quality assurance service/program in accordance with requirements for work specified in this section; www.woodworkinstitute.com/#sle.
 - 2. Provide labels or certificates indicating that installed work will comply with AWMAC/WI (NAAWS) requirements for grade or grades specified.
 - 3. Provide designated labels on shop drawings as required by quality assurance program.
 - 4. Provide designated labels on installed products as required by quality assurance program.
 - 5. Submit documentation upon completion of installation that verifies this work is in compliance with specified requirements.

1.06 DELIVERY, STORAGE, AND HANDLING

- A. Package, deliver and store doors in accordance with specified quality standard.
- B. Accept doors on site in manufacturer's packaging, and inspect for damage.
- C. Protect doors with resilient packaging sealed with heat shrunk plastic; do not store in damp or wet areas or areas where sunlight might bleach veneer; seal top and bottom edges with tinted sealer if stored more than one week, and break seal on site to permit ventilation.

1.07 WARRANTY

- A. See Section 01 78 00 - Closeout Submittals for additional warranty requirements.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Wood Veneer Faced Doors:
 - 1. Haley Brothers: www.haleybros.com/#sle.
 - 2. Masonite Architectural; Aspiro Select Wood Veneer Doors: www.architectural.masonite.com/#sle.

3. Oregon Door: www.oregondoor.com.
4. VT Industries, Inc: www.vtindustries.com/#sle.
5. Substitutions: See Section 01 60 00 - Product Requirements.

2.02 DOORS

- A. Doors: See drawings for locations and additional requirements.
 1. Quality Standard: Custom Grade, Extra Heavy Duty performance, in accordance with AWMAC/WI (NAAWS) or WDMA I.S. 1A.
 2. Wood Veneer Faced Doors: 5-ply unless otherwise indicated.
- B. Interior Doors: 1-3/4 inches thick unless otherwise indicated; flush construction.
 1. Provide solid core doors at each location.
 2. Wood veneer facing with factory transparent finish.

2.03 DOOR AND PANEL CORES

- A. Non-Rated Solid Core and 20 Minute Rated Doors: Type staved lumber core (SLC), plies and faces as indicated.

2.04 DOOR FACINGS

- A. Veneer Facing for Transparent Finish: Architect selected, veneer grade in accordance with quality standard indicated, quarter cut, with slip match between leaves of veneer, running match of spliced veneer leaves assembled on door or panel face; unless otherwise indicated.
 1. Vertical Edges: Any option allowed by quality standard for grade.
 2. "Running Match" each pair of doors and doors in close proximity to each other.
 3. "Pair Match" each pair of doors; "Set Match" pairs of doors within 10 feet of each other when doors are closed.
- B. Facing Adhesive: Type II - water resistant.

2.05 DOOR CONSTRUCTION

- A. Fabricate doors in accordance with door quality standard specified.
- B. Cores Constructed with stiles and rails:
 1. Provide solid blocks at lock edge and top of door for closer for hardware reinforcement.
- C. Where supplementary protective edge trim is required, install trim after veneer facing has been applied full-width.
- D. Factory machine doors for hardware other than surface-mounted hardware, in accordance with hardware requirements and dimensions.
- E. Factory fit doors for frame opening dimensions identified on shop drawings, with edge clearances in accordance with specified quality standard.
- F. Provide edge clearances in accordance with the quality standard specified.

2.06 FINISHES - WOOD VENEER DOORS

- A. Finish work in accordance with AWMAC/WI (NAAWS), Section 5 - Finishing for grade specified and as follows:
 - 1. Transparent:
 - a. System - 11 Polyurethane Catalyzed.
 - b. Stain: As selected by Architect.
 - c. Sheen: Satin.
 - 2. Opaque:
 - a. System - 4 Latex Acrylic Water-based.
 - b. Color: As selected by Architect.
 - c. Sheen: Flat.
- B. Finish work in accordance with WDMA I.S. 1A for grade specified and as follows:
 - 1. Transparent:
 - a. System - TR-6, Catalyzed Polyurethane.
 - b. Stain: As selected by Architect.
 - c. Sheen: Satin.
 - 2. Opaque:
 - a. Manufacturers standard, in compliance with performance duty level indicated.
 - b. Color: As selected by Architect.
 - c. Sheen: Satin.
- C. Factory finish doors in accordance with approved sample.
- D. Seal door top edge with color sealer to match door facing.

2.07 ACCESSORIES

- A. Hollow Metal Door Frames: See Section 08 11 13.
- B. Metal Louvers:
 - 1. Material and Finish: Roll formed steel; pre-painted finish to color as selected.
 - 2. Louver Blade: Inverted V blade, sight proof, light proof.
 - 3. Louver Free Area: ____ percent.
- C. Door Hardware: See Section 08 71 00.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify existing conditions before starting work.
- B. Verify that opening sizes and tolerances are acceptable.
- C. Do not install doors in frame openings that are not plumb or are out-of-tolerance for size or alignment.

3.02 INSTALLATION

- A. Install doors in accordance with manufacturer's instructions, rated listing, and specified quality standard.
- B. Factory-Finished Doors: Do not field cut or trim; if fit or clearance is not correct, replace door.
- C. Field-Finished Doors: Trimming to fit is acceptable.
 - 1. Adjust width of non-rated doors by cutting equally on both jamb edges.
 - 2. Trim maximum of 3/4 inch off bottom edges.
- D. Use machine tools to cut or drill for hardware.
- E. Coordinate installation of doors with installation of frames and hardware.
- F. Coordinate installation of glazing.

3.03 TOLERANCES

- A. Comply with specified quality standard for fit and clearance tolerances.
- B. Comply with specified quality standard for telegraphing, warp, and squareness.

3.04 ADJUSTING

- A. Adjust doors for smooth and balanced door movement.
- B. Adjust closers for full closure.

3.05 SCHEDULE - SEE DRAWINGS

END OF SECTION

FOR REFERENCE ONLY

SECTION 08 31 00 ACCESS DOORS AND PANELS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Wall- and ceiling-mounted access units.

1.02 RELATED REQUIREMENTS

- A. Section 09 91 23 - Interior Painting: Field paint finish.

1.03 REFERENCE STANDARDS

- A. DSA IR 25-3 - Suspended Gypsum Board Ceiling.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide sizes, types, finishes, hardware, scheduled locations, and details of adjoining work.
- C. Shop Drawings: Indicate exact position of each access door and/or panel unit.
- D. Manufacturer's Installation Instructions: Indicate installation requirements.
- E. Installer's qualification statement.
- F. Project Record Documents: Record actual locations of each access unit.

1.05 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum three years documented experience.
- B. Installer Qualifications: Company specializing in performing work of the type specified and with at least three years documented experience.
- C. Single-Source Responsibility: Obtain access doors for entire project from one source from a single manufacturer.
- D. Size Variations: Obtain Architect's acceptance of manufacturer's standard size units, which may vary slightly from sizes indicated.
- E. Coordination: Furnish inserts and anchoring devices for building into adjoining Work for installation of access doors.

PART 2 PRODUCTS

2.01 ACCESS DOORS AND PANELS ASSEMBLIES

- A. Access Door Materials and Fabrication, General: Provide each access door assembly manufactured as an integral unit, complete with all parts, and ready for installation.

FOR REFERENCE ONLY

1. If size is not indicated, provide size as directed to adequately access concealed operable mechanisms.
- B. Wall-Mounted Units:
1. Location: As indicated on drawings.
 2. Panel Material: Steel.
 3. Size: 12 by 12 inches, nominal minimum..
 4. Door/Panel: Hinged, standard duty, with tool-operated spring or cam lock and no handle.
 5. Wall Mounting Criteria: Provide surface-mounted face frame and door surface flush with frame surface.
- C. Wall-Mounted Units in Wet Areas:
1. Location: As indicated on drawings.
 2. Panel Material: Stainless steel, Type 304.
 3. Size: 12 by 12 inches, nominal minimum..
 4. Door/Panel: Hinged, standard duty, with tool-operated spring or cam lock and no handle.
 5. Wall Mounting Criteria: Provide surface-mounted face frame and door surface flush with frame surface.
- D. Ceiling-Mounted Units:
1. Location: As indicated on drawings.
 2. Panel Material: Steel.
 3. Size - Lay-In Grid Ceilings: To match module of ceiling grid.
 4. Size - Other Ceilings: 12 by 12 inches.
 - a. Maximum 325 square inches per DSA IR 25-3 in suspended gypsum board ceilings, for utility access only.
 - 1) Provide a permanently attached warning label stating:
 - (a) "Warning: Do not climb, walk, or crawl on the gypsum board ceiling panels or metal framing. Do not store or stow anything on the gypsum board or metal framing."
 5. Door/Panel: Hinged, standard duty, with tool-operated spring or cam lock and no handle.
 - a. Open with allen wrench - no keys.
 - b. Include a retention spring or bar to keep door from falling open rapidly.

2.02 WALL- AND CEILING-MOUNTED ACCESS UNITS

- A. Manufacturers:
1. Activar Construction Products Group, Inc. - JL Industries: www.activarcpg.com/#sle.
 2. ACUDOR Products Inc: www.acudor.com/#sle.
 3. Babcock-Davis: www.babcockdavis.com/#sle.

FOR REFERENCE ONLY

4. Cendrex, Inc: www.cendrex.com/#sle.
 5. Karp Associates, Inc: www.karpinc.com/#sle.
 6. Larsen's Manufacturing Co.: www.larsensmfg.com.
 7. Nystrom, Inc: www.nystrom.com/#sle.
 8. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Wall- and Ceiling-Mounted Units: Factory-fabricated door and frame, fully assembled units with corner joints welded, filled and ground flush; square and without rack or warp; coordinate requirements with type of installation assembly being used for each unit.
1. Style: Exposed frame with door surface flush with frame surface.
 - a. Gypsum Board Mounting Criteria: Use drywall bead type frame.
 - b. Plaster Mounting Criteria: Use plaster bead type frame.
 2. Door Style: Single thickness with rolled or turned in edges.
 3. Frames: 16-gauge, 0.0598-inch minimum thickness.
 4. Heavy-Duty Frames: 14-gauge, 0.0747-inch minimum thickness.
 5. Single Steel Sheet Door Panels: 16-gauge, 0.0625-inch minimum thickness.
 6. Door Panels to Receive Wall/Ceiling Finish: Surface recessed 5/8 inch back from wall face.
 - a. For recess-mounted access doors, provide access sleeves for each locking device.
 - b. Provide plastic grommets for installation in holes cut through finish.
 - c. Provide recess-mounted doors for concealed installation in:
 - 1) Acoustic tile ceiling systems, where indicated.
 - 2) Acoustical tile-finished gypsum board ceilings, where indicated.
 - 3) Gypsum board walls, where indicated.
 - 4) Ceramic tile walls, where indicated.
 7. Insulation: Non-combustible mineral wool or glass fiber.
 8. Primed and Factory Finish: Polyester powder coat; color as selected by Architect from manufacturer's standard colors.
 9. Door/Panel Size: As indicated on the drawings.
 10. Hardware:
 - a. Hinges for Non-Fire-Rated Units: Concealed, constant force closure spring type.
 - b. Latch/Lock: Screw driver slot for quarter turn cam latch.
 - c. Gasketing: Extruded neoprene, around perimeter of door panel.
- C. Provide recess-mounted doors and frames with expanded metal lath for concealed installation in plaster.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that rough openings are correctly sized and located.
- B. Begin installation only after substrates have been properly prepared, and if the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.

3.02 PREPARATION

- A. Clean surfaces thoroughly prior to proceeding with this work.
- B. Prepare surfaces using methods recommended by manufacturer for applicable substrates in accordance with project conditions.

3.03 INSTALLATION

- A. Install units in accordance with manufacturer's instructions.
- B. Install frames plumb and level in openings, and secure units rigidly in place.
- C. Provide for correct termination of adjoining finish materials.
- D. Position units to provide convenient access to concealed equipment when necessary.

3.04 ADJUST AND CLEAN

- A. Adjust access doors and hardware after installation for proper and smooth operation.
- B. Remove and replace panels or frames that are warped, bowed, or otherwise damaged.
- C. Remove protective coverings and clean stainless steel access doors during cleaning for Substantial Completion Review.

3.05 SCHEDULES

- A. Access Door Locations:
 - 1. Provide access doors where indicated on Architectural, Mechanical, Plumbing and Electrical Drawings.
 - 2. Access doors indicated and required for Mechanical, Plumbing and Electrical Work shall be of a type matching those specified in this Section.
 - 3. Provide access doors as required to service building systems and as required by governing authorities, although not shown on Drawings.
 - a. Provide at smoke or fire detector in attic spaces. Size to allow for access and testing.
 - 4. Locate access doors, where practical, in building service areas and not in public or guest view.
 - 5. Submit proposed locations for access doors, not indicated on Drawings, to Architect for review prior to rough-in.
- B. Non-Fire Rated Door and Frame Units in Walls:
 - 1. In Gypsum Board on Studs:
 - a. For service and utility locations, primer paint finish, Model DSC-214M manufactured by Karp.

FOR REFERENCE ONLY

- b. For food service, toilet and damp locations, stainless steel, Model DSC-214M manufactured by Karp.
 - c. For Administration, Multi-Purpose and similar areas accessible by general public, recessed face for field-applied and finished plaster on door face, Model RDW manufactured by Karp.
 - d. For toilets and locations accessible by general public with ceramic tile wall finish, flush-mounted with face of tile, stainless steel, Model DSB-214M manufactured by Karp.
- C. Non-Fire Rated Door and Frame Units in Ceilings:
- 1. In Gypsum Board on Metal Furring:
 - a. For service and utility locations, primer paint finish, Model DSC-214M manufactured by Karp.
 - b. For food service, toilet and damp locations, stainless steel, Model DSC-214M manufactured by Karp.
 - c. For Administration, Multi-Purpose and similar areas accessible by general public, recessed face for field-applied and finished plaster on door face, Model RDW manufactured by Karp.
- D. Fire-Rated Access Doors: Access doors in time-rated fire-resistive walls, partitions and ceilings shall carry same rating as the wall, partition or ceiling.
- E. Fire Rated Door and Frame Units in Walls:
- 1. In Gypsum Board on Studs:
 - a. 1-1/2 hour B label fire rating.
 - b. For public areas, service and utility locations, primer paint finish, surface mounted, filled with 2-inch thick fire-rated insulation, with automatic closer, self-latching bolt-type latch, Model KPR-150FR manufactured by Karp.
 - c. For Food Service, Toilet and other damp locations with ceramic tile finish, stainless steel finish, surface mounted, filled with 2-inch thick fire-rated insulation, with automatic closer, self-latching bolt-type latch, Model KPR-150FR manufactured by Karp.
- F. Fire Rated Door and Frame Units in Ceilings:
- 1. In Gypsum Board on Metal Furring:
 - a. For typical dry locations, surface mounted, primer paint finish, filled with 2-inch thick fire-rated insulation, with automatic closer, self-latching bolt-type latch, Model KRP-150FR manufactured by Karp.
 - b. For Food Service, Toilet and other damp locations, stainless steel finish, surface mounted, filled with 2-inch thick fire-rated insulation, with automatic closer, self-latching bolt-type latch, Model KPR-150FR manufactured by Karp.

END OF SECTION

SECTION 08 33 13 COILING COUNTER DOORS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Non-fire-rated coiling counter doors and operating hardware.
- B. Electric motor operation; wiring from electric circuit disconnect to operator to control station.

1.02 RELATED REQUIREMENTS

- A. Section 07 92 00 - Joint Sealants: Sealing joints between frames and adjacent construction.
- B. Division 26 - Electrical:
 - 1. Power to disconnect.
 - 2. Conduit from electric circuit to operator and from operator to control station.
- C. Section 26 05 83 - Wiring Connections: Power to disconnect.

1.03 REFERENCE STANDARDS

- A. ASTM A666 - Standard Specification for Annealed or Cold-Worked Austenitic Stainless Steel Sheet, Strip, Plate, and Flat Bar.
- B. ITS (DIR) - Directory of Listed Products.
- C. NEMA 250 - Enclosures for Electrical Equipment (1000 Volts Maximum).
- D. NEMA MG 1 - Motors and Generators.
- E. UL (DIR) - Online Certifications Directory.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Submit manufacturer's standard literature showing materials and details of construction and finish. Include data on electrical operation.
- C. Shop Drawings: Indicate rough and actual opening dimensions, anchorage methods, hardware locations, and installation details.
- D. Samples: Two slats, 4 inches long, illustrating shape, color, and finish texture.
- E. Manufacturer's Installation Instructions: Indicate installation sequence and installation, adjustment, and alignment procedures.
- F. Manufacturer's qualification statement.
- G. Installer's qualification statement.
- H. Specimen warranty.
- I. Operation and Maintenance Data: Indicate modes of operation, lubrication requirements and frequency, and periodic adjustments required.
- J. Project Record Documents: Include as-built electrical diagrams for electrical operation and connection to fire alarm system.

1.05 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum three years of documented experience.
- B. Installer Qualifications: Company specializing in performing work of type specified and with at least three years documented experience.
- C. Products Requiring Electrical Connection: Listed and classified by ITS (DIR), UL (DIR), or testing firm acceptable to authorities having jurisdiction as suitable for the purpose specified and indicated.
- D. Coordinate with the following sections to provide these doors from the same manufacturer.
 - 1. Section 08 36 13 - Sectional Doors.

1.06 WARRANTY

- A. See Section 01 78 00 - Closeout Submittals for additional warranty requirements.
- B. Manufacturer Warranty: Provide 2-year manufacturer warranty for counterbalance shaft assembly. Complete forms in District's name and register with manufacturer.

1.07 WARRANTY

- A. Standard Warranty: Two years from date of substantial completion against defects in material and workmanship.
- B. Maintenance: Submit for District's consideration and acceptance of a maintenance service agreement for installed products.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Coiling Counter Doors:
 - 1. PC-1 Basis of Design Product: Model ESC10 as manufactured by CornellCookson, or approved equal.
 - 2. Clopay Building Products : www.clopaydoor.com.
 - 3. CornellCookson : www.cornellcookson.com.
 - 4. Overhead Door Corp. : www.overhaddoor.com.
 - 5. Substitutions: See Section 01 60 00 - Product Requirements.

2.02 COILING COUNTER DOORS

- A. Coiling Counter Doors, Non-Fire-Rated: Stainless steel slat curtain.
 - 1. Mounting: As indicated on drawings.
 - 2. Provide integral frame and sill of same material and finish.
 - 3. Nominal Slat Size: 1-1/2 inches wide.
 - 4. Slat Profile: Flat.
 - 5. Finish, Galvanized Steel: Factory powder coated.

6. Color: As indicated on drawings.
7. Guides: Formed track; same material and finish unless otherwise indicated.
8. Hood Enclosure: Manufacturer's standard; stainless steel.
9. Electric operation.

2.03 COMPONENTS

- A. Metal Curtain Construction: Interlocking, single-thickness slats.
 1. Slat Ends: Alternate slats fitted with end locks to act as wearing surface in guides and to prevent lateral movement.
 2. Curtain Bottom: Fitted with angles to provide reinforcement and positive contact in closed position.
 3. Stainless Steel Slats: ASTM A666, Type 304; minimum thickness 22 gauge, 0.03 inch.
- B. Guide Construction: Continuous, of profile to retain door in place, with mounting brackets of same metal.
 1. Stainless Steel Guides: ASTM A666, Type 304, rollable temper.
- C. Hood Enclosure: Internally reinforced to maintain rigidity and shape.
- D. Lock Hardware:
 1. For motor operated units, additional lock or latching mechanisms are not required.
- E. Roller Shaft Counterbalance: Steel pipe and torsion steel spring system, capable of producing torque sufficient to ensure smooth operation of curtain from any position and capable of holding position at mid-travel; with adjustable spring tension; requiring 25 lb nominal force to operate.

2.04 ELECTRIC OPERATION

- A. Operator, Controls, Actuators, and Safeties: Listed and classified by ITS (DIR), UL (DIR), or testing agency acceptable to authorities having jurisdiction (AHJ) as suitable for purpose specified and indicated.
 1. Provide interlock switches on motor operated units.
 2. Provide tamper-proof operation cycle counter.
- B. Electric Operators:
 1. Mounting: Concealed Tubular Mounted.
 2. Motor Enclosure: NEMA MG 1.
 3. Motor Rating: As recommended by manufacturer; continuous duty.
 4. Motor Voltage: 110-120 VAC, single phase, 60 Hz.
 5. Opening Speed: 6 inches per second.
 6. Manual override in case of power failure.
- C. Control Station: Standard three button (OPEN-STOP-CLOSE) momentary control for each electrical operator.
 1. Controls: 24 VAC circuit.
 2. Recessed.

3. Switch type: Toggle, NEMA 250, 1.
- D. Safety Edge: Located at bottom of curtain, full width, electro-mechanical sensitized type, wired to stop operator upon striking object, hollow neoprene covered.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that adjacent construction is suitable for door installation.
- B. Verify that electrical services have been installed and are accessible.
- C. Verify that door opening is plumb, header is level, and dimensions are correct.
- D. Notify Architect of any unacceptable conditions or varying dimensions.
- E. Commencement of installation indicates acceptance of substrate and door opening conditions.

3.02 INSTALLATION

- A. Install units in accordance with manufacturer's instructions.
- B. Use anchorage devices to securely fasten assembly to wall construction and building framing without distortion or stress.
- C. Securely and rigidly brace components suspended from structure. Secure guides to structural members only.
- D. Fit and align assembly including hardware; level and plumb, to provide smooth operation.
- E. Coordinate installation of electrical service with Division 26 - Electrical.
- F. Complete wiring from disconnect to unit components.
- G. Install perimeter trim as indicated.

3.03 TOLERANCES

- A. Maintain dimensional tolerances and alignment with adjacent work.
- B. Maximum Variation From Plumb: 1/16 inch.
- C. Maximum Variation From Level: 1/16 inch.
- D. Longitudinal or Diagonal Warp: Plus or minus 1/8 inch per 10 ft straight edge.

3.04 FIELD QUALITY CONTROL

- A. Completed Installation: Coiling doors shall be free from warps, twists and other distortions, and operate freely.
- B. Demonstration: Upon completion of installation and for Final Inspection review, demonstrate proper operation of each coiling door.
 1. Open and close each motorized coiling door 5 cycles with motor-operator and 1 cycle with manual operator.
 2. Operate emergency operating device through 2 cycles.

FOR REFERENCE ONLY

3.05 ADJUSTING

- A. Adjust operating assemblies for smooth and noiseless operation.

3.06 CLEANING

- A. Clean installed components.
- B. Remove labels and visible markings.

END OF SECTION

SECTION 08 43 13 ALUMINUM-FRAMED STOREFRONTS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Aluminum-framed storefront, with vision glass. ALUM-1
- B. Infill panels of glass.
- C. Aluminum doors and frames.
- D. Weatherstripping.
 - 1. Perimeter sealant.

1.02 RELATED REQUIREMENTS

- A. Section 05 12 00 - Structural Steel Framing: Steel attachment members.
- B. Section 05 50 00 - Metal Fabrications: Steel attachment devices.
- C. Section 07 25 00 - Weather Barriers: Sealing framing to water-resistive barrier installed on adjacent construction.
- D. Section 07 92 00 - Joint Sealants: Sealing joints between frames and adjacent construction.
- E. Section 08 71 00 - Door Hardware: Hardware items other than specified in this section.
- F. Section 08 80 00 - Glazing: Glass and glazing accessories.

1.03 REFERENCE STANDARDS

- A. AAMA CW-10 - Care and Handling of Architectural Aluminum from Shop to Site.
- B. ADA Standards - 2010 ADA Standards for Accessible Design.
- C. AAMA 501.2 - Quality Assurance and Diagnostic Water Leakage Field Check of Installed Storefronts, Curtain Walls, and Sloped Glazing Systems.
- D. AAMA 503 - Voluntary Specification for Field Testing of Newly Installed Storefronts, Curtain Walls and Sloped Glazing Systems.
- E. AAMA 609 & 610 - Cleaning and Maintenance Guide for Architecturally Finished Aluminum (Combined Document).
- F. AAMA 611 - Voluntary Specification for Anodized Architectural Aluminum.
- G. ASCE 7 - Minimum Design Loads and Associated Criteria for Buildings and Other Structures.
- H. ASTM B209/B209M - Standard Specification for Aluminum and Aluminum-Alloy Sheet and Plate.
- I. ASTM B221 - Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes.
- J. ASTM B221M - Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes (Metric).
- K. ASTM D2000 - Standard Classification System for Rubber Products in Automotive Applications.

- L. ASTM D2287 - Standard Specification for Nonrigid Vinyl Chloride Polymer and Copolymer Molding and Extrusion Compounds.
- M. ASTM E283/E283M - Standard Test Method for Determining Rate of Air Leakage Through Exterior Windows, Skylights, Curtain Walls, and Doors Under Specified Pressure Differences Across the Specimen.
- N. ASTM E330/E330M - Standard Test Method for Structural Performance of Exterior Windows, Doors, Skylights and Curtain Walls by Uniform Static Air Pressure Difference.
- O. ASTM E331 - Standard Test Method for Water Penetration of Exterior Windows, Skylights, Doors, and Curtain Walls by Uniform Static Air Pressure Difference.
- P. ASTM E1105 - Standard Test Method for Field Determination of Water Penetration of Installed Exterior Windows, Skylights, Doors, and Curtain Walls, by Uniform or Cyclic Static Air Pressure Difference.
- Q. CBC Chapter 11B - California Building Code-Chapter 11B.
- R. NFRC 100 - Procedure for Determining Fenestration Product U-factors.
- S. NFRC 200 - Procedure for Determining Fenestration Product Solar Heat Gain Coefficient and Visible Transmittance at Normal Incidence.
- T. NFRC 300 - Test Method for Determining the Solar Optical Properties of Glazing Materials and Systems.
- U. SSPC-Paint 20 - Zinc-Rich Coating (Type I - Inorganic, and Type II - Organic).

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordinate with installation of other components that comprise the exterior enclosure.
- B. Preinstallation Meeting: Conduct a preinstallation meeting one week before starting work of this section; require attendance by all affected installers.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Structural and Energy design of the system has already been used as a basis of approval by Division of the State Architect and other agencies. If a substitution is proposed, then the Contractor is responsible for the re-approval of the documents in a timely manner within the original project schedule, along with all professional and agency fees related to this substitution. See Section 01 60 00 - Product Requirements.
- C. Product Data: Provide component dimensions, describe components within assembly, anchorage and fasteners, glass and infill, door hardware, and internal drainage details.
- D. Shop Drawings: Indicate system dimensions, framed opening requirements and tolerances, affected related work, expansion and contraction joint location and details, and field welding required.
 - 1. Include construction details and fabrication methods, profiles and dimensions of individual components, data on hardware, accessories, and finishes.
 - 2. Complete, indicating elevation views of all units, attachments to surrounding construction of Project, type of glazing, and all door hardware and weatherstripping. Manufacturer to prepare all Shop Drawings and include manufacturer's logo.

- E. Samples: Submit two samples 2 x 3 inches in size illustrating finished aluminum surface, glass, glazing materials.
- F. Manufacturer's Certificate: Certify that the products supplied meet or exceed the specified requirements.
 - 1. Energy Model Submissions:
 - a. Provide a copy of the project ENV-1 form.
 - b. Provide evidence that the proposed products can meet or exceed the energy values listed on the ENV-1 form. Preferred method is an NFRC site certificate, but a simulation report by an independent NFRC certified simulator will be considered. *AAMA test reports and or simulations will not be accepted as they are not allowed under the current code.*
 - c. Provide a statement of who will be the "responsible party" in issuing the NFRC site certificates.
- G. Field Quality Control Submittals: Report of field testing for water penetration and air leakage.
- H. Manufacturer's qualification statement.
- I. Installer's qualification statement.
- J. Specimen warranty.

1.06 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in performing work of type specified and with at least ten years of documented experience.
 - 1. Provide certified glass products through ANSI accredited certifications that include plant audits and independent laboratory performance testing.
 - a. Insulating Glass Certification Council (IGCC).
 - b. Safety Glazing Certification Council (SGCC).
- B. Installer Qualifications: Company specializing in performing work of type specified and with at least three years of documented experience.
 - 1. Provide company, field supervisors, and installers that hold active ANSI accredited certifications in appropriate categories for work specified.
 - a. North American Contractor Certification (NACC) for glazing contractors.
 - b. Equivalent independent third-party ANSI accredited certification.
- C. Single-Source Responsibility: All entrances and storefront framing and doors, including finish, shall be the product of one manufacturer.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Handle products of this section in accordance with AAMA CW-10.
- B. Protect finished aluminum surfaces with wrapping. Do not use adhesive papers or sprayed coatings that bond to aluminum when exposed to sunlight or weather.
 - 1. Store storefront sections out of contact with the ground and under a weather tight covering. Do not cover storefront sections with polyethylene film or similar coverings that will create a humidity chamber.

2. Protect surfaces during shipping and handling to prevent scratching, gouging or other damage to the finish.

1.08 FIELD CONDITIONS

- A. Do not install sealants when ambient temperature is less than 40 degrees F. Maintain this minimum temperature during and 48 hours after installation.

1.09 WARRANTY

- A. See Section 01 78 00 - Closeout Submittals for additional warranty requirements.
- B. Correct defective Work within a five year period after Date of Substantial Completion.
- C. Provide five year manufacturer warranty against failure of glass seal on insulating glass units, including interpane dusting or misting. Include provision for replacement of failed units.
- D. Provide five year manufacturer warranty against excessive degradation of exterior finish. Include provision for replacement of units with excessive fading, chalking, or flaking.
- E. Provide two year manufacturer warranty against failure of door corner construction for standard duty narrow or medium stile doors.
- F. Provide five year manufacturer warranty against failure of door corner construction for heavy duty wide stile doors.

PART 2 PRODUCTS

2.01 REGULATORY REQUIREMENTS

- A. Comply with Code requirements for safety glazing, accessibility and exit devices.
 1. Conform to applicable requirements of the ADA Standards regarding accessibility requirements for door and entrance hardware.
 2. Exit Doors: Openable at all times from the inside without the use of a key or any special knowledge or effort.
 3. Exit devices shall comply with CBC Section 1010.1.9.1 and 11B-404.2.7. Lever handle trim to match locksets.
 4. Conform to applicable requirements of Title 24, Part 2, CCR, including CBC Chapter 11B-404.2.7, 11B-404.2.9, and 1010.1.9, regarding exiting and accessibility requirements for door and entrance hardware.
 5. Exterior doors to have 5 pounds maximum pressure to open and interior doors to have 5 pounds maximum pressure to open. CBC Chapter 11B-404.2.9.

2.02 MANUFACTURERS

- A. Aluminum-Framed Storefronts:
 1. Basis of Design: Arcadia, Inc: www.arcadiainc.com/#sle.
 2. C.R. Laurence Company, Inc; U.S. Aluminum: www.crl-arch.com/#sle.
 3. Kawneer North America: www.kawneer.com/#sle.
 4. Substitutions: See Section 01 60 00 - Product Requirements.

- a. For any product not identified as "Basis of Design", submit information as specified for substitutions.
- b. Substitutions shall include all costs for redesign with consequential changes by other trades along with the Architect and related approvals by governing agencies.
 - 1) Revision to shop drawings illustrating changes is not considered adequate for DSA review and approval.
- c. Substitutions may be acceptable, based on Architect's review and approval, for submittal to DSA.
 - 1) If substituted manufacturer cannot reproduce design and DSA approval in a timely manner, then they shall be subject to a time and material back charge for any delays in the project.
 - 2) Architect approval is required prior to DSA submittal and DSA approval is required prior to installation.

2.03 BASIS OF DESIGN -- FRAMING FOR INSULATING GLAZING

- A. Front-Set Style, Thermally-Broken:
 1. Basis of Design: Arcadia, Inc.; Offset Glazed System TC470 Series - Thermal - Shear Block Inside Set: www.arcadiainc.com.
- B. Substitutions: See Section 01 60 00 - Product Requirements.
 1. For any product not identified as "Basis of Design", submit information as specified for substitutions.

2.04 BASIS OF DESIGN -- FRAMING FOR MONOLITHIC GLAZING

- A. Center-Set Style:
 1. Basis of Design: Arcadia, Inc.; Center Glazed System A400 Series - Non-Them - Shear Block Inside Set: www.arcadiainc.com.
- B. Substitutions: See Section 01 60 00 - Product Requirements.
 1. For any product not identified as "Basis of Design", submit information as specified for substitutions.

2.05 ALUMINUM-FRAMED STOREFRONT

- A. Aluminum-Framed Storefront: Factory fabricated, factory finished aluminum framing members with infill, and related flashings, anchorage and attachment devices.
 1. Glazing Rabbet: For 1 inch insulating glazing.
 2. Finish: Class I natural anodized.
 - a. Factory finish all surfaces that will be exposed in completed assemblies.
 - b. Coat concealed metal surfaces that will be in contact with cementitious materials or dissimilar metals with bituminous paint.
 3. Fabrication: Joints and corners flush, hairline, and weatherproof, accurately fitted and secured; prepared to receive anchors and hardware; fasteners and attachments concealed from view; reinforced as required for imposed loads.

FOR REFERENCE ONLY

4. Construction: Eliminate noises caused by wind and thermal movement, prevent vibration harmonics, and prevent "stack effect" in internal spaces.
 5. System Internal Drainage: Drain to the exterior by means of a weep drainage network any water entering joints, condensation occurring in glazing channel, and migrating moisture occurring within system.
 6. Expansion/Contraction: Provide for expansion and contraction within system components caused by cycling temperature range of 170 degrees F over a 12 hour period without causing detrimental effect to system components, anchorages, and other building elements.
 7. Movement: Allow for movement between storefront and adjacent construction, without damage to components or deterioration of seals.
 8. Perimeter Clearance: Minimize space between framing members and adjacent construction while allowing expected movement.
 9. Maintain continuous air barrier and/or vapor retarder seal throughout assembly, primarily in line with inside pane of glazing and inner sheet of infill panel, and heel bead of glazing compound.
- B. Performance Requirements
1. Wind Loads: Design and size components to withstand the specified load requirements without damage or permanent set, when tested in accordance with ASTM E330/E330M, using loads 1.5 times the design wind loads and 10 second duration of maximum load.
 - a. Design Wind Loads: Comply with requirements of ASCE 7.
 - b. Member Deflection: Limit member deflection to flexure limit of glass or 1/175 of span, maximum 3/4 inch (over 11'-0" span), in any direction, with full recovery of glazing materials.
 2. Water Penetration Resistance on Manufactured Assembly: No uncontrolled water on interior face, when tested in accordance with ASTM E331 at pressure differential of 8 psf.
 3. Air Leakage: 0.06 cfm/sq ft maximum leakage of storefront wall area when tested in accordance with ASTM E283/E283M at 1.57 psf pressure difference.
 4. Energy Performance:
 - a. NFRC Values:

U-Value, NFRC 100	0.41
Solar Heat Gain Coefficient, NFRC 300	0.34
Visible Transmittance, NFRC 200	0.61
 - b. The District has used NFRC certified values for the analysis of this building. It does not allow for the use of CCR Title 24 default values.
 - c. Provide products that meet or exceed the U-factor and S.H.G.C. values listed on the ENV-1 form, filed in the contract documents elsewhere.
 - d. AAMA ratings are not allowed under CCR Title 24 and will not be acceptable.
 5. Resistance to Forcible Entry: Jambs adjacent to door locks shall resist a force of 1600 lbs

2.06 COMPONENTS

- A. Aluminum Framing Members: Tubular aluminum sections, drainage holes and internal weep drainage system.
 - 1. Framing members for interior applications need not be thermally broken.
 - 2. Glazing Stops: Flush.
 - 3. Cross-Section: As indicated on drawings.
- B. Glazing: See Section 08 80 00.
- C. Swing Doors: Glazed aluminum.
 - 1. Thickness: 1-3/4 inches.
 - 2. Top Rail: 6 inches wide, nominal.
 - 3. Vertical Stiles: 5 inches wide, nominal. Coordinate with hardware for a complete installation.
 - 4. Bottom Rail: 10 inches wide.
 - 5. Glazing Stops: Square.
 - 6. Finish: Same as storefront.

2.07 MATERIALS

- A. Extruded Aluminum: ASTM B221 (ASTM B221M).
- B. Sheet Aluminum: ASTM B209/B209M.
- C. Fasteners: Stainless steel.
- D. Exposed Flashings: Aluminum sheet, 20 gauge, 0.032 inch minimum thickness; finish to match framing members.
- E. Concealed Flashings: Galvanized steel, 26 gauge, 0.0179 inch minimum base metal thickness.
- F. Perimeter Sealant: As specified in Section 07 92 00 - Joint Sealants.
- G. Sill Flashing Sealant: Elastomeric, silicone or polyurethane, compatible with flashing material.
- H. Sealant for Setting Thresholds: Non-curing butyl type.
- I. Glazing Gaskets: Type to suit application to achieve weather, moisture, and air infiltration requirements.
- J. Glazing Accessories: See Section 08 80 00.
- K. Shop and Touch-Up Primer for Steel Components: Zinc oxide, alkyd, linseed oil primer appropriate for use over hand cleaned steel.
- L. Touch-Up Primer for Galvanized Steel Surfaces: SSPC-Paint 20, zinc rich.

2.08 FINISHES

- A. Class I Natural Anodized Finish: AAMA 611 AA-M12C22A41 Clear anodic coating not less than 0.7 mils thick.
- B. Touch-Up Materials: As recommended by coating manufacturer for field application.

2.09 HARDWARE

- A. Other Door Hardware: See Section 08 71 00.
- B. Weatherstripping: Manufacturer's standard replaceable compressible weatherstripping gaskets of molded neoprene complying with ASTM D2000 or molded PVC complying with ASTM D2287 pile, continuous and replaceable; provide on all exterior doors.
- C. Sill Sweep Strips: Resilient seal type, retracting, of neoprene; provide on all doors.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify dimensions, tolerances, and method of attachment with other work.
- B. Verify that storefront wall openings and adjoining water-resistive and/or air barrier seal materials are ready to receive work of this section.

3.02 INSTALLATION

- A. Install wall system in accordance with manufacturer's instructions.
 - 1. Anchoring: Firmly anchor framing using fasteners as recommended by manufacturer, sized to suit loads and type suitable for substrate, to positively attach members for long life under hard use.
- B. Attach to structure to permit sufficient adjustment to accommodate construction tolerances and other irregularities.
- C. Provide alignment attachments and shims to permanently fasten system to building structure.
- D. Align assembly plumb and level, free of warp or twist. Maintain assembly dimensional tolerances, aligning with adjacent work.
- E. Provide thermal isolation where components penetrate or disrupt building insulation.
- F. Install sill flashings. Turn up ends and edges; seal to adjacent work to form water tight dam.
 - 1. Comply with requirements specified in Section 07 62 00 - Sheet Metal Flashing and Trim. Set sill flashing in bedding sealant as specified in Section 07 92 00 - Joint Sealants.
- G. Where fasteners penetrate sill flashings, make watertight by seating and sealing fastener heads to sill flashing.
- H. Coordinate attachment and seal of perimeter air and vapor barrier materials.
- I. Install perimeter sealant in accordance with Section 07 92 00-Joint Sealants.
- J. Pack fibrous insulation in shim spaces at perimeter of assembly to maintain continuity of thermal barrier.
- K. Door Installation: Assemble doors in shop with glazing installed.
 - 1. Door Joints: Make joints rigid and suitable for heavy use.
- L. Touch-up minor damage to factory applied finish; replace components that cannot be satisfactorily repaired.

3.03 TOLERANCES

- A. Maximum Variation from Plumb: 0.06 inch per 3 feet non-cumulative or 0.06 inch per 10 feet, whichever is less.
- B. Maximum Misalignment of Two Adjoining Members Abutting in Plane: 1/32 inch.

3.04 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements for independent field testing and inspection requirements, and requirements for monitoring quality of specified product installations.
- B. Water-Spray Test by Contractor: Provide water spray quality test of installed storefront components in accordance with AAMA 501.2 during construction process and before installation of interior finishes.
 - 1. Perform a minimum of two tests in each designated area as directed by Architect.
 - 2. Conduct tests in each area prior to 10 percent and 50 percent completion of this work.
 - 3. Testing: Installer to water test all storefront and glazing in the presence of the Architect, Project Inspector (IOR), and Construction Manager by spraying with hose heavily for 5 minutes. Repair all leaks discovered by testing procedures and repeat test until leak-free performance is achieved.
- C. District to Provide field testing of installed storefront system by AAMA accredited independent laboratory in accordance with AAMA 503 during construction process and before installation of interior finishes.
 - 1. Perform a minimum of two tests in each designated area as indicated on drawings.
 - 2. Conduct tests in each area prior to 35 percent and 70 percent completion of this work.
 - 3. Field test for water penetration in accordance with ASTM E1105 with uniform static air pressure difference (Procedure A) not less than 4.18 psf.
 - a. Maximum allowable rate of water penetration in 15-minute test is 0.5 ounce that is not contained in an area with provisions to drain to exterior, or collected on surface of interior horizontal framing member.
- D. Repair or replace storefront components that have failed designated field testing, and retest to verify performance complies with specified requirements.

3.05 ADJUSTING

- A. Adjust operating hardware and sash for smooth operation.

3.06 CLEANING

- A. Remove protective material from pre-finished aluminum surfaces.
- B. Wash down surfaces with a solution of mild detergent in warm water, applied with soft, clean wiping cloths, and take care to remove dirt from corners and to wipe surfaces clean.
- C. Upon completion of installation, thoroughly clean aluminum surfaces in accordance with AAMA 609 & 610.

FOR REFERENCE ONLY

3.07 PROTECTION

- A. Protect installed products from damage until Date of Substantial Completion.

END OF SECTION

SECTION 08 51 13 ALUMINUM WINDOWS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Extruded aluminum windows with fixed sash, operating sash, and infill panels.
- B. Factory glazing.
- C. Operating hardware.
- D. Insect screens.

1.02 RELATED REQUIREMENTS

- A. Section 06 10 00 - Rough Carpentry: Rough opening framing.
- B. Section 06 10 00 - Rough Carpentry: Wood perimeter shims.
- C. Section 07 25 00 - Weather Barriers: Sealing frame to water-resistive barrier installed on adjacent construction.
- D. Section 07 92 00 - Joint Sealants: Sealing joints between window frames and adjacent construction.
- E. Section 08 80 00 - Glazing.

1.03 REFERENCE STANDARDS

- A. AAMA/WDMA/CSA 101/I.S.2/A440 - North American Fenestration Standard/Specification for Windows, Doors, and Skylights.
- B. AAMA CW-10 - Care and Handling of Architectural Aluminum from Shop to Site.
- C. AAMA 502 - Voluntary Specification for Field Testing of Newly Installed Fenestration Products.
- D. AAMA 609 & 610 - Cleaning and Maintenance Guide for Architecturally Finished Aluminum (Combined Document).
- E. AAMA 611 - Voluntary Specification for Anodized Architectural Aluminum.
- F. AAMA 1503 - Voluntary Test Method for Thermal Transmittance and Condensation Resistance of Windows, Doors and Glazed Wall Sections.
- G. AAMA 2605 - Voluntary Specification, Performance Requirements and Test Procedures for Superior Performing Organic Coatings on Aluminum Extrusions and Panels (with Coil Coating Appendix).
- H. ASHRAE Std 90.1 I-P - Energy Standard for Buildings Except Low-Rise Residential Buildings.
- I. ASTM A123/A123M - Standard Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products.
- J. ASTM B221 - Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes.
- K. ASTM B221M - Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes (Metric).

- L. ASTM B633 - Standard Specification for Electrodeposited Coatings of Zinc on Iron and Steel.
- M. ASTM E90 - Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions and Elements.
- N. ASTM E283/E283M - Standard Test Method for Determining Rate of Air Leakage Through Exterior Windows, Skylights, Curtain Walls, and Doors Under Specified Pressure Differences Across the Specimen.
- O. ASTM E331 - Standard Test Method for Water Penetration of Exterior Windows, Skylights, Doors, and Curtain Walls by Uniform Static Air Pressure Difference.
- P. ASTM E783 - Standard Test Method for Field Measurement of Air Leakage Through Installed Exterior Windows and Doors.
- Q. ASTM E1105 - Standard Test Method for Field Determination of Water Penetration of Installed Exterior Windows, Skylights, Doors, and Curtain Walls, by Uniform or Cyclic Static Air Pressure Difference.
- R. ASTM E1332 - Standard Classification for Rating Outdoor-Indoor Sound Attenuation.
- S. ASTM F588 - Standard Test Methods for Measuring the Forced Entry Resistance of Window Assemblies, Excluding Glazing Impact.
- T. NFRC 100 - Procedure for Determining Fenestration Product U-factors.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Preinstallation Meeting: Convene one week before starting work of this section.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Include component dimensions, information on glass and glazing, internal drainage details, and descriptions of hardware and accessories.
- C. Shop Drawings: Indicate opening dimensions, elevations of different types, framed opening tolerances, method for achieving air and vapor barrier seal to adjacent construction, anchorage locations, and installation requirements.
- D. Grade Substantiation: Prior to submitting shop drawings or starting fabrication, submit one of the following showing compliance with specified grade:
 - 1. Evidence of AAMA Certification.
 - 2. Evidence of WDMA Certification.
 - 3. Evidence of CSA Certification.
 - 4. Test report(s) by independent testing agency itemizing compliance and acceptable to authorities having jurisdiction.
- E. Test Reports: Prior to submitting shop drawings or starting fabrication, submit test report(s) by independent testing agency showing compliance with performance requirements in excess of those prescribed by specified grade.
- F. Manufacturer's Installation Instructions: Include complete preparation, installation, and cleaning requirements.
- G. Field Quality Control Submittals: Report of field testing for water penetration and air leakage.

1.06 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing products specified in this section with minimum three years of documented experience.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Comply with requirements of AAMA CW-10.
- B. Protect finished surfaces with wrapping paper or strippable coating during installation. Do not use adhesive papers or sprayed coatings that bond to substrate when exposed to sunlight or weather.

1.08 FIELD CONDITIONS

- A. Do not install sealants when ambient temperature is less than 40 degrees F.
- B. Maintain this minimum temperature during and 24 hours after installation of sealants.

1.09 WARRANTY

- A. See Section 01 78 00 - Closeout Submittals for additional warranty requirements.
- B. Correct defective work within a five year period after Date of Substantial Completion.

PART 2 PRODUCTS

2.01 BASIS OF DESIGN - AW PERFORMANCE CLASS WINDOWS

- A. Grade: AAMA/WDMA/CSA 101/I.S.2/A440 having Performance Class of AW, and Performance Grade at least as high as specified design pressure.
- B. Horizontal Sliding:
 - 1. Basis of Design Product: 2820 Pass Thru Series (Non-Thermal) as manufactured by Arcadia, Inc, or approved equal.

2.02 ALUMINUM WINDOWS

- A. Aluminum Windows: Extruded aluminum frame and sash, factory fabricated, factory finished, with operating hardware, related flashings, and anchorage and attachment devices.
 - 1. Operable Units: Double weatherstripped.
 - 2. Provide factory-glazed units.
 - 3. Fabrication: Joints and corners flush, hairline, and weatherproof, accurately fitted and secured; prepared to receive anchors; fasteners and attachments concealed from view; reinforced as required for operating hardware and imposed loads.
 - 4. Perimeter Clearance: Minimize space between framing members and adjacent construction while allowing expected movement.
 - 5. Movement: Accommodate movement between window and perimeter framing and deflection of lintel, without damage to components or deterioration of seals.
 - 6. System Internal Drainage: Drain to the exterior by means of a weep drainage network any water entering joints, condensation occurring in glazing channel, and migrating moisture occurring within system.

FOR REFERENCE ONLY

7. Thermal Movement: Design to accommodate thermal movement caused by 180 degrees F surface temperature without buckling stress on glass, joint seal failure, damaging loads on structural elements, damaging loads on fasteners, reduction in performance or other detrimental effects.
- B. Exterior Horizontal Sliding Type:
1. Construction: Thermally broken.
 2. Provide screens.
 3. Glazing: Double; clear; low-e.
 4. Exterior Finish: Class I natural anodized.
 5. Interior Finish: Class I natural anodized.
- C. Single-Hung Type:
1. Construction: Thermally broken.
 2. Provide screens.
 3. Glazing: Double; clear; transparent.
 4. Exterior Finish: Class I natural anodized.
 5. Interior Finish: Class I natural anodized.

2.03 PERFORMANCE REQUIREMENTS

- A. Grade: AAMA/WDMA/CSA 101/I.S.2/A440 requirements for specific window type:
1. Performance Class (PC): AW.
 2. Performance Grade (PG): 15, with minimum design pressure (DP) of 15.04 psf.
- B. Member Deflection: Limit member deflection to flexure limit of glass in any direction, with full recovery of glazing materials.
- C. Water Leakage: No uncontrolled leakage on interior face when tested in accordance with ASTM E331 at differential pressure of 9.19 psf.
- D. Air Leakage: 0.1 cfm/sq ft maximum leakage per unit area of outside window frame dimension when tested at 1.57 psf pressure difference in accordance with ASTM E283/E283M.
- E. Condensation Resistance Factor of Frame: 50, measured in accordance with AAMA 1503.
- F. Fenestration Assembly Thermal Transmittance (U-value): Comply with ASHRAE Std 90.1 I-P for building envelope requirements for applicable climate zone.
1. U value simulation: per NFRC 100, at the prescribed 48 x 72 inch Non-Residential Size, glazed with 1 inch insulating glass made with 1/8 inch clear glass, argon gas, and 1/8 inch soft coat low E glass: Thermal Transmittance to be maximum .47 BTU/HR/SQ.FT/°F U value.
- G. Forced Entry Resistance: Tested to comply with ASTM F588 requirements for performance level of Grade 10 for specific window style required.
- H. Acoustic Performance: Minimum outdoor-indoor transmission class (OITC) rating of 34, when tested in accordance with ASTM E90 and ASTM E1332.

2.04 COMPONENTS

- A. Frames: 1-3/8 inch wide x 3-1/2 inch deep profile, of 0.062 inch thick section; flush glass stops of snap-on type.
- B. Glazing: See Section 08 80 00.
- C. Balances: Class 5 heavy duty spring conforming to AAMA 902-07; of appropriate capacity to hold sash stationary and permit smooth operation.
- D. Sills: 0.060 inch thick, extruded aluminum; sloped for positive wash; fit under sash leg to 1/2 inch beyond wall face; one piece full width of opening; jamb angles to terminate sill end.
- E. Provide mullions and cover plates matching window units, complete with anchors for support to structure and for installation of window units. Allow for erection tolerances and provide for movements of window units due to thermal expansion and building deflections.
- F. Insect Screens: Extruded aluminum frame with mitered and reinforced corners; screen mesh taut and secure to frame; secured to window with adjustable hardware allowing screen removal without use of tools.
 - 1. Hardware: Spring loaded steel pins; four per screen unit.
 - 2. Screen Mesh: Vinyl-coated fiberglass, window manufacturer's standard mesh.
 - 3. Frame Finish: Same as frame and sash.
 - 4. Provide insect screens for each operable exterior sash. Locate screens on the inside or outside of the window sash, depending upon window type. Design windows and hardware to accommodate screens in a tight fitting removable arrangement, with a minimum of exposed fasteners and latches.
- G. Operable Sash Weatherstripping: EPDM; permanently resilient, profiled to achieve effective weather seal.
- H. Fasteners: Stainless steel, series 300, nonmagnetic.
 - 1. Reinforcement: Where fasteners screw-anchor into aluminum less than 1.125 inch thick, reinforce interior with aluminum or nonmagnetic stainless steel to receive screw threads or provide standard non-corrosive pressed-in splined grommet nuts.
- I. Glazing Materials: See Section 08 80 00.
- J. Sealant for Setting Sills and Sill Flashing: Non-curing butyl type.
 - 1. See Section 07 92 00 for additional requirements.

2.05 MATERIALS

- A. Extruded Aluminum: ASTM B221 (ASTM B221M), 6063 alloy, T6 temper.
- B. Concealed Steel Items: Profiled to suit mullion sections; galvanized in accordance with ASTM A123/A123M.
- C. Anchors, Clips, and Window Accessories: Fabricate anchors, clips, and window accessories of aluminum, nonmagnetic stainless steel, or hot-dip zinc-coated steel or iron meeting the requirements of ASTM B633; provide sufficient strength to withstand design pressure specified.
- D. Bituminous Coatings: Cold applied asphalt mastic meeting the requirements of SSPC PS 12, compounded for 30 mil thickness per coat.

2.06 HARDWARE

- A. Regulatory Requirements:
 - 1. Windows:
 - a. Where glazed openings are provided in accessible rooms or spaces for operation by occupants, at least one shall comply with CBC sections 11B-229.1 and 11B-309.
 - 2. Pass-Through Windows:
 - a. Pass-through windows of sales/service counter shall comply with the reach and access requirements of CBC Sections 11B-227.3, 11B-305, 11B-306, 11B-308, 11B-309, and 11B-904.4.
- B. Sash lock: Mortise cylinder with ADA turnknob.
 - 1. Basis of Design Product: Captive Turnknob 5 pin and Thumbturn model no. ADA-xxxx sized form frame as manufactured by ilco, or approved equal.
- C. Operator: Offset Pull fitted to projecting sash arms with limit stops.
 - 1. Basis of Design Product: 90 degree Offset Pull Model no. BF156, 8 inches Center to Center as manufactured by Rockwood, or approved equal.
 - 2. Finish: Satin chrome or stainless steel.
- D. Projecting Sash Arms/Hinges: Stainless steel, friction pivot joints with nylon bearings, removable pivot clips for cleaning.
- E. Pulls: Manufacturer's standard type.
 - 1. Lift Handle: Continuous, integral, sash lift bar on bottom rail of lower sash.
- F. Bottom Rollers: Stainless steel, adjustable.
- G. Limit Stops: Resilient rubber or manufacturers standard.

2.07 FINISHES

- A. Class I Natural Anodized Finish: AAMA 611 AA-M12C22A41, clear anodic coating not less than 0.7 mil thick.
- B. Superior Performing Organic Coatings System: Manufacturer's standard multi-coat superior performing organic coatings system complying with AAMA 2605, including at least 70 percent polyvinylidene fluoride (PVDF) resin, and at least 80 percent of aluminum extrusion and panels surfaces having minimum total dry film thickness (DFT) of 1.2 mils, 0.0012 inch.
- C. Finish Color: As selected by Architect from manufacturer's standard range.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that wall openings and adjoining water-resistive barrier materials are ready to receive aluminum windows; see Section 07 25 00.

FOR REFERENCE ONLY

- B. Before starting fabrication, thoroughly examine actual field conditions affecting the work. Take actual field measurements of all spaces and places into which this work is to be fitted. If the field investigations indicate that the work of other trades does not conform to the design dimensions and conditions, make corrections before installation of windows.

3.02 PRIME WINDOW INSTALLATION

- A. Install windows in accordance with manufacturer's instructions.
- B. Install window assembly in accordance with AAMA/WDMA/CSA 101/I.S.2/A440.
- C. Attach window frame and shims to perimeter opening to accommodate construction tolerances and other irregularities.
- D. Align window plumb and level, free of warp or twist. Maintain dimensional tolerances and alignment with adjacent work.
- E. Install sill and sill end angles.
- F. Where aluminum surfaces are in contact with dissimilar metals, except stainless steel or zinc, protect the aluminum surface with one coat of alkali resistant bitumastic paint or zinc chromate paint.
- G. Provide thermal isolation where components penetrate or disrupt building insulation. Pack fibrous insulation in shim spaces at perimeter of assembly to maintain continuity of thermal barrier.
- H. Coordinate attachment and seal of perimeter air barrier and vapor retarder materials.
- I. Install operating hardware not pre-installed by manufacturer.
- J. Install glass and infill panels in accordance with requirements; see Section 08 80 00.

3.03 TOLERANCES

- A. Maximum Variation from Level or Plumb: 1/16 inches every 3 ft non-cumulative or 1/8 inches per 10 ft, whichever is less.

3.04 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements for independent field testing and inspection requirements, and requirements for monitoring quality of specified product installations.
- B. Provide field testing of installed aluminum windows by independent laboratory in accordance with AAMA 502 and AAMA/WDMA/CSA 101/I.S.2/A440 during construction process and before installation of interior finishes.
 - 1. Perform tests on three individual windows in designated locations as indicated on drawings.
 - 2. Field test for water penetration in accordance with ASTM E1105 using Procedure B - cyclic static air pressure difference; test pressure shall not be less than 1.9 psf.
 - 3. Field test for air leakage in accordance with ASTM E783 with uniform static air pressure difference of 1.57 psf.
 - a. Maximum allowable rate of air leakage is 0.30 cfm/sq ft.
- C. Repair or replace fenestration components that have failed designated field testing, and retest to verify performance complies with specified requirements.

3.05 ADJUSTING

- A. Adjust hardware for smooth operation and secure weathertight closure.

3.06 CLEANING

- A. See Section 01 74 19 - Construction Waste Management and Disposal for additional requirements.
- B. Remove protective material from factory finished aluminum surfaces.
- C. Wash surfaces by method recommended and acceptable to window manufacturer; rinse and wipe surfaces clean.
- D. Upon completion of installation, thoroughly clean aluminum surfaces in accordance with AAMA 609 & 610.
- E. Remove excess glazing sealant by moderate use of mineral spirits or other solvent acceptable to sealant and window manufacturer.

END OF SECTION

SECTION 08 56 59 SERVICE AND TELLER WINDOWS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Service and teller windows.

1.02 RELATED REQUIREMENTS

- A. Section 07 92 00 - Joint Sealants: Sealing joints between frames and adjacent construction.
- B. Section 12 36 00 - Countertops: Service counter surface.

1.03 REFERENCE STANDARDS

- A. AAMA 611 - Voluntary Specification for Anodized Architectural Aluminum.
- B. AAMA 2603 - Voluntary Specification, Performance Requirements and Test Procedures for Pigmented Organic Coatings on Aluminum Extrusions and Panels (with Coil Coating Appendix).
- C. ASTM A123/A123M - Standard Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products.
- D. ASTM B221 - Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes.
- E. ASTM B221M - Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes (Metric).
- F. {RSTEMP#10005050}
- G. {RSTEMP#10005085}
- H. ITS (DIR) - Directory of Listed Products.
- I. UL (DIR) - Online Certifications Directory.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordinate work with adjacent materials specified in other sections and as indicated on drawings and approved shop drawings.
- B. Preinstallation Meeting: Prior to start of installation arrange a meeting on site to familiarize installer and installers of related work with requirements relating to this work.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Submit manufacturer's product data for specified products indicating materials, operation, glazing, finishes, and installation instructions.
- C. Shop Drawings: Indicate configuration, sizes, rough-in, mounting, anchors and fasteners, and installation clearances.
- D. Samples for Selection of Finishes:
 - 1. Applied Finishes: Color charts for factory finishes.

2. Color Anodized Finishes: Frame member sections showing range of color to be expected in finished work.
- E. Manufacturer Qualification Statement.
- F. Installer Qualification Statement.
- G. Warranty: Submit manufacturer warranty and ensure that forms have been completed in District's name and registered with manufacturer.

1.06 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing products specified in this section with at least ten years documented experience, and with ability to provide test reports showing that their standard manufactured products meet the specified requirements.
- B. Installer Qualifications: Company specializing in performing work of the type specified and with at least three years of documented experience.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Deliver units in manufacturer's original packaging and unopened containers with identification labels intact.
- B. Store units in area protected from exposure to weather and vandalism.

1.08 WARRANTY

- A. See Section 01 78 00 - Closeout Submittals for additional warranty requirements.
- B. Provide manufacturer's warranty agreeing to repair or replace units and their components that fail in materials or workmanship within five years from Date of Substantial Completion.

PART 2 PRODUCTS

2.01 REGULATORY REQUIREMENTS

- A. Pass-through windows of sales/service counter shall comply with the reach and access requirements of CBC Sections 11B-227.3 Counters, 11B-305 Clear Floor or Ground Space, 11B-306 Knee and Toe Clearance, 11B-308 Reach Range, 11B-309 Operable Parts, and 11B-904 Check-out aisles and sales and service counters.
- B. Where glazed openings are provided in accessible rooms or spaces for operation by occupants, at least one shall comply with {RS#10005085}-229.1 and 11B-309.
- C. Comply with requirement of {RS#10005050} Chapter 24.

2.02 SERVICE AND TELLER WINDOWS

- A. Location: Built within exterior wall, as indicated on drawings.
- B. Type of Use: As indicated on drawings.
- C. Window Type: Vertical lift up.
 1. Operation: Automatic.
 2. Mounting: As indicated on drawings.
 3. Window Size: 24 inch wide by 48 inch high.

4. Size of Counter Space: As indicated on drawings.
- D. Glazing: Insulating glass, clear.
- E. Counter Staging Area: Attendant-side.
- F. Air Curtain: Heated, for thermal and insect control, mounted on inside.
- G. Basis of Design Products:
 1. Easi-Serv Products; SUI Series Heavy Duty Vertical Lift Window, Model SUI100 Automatic: www.easi-serv.com/#sle.
 2. Substitutions: See Section 01 60 00 - Product Requirements.

2.03 ASSEMBLY COMPONENTS

- A. Windows: Factory-fabricated, finished, and glazed, with extruded aluminum frame and glazing stops; complete with hardware and anchors.
 1. Provide window units that are re-glazable from the secure side without dismantling the non-secure side of framing.
 2. Rigidly fit and secure joints and corners with internal reinforcement. Make joints and connections flush, hairline, and weatherproof. Fully weld corners.
 3. Apply factory finish to exposed surfaces.
 4. Apply bituminous paint to concealed metal surfaces in contact with cementitious or dissimilar materials.
 5. Ensure joint sealant is applied between frames and adjacent construction; see Section 07 92 00.
 6. Wind Design: Design and size components to withstand dead loads and live loads caused by pressure and negative wind loads acting normal to plane of window as calculated in accordance with applicable code.
 7. Electric Operation: Provide photo-electric or optic sensor bar.
- B. Products Requiring Electrical Connection: Listed and classified by ITS (DIR), UL (DIR), or testing agency acceptable to authorities having jurisdiction.

2.04 MATERIALS

- A. Aluminum Extrusions: Minimum 1/8 inch thick frame and sash material complying with ASTM B221 and ASTM B221M.
- B. Stainless Steel: Type 304 with No. 3 - Coarse finish.
- C. Concealed Steel Items: Galvanized in accordance with ASTM A123/A123M to thickness Grade 85, 2.0 ounces per square foot.
- D. Sealant for Setting Sills and Sill Flashing: Non-curing butyl type.

2.05 FINISHES

- A. Pigmented Organic Coating System: AAMA 2603; polyester or acrylic baked enamel finish.
- B. Color: To be selected by Architect from manufacturer's custom range.

2.06 ACCESSORIES

- A. Electrical Components: 120 VAC, 60 Hz, 15 amps, single phase, unless otherwise indicated.
- B. Air Curtain: Commercial grade, corrosion resistant clear anodized aluminum fan unit, ITS (DIR) listed, with rheostat air flow control.
- C. Hardware and Security Devices for Sliding Windows:
 - 1. Auto-Lock Handle: Stainless steel auto-locking handle on all self-closing sliders to prevent intrusion.
 - 2. Weatherstripping and Glazing Sealant: Factory applied.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that window openings are ready for installation of windows.
- B. Verify that correct embedded anchors are in place and in proper location; repair or replace anchors as required to achieve satisfactory installation.
- C. Notify Architect if conditions are not suitable for installation of units; do not proceed until conditions are satisfactory.

3.02 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Install units in correct orientation (inside/outside or secure/non-secure).
- C. Anchor units securely in manner so as to achieve performance specified.
- D. Separate metal members from concrete and masonry using bituminous paint or with products recommended in writing by the manufacturer for this purpose.
- E. Connect electrical components to power source.
- F. Remove and replace defective work.

3.03 ADJUSTING

- A. Adjust operating components for smooth operation while also maintaining a secure, weather-tight enclosure and a tight fit at the contact points; lubricate operating hardware.

3.04 CLEANING

- A. Remove protective material from factory finished surfaces.
- B. Clean exposed surfaces promptly after installation without damaging finishes.

3.05 DEMONSTRATION

- A. Train District's maintenance personnel to adjust, operate, and maintain operable units.
 - 1. Instructor: Manufacturer's training personnel.
 - 2. Location: At project site.
 - 3. Use operation and maintenance manual as training reference, supplemented with additional training materials as required.

FOR REFERENCE ONLY

3.06 PROTECTION

- A. Provide temporary protection to ensure that service and teller windows are without damage upon Date of Substantial Completion.

END OF SECTION

SECTION 08 71 00 DOOR HARDWARE

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Hardware for hollow metal doors.
- B. Electrically operated and controlled hardware.
- C. Lock cylinders for doors that hardware is specified in other sections.
- D. Thresholds.
- E. Weatherstripping and gasketing.
- F. Replacement hardware for existing doors.

1.02 RELATED REQUIREMENTS

- A. Section 07 92 00 - Joint Sealants: Sealants for setting exterior door thresholds.
- B. Section 08 06 71 - Door Hardware Schedule: Schedule of door hardware sets.
- C. Section 08 11 13 - Hollow Metal Doors and Frames.
- D. Section 10 14 23 - Panel Signage: Additional signage requirements.
- E. Section 28 15 00.10 - Campus Integrated Access Control Hardware Devices: Electronic access control devices.

1.03 REFERENCE STANDARDS

- A. ADA Standards - 2010 ADA Standards for Accessible Design.
- B. BHMA (CPD) - Certified Products Directory.
- C. BHMA A156.1 - Standard for Butts and Hinges.
- D. BHMA A156.3 - Exit Devices.
- E. BHMA A156.4 - Door Closers and Pivots.
- F. BHMA A156.5 - Cylinders and Input Devices for Locks.
- G. BHMA A156.7 - Template Hinge Dimensions.
- H. BHMA A156.8 - Door Controls - Overhead Stops and Holders.
- I. BHMA A156.13 - Mortise Locks & Latches Series 1000.
- J. BHMA A156.16 - Standard for Auxiliary Hardware.
- K. BHMA A156.17 - Self Closing Hinges & Pivots.
- L. BHMA A156.20 - Standard for Strap and Tee Hinges, and Hasps.
- M. BHMA A156.21 - Thresholds.
- N. BHMA A156.22 - Standard for Gasketing.
- O. BHMA A156.28 - Standard for Recommended Practices for Mechanical Keying Systems.
- P. BHMA A156.115 - Hardware Preparation in Steel Doors and Frames.

- Q. {RSTEMP#10005085}
- R. DHI (H&S) - Sequence and Format for the Hardware Schedule.
- S. DHI (KSN) - Keying Systems and Nomenclature.
- T. DHI (LOCS) - Recommended Locations for Architectural Hardware for Standard Steel Doors and Frames.
- U. NFPA 70 - National Electrical Code.
- V. UL (DIR) - Online Certifications Directory.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordinate the manufacture, fabrication, and installation of products that door hardware is installed on.
- B. Sequence installation to ensure utility connections are achieved in an orderly and expeditious manner.
- C. Preinstallation Meeting: Convene a preinstallation meeting one week prior to commencing work of this section; attendance is required by affected installers and the following:
 - 1. Architect.
 - 2. Installer's Architectural Hardware Consultant (AHC).
 - 3. Hardware Installer.
 - 4. Owner's Security Consultant.
- D. Furnish templates for door and frame preparation to manufacturers and fabricators of products requiring internal reinforcement for door hardware.
- E. Keying Requirements Meeting:
 - 1. Schedule meeting at project site prior to Contractor occupancy.
 - 2. Attendance Required:
 - a. Contractor.
 - b. District and relevant staff.
 - c. Architect.
 - d. Installer's Architectural Hardware Consultant (AHC).
 - e. Hardware Installer.
 - f. Owner's Security Consultant.
 - 3. Agenda:
 - a. Establish keying requirements.
 - b. Verify locksets and locking hardware are functionally correct for project requirements.
 - c. Verify that keying and programming complies with project requirements.
 - d. Establish keying submittal schedule and update requirements.
 - 4. Contractor to provide a blank key schedule in excel format for District review and approval prior to formal submittal.

FOR REFERENCE ONLY

5. Incorporate "Keying Requirements Meeting" decisions into keying submittal upon review of door hardware keying system including, but not limited to, the following:
 - a. Access control requirements.
 - b. Key control system requirements.
 - c. Schematic diagram of preliminary key system.
6. Record minutes and distribute copies within two days after meeting to participants, with two copies to Architect, District, participants, and those affected by decisions made.
 - a. Furnish District's written approval of the system; do not order keys or cylinders without written confirmation of actual requirements from the District.
7. Deliver established keying requirements to manufacturers.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Prior to submittal, carefully inspect existing conditions to verify finish hardware required to complete Work, including sizes, quantities, existing hardware scheduled for re-use, and sill condition material. If conflict between the specified/scheduled hardware and existing conditions, submit request for direction from Architect. Include date of jobsite visit in the submittal.
 1. Submittals prepared without thorough jobsite visit by qualified hardware expert may be rejected as non-compliant.
- C. Product Data: Manufacturer's catalog literature for each type of hardware, marked to clearly show products to be furnished for this project, and includes construction details, material descriptions, finishes, and dimensions and profiles of individual components.
- D. Shop Drawings - Door Hardware Schedule: Submit detailed listing that includes each item of hardware to be installed on each door. Use door numbering scheme as included in Contract Documents.
 1. Prepared by or under supervision of Architectural Hardware Consultant (AHC).
 2. Comply with DHI (H&S) using door numbers and hardware set numbers as indicated in construction documents.
 - a. Submit in vertical format; see Section 08 0671.
 3. List groups and suffixes in proper sequence.
 4. Provide complete description for each door listed.
 5. Provide manufacturer name, product names, and catalog numbers; include functions, types, styles, sizes and finishes of each item.
 6. Include account of abbreviations and symbols used in schedule.
- E. Shop Drawings - Electrified Door Hardware: Submit diagrams for power, signal, and control wiring for electrified door hardware that include details of interface with building safety and security systems. Provide elevations and diagrams for each electrified door opening as follows:
 1. Prepared by or under supervision of Architectural Hardware Consultant (AHC) and Electrified Hardware Consultant (EHC).

FOR REFERENCE ONLY

2. Elevations: Submit front and back elevations of each door opening showing electrified devices with connections installed and an operations narrative describing how opening operates from either side at any given time.
 3. Diagrams: Submit point-to-point wiring diagram that shows each device in door opening system with related colored wire connections to each device.
- F. Samples for Verification:
1. Submit minimum size of 2 by 4 inch for sheet samples, and minimum length of 4 inch for other products.
 2. Submit one (1) sample of hinge, latchset, lockset, and closer illustrating style, color, and finish.
 3. Return full-size samples to be incorporated into this Work.
 4. Submit product description with samples.
- G. Manufacturer's Installation Instructions: Indicate special procedures and perimeter conditions requiring special attention.
- H. Maintenance Data: Include data on operating hardware, lubrication requirements, and inspection procedures related to preventative maintenance.
1. Submit manufacturer's parts lists and templates.
 2. Bitting List: List of combinations as furnished.
- I. Keying Schedule:
1. Submit three (3) copies of Keying Schedule in compliance with requirements established during Keying Requirements Meeting unless otherwise indicated.
- J. Manufacturer's qualification statement.
- K. Installer's qualification statement.
- L. Supplier's qualification statement.
- M. District Responsibilities for submittal review:
1. Complete keying schedule.
 2. Complete keying legend.
 3. Provide original letter of authorization allowing hardware supplier to purchase keying hardware and to have the bitting list sent to District.
 4. Provide District the locksmith's name, address, phone number and email.
 5. Identify how doors are to be keyed.
 6. For existing systems, provide the registry number.
- N. Project Record Documents: Record actual locations of concealed equipment, services, and conduit.
1. Include keying schedule, riser and point-to-point wiring diagrams, manufacturers' installation, adjustment and maintenance information, and supplier's final inspection report
- O. Maintenance Materials and Tools: Furnish the following for District's use in maintenance of project.

FOR REFERENCE ONLY

1. See Section 01 60 00 - Product Requirements, for additional provisions.
2. Lock Cylinders: Ten for each master keyed group.
3. Temporary Cores: Return to and receipt by Contractor.
4. Tools: Two sets of each special wrench or tool applicable for each different or special hardware component, whether supplied by hardware component manufacturer or not.

1.06 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing products specified in this section with minimum three years of documented experience.
- B. Installer Qualifications: Company specializing in performing work of the type specified for commercial door hardware with at least three years of documented experience.
- C. Supplier Qualifications: Company with certified Architectural Hardware Consultant (AHC) and Electrified Hardware Consultant (EHC) to assist in work of this section.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Package hardware items individually; label and identify each package with door opening code to match door hardware schedule.

1.08 PROJECT CONDITIONS AND COORDINATION:

- A. Where exact types of hardware specified are not adaptable to finished shape or size of members requiring hardware, provide suitable types having as nearly as practical the same operation and quality as type specified, subject to Architect's approval.
- B. Coordination:
 1. Coordinate hardware with other work.
 2. Provide hardware items of proper design for use on doors and frames of the thickness, profile, swing, security and similar requirements indicated, as necessary for proper installation and function, regardless of omissions or conflicts in the information on the Contract Documents.
 3. Furnish related trades with the following information:
 - a. Location of embedded and attached items to concrete.
 - b. Location of wall-mounted hardware, including wall stops.
 - c. Location of finish floor materials and floor-mounted hardware.
 - d. Locations for conduit and raceways as needed for electrical, electronic and electro-pneumatic hardware items.
 - 1) Fire/life-safety system interfacing.
 - 2) Point-to-point wiring diagrams plus riser diagrams to related trades.
 - e. Coordinate: flush top rails of doors at outswinging exteriors, and throughout where adhesive-mounted seals occur.
 - f. Manufacturers' templates to door and frame fabricators.
- C. Check Shop Drawings for doors and entrances to confirm that adequate provisions will be made for proper hardware installation.

1.09 WARRANTY

- A. See Section 01 78 00 - Closeout Submittals for additional warranty requirements.
- B. Manufacturer's Warranty: Provide warranty against defects in material and workmanship for period indicated. Complete forms in District's name and register with manufacturer.
 - 1. Mechanical Closers: Thirty years, minimum.
 - a. Electrified Closers: Two years, minimum.
 - 2. Mechanical Exit Devices: Three years, minimum.
 - a. Electrified Exit Devices: One year, minimum.
 - 3. Mechanical Locksets and Cylinders: Three years, minimum.
 - a. Electrified Lockset Devices: One year, minimum.
 - 4. Continuous and Butt Hinges: Life of the building.
 - 5. Key Blanks: Lifetime
 - 6. Other Hardware: Two years, minimum.
- C. Warranty does not cover damage or faulty operation due to improper installation, improper use or abuse.

PART 2 PRODUCTS

2.01 DESIGN AND PERFORMANCE CRITERIA

- A. Provide specified door hardware as required to make doors fully functional, compliant with applicable codes, and secure to extent indicated.
- B. Provide individual items of single type, of same model, and by same manufacturer.
- C. Regulatory Requirements:
 - 1. Comply with State Fire Marshal Standards.
 - a. Lever of lever actuated latches or locks shall be curved with a return to within 1/2 inch of the door to prevent catching on the clothing of persons during egress. SFM 12-10-2 Latching/Locking, Section 12-10-202(f).
 - b. The cross-bar shall extend across not less than one-half the width of the door/gate. 12-10-3 Exits, Section 12-10-302(a).
 - c. The ends of the cross-bar shall be curved, guarded or otherwise designed to prevent catching on the clothing of persons during egress. SFM 12-10-3 Exits, Section 12-10-302(d).
 - 2. Conform to applicable requirements of the CBC Chapter 11B and ADA Standards regarding accessibility requirements for door and entrance hardware including gates.
 - a. Doors/doorways as part of an accessible route shall comply with CBC Sections 11B-404.
 - b. Doors shall meet California Building Code Sections 11B-206.5, 11b-404.1 and 1010.1.
 - c. The clear opening width for a door shall be 32 inches minimum. CBC Section 11B-404.2.3

FOR REFERENCE ONLY

- 1) For a swinging door it shall be measured between the face of the door and the stop, with the door open 90 degrees.
 - 2) There shall be no projections into it below 34 inches and 4 inches maximum projections into it between 34 inches and 80 inches above the finish floor or ground.
 - 3) Door closers and stops shall be permitted to be 78 inches minimum above the finish floor or ground.
 - 4) Exception: Doors not requiring full passage through the opening, that is, to spaces less than 24 inches in depth, may have the clear opening width reduced to 20 inches. Example: shallow closets.
- d. Handles, pulls, latches, locks, and other operable parts on accessible doors shall comply with CBC Section 11B-309.4 and shall be operable with one hand and shall not require tight grasping, pinching, or twisting of the wrist.
- 1) Operable parts of such hardware shall be 34 inches minimum and 44 inches maximum above finish floor or ground.
 - 2) Where sliding doors are in the fully open position, operating hardware shall be exposed and usable from both side. CBC Section 11B-404.2.7
- e. The force for pushing or pulling open a door shall be as follows : CBC Section 11B-404.2.9.
- 1) Interior Hinged Doors, sliding or folding doors, and exterior hinged doors: 5 lbs maximum.
 - 2) Required Fire Doors: the minimum opening force allowable by the DSA authority, not to exceed 15 lbs..
 - 3) These forces do not apply to the force required to retract latch bolts or disengage other devices that hold the door in a closed position.
 - 4) The force required to activate any operable parts, such as retracting latch bolts or disengaging other devices, shall be 5 lbs. maximum to comply with CBC Section 11B-309.4.
- f. Door closing speed shall be as follows: CBC Section 11B-404.2.8
- 1) Closer shall be adjusted so that the required time to move a door from an open position of 90 degrees to a position of 12 degrees from the latch is 5 seconds minimum.
 - 2) Spring hinges shall be adjusted so that the required time to move a door from an open position of 70 degrees to the closed position is 1.5 seconds minimum.
- g. Thresholds shall comply with CBC Section 11B-404.2.5.
- h. Floor stops shall not be located in the path of travel and 4 inches maximum from walls.
- i. Hardware (including exit devices) shall not be provided with "Night Latch" (NL) function for any accessible doors or gates unless the following conditions are met.
- 1) Such hardware has a 'dogging' feature.
 - 2) It is dogged during the time the facility is open.

FOR REFERENCE ONLY

- 3) Such 'dogging' operation is performed only by employees as their job function (non-public use).
- j. Pair of doors: Limit swing of one leaf to 90 degrees so that a clear floor space is provided beyond the arc of the swing for the wall-mounted tactile sign. CBC Section 11B-703.4.2.1
3. Door and door hardware encroachment: when door is swung fully-open into means-of-egress path, the door, including the hardware, may not encroach or project more than 7 inches into the required exit width. California Building Code 1005.7.1.
4. SB 211 - DSA Bulletin 11-05
 - a. Provide all latching devices that are lockable (including but not limited to door locks and panic/exit devices) that comply with CBC 1010.1.11:
 - 1) All new construction projects to include locks that allow the doors to be locked from the inside.
 - 2) The requirement applies to classrooms and any other room with an occupancy of 5 or more persons, but does not include doors that are locked from the outside at all times or student restrooms.
- D. Provide door hardware products that comply with the following requirements:
 1. Applicable provisions of federal, state, and local codes.
 2. Comply with SB 211 (DSA Bulletin 11-05); CBC section 1010.1.11.
 3. Accessibility: ADA Standards, CBC Chapter 11B.
 4. Listed and certified compliant with specified standards by BHMA (CPD).
 5. Auxiliary Hardware: BHMA A156.16.
 6. Straps and Tee Hinges: BHMA A156.20.
 7. Hardware Preparation for Steel Doors and Steel Frames: BHMA A156.115.
 8. Products Requiring Electrical Connection: Listed and classified by UL (DIR) as suitable for the purpose specified.
- E. Electrically Operated and/or Controlled Hardware: Provide necessary power supplies, power transfer hinges, relays, and interfaces as required for proper operation; provide wiring between hardware and control components and to building power connection in compliance with NFPA 70.
 1. See Section 28 15 00.10 for additional access control system requirements.
- F. Lock Function: Provide lock and latch function numbers and descriptions of manufacturer's series. See Door Hardware Schedule.
 1. Exit Doors: Openable at all times from the inside without the use of a key or any special knowledge or effort.
- G. Fasteners:
 1. Provide fasteners of proper type, size, quantity, and finish that comply with commercially recognized standards for proposed applications.
 - a. Aluminum fasteners are not permitted.

FOR REFERENCE ONLY

- b. Provide phillips flat-head screws with heads finished to match door surface hardware unless otherwise indicated.
2. Provide machine screws for attachment to reinforced hollow metal and aluminum frames.
 - a. Self-drilling (Tek) type screws are not permitted.
3. Provide stainless steel machine screws and lead expansion shields for concrete and masonry substrates.
4. Coordinate With Doors: Ensure provision of proper blocking to support machine screws at metal doors/frames to mounting panic hardware and door closers.
5. No through-bolts are allowed on any door type.
6. Concealed Fasteners: Do not use through or sex bolt type fasteners on door panel sides indicated as concealed fastener locations, unless otherwise indicated.

2.02 HINGES

- A. Manufacturers:
 1. Basis of Design: McKinney.
 2. McKinney; an Assa Abloy Group company: www.assaabloydss.com.
 3. Substitutions: Not permitted.
- B. Hinges: Comply with BHMA A156.1, Grade 1.
 1. Self Closing Hinges: Comply with BHMA A156.17.
 2. Butt Hinges: Comply with BHMA A156.1 and BHMA A156.7 for templated hinges.
 - a. Provide hinge width required to clear surrounding trim.
 - b. Drawings typically depict doors at 90 degrees, doors will actually swing to maximum allowable.
 - 1) Use wide-throw conventional or continuous hinges as needed up to 8 inches in width to allow door to stand parallel to wall for true 180-degree opening.
 - 2) Advise Architect if 8 inch width is insufficient.
 - c. Conform to manufacturer's published hinge selection standard for door dimensions, weight and frequency, and to hinge selection as scheduled.
 - 1) Where manufacturer's standard exceeds the scheduled product, furnish the heavier of the two choices, notify Architect of deviation from scheduled hardware.
 - d. Conventional Hinges: Steel or stainless steel pins and concealed bearings. Hinge open widths minimum, but of sufficient throw to permit maximum door swing.
 3. Provide hinges on every swinging door.
 4. Provide five-knuckle full mortise butt hinges unless otherwise indicated.
 5. Provide ball-bearing hinges at each door with closer.
 6. Provide non-removable pins on exterior outswinging doors.
 - a. Out-swinging exterior doors: Non-ferrous with non-removable (NRP) pins and security studs.

FOR REFERENCE ONLY

- b. Non-ferrous material exteriors and at doors subject to corrosive atmospheric conditions.
- 7. Provide non-removable pins on interior outswinging doors at locations as indicated in Door Hardware Schedule.
- 8. Provide power transfer hinges where electrified hardware is mounted in door leaf.
 - a. Provide power transfer with electrified options as scheduled in the hardware sets. Provide with number and gage of wires sufficient to accommodate electric function of specified hardware.
- 9. Provide following quantity of butt hinges for each door:
 - a. Doors up to 60 inches High: Two hinges.
 - b. Doors From 60 inches High up to 90 inches High: Three hinges.
 - c. Doors 90 inches High up to 120 inches High: Four hinges.

2.03 EXIT DEVICES

- A. Comply with SB 211 (DSA Bulletin 11-05); CBC section 1010.1.11.
- B. Manufacturers:
 - 1. Basis of Design: Sargent, District Standard.
 - 2. Sargent; an Assa Abloy Group company: www.assaabloydss.com/#sle.
 - 3. Substitutions: Not permitted.
- C. Exit Devices: Comply with BHMA A156.3, Grade 1.
 - 1. Lever design to match lockset trim.
 - a. Where lever handles are specified as outside trim for exit devices, provide heavy-duty lever trims with forged or cast escutcheon plates. Provide vandal-resistant levers that will travel to 90-degree down position when more than 35 pounds of torque are applied, and which can easily be re-set.
 - 1) Tactile Warning (Knurling): Where required by authority having jurisdiction. Provide on levers on exterior (secure side) of doors serving rooms considered to be hazardous.
 - 2. Provide cylinder with cylinder dogging or locking trim on fire non-rated doors.
 - 3. Provide exit devices properly sized for door width and height.
 - 4. Provide strike as recommended by manufacturer for application indicated.
 - 5. Releasable in normal operation with 5-lb. maximum operating force per {RS#10005085}-309.4.
 - 6. Readily openable from egress side with one hand and without tight grasping, tight pinching, or twisting of the wrist to operate.
 - 7. Comply with CBC Section 1010.1.9 and State Fire Marshal Standard 12-10-3 Exits, Section 12-10-302.
 - 8. Trim to meet BHMA A156.3 Trim Security Test.
 - 9. Provide weather-resistant devices when installed on exterior gates.
 - 10. Independent lab-tested 1,000,000 cycles.

FOR REFERENCE ONLY

11. Provide UL (DIR) listed exit device assemblies for fire-rated doors and panic device assemblies for non-fire-rated doors.
12. Removable Mullions: 2 inches (51 mm) x 3 inches (76 mm) steel tube. Where scheduled as keyed removable mullion, provide type that can be removed by use of a keyed cylinder, which is self-locking when re-installed. See also Secion 08 11 13 - Hollow Metal Doors and Frames.
13. For electrical options, provide quick connect plug-in pre-wired connectors.

2.04 LOCK CYLINDERS

- A. Manufacturers:
 1. Basis of Design: Match Existing, District Standard.
 2. Substitutions: Not permitted.
- B. Lock Cylinders: Provide key access on outside of each lock, unless otherwise indicated.
 1. Provide standard, electronic, conventional, and full size interchangeable core (FSIC) type cylinders, Grade 1, with six-pin core in compliance with BHMA A156.5 at locations indicated.
 2. Provide cylinders from same manufacturer as locking device.
 3. Provide cams and/or tailpieces as required for locking devices.
 4. Furnish keyed at factory of lock manufacturer where permanent records are maintained.
 5. Locks and cylinders by the same manufacturer.
 6. Within specific Door Sections, when provisions for lock cylinder are being referenced to this Section, provide specified lock cylinder and keyed to building keying system, unless otherwise indicated.

2.05 MORTISE LOCKS

- A. Comply with SB 211 (DSA Bulletin 11-05); CBC section 1010.1.11.
- B. Manufacturers:
 1. Basis of Design: Sargent, District Standard.
 2. Sargent; an Assa Abloy Group company: www.assaabloydss.com/#sle.
 3. Substitutions: Not permitted.
- C. Mortise Locks: Complying with BHMA A156.13, Grade 1.
 1. Latchbolt Throw: 3/4 inch, minimum.
 2. Deadbolt Throw: 1 inch, minimum.
 3. Backset: 2-3/4 inch unless otherwise indicated.
 4. Strikes: Provide manufacturer's standard strike for each latchset or lockset with strike box and curved lip extending to protect frame in compliance with indicated requirements.
 - a. Flat-Lip Strikes: Provide for locks with three piece antifriction latchbolts as recommended by manufacturer.
 - b. Rabbet Front and Strike: Provide on locksets for use with rabbeted meeting rails.

- c. Finish: To match lock or latch.
- 5. Lever Trim: through-bolted, accessible design, cast lever or solid extruded bar type levers as scheduled. Filled hollow tube design unacceptable.
 - a. Spindles: security design independent breakaway. Breakage of outside lever does not allow access to inside lever's hubworks to gain wrongful entry.
 - b. Inside lever applied by screwless shank mounting – no exposed trim mount screws.
 - c. Levers rotate up or down for ease of use.

2.06 CLOSERS

- A. Manufacturers; Surface Mounted:
 - 1. Basis of Design: Norton, District Standard.
 - 2. Norton; an Assa Abloy Group company: www.assaabloydss.com/#sle.
 - 3. Substitutions: Not permitted.
- B. Closers: Comply with BHMA A156.4, Grade 1.
 - 1. Type: Surface mounted to door.
 - 2. Provide door closer on each exterior door.
 - 3. Provide door closer on each fire-rated and smoke-rated door.
 - a. Spring hinges are not an acceptable self-closing device, unless otherwise indicated.
 - 4. Operating Force: Adjustable to maximum 5 lbs operating force. Comply with ADA Standards and CBC Ch. 11B.
 - 5. Where an overlapping astragal is included on pairs of swinging doors, provide coordinator to ensure door leaves close in proper order.
 - 6. At outswinging exterior doors, mount closer on interior side of door.

2.07 OVERHEAD STOPS AND HOLDERS

- A. Manufacturers:
 - 1. Basis of Design: Rixson.
 - 2. Rixson; an Assa Abloy Group company: www.assaabloydss.com/#sle.
 - 3. Substitutions: Not permitted.
- B. Overhead Stops and Holders (Door Checks): Comply with BHMA A156.8, Grade 1.
 - 1. Provide stop for every swinging door, unless otherwise indicated.
 - 2. Stop is not required if positive stop feature is specified for door closer; positive stop feature of door closer is not an acceptable substitute for a stop, unless otherwise indicated.

2.08 KICK PLATES

- A. Manufacturers:
 - 1. Basis of Design: Rockwood.
 - 2. Rockwood; an Assa Abloy Group company: www.assaabloydss.com/#sle.

3. Substitutions: Not permitted.
- B. Kick Plates: Provide along bottom edge of push side of every door with closer, except aluminum storefront and glass entry doors, unless otherwise indicated.
 1. Size: 10 inch high by 2 inch less door width (LDW) on push side of door.

2.09 WALL STOPS

- A. Manufacturers:
 1. Basis of Design: Rockwood.
 2. Rockwood; an Assa Abloy Group company: www.assaabloydss.com/#sle.
 3. Substitutions: Not permitted.
- B. Wall Stops: Comply with BHMA A156.16, Grade 1 and Resilient Material Retention Test as described in this standard.
 1. Provide wall stops to prevent damage to wall surface upon opening door.
 2. Type: Bumper, concave, wall stop.
 3. Material: Brass housing with rubber insert.

2.10 THRESHOLDS

- A. Manufacturers:
 1. Basis of Design: Pemko.
 2. Pemko; an Assa Abloy Group company: www.assaabloydss.com/#sle.
 3. Substitutions: Not permitted.
- B. Thresholds: Comply with BHMA A156.21.
 1. Provide threshold at interior doors for transition between two different floor types, unless otherwise indicated.
 2. Provide threshold at each exterior door, unless otherwise indicated.
 3. Type: Flat surface.
 4. Material: Aluminum.
 5. Threshold Surface: Fluted horizontal grooves across full width.
 6. Field cut threshold to profile of frame and width of door sill for tight fit.
 7. Provide non-corroding fasteners at exterior locations.

2.11 WEATHERSTRIPPING AND GASKETING

- A. Rigid Seals:
 1. Manufacturers:
 - a. Basis of Design: Pemko, District Standard.
 - b. Pemko; an Assa Abloy Group company: www.assaabloydss.com/#sle.
 - c. Substitutions: Not permitted.
 2. Weatherstripping and Gasketing: Comply with BHMA A156.22.
 - a. Head and Jamb Type: Adjustable.

- b. Door Sweep Type: Encased in retainer.
 - c. Material: Aluminum, with brush weatherstripping.
 - d. Provide weatherstripping on each exterior door at head, jambs, and meeting stiles of door pairs, unless otherwise indicated.
 - e. Provide door bottom sweep on each exterior door, unless otherwise indicated.
- B. Adhesive Seals and Bottoms:
- 1. Manufacturers:
 - a. Basis of Design: Pemko.
 - b. Pemko; an Assa Abloy Group company: www.assaabloydss.com/#sle.
 - c. Substitutions: Not permitted.
 - 2. Weatherstripping and Gasketing: Comply with BHMA A156.22.
 - a. Head and Jamb Type: Adjustable.
 - b. Door Sweep Type: Encased in retainer.
 - c. Material: Aluminum, with neoprene weatherstripping.
 - d. Provide weatherstripping on each exterior door at head, jambs, and meeting stiles of door pairs, unless otherwise indicated; .
 - e. Provide door bottom sweep on each exterior door, unless otherwise indicated.

2.12 SIGNAGE

- A. See Section 10 14 23 for additional signage requirements.

2.13 SILENCERS

- A. Manufacturers:
 - 1. Basis of Design: Rockwood.
 - 2. Rockwood; an Assa Abloy Group company: www.assaabloydss.com/#sle.
 - 3. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Silencers: Provide at equal locations on door frame to mute sound of door's impact upon closing.
 - 1. Single Door: Provide three on strike jamb of frame.
 - 2. Pair of Doors: Provide two on head of frame, one for each door at latch side.
 - 3. Material: Rubber, gray color.

2.14 KEY CONTROL SYSTEMS

- A. Manufacturers:
 - 1. Basis of Design: Match existing, District Standard.
 - 2. Substitutions: Not permitted.
- B. Key Control Systems: Comply with guidelines of BHMA A156.28.
 - 1. Provide keying information in compliance with DHI (KSN) standards.
 - 2. Keying: Grand master keyed.

FOR REFERENCE ONLY

3. Include construction keying and control keying with removable core cylinders.
 - a. Provide temporary keyed-alike cores.
 - b. Remove at substantial completion and install permanent cylinders/cores in District's presence.
 - 1) Demonstrate that construction key no longer operates.
4. Key to existing keying system.
 - a. Factory registered master key system.
 - b. Restricted keyway, interchangeable core.
 - c. Contact District Locksmith with for keying requirements.
 - d. Key blanks available only from factory-direct sources, not available from after-market key blank manufacturers.
 - e. For estimate use factory GMK charge.
 - f. Furnish District's written approval of the system.
5. Supply keys in following quantities:
 - a. 4 each Master keys.
 - b. 1 each Grand Master keys.
 - c. 6 each Construction Master keys.
 - d. 15 each Construction keys.
 - e. 2 each Construction Control keys.
 - f. 2 each Control keys if new system.
 - g. 2 each Extra Cylinder cores.
 - h. 2 each Change keys for each keyed core.
6. Key Management System: For each keyed lock on project, provide one set of consecutively numbered duplicate key tags with hanging hole and snap catch.
7. Security Key Tags: For each keyed lock on project, provide one set of matching key tags for permanent attachment to one key of each set.
8. Provide key collection envelopes, receipt cards, and index cards in quantity suitable to manage number of keys.
9. Deliver keys with identifying tags to District by security shipment direct from hardware supplier.
10. Bitting List: Use secured shipment direct from point of origination to District upon completion.
11. Permanent Keys and Cores: Stamped with applicable key marking for identification. Do not include actual key cuts within visual key control marks or codes. Stamp permanent keys "Do Not Duplicate."

2.15 FINISHES

- A. Finishes: Identified in Section 08 0671 - Door Hardware Schedule.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that doors and frames are ready to receive this work; labeled, fire-rated doors and frames are properly installed, and dimensions are as indicated on shop drawings.
- B. Verify that electric power is available to power operated devices and of correct characteristics.
- C. Field-verify existing conditions and measurements prior to ordering hardware. Fill existing hardware cut outs not being used by the new hardware.
- D. Remove existing hardware not being reused. Tag and bag removed hardware, turn over to District.

3.02 INSTALLATION

- A. Install hardware in accordance with manufacturer's instructions and applicable codes.
 - 1. Locate hardware per SDI-100 and applicable building, fire, life-safety, accessibility, and security codes.
 - 2. Set units level, plumb and true to line and location. Adjust and reinforce attachment substrate for proper installation and operation. Remove and reinstall or replace work deemed defective by Architect.
 - a. Gaskets:
 - 1) Install jamb-applied gaskets before closers, overhead stops, rim strikes, etc; fasten hardware over and through these seals.
 - 2) Install sweeps across bottoms of doors before astragals, cope sweeps around bottom pivots, trim astragals to tops of sweeps.
 - b. When hardware is to be attached to existing metal surface and insufficient reinforcement exists, use RivNuts, NutSerts or similar anchoring device for screws.
 - c. Use manufacturers' fasteners furnished with hardware items, or submit Request for Substitution with Architect.
 - d. Replace fasteners damaged by power-driven tools.
 - 3. Core concrete for exterior door stop anchors. Set anchors in approved non-shrink grout.
 - 4. Lubricate and adjust existing hardware scheduled to remain. Carefully remove and give to District items not scheduled for reuse.
- B. Existing frames and doors to be retrofitted with new hardware:
 - 1. Field-verify conditions and dimensions prior to ordering hardware. Fill existing hardware cut outs not being reused by the new hardware. Remove existing hardware not being reused, return to Owner unless directed otherwise.
 - 2. Remove existing floor closers not scheduled for reuse, fill cavities with non-shrinking concrete and finish smooth.
 - 3. Cut and weld existing steel frames currently prepared with 2.25 inch height strikes. Cut an approximate 8 inch section from the strike jamb and weld in a reinforced section to accommodate specified hardware's strike.

FOR REFERENCE ONLY

4. Patch and weld flush filler pieces into existing door hardware preparations in steel doors and frames, leave surfaces smooth.
 5. Where existing wall conditions will not allow door to swing using the scheduled hinges, provide wide-throw hinges and if needed, extended arms on closers.
 6. Provide manufacturer's recommended brackets to accommodate the mounting of closers on doors with flush transoms.
- C. Use templates provided by hardware item manufacturer.
- D. Do not install surface mounted items until application of finishes to substrate are fully completed.
- E. Door Hardware Mounting Heights: Distance from finished floor to center line of hardware item. As indicated in following list; unless noted otherwise in Door Hardware Schedule or on drawings.
1. Comply with California Building Code, Section 1010.1.9.2, 11B-309.4 and 11B-404.2.7.
 - a. Refer also to CBC requirements noted in Part 1 of this section.
 2. For Steel Doors and Frames: Install in compliance with DHI (LOCS) recommendations.
 3. For Steel Doors and Frames: See Section 08 11 13.
 4. Mounting heights in compliance with ADA Standards and CBC Chapter 11B:
 - a. Locksets: 34 to 44 inches.
 - b. Push/Pulls: 34 to 44 inches.
 - c. Dead Locks: 44 inches.
 - d. Exit Devices: 36 (clear) to 44 inches.
 - e. Where new hardware is to be installed near existing doors/hardware scheduled to remain, match locations of existing hardware when compliant with codes.
- F. Set exterior door thresholds with full-width bead of elastomeric sealant at each point of contact with floor providing a continuous weather seal; anchor thresholds with stainless steel countersunk screws.
1. See Section 07 92 00 for additional requirements.
- G. Locate floor stops no more that 4 inches (maximum outside dimension) from walls and not within paths of travel. See Article "Hinges" in Part 2 regarding hinge widths, door should be well clear of point of wall reveal. Point of door contact no closer to the hinge edge than half the door width. Where situation is questionable or difficult, contact Architect for direction.
- H. Locate overhead stops for minimum 90 degrees at rest and for maximum allowable degree of swing.

3.03 FIELD QUALITY CONTROL

- A. Perform field inspection and testing under provisions of Section 01 40 00 - Quality Requirements.
- B. Provide an Architectural Hardware Consultant (AHC) to inspect installation and certify that hardware and installation has been furnished and installed in accordance with manufacturer's instructions and as specified.

3.04 ADJUSTING

- A. Adjust work under provisions of Section 01 70 00 - Execution and Closeout Requirements.
- B. Adjust hardware for smooth operation.
 - 1. Adjust and check for proper operation and function. Replace units, which cannot be adjusted to operate freely and smoothly.
 - a. Hardware damaged by improper installation or adjustment methods: repair or replace to District's satisfaction.
 - b. Adjust doors to fully latch with no more than 1 pound of pressure.
 - c. Adjust door closers per "Commissioning" article below.
- C. Adjust gasketing for complete, continuous seal; replace if unable to make complete seal.
- D. Final inspection: Installer to provide letter to District that upon completion installer has visited the Project and has accomplished the following:
 - 1. Has re-adjusted hardware.
 - 2. Has evaluated maintenance procedures and recommend changes or additions, and instructed District's personnel.
 - 3. Has identified items that have deteriorated or failed.
 - 4. Has submitted written report identifying problems.

3.05 COMMISSIONING:

- A. Conduct these tests prior to request for certificate of substantial completion:
 - 1. With installer, access control contractor and electrical contractor present, test electrical, electronic and electro-pneumatic hardware systems for satisfactory operation.
 - 2. With installer present, test door hardware operation for compliance with push and pull force requirements per ADA and CBC.

3.06 CLEANING

- A. Clean finished hardware in accordance with manufacturer's written instructions after final adjustments have been made.
- B. Clean adjacent surfaces soiled by hardware installation.
- C. Replace items that cannot be cleaned to manufacturer's level of finish quality at no additional cost.
- D. See Section 01 74 19 - Construction Waste Management and Disposal for additional requirements.

3.07 PROTECTION

- A. Protect finished Work under provisions of Section 01 70 00 - Execution and Closeout Requirements.
- B. Do not permit adjacent work to damage hardware or finish.

3.08 CLOSEOUT

- A. Return of temporary cores for return/receipt by Contractor.

- B. Final inspection: Installer to provide letter to District that upon completion installer has visited the Project and has accomplished the following:
 - 1. Has re-adjusted hardware.
 - 2. Has evaluated maintenance procedures and recommend changes or additions, and instructed District's personnel.
 - 3. Has identified items that have deteriorated or failed.
 - 4. Has submitted written report identifying problems.

3.09 SCHEDULE OF FINISH HARDWARE

- A. See door schedule in drawings for hardware set assignments.
- B. No hardware shall be ordered until Finish Hardware has been reviewed and approved by Architect's hardware consultant.
- C. Provide Factory order numbers for all products supplied on this project as part of close out documents for Owner's warranty records.
- D. See schedule in Section 08 06 71 - Door Hardware Schedule.

END OF SECTION

SECTION 08 80 00 GLAZING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Insulating glass units. GL-1, GL-1T
- B. Glazing units.
- C. Glazing compounds.

1.02 RELATED REQUIREMENTS

- A. Section 07 25 00 - Weather Barriers.
- B. Section 07 27 00 - Air Barriers.
- C. Section 07 92 00 - Joint Sealants: Sealants for other than glazing purposes.
- D. Section 08 11 13 - Hollow Metal Doors and Frames: Glazed lites in doors and borrowed lites.
- E. Section 08 43 13 - Aluminum-Framed Storefronts: Glazing provided as part of storefront assembly.

1.03 REFERENCE STANDARDS

- A. 16 CFR 1201 - Safety Standard for Architectural Glazing Materials.
- B. ANSI Z97.1 - American National Standard for Safety Glazing Materials Used in Buildings - Safety Performance Specifications and Methods of Test.
- C. ASCE 7 - Minimum Design Loads and Associated Criteria for Buildings and Other Structures.
- D. ASTM C864 - Standard Specification for Dense Elastomeric Compression Seal Gaskets, Setting Blocks, and Spacers.
- E. ASTM C920 - Standard Specification for Elastomeric Joint Sealants.
- F. ASTM C1036 - Standard Specification for Flat Glass.
- G. ASTM C1048 - Standard Specification for Heat-Strengthened and Fully Tempered Flat Glass.
- H. ASTM C1193 - Standard Guide for Use of Joint Sealants.
- I. ASTM C1376 - Standard Specification for Pyrolytic and Vacuum Deposition Coatings on Flat Glass.
- J. ASTM E1300 - Standard Practice for Determining Load Resistance of Glass in Buildings.
- K. ASTM E2190 - Standard Specification for Insulating Glass Unit Performance and Evaluation.
- L. {RSTEMP#10005050}
- M. GANA (GM) - GANA Glazing Manual.
- N. GANA (SM) - GANA Sealant Manual.
- O. GANA (LGRM) - Laminated Glazing Reference Manual.
- P. IGMA TM-3000 - North American Glazing Guidelines for Sealed Insulating Glass Units for Commercial & Residential Use.

- Q. NFRC 100 - Procedure for Determining Fenestration Product U-factors.
- R. NFRC 200 - Procedure for Determining Fenestration Product Solar Heat Gain Coefficient and Visible Transmittance at Normal Incidence.
- S. NFRC 300 - Test Method for Determining the Solar Optical Properties of Glazing Materials and Systems.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Preinstallation Meeting: Convene a preinstallation meeting one week before starting work of this section; require attendance by each of the affected installers.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data on Insulating Glass Unit, Glazing Unit, Plastic Sheet Glazing Unit, and Plastic Film Glazing Types: Provide structural, physical and environmental characteristics, size limitations, special handling and installation requirements.
- C. Product Data on Glazing Compounds and Accessories: Provide chemical, functional, and environmental characteristics, limitations, special application requirements, and identify available colors.
- D. Samples: Submit two samples 12 by 12 inch in size of glass and plastic units.
- E. Certificate: Certify that products of this section meet or exceed specified requirements.
- F. Manufacturer's qualification statement.
- G. Installer's qualification statement.
- H. Warranty Documentation: Submit manufacturer warranty and ensure that forms have been completed in District's name and registered with manufacturer.
- I. Maintenance Materials: Furnish the following for District's use in maintenance of project.
 - 1. See Section 01 60 00 - Product Requirements, for additional provisions.

1.06 QUALITY ASSURANCE

- A. Perform Work in accordance with GANA (GM), GANA (SM), GANA (LGRM), and IGMA TM-3000 for glazing installation methods. Maintain one copy on site.
- B. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum three years of documented experience.
 - 1. Provide certified glass products through ANSI accredited certifications that include plant audits and independent laboratory performance testing.
 - a. Insulating Glass Certification Council (IGCC).
 - b. Safety Glazing Certification Council (SGCC).
- C. Installer Qualifications: Company specializing in performing work of the type specified and with at least three years documented experience.
 - 1. Provide company, field supervisors, and installers that hold active ANSI accredited certifications in appropriate categories for work specified.

- D. Testing Agency Qualifications: Independent firm specializing in performing testing and inspections of the type specified in this section.

1.07 MOCK-UPS

- A. See Section 01 40 00 - Quality Requirements for additional requirements.
- B. Provide mock-up of each type of glazing system including glass and air barrier and vapor retarder seal.
- C. Provide on-site glazing mock-up with the specified glazing components.
- D. Locate where directed.
- E. Mock-ups may remain as part of the Work.

1.08 FIELD CONDITIONS

- A. Do not install glazing when ambient temperature is less than 40 degrees F.
- B. Maintain minimum ambient temperature before, during and 24 hours after installation of glazing compounds.

1.09 WARRANTY

- A. See Section 01 78 00 - Closeout Submittals for additional warranty requirements.
- B. Insulating Glass Units: Provide a five (5) year manufacturer warranty to include coverage for seal failure, interpane dusting or misting, including providing products to replace failed units.
- C. Polycarbonate Sheet Glazing: Provide a five (5) year manufacturer warranty to include coverage for breakage, coating failure, abrasion resistance, including providing products to replace failed units.

PART 2 PRODUCTS

2.01 REGULATORY REQUIREMENTS

- A. Comply with the all applicable codes and ordinances, including California Building Code ({RS#10005050}), Title 24, Part 2, Chapter 24 as amended and adopted by authorities having jurisdiction, and US Consumer Product Safety Commission Standard 16 CFR 1201 CI and CII.
- B. Where safety glass is indicated or required, provide glazing materials that conform to ANSI Z97.1 and CPSC 16 CFR 1201 and are so identified in accordance with CBC Section 2406.3.
- C. Glass Identification: Per {RS#10005050} Section 2403.1, each light shall bear the manufacturer's label designating the type and thickness of glass.
 - 1. When approved by the enforcement agency, labels may be omitted from other than safety glazing materials, provided an affidavit is furnished by the glazing contractor certifying that each light is glazed in accordance with approved plans and specifications.
 - 2. Identification of safety glazing material installed in hazardous locations as defined in Section 2406 of this chapter shall be identified by label which will specify the labeler, whether the manufacturer or installer, and state that safety glazing material has been utilized in such installations.
 - 3. The label shall be legible and visible from the inside of the building after installation and shall specify that label shall not be removed.

4. Tempered glass shall have an etched manufacturer's label.

2.02 MANUFACTURERS

A. Glass Fabricators:

1. Glass Fab; www.glassfabusa.com.
2. Glasswerks Inc.: www.glasswerks.com.
3. GlasPro, Inc.: www.glas-pro.com
4. Viracon, Inc: www.viracon.com/#sle.
5. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.

B. Float Glass Manufacturers:

1. Cardinal Glass Industries: www.cardinalcorp.com/#sle.
2. GlasPro, Inc.: www.glas-pro.com
3. Guardian Glass, LLC: www.guardianglass.com/#sle.
4. Pilkington North America Inc: www.pilkington.com/na/#sle.
5. Saint Gobain North America: www.saint-gobain.com/#sle.
6. Vitro Architectural Glass (formerly PPG Glass): www.vitroglazings.com/#sle.
7. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.

2.03 PERFORMANCE REQUIREMENTS - EXTERIOR GLAZING ASSEMBLIES

A. Provide type and thickness of exterior glazing assemblies to support assembly dead loads, and to withstand live loads caused by positive and negative wind pressure acting normal to plane of glass.

1. Design Pressure: Calculated in accordance with ASCE 7.
 - a. Where glass thicknesses are not indicated, provide thickness based on the wind pressures required by the California Building Code ({{RS#10005050}}, Title 24, Part 2, 2403 and 2404, wind pressure shall be assumed to have a one minute duration.
 - b. Upon first application of design wind load for the specified durations, probability of breakage shall not exceed 8/1000 for vertical glass.
 - c. Probability of breakage relative to glass thermal stress shall not exceed 8/1000 for vertical glass.
2. Comply with ASTM E1300 for design load resistance of glass type, thickness, dimensions, and maximum lateral deflection of supported glass.
3. Seismic Loads: Design and size glazing components to withstand seismic loads and sway displacement in accordance with the requirements of ASCE 7
4. Provide glass edge support system sufficiently stiff to limit the lateral deflection of supported glass edges to less than 1/175 of their lengths under specified design load.
5. Glass thicknesses listed are minimum.

B. Weather-Resistive Barrier Seals: Provide completed assemblies that maintain continuity of building enclosure water-resistive barrier, vapor retarder, and/or air barrier.

1. In conjunction with weather barrier related materials described in other sections, as follows:
 - a. Water-Resistive Barriers: See Section 07 25 00.
 - b. Air Barriers: See Section 07 27 00.
 2. To utilize inner pane of multiple pane insulating glass units for continuity of vapor retarder and/or air barrier seal.
 3. To maintain a continuous vapor retarder and/or air barrier throughout glazed assembly from glass pane to heel bead of glazing sealant.
- C. Thermal and Optical Performance: Provide exterior glazing products with performance properties as indicated. Performance properties are in accordance with manufacturer's published data as determined with the following procedures and/or test methods:
1. Center of Glass U-Value: Comply with NFRC 100 using Lawrence Berkeley National Laboratory (LBNL) WINDOW 6.3 computer program.
 2. Center of Glass Solar Heat Gain Coefficient (SHGC): Comply with NFRC 200 using Lawrence Berkeley National Laboratory (LBNL) WINDOW 6.3 computer program.
 3. Solar Optical Properties: Comply with NFRC 300 test method.

2.04 GLASS MATERIALS

- A. Float Glass: Provide float glass based glazing unless otherwise indicated.
1. Annealed Type: ASTM C1036, Type I - Transparent Flat, Class 1 - Clear, Quality - Q3.
 2. Kind HS - Heat-Strengthened Type: Complies with ASTM C1048.
 3. Kind FT - Fully Tempered Type: Complies with ASTM C1048.
 4. Fully Tempered Safety Glass: Complies with ANSI Z97.1 or 16 CFR 1201 criteria for safety glazing used in hazardous locations.
 5. Impact Resistant Safety Glass: Complies with ANSI Z97.1 - Class B, or 16 CFR 1201 - Category II criteria.
 6. Thicknesses: As indicated; provide greater thickness as required for exterior glazing wind load design.

2.05 INSULATING GLASS UNITS

- A. Manufacturers:
1. Glass: Any of the manufacturers specified for float glass.
 2. Cardinal Glass Industries: www.cardinalcorp.com/#sle.
 3. Glasswerks: glasswerks.com.
 4. Pilkington North America Inc: www.pilkington.com/na/#sle.
 5. Viracon, Apogee Enterprises, Inc: www.viracon.com/#sle.
 6. Vitro Architectural Glass (formerly PPG Glass): www.vitroglazings.com/#sle.
 7. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- B. Fabricator: Certified by glass manufacturer for type of glass, coating, and treatment involved and capable of providing specified warranty.

- C. Insulating Glass Units: Types as indicated.
1. Durability: Certified by an independent testing agency to comply with ASTM E2190.
 2. Coated Glass: Comply with requirements of ASTM C1376 for pyrolytic (hard-coat) or magnetic sputter vapor deposition (soft-coat) type coatings on flat glass; coated vision glass, Kind CV; coated overhead glass, Kind CO; or coated spandrel glass, Kind CS.
 3. Metal-Edge Spacers: Aluminum, bent and soldered corners.
 4. Spacer Color: Black.
 5. Edge Seal:
 - a. Single-Sealed System: Provide silicone, polysulfide, or polyurethane sealant as seal applied around perimeter.
 - b. Color: Black.
 6. Purge interpane space with dry air, hermetically sealed.
 7. Capillary Tubes: Provide tubes from air space for insulating glass units without inert type gas that have a change of altitude greater than 2500 feet between point of fabrication and point of installation to permit pressure equalization of air space.
 - a. Capillary Tubes: Tubes to remain open and be of length and material type in accordance with insulating glass fabricator's requirements.
 - b. Inert gas may be installed in the field into air space in accordance with insulating glass fabricator's and installer's requirements.
- D. Insulating Glass Units: Safety glazing.
1. Applications:
 - a. Glazed lites in exterior doors.
 - b. Glazed sidelights and panels next to doors.
 - c. Other locations required by applicable federal, state, and local codes and regulations.
 - d. Other locations indicated on drawings.
 2. Space between lites filled with air.
 3. Glass Type: Same as other vision glazing except use fully tempered float glass for both outboard and inboard lites.
 4. Total Thickness: 1 inch.
 5. Metal edge spacer.
 6. Glazing Method: Dry glazing method, gasket glazing.

2.06 BASIS OF DESIGN - INSULATING GLASS UNITS

- A. Basis of Design - Insulating Glass Units: Vision glazing, with low-e coating.
1. Applications: Exterior insulating glass glazing unless otherwise indicated.
 2. Space between lites filled with air.
 3. Total Thickness: 1 inch.
 4. Thermal Transmittance (U-Value), Summer - Center of Glass: 0.28, nominal.

5. Visible Light Transmittance (VLT): 64 percent, nominal.
6. Solar Heat Gain Coefficient (SHGC): 0.27, nominal.
7. Visible Light Reflectance, Outside: 12 percent, nominal.
8. Glazing Method: Dry glazing method, gasket glazing.
9. Durability: Certified by an independent testing agency to comply with ASTM E2190.
10. Coated Glass: Comply with requirements of ASTM C1376 for pyrolytic (hard-coat) or magnetic sputter vapor deposition (soft-coat) type coatings on flat glass; coated vision glass, Kind CV; coated overhead glass, Kind CO; or coated spandrel glass, Kind CS.
11. Metal Edge Spacers: Aluminum, bent and soldered corners.
12. Spacer Color: Black.
13. Edge Seal:
 - a. Single-Sealed System: Provide silicone, polysulfide, or polyurethane sealant as seal applied around perimeter.
14. Color: Black.
15. Purge interpane space with dry air, hermetically sealed.
16. Basis of Design - Vitro Architectural Glass (formerly PPG Glass): www.vitroglazings.com/#sle.
17. Outboard Lite: Annealed float glass, 1/4 inch thick, minimum.
 - a. Low-E Coating: Vitro Architectural Glass (formerly PPG Glass) Solarban 60 on #2 surface.
 - b. Glass: Clear.
18. Inboard Lite: Heat-strengthened float glass, 1/4 inch thick.
 - a. Coating: No coating on inboard lite.
 - b. Glass: Clear.
19. Substitution Procedures: See Section 01 60 00 - Product Requirements.
 - a. For any product not identified as "Basis of Design", submit information as specified for substitutions.

2.07 GLAZING UNITS

- A. Monolithic Interior Vision Glazing:
 1. Applications: Interior glazing unless otherwise indicated.
 2. Glass Type: Annealed float glass.
 3. Tint: Clear.
 4. Thickness: 1/4 inch, nominal.
- B. Monolithic Safety Glazing: Non-fire-rated.
 1. Applications:
 - a. Glazed lites in doors, except fire doors.
 - b. Glazed sidelights to doors, except in fire-rated walls and partitions.

- c. Other locations required by applicable federal, state, and local codes and regulations.
- d. Other locations indicated on drawings.
- 2. Glass Type: Fully tempered safety glass as specified.
- 3. Tint: Clear.
- 4. Thickness: 1/4 inch, nominal.
- 5. Glazing Method: Dry glazing method, gasket glazing.

2.08 GLAZING COMPOUNDS

- A. Type GC-3 - Polysulfide Sealant: Two component; chemical curing, nonsagging type; ASTM C920 Type M, Grade NS, Class 25, Uses M, A, and G; with cured Shore A hardness range of 15 to 25; color as selected.
- B. Type GC-5 - Silicone Sealant: Single component; neutral curing; capable of water immersion without loss of properties; nonbleeding, nonstaining; ASTM C920 Type S, Grade NS, Class 25, Uses M, A, and G; with cured Shore A hardness range of 15 to 25; color as selected.

2.09 ACCESSORIES

- A. Setting Blocks: Silicone, with 80 to 90 Shore A durometer hardness; ASTM C864 Option II. Length of 0.1 inch for each square foot of glazing or minimum 4 inch by width of glazing rabbet space minus 1/16 inch by height to suit glazing method and pane weight and area.
- B. Spacer Shims: Neoprene, 50 to 60 Shore A durometer hardness; ASTM C864 Option II. Minimum 3 inch long by one half the height of the glazing stop by thickness to suit application, self adhesive on one face.
- C. Glazing Tape, Back Bedding Mastic Type: Preformed, butyl-based, 100 percent solids compound with integral resilient spacer rod applicable to application indicated; 5 to 30 cured Shore A durometer hardness; coiled on release paper; black color.
 - 1. Width: As required for application.
 - 2. Thickness: As required for application.
- D. Glazing Gaskets: Resilient silicone extruded shape to suit glazing channel retaining slot; ASTM C864 Option II; color black.
- E. Glazing Clips: Manufacturer's standard type.

2.10 SOURCE QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements for additional requirements.
- B. Provide shop inspection and testing for Type _____ glass.

PART 3 EXECUTION

3.01 VERIFICATION OF CONDITIONS

- A. Verify that openings for glazing are correctly sized and within tolerances, including those for size, squareness, and offsets at corners.
- B. Verify that the minimum required face and edge clearances are being provided.

FOR REFERENCE ONLY

- C. Verify that surfaces of glazing channels or recesses are clean, free of obstructions that may impede moisture movement, weeps are clear, and support framing is ready to receive glazing system.
- D. Verify that sealing between joints of glass framing members has been completed effectively.
- E. Proceed with glazing system installation only after unsatisfactory conditions have been corrected.

3.02 PREPARATION

- A. Clean contact surfaces with appropriate solvent and wipe dry within maximum of 24 hours before glazing. Remove coatings that are not tightly bonded to substrates.
- B. Seal porous glazing channels or recesses with substrate compatible primer or sealer.
- C. Prime surfaces scheduled to receive sealant where required for proper sealant adhesion.

3.03 INSTALLATION, GENERAL

- A. Install glazing in compliance with written instructions of glass, gaskets, and other glazing material manufacturers, unless more stringent requirements are indicated, including those in glazing referenced standards.
- B. Install glazing sealants in accordance with ASTM C1193, GANA (SM), and manufacturer's instructions.
- C. Do not exceed edge pressures around perimeter of glass lites as stipulated by glass manufacturer.
- D. Set glass lites of system with uniform pattern, draw, bow, and similar characteristics.
- E. Set glass lites in proper orientation so that coatings face exterior or interior as indicated.
- F. Prevent glass from contact with any contaminating substances that may be the result of construction operations such as, and not limited to the following; weld splatter, fire-safing, plastering, mortar droppings, etc.

3.04 INSTALLATION - DRY GLAZING METHOD (GASKET GLAZING)

- A. Application - Exterior and/or Interior Glazed: Set glazing infills from either the exterior or the interior of the building.
- B. Place setting blocks at 1/4 points with edge block no more than 6 inch from corners.
- C. Rest glazing on setting blocks and push against fixed stop with sufficient pressure on gasket to attain full contact.
- D. Install removable stops without displacing glazing gasket; exert pressure for full continuous contact.

3.05 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements for additional requirements.
- B. Glass and Glazing product manufacturers to provide field surveillance of the installation of their products.
- C. Monitor and report installation procedures and unacceptable conditions.

3.06 CLEANING

- A. See Section 01 74 19 - Construction Waste Management and Disposal, for additional requirements.
- B. Remove excess glazing materials from finish surfaces immediately after application using solvents or cleaners recommended by manufacturers.
- C. Remove nonpermanent labels immediately after glazing installation is complete.
- D. Clean glass and adjacent surfaces after sealants are fully cured.
- E. Clean glass on both exposed surfaces not more than 4 days prior to Date of Substantial Completion in accordance with glass manufacturer's written recommendations.

3.07 PROTECTION

- A. After installation, mark pane with an 'X' by using removable plastic tape or paste; do not mark heat absorbing or reflective glass units.
- B. Remove and replace glass that is damaged during construction period prior to Date of Substantial Completion.

END OF SECTION

SECTION 08 87 33 ARCHITECTURAL DECORATIVE WINDOW FILMS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Window Film for existing windows.

1.02 REFERENCE STANDARDS

- A. ASTM E308 - Standard Practice for Computing the Colors of Objects by Using the CIE System.
- B. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials.
- C. ASTM E903 - Standard Test Method for Solar Absorptance, Reflectance, and Transmittance of Materials Using Integrating Spheres.

1.03 ADMINISTRATIVE REQUIREMENTS

- A. Preinstallation Meeting: Conduct a preinstallation meeting one week prior to the start of the work of this section; require attendance by all affected installers.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide manufacturer's data sheets on each product to be used.
- C. Shop Drawings:
 - 1. Submit shop drawings covering fabrication, installation and finish of specified systems.
 - 2. Include fully dimensioned plans and elevations with material coordination keys.
- D. Samples:
 - 1. Selection Samples: For each finish product specified, two complete sets of color chips representing manufacturer's full range of available colors and patterns.
 - 2. Verification Samples: For each finish product specified, two samples representing actual product, color, and patterns.
- E. Manufacturer's Qualification Statement.
- F. Specimen Warranty.
- G. Installer's Qualification Statement.
- H. Manufacturer's Instructions:
 - 1. Preparation instructions and recommendations.
 - 2. Storage and handling requirements and recommendations.
 - 3. Installation methods.
- I. Maintenance Data: Operation and maintenance data for installed products, including precautions against harmful cleaning materials and methods.
- J. Warranty: Submit manufacturer warranty and ensure that forms have been completed in District's name and registered with manufacturer.

1.05 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing products specified in this section, with not less than ten years of documented experience.
- B. Installer Qualifications: Company specializing in performing the work of this section and approved by manufacturer.
 - 1. Provide documentation that the installer is authorized by the Manufacturer to perform Work specified in this section.
 - 2. Provide a commercial building reference list of five (5) properties where the installer has applied window film. This list will include the following information:
 - a. Name of building.
 - b. The name and telephone number of a management contact.
 - c. Type of glass.
 - d. Type of film.
 - e. Amount of film installed.
 - f. Date of completion.
- C. Single-Source Responsibility: For each separate film graphic type required from one source of a single manufacturer.

1.06 MOCK-UP

- A. Provide window film mock-up, one complete window, illustrating installation for evaluation of surface preparation techniques and application workmanship.
- B. Locate where directed.
- C. Do not proceed with remaining work until workmanship, color, and sheen are approved by Architect.
- D. Refinish mock-up area as required to produce acceptable work.
- E. Mock-up may remain as part of the Work.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Store products in manufacturer's unopened packaging until ready for installation.
- B. Store products protected from weather, temperature, and other harmful conditions as recommended by supplier.
- C. Product must remain in original plastic bag and boxes and have storage conditions as follows:
 - 1. 40°F (5°C) - 90°F (32°C) storage temperature range
 - 2. Out of Sunlight
 - 3. Clean dry area
 - 4. Original container
 - 5. Do not stack boxes over six (6) units high. Excessive weight can damage the film
 - 6. Products are not recommended for interior applications where condensation consistently occurs.

7. Handle products in accordance with manufacturer's instructions.
8. Total pre-installation shelf life: 2 years. Up to 2 years unprocessed, OR process within 1 year and apply within 1 year of processing.

1.08 FIELD CONDITIONS

- A. Maintain environmental conditions (temperature, humidity, and ventilation) within limits recommended by manufacturer for optimum results. Do not install products under environmental conditions outside manufacturer's absolute limits.
 1. Application temperature range is from 53 to 100 degrees F (12 to 38 degrees C).
- B. Environmental Limitations: Do not install until spaces are enclosed and weatherproof, wet work in spaces is complete and dry, work above ceilings is complete, and ambient temperature and humidity conditions are maintained at the levels indicated for Project when occupied for its intended use.
- C. Existing Conditions: Existing interior and exterior windows from the original building.

1.09 WARRANTY

- A. See Section 01 78 00 - Closeout Submittals, for additional warranty requirements.
- B. Correct defective Work within a one year period after Date of Substantial Completion.
- C. Provide five year manufacturer warranty for thermal shock fracture, appearance, adhesion, and solar reflective properties.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Basis of Design: 3M Window Film: www.3m.com/windowfilm.
- B. Other Acceptable Manufacturers:
 1. Flexvue Films: www.flexvuefilms.com.
 2. Madico, Inc: www.madico.com.
 3. Substitutions: See Section 01 60 00 - Product Requirements.

2.02 PERFORMANCE REQUIREMENTS

- A. Fire Performance: Surface burning characteristics when tested in accordance ASTM E84:
 1. Flame Spread: 25, maximum.
 2. Smoke Developed: 450, maximum.

2.03 MATERIAL PROPERTIES

- A. General: Glass and plastic finishes field-applied application to glass or plastic material as visually opaque or decorative film.
- B. Adhesive: Acrylic, Pressure Sensitive.
- C. Length: 100 ft.
- D. Width: 60 inches.

- E. Average Overall Thickness (Film and Adhesive without Liner):
 - 1. Solar Control: 2 mils (51 micron)

2.04 SOLAR CONTROL FILM

- A. GF-1 Basis of Design Product: 3M™ Sun Control Window Film Ceramic Series CM40, 60 in x 100 ft as manufactured by 3M, or equal.
 - 1. Visible Light Transmission (ASTM E903, ASTM E308): 44 percent.
 - 2. Solar Heat Gain Coefficient (Normal Incidence) (ASTM E903): 0.47.
 - 3. U-Value: 1.03.
 - 4. Total Solar Energy Reduction: 53 percent.
 - 5. Exterior Visible Light Reflection (ASTM E903): 14 percent.
 - 6. Interior Visible Light Reflection (ASTM E903): 12 percent.
 - 7. Ultraviolet Rejected (ASTM E903): Not less than 99 percent.

2.05 FABRICATION

- A. Shop fabrication and tolerances for graphic artwork shall conform to the standards of the industry. All items shall be shop fabricated so far as practicable. Perform high-quality, professional workmanship. Fabricate work to proper proportions, with orientation that will be straight, plumb, level and square and to sizes, shapes and profiles indicated on the approved shop drawings.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify pattern prior to material acquisition.
- B. Confirm appropriate substrate is suitable for mounting of glass finish components prior to start of installation.
- C. Examine substrate(s) for compliance. Do not proceed with installation until unsatisfactory conditions have been corrected.
- D. Reference 3M Technical Data Sheet to determine compatibility of finish to substrate
- E. Responsibility for state of surfaces prior to installation to be pre-determined by installation specialist.
- F. Do not proceed with installation until unsatisfactory conditions have been corrected.
- G. Proceeding with installation implies installer's acceptance of substrate and conditions.

3.02 PREPARATION

- A. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.
- B. Thoroughly clean substrate of substances that could impair the overlay's bond, including mold, mildew, oil, grease.

- C. Re-clean surfaces with appropriate surface prep solvent and remove any haze or surface contamination.

3.03 INSTALLATION

- A. Application must be performed by qualified installer.
- B. Do not proceed with installation until all finishing work has been completed in and around the work area.
- C. Install in accordance with manufacturer's instructions.
- D. Cut film edges neatly and square at a uniform distance of 1/8 inch (3 mm) to 1/16 inch (1.5 mm) of window sealant. Use new blade tips after 3 to 4 cuts.
- E. Spray the slip solution, composed of one capful of baby shampoo or dishwashing liquid to 1 gallon of water, on window glass and adhesive to facilitate proper positioning of film.
- F. Apply film to glass and lightly spray film with slip solution.
- G. Squeegee from top to bottom of window. Spray slip solution to film and squeegee a second time.
- H. Bump film edge with lint-free towel wrapped around edge of a 5-way tool.
- I. Upon completion of film application, allow 30 days for moisture from film installation to dry thoroughly, and to allow film to dry flat with no moisture dimples when viewed under normal viewing conditions.
- J. Refer to the applicable manufacturer's Installation Guide for additional details.

3.04 CLEANING

- A. Remove left over material and debris from Work area. Use necessary means to protect film before, during, and after installation.
- B. Touch-up, repair or replace damaged products before Substantial Completion.
- C. After application of film, wash film using common window cleaning solutions, including ammonia solutions, 30 days after application.
 - 1. Do not use abrasive type cleaning agents and bristle brushes to avoid scratching film.
 - 2. Use synthetic sponges or soft cloths.

3.05 EXTRA MATERIALS

- A. Furnish 2 percent extra material at time of installation. Deliver in protective packaging for storage and label contents appropriately.

END OF SECTION

SECTION 09 05 61 COMMON WORK RESULTS FOR FLOORING PREPARATION

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. This section applies to floors identified in Contract Documents that are receiving the following types of floor coverings:
 - 1. Resilient tile and sheet.
 - a. Moisture vapor seal is required at all locations to receive resilient flooring regardless of moisture test.
 - 2. Thin-set ceramic tile and stone tile.
 - 3. Fluid-Applied flooring
 - a. Moisture vapor seal is required at all locations to receive fluid-applied flooring regardless of moisture test.
- B. Preparation of new and existing concrete floor slabs for installation of floor coverings.
- C. Testing of concrete floor slabs for moisture and alkalinity (pH).
- D. Remediation of concrete floor slabs due to unsatisfactory moisture or alkalinity (pH) conditions.
 - 1. Contractor shall perform all specified remediation of concrete floor slabs. If such remediation is indicated by testing agency's report and is due to a condition not under Contractor's control or could not have been predicted by examination prior to entering into the contract, a contract modification will be issued.
- E. Patching compound.
- F. Remedial floor coatings.

1.02 RELATED REQUIREMENTS

- A. Section 01 40 00 - Quality Requirements: Additional requirements relating to testing agencies and testing.
- B. Section 01 74 19 - Construction Waste Management and Disposal: Handling of existing floor coverings removed.
- C. Section 03 30 00 - Cast-in-Place Concrete: Moisture emission reducing curing and sealing compound for slabs to receive adhered flooring, to prevent moisture content-related flooring failures; to remain in place, not to be removed.
- D. Section 03 30 00 - Cast-in-Place Concrete: Limitations on curing requirements for new concrete floor slabs.

1.03 REFERENCE STANDARDS

- A. ASTM C109/C109M - Standard Test Method for Compressive Strength of Hydraulic Cement Mortars (Using 2-in. or [50 mm] Cube Specimens).

- B. ASTM C472 - Standard Test Methods for Physical Testing of Gypsum, Gypsum Plasters, and Gypsum Concrete.
- C. ASTM F710 - Standard Practice for Preparing Concrete Floors to Receive Resilient Flooring.
- D. ASTM F1869 - Standard Test Method for Measuring Moisture Vapor Emission Rate of Concrete Subfloor Using Anhydrous Calcium Chloride.
- E. ASTM F2170 - Standard Test Method for Determining Relative Humidity in Concrete Floor Slabs Using in situ Probes.
- F. RFCI (RWP) - Recommended Work Practices for Removal of Resilient Floor Coverings.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordinate scheduling of cleaning and testing, so that preliminary cleaning has been completed for at least 24 hours prior to testing.

1.05 SUBMITTALS

- A. Visual Observation Report: For existing floor coverings to be removed.
- B. Floor Covering and Adhesive Manufacturers' Product Literature: For each specific combination of substrate, floor covering, and adhesive to be used; showing:
 - 1. Moisture and alkalinity (pH) limits and test methods.
 - 2. Manufacturer's required bond/compatibility test procedure.
- C. Remedial Materials Product Data: Manufacturer's published data on each product to be used for remediation.
 - 1. Manufacturer's qualification statement.
 - 2. Test reports indicating compliance with specified performance requirements, performed by nationally recognized independent testing agency.
 - 3. Manufacturer's installation instructions.
 - 4. Specimen Warranty: Copy of warranty to be issued by coating manufacturer and certificate of underwriter's coverage of warranty.
- D. Testing Agency's Report:
 - 1. Description of areas tested; include floor plans and photographs if helpful.
 - 2. Summary of conditions encountered.
 - 3. Moisture and alkalinity (pH) test reports.
 - 4. Copies of specified test methods.
 - 5. Recommendations for remediation of unsatisfactory surfaces.
 - 6. Submit report directly to District.
 - 7. Submit report not more than two business days after conclusion of testing.
- E. Adhesive Bond and Compatibility Test Report.
- F. Floor Moisture Testing Technician Certificate: International Concrete Repair Institute (ICRI) Concrete Slab Moisture Testing Technician- Grade I certificate.
- G. Copy of RFCI (RWP).

1.06 QUALITY ASSURANCE

- A. Moisture and alkalinity (pH) testing will be performed by an independent testing agency employed and paid by District.
- B. Contractor may perform additional adhesive and bond test with Contractor's own personnel or hire a testing agency.
- C. Testing Agency Qualifications: Independent testing agency experienced in the types of testing specified.
 - 1. Submit evidence of experience consisting of at least 3 test reports of the type required, with project District's project contact information.
- D. Contractor's Responsibility Relating to Independent Agency Testing:
 - 1. Provide access for and cooperate with testing agency.
 - 2. Confirm date of start of testing at least 10 days prior to actual start.
 - 3. Allow at least 4 business days on site for testing agency activities.
 - 4. Achieve and maintain specified ambient conditions.
 - 5. Notify District when specified ambient conditions have been achieved and when testing will start.
- E. Floor Moisture Testing Technician Qualifications: International Concrete Repair Institute (ICRI) Concrete Slab Moisture Testing Technician Certification- Grade I.
- F. Remedial Coating Installer Qualifications: Company specializing in performing work of the type specified in this section, trained by or employed by coating manufacturer, and able to provide at least 3 project references showing at least 3 years' experience installing moisture emission coatings.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Deliver, store, handle, and protect products in accordance with manufacturer's instructions and recommendations.
- B. Deliver materials in manufacturer's packaging; include installation instructions.
- C. Keep materials from freezing.

1.08 FIELD CONDITIONS

- A. Maintain ambient temperature in spaces where concrete testing is being performed, and for at least 48 hours prior to testing, at not less than 65 degrees F or more than 85 degrees F.
- B. Maintain relative humidity in spaces where concrete testing is being performed, and for at least 48 hours prior to testing, at not less than 40 percent and not more than 60 percent.

PART 2 PRODUCTS

2.01 MATERIALS

- A. Patching Compound: Floor covering manufacturer's recommended product, suitable for conditions, and compatible with adhesive and floor covering. In the absence of any recommendation from flooring manufacturer, provide a product with the following characteristics:
1. Cementitious moisture-, mildew-, and alkali-resistant compound, compatible with floor, floor covering, and floor covering adhesive, and capable of being feathered to nothing at edges.
 2. Latex or polyvinyl acetate additions are permitted; gypsum content is prohibited.
 3. Compressive Strength: 3000 psi, minimum, after 28 days, when tested in accordance with ASTM C109/C109M or ASTM C472, whichever is appropriate.
 4. Products:
 - a. ARDEX Engineered Cements; ARDEX Feather Finish: www.ardexamericas.com/#sle.
 - b. H.B. Fuller Construction Products, Inc; TEC Feather Edge Skim Coat: www.tecspecialty.com/#sle.
 - c. Mapei International; Mapei Ultraplan 1 Plus: www.mapei.com.
 - d. Sika Corporation; Sika Level-315: www.sikafloorusa.com.
 - e. USG Corporation; Durock Brand Advanced Skim Coat Floor Patch: www.usg.com/#sle.
 - f. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Alternate Flooring Adhesive: Floor covering manufacturer's recommended product, suitable for the moisture and pH conditions present; low-VOC. In the absence of any recommendation from flooring manufacturer, provide a product recommended by adhesive manufacturer as suitable for substrate and floor covering and for conditions present.
- C. Remedial Floor Coating: Single- or multi-layer coating or coating/overlay combination intended by its manufacturer to resist water vapor transmission to degree sufficient to meet flooring manufacturer's emission limits, resistant to the level of alkalinity (pH) found, and suitable for adhesion of flooring without further treatment.
1. Thickness: As required for application and in accordance with manufacturer's installation instructions.
 2. Products:
 - a. ARDEX Engineered Cements; ARDEX MC RAPID: www.ardexamericas.com/#sle.
 - b. Custom Building Products; TechMVC Moisture Vapor and Alkalinity Barrier: www.custombuildingproducts.com/#sle.
 - c. Floor Seal Technology, Inc; MES 100 with Floor Seal FloorCem SLU: www.floorseal.com/#sle.
 - d. Koster American Corporation; Koster VAP I 2000 with Koster SL Premium overlay: www.kosterusa.com/#sle.

- e. LATICRETE International, Inc; LATICRETE NXT Vapor Reduction Coating with LATICRETE NXT Level Plus: www.laticrete.com/#sle.
- f. LATICRETE International, Inc; LATICRETE SUPERCAP Moisture Vapor Control with LATICRETE SUPERCAP Underlayment: www.laticrete.com/#sle.
- g. Maxxon Corporation; Aquafin SG4: www.maxxon.com/#sle.
- h. Sika Corporation; Sikafloor Moisture Tolerance Epoxy Primer and Sikafloor Self-Leveling Moisture Tolerant Resurfacer: www.sikafloorusa.com/#sle.
- i. Tnemec Company, Inc; Series 208 Epoxoprime MVT: www.tnemec.com/#sle.
- j. USG Corporation; Durock CoverPrep: www.usg.com/#sle.
- k. Substitutions: See Section 01 60 00 - Product Requirements.

PART 3 EXECUTION

3.01 CONCRETE SLAB PREPARATION

- A. Follow recommendations of testing agency.
- B. Perform following operations in the order indicated:
 - 1. Preliminary cleaning.
 - 2. Moisture vapor emission tests; 3 tests in the first 1000 square feet and one test in each additional 1000 square feet, unless otherwise indicated or required by flooring manufacturer.
 - 3. Internal relative humidity tests; in same locations as moisture vapor emission tests, unless otherwise indicated.
 - 4. Alkalinity (pH) tests; in same locations as moisture vapor emission tests, unless otherwise indicated.
 - 5. Specified remediation, if required.
 - 6. Patching, smoothing, and leveling, as required.
 - 7. Other preparation specified.
 - 8. Adhesive bond and compatibility test.
 - 9. Protection.
- C. Remediations:
 - 1. Active Water Leaks or Continuing Moisture Migration to Surface of Slab: Correct this condition before doing any other remediation; re-test after correction.
 - 2. Excessive Moisture Emission or Relative Humidity: If an adhesive that is resistant to the level of moisture present is available and acceptable to flooring manufacturer, use that adhesive for installation of the flooring; if not, apply remedial floor coating or remedial sheet membrane over entire suspect floor area.
 - 3. Excessive Alkalinity (pH): If remedial floor coating is necessary to address excessive moisture, no additional remediation is required; if not, if an adhesive that is resistant to the level present is available and acceptable to the flooring manufacturer, use that adhesive for installation of the flooring; otherwise, apply a skim coat of specified patching compound over entire suspect floor area.

3.02 PRELIMINARY CLEANING

- A. Clean floors of dust, solvents, paint, wax, oil, grease, asphalt, residual adhesive, adhesive removers, film-forming curing compounds, sealing compounds, alkaline salts, excessive laitance, mold, mildew, and other materials that might prevent adhesive bond.
- B. Do not use solvents or other chemicals for cleaning.

3.03 MOISTURE VAPOR EMISSION TESTING

- A. Where the floor covering manufacturer's requirements conflict with either the referenced test method or this specification, comply with the manufacturer's requirements.
- B. Where this specification conflicts with the referenced test method, comply with the requirements of this section.
- C. Test in accordance with ASTM F1869 and as follows.
- D. Plastic sheet test and mat bond test may not be substituted for the specified ASTM test method, as those methods do not quantify the moisture content sufficiently.
- E. In the event that test values exceed floor covering manufacturer's limits, perform remediation as indicated. In the absence of manufacturer limits, perform remediation if test values exceed 3 pounds per 1000 square feet per 24 hours.
- F. Report: Report the information required by the test method.

3.04 INTERNAL RELATIVE HUMIDITY TESTING

- A. Where the floor covering manufacturer's requirements conflict with either the referenced test method or this specification, comply with the manufacturer's requirements.
- B. Where this specification conflicts with the referenced test method, comply with the requirements of this section.
- C. Test in accordance with ASTM F2170 Procedure A and as follows.
- D. Testing with electrical impedance or resistance apparatus may not be substituted for the specified ASTM test method, as the values determined are not comparable to the ASTM test values and do not quantify the moisture content sufficiently.
- E. In the event that test values exceed floor covering manufacturer's limits, perform remediation as indicated. In the absence of manufacturer limits, perform remediation if any test value exceeds 75 percent relative humidity.
- F. Report: Report the information required by the test method.

3.05 ALKALINITY TESTING

- A. Where the floor covering manufacturer's requirements conflict with either the referenced test method or this specification, comply with the manufacturer's requirements.
- B. The following procedure is the equivalent of that described in ASTM F710, repeated here for the Contractor's convenience.
 - 1. Use a wide range alkalinity (pH) test paper, its associated chart, and distilled or deionized water.

2. Place several drops of water on a clean surface of concrete, forming a puddle approximately 1 inch in diameter. Allow the puddle to set for approximately 60 seconds, then dip the alkalinity (pH) test paper into the water, remove it, and compare immediately to chart to determine alkalinity (pH) reading.
 3. Use of a digital pH meter with probe is acceptable; follow meter manufacturer's instructions.
- C. In the event that test values exceed floor covering manufacturer's limits, perform remediation as indicated. In the absence of manufacturer limits, perform remediation if alkalinity (pH) test value is over 10.

3.06 PREPARATION

- A. See individual floor covering section(s) for additional requirements.
- B. Comply with recommendations of testing agency.
- C. Comply with requirements and recommendations of floor covering manufacturer.
- D. Fill and smooth surface cracks, grooves, depressions, control joints and other non-moving joints, and other irregularities with patching compound.
- E. Do not fill expansion joints, isolation joints, or other moving joints.

3.07 ADHESIVE BOND AND COMPATIBILITY TESTING

- A. Comply with requirements and recommendations of floor covering manufacturer.

3.08 APPLICATION OF REMEDIAL FLOOR COATING

- A. Comply with requirements and recommendations of coating manufacturer.
- B. Install remedial coating over all concrete floor areas where moisture emission and/or alkalinity exceeds the floor covering manufacturer's published limits.
- C. Prepare floor areas to be coated in accordance with coating manufacturer's requirements.
 1. Mask and protect adjacent wall and floor surfaces from damage due to this work.
- D. Apply coating using manufacturer's recommended procedures.
- E. Apply 1/8 inch thick cementitious surfacing over coating in areas to receive adhesively applied floor coverings.
- F. Verify that prepared floor slab has moisture emission rate and alkalinity meeting requirements.

3.09 PROTECTION

- A. Cover prepared floors with building paper or other durable covering.

END OF SECTION

SECTION 09 21 16 GYPSUM BOARD ASSEMBLIES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Gypsum sheathing.
- B. Cementitious backing board.
- C. Gypsum wallboard.
- D. Joint treatment and accessories.

1.02 RELATED REQUIREMENTS

- A. Section 01 61 16 - Volatile Organic Compound (VOC) Content Restrictions.
- B. Section 06 10 00 - Rough Carpentry: Building framing and sheathing.
- C. Section 06 10 00 - Rough Carpentry: Wood blocking product and execution requirements.
- D. Section 07 25 00 - Weather Barriers: Water-resistive barrier over sheathing.
- E. Section 07 92 00 - Joint Sealants: Sealing acoustical gaps in construction other than gypsum board or plaster work.

1.03 REFERENCE STANDARDS

- A. ANSI A108.11 - American National Standard Specifications for Interior Installation of Cementitious Backer Units.
- B. ANSI A118.9 - American National Standard Specifications for Test Methods and Specifications for Cementitious Backer Units.
- C. ASTM A780/A780M - Standard Practice for Repair of Damaged and Uncoated Areas of Hot-Dip Galvanized Coatings.
- D. ASTM C475/C475M - Standard Specification for Joint Compound and Joint Tape for Finishing Gypsum Board.
- E. ASTM C514 - Standard Specification for Nails for the Application of Gypsum Board.
- F. ASTM C557 - Standard Specification for Adhesives for Fastening Gypsum Wallboard to Wood Framing.
- G. ASTM C840 - Standard Specification for Application and Finishing of Gypsum Board.
- H. ASTM C1047 - Standard Specification for Accessories for Gypsum Wallboard and Gypsum Veneer Base.
- I. ASTM C1177/C1177M - Standard Specification for Glass Mat Gypsum Substrate for Use as Sheathing.
- J. ASTM C1280 - Standard Specification for Application of Exterior Gypsum Panel Products for Use as Sheathing.
- K. ASTM C1325 - Standard Specification for Fiber-Mat Reinforced Cementitious Backer Units.
- L. ASTM C1396/C1396M - Standard Specification for Gypsum Board.

- M. ASTM D3273 - Standard Test Method for Resistance to Growth of Mold on the Surface of Interior Coatings in an Environmental Chamber.
- N. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials.
- O. GA-216 - Application and Finishing of Gypsum Panel Products.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data:
 - 1. Joint Treatment Materials: Submit manufacturer's product data, indicating VOC content.
- C. Provide letter from manufacturer that upper and lower track system to be utilized will maintain sound and fire rating of specified assembly.

1.05 QUALITY ASSURANCE

- A. Installer Qualifications: Company specializing in performing work of the type specified and with at least three years of documented experience.
- B. Regulatory Requirements: Conform to California Building Code (CBC), Title 24, Part 2, Chapter 7, Chapter 8, and Chapter 25, as amended and adopted by authorities having jurisdiction.
- C. Documents at Project Site: Maintain at the project site a copy of manufacturer's instructions, erection drawings, and shop drawings.

1.06 DELIVERY, STORAGE, AND HANDLING

- A. See Section 01 74 19 - Construction Waste Management and Disposal for packaging waste requirements.
- B. Store gypsum products and accessories indoors and keep above freezing. Elevate boards above floor, on nonwicking supports, in accordance with manufacturer's recommendations.
- C. Store metal products to prevent corrosion.

1.07 DELIVERY, STORAGE AND HANDLING

- A. Deliver gypsum board and accessories in manufacturer's original unopened containers, bundles or rolls bearing manufacturer's identification.
- B. Store materials inside the building or in other dry weather tight enclosure. Stack gypsum board flat and off the floor. Do not stack long lengths over shorter lengths.
- C. Store flammable adhesives away from fire, sparks and smoking areas.
- D. Handle gypsum board to prevent damage to edges, ends, and surfaces.

1.08 WARRANTY

- A. See Section 01 78 00 - Closeout Submittals for additional warranty requirements.
- B. Manufacturer Warranty: Provide 1-year manufacturer warranty for manufacturing defects. Complete forms in District's name and register with manufacturer.

PART 2 PRODUCTS

2.01 GYPSUM BOARD ASSEMBLIES

- A. Provide completed assemblies complying with ASTM C840 and GA-216.
 - 1. See PART 3 for finishing requirements.

2.02 BOARD MATERIALS

- A. General: Gypsum board, joint treatment and finishing materials shall be manufactured from asbestos-free materials.
- B. Manufacturers - Gypsum-Based Board:
 - 1. CertainTeed Corporation: www.certainteed.com/#sle.
 - 2. Georgia-Pacific Gypsum: www.gpgypsum.com/#sle.
 - 3. National Gypsum Company: www.nationalgypsum.com/#sle.
 - 4. USG Corporation: www.usg.com/#sle.
 - 5. Substitutions: See Section 01 60 00 - Product Requirements.
- C. Gypsum Wallboard: Paper-faced gypsum panels as defined in ASTM C1396/C1396M; sizes to minimize joints in place; ends square cut.
 - 1. Application: Use for vertical surfaces and ceilings, unless otherwise indicated.
 - 2. Mold Resistance: Score of 10, when tested in accordance with ASTM D3273.
 - a. Mold-resistant board is required whenever board is being installed before the building is enclosed and conditioned.
 - b. Mold resistant board is required at all locations.
 - 3. Thickness:
 - a. Vertical Surfaces: 5/8 inch.
 - b. Ceilings: 5/8 inch.
 - c. Multi-Layer Assemblies: Thicknesses as indicated on drawings.
 - 4. Mold-Resistant, Paper-Faced Products:
 - a. Georgia-Pacific Gypsum; ToughRock Mold-Guard: www.gpgypsum.com/#sle.
 - b. Georgia-Pacific Gypsum; ToughRock Fireguard X Mold-Guard: www.gpgypsum.com/#sle.
 - c. Gold Bond Building Products, LLC provided by National Gypsum Company; Gold Bond XP Gypsum Board: www.goldbondbuilding.com/#sle.
 - d. USG Corporation; Sheetrock Brand EcoSmart Panels Mold Tough Firecode X 5/8 in. (15.9 mm): www.usg.com/#sle.
 - e. USG Corporation; Sheetrock Brand UltraLight Panels Mold Tough 1/2 in. (12.7 mm): www.usg.com/#sle.
- D. Backing Board For Wet Areas:
 - 1. Application: Surfaces behind tile in wet areas including locations where noted.

FOR REFERENCE ONLY

2. Application: Horizontal surfaces behind tile in wet areas including countertops.
 3. Mold Resistance: Score of 10, when tested in accordance with ASTM D3273.
 4. ANSI Cement-Based Board: Non-gypsum-based; aggregated Portland cement panels with glass fiber mesh embedded in front and back surfaces complying with ANSI A118.9 or ASTM C1325.
 - a. Thickness: 1/2 inch.
 - b. Products:
 - 1) Custom Building Products; Wonderboard: www.custombuildingproducts.com/#sle.
 - 2) PermaBASE Building Products, LLC provided by National Gypsum Company; PermaBase Cement Board: www.goldbondbuilding.com/#sle.
 - 3) Substitutions: See Section 01 60 00 - Product Requirements.
- E. Backing Board For Non-Wet Areas: Water-resistant gypsum backing board as defined in ASTM C1396/C1396M; sizes to minimum joints in place; ends square cut.
1. Application: Vertical surfaces behind thinset tile, except in wet areas.
 2. Mold Resistance: Score of 10, when tested in accordance with ASTM D3273.
 3. At Assemblies Indicated with Fire-Resistance Rating: Use type required by indicated tested assembly; if no tested assembly is indicated, use Type X board, UL or WH listed.
 4. Type X Thickness: 5/8 inch.
 5. Regular Board Thickness: 5/8 inch.
 6. Edges: Tapered.
 7. Products:
 - a. CertainTeed Corporation; ProRoc Brand Moisture & Mold Resistant Gypsum Board.
 - b. Georgia-Pacific Gypsum; ToughRock Mold-Guard Gypsum Board: www.gpgypsum.com/#sle.
 - c. Lafarge North America Inc; Mold Defense Drywall.
 - d. Gold Bond Building Products, LLC provided by National Gypsum Company; Gold Bond XP Fire-Shield Gypsum Board: www.goldbondbuilding.com/#sle.
 - e. USG Corporation; Sheetrock Brand Mold Tough Gypsum Panels.
 - f. Substitutions: See Section 01 60 00 - Product Requirements.
- F. Exterior Sheathing Board: Sizes to minimize joints in place; ends square cut.
1. Application: Exterior sheathing, unless otherwise indicated.
 - a. Where plywood sheathing is not indicated.
 2. Mold Resistance: Score of 10, when tested in accordance with ASTM D3273.
 3. Glass Mat Faced Sheathing: Glass mat faced gypsum substrate as defined in ASTM C1177/C1177M.
 4. Core Type: Regular and Type X, as indicated.
 5. Type X Thickness: 5/8 inch.

6. Regular Board Thickness: 5/8 inch.
7. Edges: Square, for vertical application or horizontal.
8. Glass Mat Faced Products:
 - a. Georgia-Pacific Gypsum; DensGlass Sheathing: www.gpgypsum.com/#sle.
 - b. Georgia-Pacific Gypsum; DensGlass Fireguard Sheathing: www.gpgypsum.com/#sle.
 - c. Gold Bond Building Products, LLC provided by National Gypsum Company; Gold Bond eXP Fire-Shield Sheathing: www.goldbondbuilding.com/#sle.
 - d. USG Corporation; Securock Brand UltraLight Glass-Mat Sheathing 1/2 in. (12.7 mm): www.usg.com/#sle.
 - e. USG Corporation; Securock Brand UltraLight Glass-Mat Sheathing Firecode X 5/8 in. (15.9 mm): www.usg.com/#sle.
 - f. Substitutions: See Section 01 60 00 - Product Requirements.

2.03 GYPSUM BOARD ACCESSORIES

- A. Acoustic Insulation: ASTM C665; preformed glass fiber, friction fit type, unfaced. Thickness: Fill the stud wall cavity.
 1. Application:
 - a. Partitions with STC Rating:
 - 1) Insulation fill at gypsum board partition stud framing.
 - 2) Surround penetrations in gypsum board partitions.
 - b. Gypsum board ceilings adjacent to sound-rated partitions.
 2. Surface Burning Characteristics as per ASTM E84: Flame Spread of 10; Smoke Developed of 10.
 3. Products:
 - a. Owens-Corning; Sound Attenuation Batts: www.owenscorning.com.
 - b. CertainTeed; "NoiseReducer" Sound Attenuation Batts: www.certainteed.com.
 - c. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- B. Sealants: For penetrations at fire-rated construction, provide firestopping as specified in Section 07 84 00 - Firestopping.
- C. Water-Resistive Barrier: See Section 07 25 00.
- D. Beads, Joint Accessories, and Other Trim: ASTM C1047, galvanized steel, unless noted otherwise.
 1. Manufacturers - Finishing Accessories:
 - a. Flannery, Inc.: flannerytrim.com.
 - b. Fry Reglet: fryreglet.com.
 - c. Phillips Manufacturing Co: www.phillipsmfg.com.
 - d. Pittcon Industries: www.pittconinsutries.com
 - e. Trim-tex, Inc.: www.trim-tex.com.

- f. CEMCO Products, Inc; www.cemco.com.
 - g. USG Corporation: www.usg.com
 - h. Substitutions: See Section 01 60 00 - Product Requirements.
2. Corner Beads: Low profile, for 90 degree outside corners.
- a. Cornerbead: USG Sheetrock B1 XW EL, or equal.
 - b. L Trim: USG Paper-faced "L" trim, B4 or equal.
- E. Joint Materials: ASTM C475/C475M and as recommended by gypsum board manufacturer for project conditions.
- 1. Fiberglass Tape: 2 inch wide, coated glass fiber tape for joints and corners, except as otherwise indicated.
 - 2. Joint Compound: Drying type, vinyl-based, ready-mixed.
 - 3. Joint Compound: Setting type, field-mixed.
- F. Nails for Attachment to Wood Members: ASTM C514, as required for fire-resistive construction.
- G. Staples For Attachment of Base Ply of Two-Ply Assembly to Wood Members: Flattened galvanized wire type as specified in ASTM C840.
- H. Anchorage to Substrate: Tie wire, nails, screws, and other metal supports, of type and size to suit application; to rigidly secure materials in place.
- I. Adhesive for Attachment to Wood ASTM C557:
- 1. Do not use adhesive containing benzene, carbon tetrachloride, or trichloroethylene.
 - a. Adhesive shall contain a maximum VOC content of 50 grams per liter.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that project conditions are appropriate for work of this section to commence.
- B. Beginning of installation means acceptance of substrate.
- C. Coordinate gypsum board Work with Work specified in other Sections to properly locate framing members and to provide additional framing and backing as necessary for recessed and built-in components.
 - 1. Verify that framing and furring are securely attached and of sizes and spacing to provide a suitable substrate to receive gypsum board.
 - 2. Maintain a minimum temperature of 50 degrees F for a period extending from 48 hours before installation until the joint compounds have completely dried.
- D. Examine substrates which gypsum board wall construction attaches to or abuts, including the following.
 - 1. Preset hollow metal frames
 - 2. Piping.
 - 3. Conduit.

4. Ductwork.
- E. Provide adequate and continuous ventilation to ensure proper drying, setting or curing of taping and finishing compounds. Provide temporary air circulators in enclosed areas lacking natural ventilation. GA-216, article 18.2.
- F. Provide fixtures, anchors, sleeves, inserts and miscellaneous items, and provide openings and chases as necessary. Prior to closing in and finishing of drywall Work, ascertain that piping, conduit, ductwork and fixtures which are to be concealed and which penetrate gypsum boards are in place, tested and approved.
- G. Scaffolding: Construct, erect and maintain in conformance with applicable laws and ordinances.
- H. Fire Protection: Where required, the Work shall comply with the requirements for the protection rating indicated in the governing building code.

3.02 BOARD INSTALLATION

- A. Comply with ASTM C840, GA-216, and manufacturer's instructions. Install to minimize butt end joints, especially in highly visible locations.
- B. Single-Layer Nonrated: Install gypsum board in most economical direction, with ends and edges occurring over firm bearing.
 1. Exception: Tapered edges to receive joint treatment at right angles to framing.
 2. In wood frame construction, erect panels horizontally only.
- C. Double-Layer, Nonrated: Use gypsum board for first layer, placed parallel to framing or furring members, with ends and edges occurring over firm bearing. Use glass mat faced gypsum board at exterior walls and at other locations as indicated. Place second layer perpendicular to framing or furring members. Offset joints of second layer from joints of first layer.
- D. Exposed Gypsum Board in Interior Wet Areas: Seal joints, cut edges, and holes with water-resistant sealant.
- E. Exterior Sheathing: Comply with ASTM C1280. Install sheathing vertically, with edges butted tight and ends occurring over firm bearing.
 1. Seal joints, cut edges, and holes with water-resistant sealant.
 2. Paper-Faced Sheathing: Immediately after installation, protect from weather by application of water-resistive barrier.
- F. Cementitious Backing Board: Install over wood framing members and plywood substrate where indicated, in accordance with ANSI A108.11 and manufacturer's instructions.
- G. Fastener Spacing: Space fasteners in accordance with reference standards and fire rating requirements of wall, partition, floor and ceiling assembly. Maximum spacing of 1-inch screws 8 inches on centers at vertical edges and 12 inches on centers in field and at top and bottom.
- H. Installation on Wood Framing: For rated assemblies, comply with requirements of listing authority. For nonrated assemblies, install as follows:
 1. Single-Layer Applications: Adhesive application.
 2. Double-Layer Application: Install base layer using screws. Install face layer using screws or adhesive.

3.03 INSTALLATION OF TRIM AND ACCESSORIES

- A. Use longest practical lengths. Place corner beads at external corners. Place edge trim when gypsum board abuts dissimilar materials. Surfaces indicated to receive non-textured finish and semi-gloss enamels.
- B. Control Joints: Place control joints consistent with lines of building spaces and as indicated.
 - 1. Not more than 30 feet apart on walls and ceilings.
 - 2. Maintain fire and sound rating at control joints.
- C. Corner Beads: Install at external corners, using longest practical lengths.
- D. Edge Trim: Install at locations where gypsum board abuts dissimilar materials.

3.04 JOINT TREATMENT

- A. Glass Mat Faced Gypsum Board and Exterior Glass Mat Faced Sheathing: Use fiberglass joint tape, embed and finish with setting type joint compound.
- B. Paper Faced Gypsum Board: Use paper joint tape, embed with drying type joint compound and finish with drying type joint compound.
- C. Finish gypsum board in accordance with levels defined in ASTM C840, as follows:
 - 1. Level 4: Walls and ceilings to receive paint finish or wall coverings, unless otherwise indicated.
 - 2. Level 2: In utility areas, behind cabinetry, and on backing board to receive tile finish.
 - 3. Level 1: Fire-resistance-rated wall areas above finished ceilings, whether or not accessible in the completed construction.
- D. Tape, fill, and sand all exposed joints, edges, and corners, including inside corners to produce smooth surface ready to receive finishes.
 - 1. Feather coats of joint compound so that camber is maximum 1/32 inch.
 - 2. Tape shall be set over joint and seated into joint compound, leaving sufficient adhesive under tape to provide proper bond.
 - 3. Internal angles, both horizontal and vertical, shall be reinforced and with tape folded to form straight and true angle.
 - 4. Metal external corners shall be cemented in place.
 - 5. Joints shall be allowed to dry according to Gypsum Association Standards based on temperature and humidity. Allow for at least 24 hours between each application of joint compound.
 - 6. The final application of compound and sanding shall leave all surfaces uniformly smooth and in condition to receive specified finish.
 - 7. Taping, filling, and sanding are not required at surfaces behind adhesive applied tile and fixed cabinetry.
 - 8. Taping, filling, and sanding are not required at base layer of double-layer applications.
- E. Fill and finish joints and corners of cementitious backing board as recommended by manufacturer.

3.05 TOLERANCES

- A. Maximum Variation of Finished Gypsum Board Surface from True Flatness: 1/8 inch in 10 feet in any direction.

3.06 PROTECTION

- A. Protect installed gypsum board assemblies from subsequent construction operations.

3.07 REPAIR, CLEAN-UP AND PROTECTION

- A. Repair damage to galvanized coatings in conformance with ASTM A780/A780M.
- B. Repair fastener pops by driving a new fastener approximately 1-1/2 inches from the fastener pop and reset the popped fastener. When face paper is punctured, install a new fastener approximately 1-1/2 inches from the defective fastener. Fill damaged surfaces with compound.
- C. Upon completion of the work, remove from adjacent surfaces, overspray, splatter and daubs of taping and finish compound and textured finishes. Remove tools, equipment, unused material and cuttings and leave the work in a clean orderly manner.

END OF SECTION

SECTION 09 22 36 LATH

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Metal lath for cement plaster.
- B. Furring for metal lath.
- C. Metal ceiling framing.

1.02 RELATED REQUIREMENTS

- A. Section 06 10 00 - Rough Carpentry: Sheathing on exterior walls.
- B. Section 07 25 00 - Weather Barriers: Water-resistive barrier under exterior plaster and stucco.
- C. Section 08 31 00 - Access Doors and Panels: Product requirements for metal access panels integral with metal lath.
- D. Section 09 21 16 - Gypsum Board Assemblies: Sheathing on exterior walls.
- E. Section 09 24 00 - Cement Plastering.

1.03 REFERENCE STANDARDS

- A. ASTM A653/A653M - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process.
- B. ASTM A653/A653M - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process.
- C. ASTM A924/A924M - Standard Specification for General Requirements for Steel Sheet, Metallic-Coated by the Hot-Dip Process.
- D. ASTM C841 - Standard Specification for Installation of Interior Lathing and Furring.
- E. ASTM C847 - Standard Specification for Metal Lath.
- F. ASTM C933 - Standard Specification for Welded Wire Lath.
- G. ASTM C1032 - Standard Specification for Woven Wire Plaster Base.
- H. ASTM C1063 - Standard Specification for Installation of Lathing and Furring to Receive Interior and Exterior Portland Cement-Based Plaster.
- I. CBC Sections 2504, 2507, and 2510.
- J. Plaster Assemblies Manual - Technical Information Services Bureau (TSIB) of Western Walls & Ceilings Contractors Association (WWCCA); Current Edition.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide data on furring and lathing components, structural characteristics, material limitations, and finish.

1.05 QUALITY ASSURANCE

- A. Maintain one copy of each installation standard referenced on site throughout the duration of lathing and plastering work.
- B. Installer Qualifications: Company specializing in performing the work of this section with at least three years of documented experience.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Metal Lath and Accessories:
 - 1. Brand X Metals: www.brandxmetals.com.
 - 2. CEMCO: www.cemcosteel.com/#sle.
 - 3. ClarkDietrich: www.clarkdietrich.com/#sle.
 - 4. Stockton Products: www.stocktonproducts.com.
 - 5. Structa Wire Corporation; Structalath: www.structawire.com/#sle.
 - 6. Substitutions: See Section 01 60 00 - Product Requirements.

2.02 FRAMING AND LATH ASSEMBLIES

- A. Provide completed assemblies with the following characteristics: See also CBC Table 1604A.3.
 - 1. Maximum Deflection of Vertical Assemblies: 1:360 under lateral point load of 100 lbs.
 - 2. Maximum Deflection of Horizontal Assemblies: 1:240 deflection under dead loads and wind uplift.

2.03 FRAMING MATERIALS

- A. Furring Channels: Formed steel, minimum 0.020 inch thick, 3/8 inch deep by 7/8 inch high, splicing permitted; galvanized.
- B. Main Ceiling Channels: Formed steel, asphalt coated, minimum 0.05 inch thick, 3/4 inch deep by 1-1/2 inch high, single piece, no splicing; galvanized.
- C. Hangers: Steel wire, of size and type to suit application, to support ceiling components in place to deflection limits as indicated.
- D. Ceiling Hangers: Rolled steel sections, of size and type to suit application, to rigidly support ceiling components in place to deflection limits as indicated; galvanized.
- E. Lateral Bracing: Formed steel, minimum 0.060 inch thick, size and length as required; galvanized.

2.04 LATH

- A. Diamond Mesh Metal Lath: ASTM C847, galvanized; self-furring.
 - 1. Weight: To suit application comply with deflection criteria and as specified in ASTM C841 or ASTM C1063 for framing spacing.
 - 2. Minimum Weight: 3.4 lb/sq yd.
- B. Ribbed Metal Lath: ASTM C847, galvanized; 3/8 inch thick. For soffit use only.

FOR REFERENCE ONLY

1. Weight: To suit application, comply with deflection criteria, and as specified in ASTM C841 or ASTM C1063 for framing spacing.
2. Minimum Weight: 3.4 lb/sq yd.
- C. Welded Wire Lath: ASTM C933; galvanized; with 2 inch square openings, paper strips woven into lath, of weight to suit application, comply with deflection criteria, and as specified in ASTM C841 or ASTM C1063 for framing spacing.
- D. Finishing Accessories: ASTM C841 (gypsum plaster) or ASTM C1063 (cement plaster); extruded aluminum alloy (6063 T5), galvanized steel sheet ASTM A924/A924M G90, or galvanized steel wire, unless noted otherwise.
 1. Types: As detailed or required for finished appearance.
 2. Special Shapes: In addition to conventional corner bead and control joints, provide U-bead at exposed plaster edges.
 3. Products:
 - a. Same manufacturer as framing materials.
 - b. Fry Reglet; Trim and Reveal Systems: www.fryreglet.com.
 - c. Pittcon Industries: www.pittconindustries.com.
 - d. Stockton Products; Extruded Aluminum: www.stocktonproducts.com/#sle.
 - e. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- E. Beads, Screeds, Joint Accessories, and Other Trim: Depth governed by plaster thickness, maximum possible lengths.
 1. Galvanized Steel Accessories:
 - a. Types specified below conforming to Technical Services Information Bureau of the Western Walls and Ceilings Contractors Association (WWCCA) "Plaster Assemblies Manual".
 - b. Where galvanized accessories are specified, use hot-dip galvanized steel, ASTM A653/A653M, designation G90/Z275, and bonderized.
 - c. Provide metal shapes, of longest possible length, used as grounds of such size and dimension as to provide for required plaster thickness.
 2. Material: Formed galvanized sheet steel, expanded metal flanges.
 3. Casing Beads with Weep Holes: Square edges.
 - a. Fabricated of 26 gauge, 0.0217 inch hot-dip galvanized steel and bonderized. Provide beads with expanded metal flange and inverted vee at plaster edge of face flange.
 - b. Provide weep holes only where indicated on drawings and in weeping conditions.
 - c. Products:
 - 1) CEMCO: #66 Expanded Flange Casing Bead: www.cemcosteel.com/#sle.
 - 2) Phillips Manufacturing Co; #66 Expanded Flange Square Casing Bead: www.phillipsmfg.com/#sle.
 - 3) Stockton Products; JB: J-Bead: www.stocktonproducts.com.

FOR REFERENCE ONLY

- 4) Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
4. Corner Beads: Square-Edge corners.
 - a. Corner Reinforcement: Fabricated from expanded metal with large openings, from welded or woven copper bearing steel wire of minimum 28 gage, hot-dip galvanized, minimum 3 inches wide.
 - b. Products:
 - 1) CEMCO; No. 2-A Corner Bead and ; No. 2-A Reinforced Flange Corner Bead: www.cemcosteel.com/#sle.
 - 2) Phillips Manufacturing Co; #1 Expanded Corner Bead: www.phillipsmfg.com/#sle.
 - 3) Stockton Products: www.stocktonproducts.com/#sle.
 - 4) Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
5. Corner Reinforcement: Fabricated from from welded or woven copper bearing steel wire of minimum 28 gage, hot-dip galvanized, minimum 3 inches wide.
 - a. Products:
 - 1) CEMCO; Cemcorner: www.cemcosteel.com/#sle.
 - 2) Stockton Products: www.stocktonproducts.com/#sle.
 - 3) Substitutions: See Section 01 60 00 - Product Requirements.
6. Corner Reinforcement: Fabricated from expanded metal with large openings, from welded or woven copper bearing steel wire of minimum 28 gage, hot-dip galvanized, minimum 3 inches wide.
 - a. Cornerite: Expanded Metal, weighing 0.105 pounds per lineal foot, bent in center to form 105 degree angle, 6 inches wide (total).
 - 1) Product: Cornerite manufactured by Cemco.
7. Expansion Joints: Accordion profile with factory-installed protective tape, 2 inch wide flanges.
 - a. Basis of Design Product: Double "J" Control Joint (#XJ-15) manufactured by CEMCO.
 - b. Basis of Design Product at Horizontal Conditions: M-Slide Expansion Joint manufactured by CEMCO.
 - c. Stress Relief Joints (Expansion and Control Joints): Stress Relief Control Joints, fabricated of 28 gage (0.0187 inch) hot-dip galvanized steel.
 - d. Interior Corner Expansion Joints: 26 gage (0.0217 inch) hot-dip galvanized steel. Double V expansion joint formed to 90 degrees.
 - 1) Products:
 - (a) CEMCO; Corner Expansion Joint (#30): www.cemcosteel.com/#sle.
 - (b) Phillips Manufacturing Co; #15 Double V Expansion Joint: www.phillipsmfg.com/#sle.
 - (c) Stockton Products: www.stocktonproducts.com/#sle.
 - (d) Substitutions: See Section 01 60 00 - Product Requirements.
8. Base Screeds:

FOR REFERENCE ONLY

- a. Material: Galvanized steel, ASTM A653/A653M, with G90/Z275 zinc coating; minimum 26-gauge, 0.0179-inch thick base metal.
- b. Foundation Weep Screeds: Perforated type.
- c. Products:
 - 1) Basis of Design Product: NFD: #5 Drip, with weep holes manufactured by Stockton Products.
 - 2) Basis of Design Product: No. 7 Extended Foundation Screed manufactured by CEMCO. For locations where plaster is just above a paving surface.
 - 3) Stockton Products: www.stocktonproducts.com/#sle.
 - 4) Substitutions: See Section 01 60 00 - Product Requirements.
9. Drip Screeds: Fabricated from 0.018 inch thick; G-90 hot-dip galvanized steel.
 - a. Product: NFD: #5 Drip manufactured by Stockton Products.
 - b. Product: #6 Head Drip Screed manufactured by CEMCO. For locations above other flashing such as door and window heads.
10. Window/Door Drips: Self weeping 26 gage hot-dip galvanized steel.
 - a. Product: No. 3 Flashing Screed manufactured by CEMCO. For locations where plaster is offset 1-1/2 inches back from projection.
11. Strip Lath: Strip Reinforcement (Expanded Metal), weighing 2.5 lbs/sq.yd., 6 inches wide. Use hot-dip galvanized at all locations where galvanized metal lath occurs.
12. Control Joints: Accordion profile with factory-installed protective tape, 2 inch flanges.
 - a. Product: Double "V" Control Joint (#15) manufactured by CEMCO.
 - b. Stress Relief Joints (Expansion and Control Joints): Stress Relief Control Joints, fabricated of 26 gage (0.0217 inch) hot-dip galvanized steel with G60 hot-dip galvanized coating.
 - 1) Recesses on control joints shall be covered with removable tape or filled with rope to prevent plaster from filling the recess.

2.05 ACCESSORIES

- A. Access Panels: See Section 08 31 00.
- B. Anchorage: Tie wire, nails, and other metal supports, of type and size to suit application; to rigidly secure materials in place, galvanized per ASTM C1063.
 1. At Horizontal Soffit Surfaces: Comply with CBC 2507.3 (DSA).
 - a. Staples (for wood): Zinc plated, 9 gage, ring shank, hook type, 3/4 inch crown, 2 inch leg.
 - b. Tie Wire: 18 gage, double strand.
- C. Tie Wire: Annealed galvanized steel.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify existing conditions before starting work.
- B. Verify that substrates are ready to receive work and conditions are suitable for application.
- C. For exterior plaster and stucco on stud walls, verify that water-resistive barrier has been installed over sheathing substrate completely and correctly; see Section 07 25 00.
 - 1. Do not allow the control or expansion joints to interrupt or be lapped with the weather barrier.
- D. Do not begin until unacceptable conditions have been corrected.
- E. If substrate preparation is the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.

3.02 INSTALLATION - GENERAL

- A. Install interior lath and furring for gypsum plaster in accordance with ASTM C841.
- B. Install metal lath and furring for Portland cement plaster in accordance with ASTM C1063.
- C. Install lath and furring for fire-rated assemblies in accordance with requirements of assembly as indicated.

3.03 CEILING AND SOFFIT FRAMING INSTALLATION

- A. Install furring after work above ceiling or soffit is complete. Coordinate the location of hangers with other work.
- B. Install furring independent of walls, columns, and above-ceiling work.
- C. Securely anchor hangers to structural members or embed in structural slab. Space hangers as required to limit deflection to criteria indicated. Use rigid hangers at exterior soffits.
- D. Space main carrying channels at maximum 72 inch on center, and not more than 6 inches from wall surfaces. Lap splice securely.
- E. Securely fix carrying channels to hangers to prevent turning or twisting and to transmit full load to hangers.
- F. Install furring channels perpendicular to carrying channels, not more than 2 inches from perimeter walls, and rigidly secure. Lap splices securely.
- G. Reinforce openings in suspension system that interrupt main carrying channels or furring channels with lateral channel bracing. Extend bracing minimum 24 inches past each opening.
- H. Laterally brace suspension system.

3.04 CONTROL AND EXPANSION JOINT INSTALLATION

- A. At unsheathed open framing, provide double stud construction behind control joint.
- B. Locate joints as indicated on drawings and comply with ASTM C1063.
 - 1. Area of plaster panel not to exceed 144 sq ft for vertical surfaces.
 - a. Expansion Joint Spacing: 36 feet maximum on center and as indicated on drawings.

FOR REFERENCE ONLY

2. Area of plaster panel not to exceed 100 sq ft for horizontal, curved or angled surfaces.
 3. Spacing between control joints not to exceed 18 ft in each direction.
 - a. Narrow panels should not exceed 12 feet in length.
 4. Area bounded by control joints not to exceed a length-to-width ratio of 2-1/2 to 1.
 5. Vertical control joints should pass through horizontal control joints. Vertical control joints must terminate at horizontal expansion joints.
 6. Joint Placement: Approved by Architect before plastering.
- C. Install expansion joints where an expansion joint occurs in base exterior wall.
- D. Install prefabricated joint accessories in accordance with ASTM C1063.
1. Install factory-made joints at reveal-to-reveal and reveal-to-control joint intersections.
- E. Discontinue metal lath at joint and apply 12 inch wide strip of flexible flashing behind each joint
- F. Hold casing beads back 3/8 to 1/4 inch from abutting frames and other elements to provide joint for sealant.
- G. Apply sealant at splices, intersections and terminals in accordance with Section 07 92 00 - Joint Sealants.

3.05 ACCESS PANELS INSTALLATION

- A. Install access panels and rigidly secure in place.
- B. Install frames plumb and level in opening. Secure rigidly in place.
- C. Position to provide convenient access to concealed work requiring access.

3.06 LATH INSTALLATION

- A. Apply lath taut, with long dimension perpendicular to supports.
- B. Lap or nest ends of metal lath in accordance with ASTM C841.
- C. Secure end laps with tie wire where they occur between supports.
- D. Do not continue lath through control or expansion joints.
- E. Apply ribbed lath with self-furring ribs perpendicular to supports at soffits and horizontal surfaces.
 1. Lap sides of ribbed lath minimum 1-1/2 inches.
 2. Nest outside ribs of rib lath together.
 3. Attach lath to supports using specified screws at maximum 6 inches on center vertical and 16 inches on center horizontal.
 4. At horizontal metal lath application, secure lath to each support with specified screws.
- F. Expanded metal lath at vertical supports, apply self-furring "grooved" metal lath with self-furring rib perpendicular to supports.
 1. Install per Table 2507.2 California Building Code.
 2. Maintain lath 1/4 inch away from vertical supports.

FOR REFERENCE ONLY

3. At concrete or masonry, install with drill and drive fasteners, power or powder actuated fasteners in accordance with manufacturer's recommendations and ASTM C1063.
- G. Attach metal lath to supports using screws at maximum 12 inches on center.
- H. Attach horizontal metal lath to metal supports using tie wire at maximum 6 inches on center vertical.
- I. Attach non-metallic lath to metal supports using manufacturers recommended fasteners at maximum 7 inches on center.
- J. Continuously reinforce internal angles with corner mesh, except where the metal lath returns 3 inches from corner to form the angle reinforcement; fasten at perimeter edges only.
- K. Place corner bead with mesh at external wall corners; fasten at outer edges of lath only.
- L. Place strip lath diagonally at corners of lathed openings. Secure rigidly in place.
- M. Place strip lath centered over junctions of dissimilar backing materials on same plane. Secure rigidly in place.
- N. Place base screeds at termination of plaster areas; secure rigidly in place.
 1. Install weep screeds at foundation. Install minimum 4 inches above earth or 2 inches above paved areas.
 2. To allow moisture to escape from a portland cement plaster (stucco) assembly, no sealant shall be placed at the bottom of the plaster termination.
- O. Place 4 inch wide strips of lath centered over junctions of dissimilar backing materials, and secure rigidly in place.
- P. Place lath vertically above each top corner and each side of door frames to 6 inches above ceiling line.
- Q. Place casing beads at terminations of plaster finish. Butt and align ends, cope or miter at corners. Secure rigidly in place, maximum 12 inches on centers..
- R. Place additional strip mesh diagonally at corners of lathed openings. Secure rigidly in place.

3.07 FIELD QUALITY CONTROL

- A. Inspection: Notify Architect minimum 2 days prior to scratch coat for inspection of all in-place lath and accessories.

3.08 TOLERANCES

- A. Install accessories to lines and levels.
- B. Maximum Variation from True Lines and Levels: 1/8 inch in 10 feet.
- C. Maximum Variation from True Position: 1/8 inch.

END OF SECTION

SECTION 09 24 00 CEMENT PLASTERING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Cement plastering. CPL-1

1.02 RELATED REQUIREMENTS

- A. Section 06 10 00 - Rough Carpentry: Wood stud framing for plaster.
- B. Section 08 31 00 - Access Doors and Panels: Access panels.
- C. Section 09 21 16 - Gypsum Board Assemblies: Gypsum Sheathing: Solid backing at all exterior plaster.
- D. Section 09 22 36 - Lath: Lath, furring, beads, screeds, and joint accessories for plaster base.
- E. Section 09 91 13 - Exterior Painting: Finish paint over integral color plaster.

1.03 REFERENCE STANDARDS

- A. ASTM C150/C150M - Standard Specification for Portland Cement.
- B. ASTM C207 - Standard Specification for Hydrated Lime for Masonry Purposes.
- C. ASTM C926 - Standard Specification for Application of Portland Cement-Based Plaster.
- D. ASTM C932 - Standard Specification for Surface-Applied Bonding Compounds for Exterior Plastering.
- E. TSIB (PAM) - Plaster Assemblies Manual, Technical Services Information Bureau.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittals procedures.
- B. Product Data: Provide data on plaster materials and trim accessories.
- C. Samples:
 - 1. Submit two samples, 8 by 8 inch in size illustrating finish color and texture.
 - 2. Submit two samples of each type trim accessory.
- D. Evaluation Service Reports: Show compliance with specified requirements.
- E. Installer's Qualification Statement.

1.05 QUALITY ASSURANCE

- A. Installer Qualifications: Company specializing in performing the work of this section with minimum three years documented experience.
- B. Copies of Documents at Project Site: Maintain at the project site a copy of each referenced document that prescribes execution requirements.

1.06 MOCK-UPS

- A. See Section 01 40 00 - Quality Requirements for additional requirements.
- B. Mock-Up Panel: Construct a 4 foot wide by 8 foot high sample panel of plaster work at the jobsite demonstrating installation procedures, finish texture, and color. Show each phase of installation including framing and reinforcement.
- C. After color and texture samples have been approved and returned, construct a mock-up not less than as noted above in size, of each texture type, in location approved by Architect.
 - 1. Use workmen, equipment and techniques proposed for use on the project.
 - 2. The panel may be constructed as a portion of the finished work, provided the approved panel is clearly identified for future reference.
 - 3. The approved panel shall become the standard of comparison for cement plaster work for the project.
 - 4. If mock-up is not a part of building construction, it must be removed when directed by Architect after completion of project.

1.07 FIELD CONDITIONS

- A. Exterior Plaster Work: Do not apply plaster when substrate or ambient air temperature is 40 degrees F or lower, or when temperature is expected to drop below 40 degrees F within 48 hours of application.

PART 2 PRODUCTS

2.01 CEMENT PLASTER APPLICATIONS

- A. Lath Plaster Base: Metal lath.
 - 1. Plaster Type: Factory prepared plaster mix.
 - 2. Number of Coats: Three.
 - 3. First Coat: Apply to a nominal thickness of 3/8 inch.
 - 4. Second Coat: Apply to a nominal thickness of 3/8 inch.
 - 5. Leveling Coat: Apply to a nominal thickness of 1/32 to 1/16 inch.
 - 6. Finish: Acrylic.

2.02 FACTORY PREPARED CEMENT PLASTER

- A. Exterior Portland cement plaster system made of scratch and brown base coat, leveling coat with reinforcing mesh, and acrylic finish coat; install in accordance with ASTM C926.
 - 1. Provide weather resistive barrier as part of the system.
 - 2. Manufacturers:
 - a. Dryvit; Commercial Cement Plaster (CCP) 4: www.dryvit.com.
 - b. LaHabra; FastWall 300: www.lahabrastucco.com/#sle.
 - c. Omega Products International, Inc.; Super Cement with Crack Isolation System: omega-products.com.

- d. Parex USA, Inc; Armourwall 300: www.parexusa.com/#sle.
 - e. Sto Corp; Sto Powerwall: www.stocorp.com/#sle.
 - f. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Premixed One-Coat Base: Mixture of Type I Portland cement complying with ASTM C150/C150M, hydrated lime complying with ASTM C207, fibers and other approved ingredients; install in accordance with ASTM C926.
 - C. Premixed Base Coats: Mixture of cement, aggregate, fibers, and proprietary admixtures for scratch and brown coats; install in accordance with ASTM C926.
 - D. Premixed Leveling Coat: Acrylic polymer-based blend approved for use with plaster manufacturer's base coat and finish materials.
 - E. Painted Finish Coating: See Section 09 91 13.
 - F. Primer: Acrylic, as recommended by coating manufacturer and compatible with plaster base coat.
 - G. Premixed Textured Coating: Polymer modified acrylic coating, integrally colored, and trowel applied to substrates prepared in accordance with manufacturer's written installation instructions.
 - 1. Color: As indicated on drawings.

2.03 ACCESSORIES

- A. Lath: See Section 09 22 36.
- B. Finishing Accessories: See Section 09 22 36.
- C. Bonding Compound: Provide type recommended for bonding plaster to solid surfaces, complying with ASTM C932.
- D. Reinforcing Mesh: 4.5 oz/sq yd alkali-resistant mesh.
- E. Water-Resistive Barrier: See Section 07 25 00.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify existing conditions are acceptable prior to starting this work.
- B. Verify lath is flat, secured to substrate, and joint and surface perimeter accessories are properly in place.
- C. Verify mechanical and electrical equipment and services located within areas to receive this work have been properly tested and approved.

3.02 PREPARATION

- A. Removal and Refinishing Existing Exterior Plaster Finish Coat: Sandblast existing exterior plaster walls to remove paint finish and finish coat plaster down to a level, workable surface.
 - 1. Sandblasted gouges due to over sandblasting, may require a leveling or skim brown coat mixture applied after wash down.
 - 2. Wash down to remove dust and other loose particles.

3. Follow with finish coat over dampened surfaces.
- B. Roughen smooth concrete surfaces and apply bonding compound in accordance with manufacturer's written installation instructions.

3.03 MIXING

- A. Mix only as much plaster as can be used prior to initial set.
- B. Mix materials dry, to uniform color and consistency, before adding water.
- C. Add air entrainment admixtures to each coat to provide 5 to 7 percent air entrainment.
- D. Protect mixtures from frost or freezing temperatures, contamination, and excessive evaporation.

3.04 APPLICATION

- A. Apply plaster in accordance with manufacturer's written instructions and comply with ASTM C926.
- B. Base Coats:
 1. Apply base coat(s) to fully embed lath and to specified thickness.
 2. Follow guidelines in ASTM C926 and manufacturer's written installation instructions for moist curing base coats and application of subsequent coats.
- C. Leveling Coat:
 1. Apply leveling coat to specified thickness.
 2. Fully embed reinforcing mesh in leveling coat.
- D. Finish Coats:
 1. Cement Plaster:
 - a. Apply with sufficient material and pressure to ensure complete coverage of base to specified thickness.
 - b. Apply desired surface texture while mix is still workable.
 - c. Float to a consistent finish.
 2. Primer and Acrylic Coatings:
 - a. Remove surface contaminants such as dust and dirt without damaging substrate.
 - b. Apply primer in accordance with manufacturer's instructions.
 - c. Apply finish coating in number of coats and to thickness recommended by manufacturer.
 - d. Finish coat to match existing texture.
 3. Acrylic Finish Texture: Apply to a consistent finish.
 - a. TSIB (PAM) Fine Sand.
- E. Finish Painting Overcoat: See Section 09 91 13 - Exterior Painting.

3.05 TOLERANCES

- A. Maximum Variation from True Flatness: 1/4 inch in 10 feet.

3.06 REPAIR

- A. Patching: Remove loose, damaged or defective plaster and replace with plaster of same composition; finish to match surrounding area.
- B. Damaged Plaster:
 - 1. Plaster Detached from Framing:
 - a. Remove loose and broken plaster.
 - b. Repair or replace damaged water-resistant backing and lath in compliance with specified standards.
 - c. Remove finish coat from surrounding area in the same plane by sandblasting.
 - d. Provide a scratch coat and a brown coat mixed with liquid bonding agent instead of water to the areas devoid of plaster.
 - e. Provide a coat of liquid bonding agent to entire wall plane.
 - f. Provide 1/8 inch thick finish coat to entire wall plane. Match existing texture and color.
 - 2. Cracked Plaster 1/8 inch to 1/2 inch:
 - a. Remove loose material from crack with a wire brush.
 - b. Fill crack with slurry of stucco and liquid bonding agent.
 - c. Provide a coat of liquid bonding agent to entire wall plane.
 - d. Provide 1/8 inch thick finish coat to entire wall plane and match existing texture and color.
 - 3. Cracks Larger than 1/2 inch - Painted:
 - a. Remove loose material from crack with a wire brush.
 - b. Fill crack with slurry of one part Portland cement to three parts masonry or stucco sand and liquid bonding agent to match existing texture of adjacent surface.
 - c. Paint entire wall plane, color to match existing.
 - d. Where patching of plaster over existing lath is feasible, fasten loose lath and install new lath with nails at 6 inch centers.
 - 1) Where metal is furnished, lap new lath 6 inches over existing and tie at 6 inch centers.
 - 2) Provide waterproof, air barrier, and vapor barrier as required, shingled into existing.
 - e. Patching of Holes, Cracks, and Gouges:
 - 1) Patch holes, cracks, gouges, missing sections, and other defects in existing improvements.
 - 2) For holes over 1 inch in size, cut small sections of lath and place in opening attached to existing material.
 - (a) Install 3 coats of plaster.

FOR REFERENCE ONLY

- 3) For holes one inch and smaller, install bonding agent to existing surfaces and neatly fill hole with plaster, installing necessary coats to match adjacent surfaces, eliminate cracks and match existing surface texture.
- 4) Cracks, gouges, and other defects shall be filled with plaster or spackle as required and neatly finished to match adjacent existing improvements.

END OF SECTION

SECTION 09 30 00 TILING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Tile for wall applications. T-1, G-1.
- B. Cementitious backer board as tile substrate.
- C. Ceramic trim.
- D. Non-ceramic trim. TB-1, TB-2.

1.02 RELATED REQUIREMENTS

- A. Section 07 92 00 - Joint Sealants: Sealing joints between tile work and adjacent construction and fixtures.

1.03 REFERENCE STANDARDS

- A. ADA Standards - 2010 ADA Standards for Accessible Design.
- B. ANSI A108/A118/A136 - American National Standard Specifications for the Installation of Ceramic Tile (Compendium).
- C. ANSI A108.10 - American National Standard Specifications for Installation of Grout in Tilework.
- D. ANSI A108.11 - American National Standard Specifications for Interior Installation of Cementitious Backer Units.
- E. ANSI A118.3 - American National Standard Specifications for Chemical Resistant, Water Cleanable Tile-Setting and -Grouting Epoxy and Water Cleanable Tile-Setting Epoxy Adhesive.
- F. ANSI A118.7 - American National Standard Specifications for High Performance Cement Grouts for Tile Installation.
- G. ANSI A118.9 - American National Standard Specifications for Test Methods and Specifications for Cementitious Backer Units.
- H. ANSI A118.15 - American National Standard Specifications for Improved Modified Dry-Set Cement Mortar.
- I. ANSI A137.1 - American National Standard Specifications for Ceramic Tile.
- J. ANSI/NFSI B101.3 - Test Method for Measuring Wet DCOF of Common Hard Surface Floor Materials.
- K. ASTM C373 - Standard Test Methods for Determination of Water Absorption and Associated Properties by Vacuum Method for Pressed Ceramic Tiles and Glass Tiles and Boil Method for Extruded Ceramic Tiles and Non-tile Fired Ceramic Whiteware Products.
- L. TCNA (HB) - Handbook for Ceramic, Glass, and Stone Tile Installation.
- M. TCNA (HB-GP) - Handbook for Gauged Porcelain Tiles and Gauged Porcelain Tile Panels/Slabs Installation.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Preinstallation Meeting: Convene a preinstallation meeting one week before starting work of this section; require attendance by affected installers.
 - 1. Discussion topics: dry times, cure times, protection of all steps of tile installation system (membranes, adhesive, grout).

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide manufacturers' data sheets on tile, mortar, grout, and accessories. Include instructions for using grouts and adhesives.
- C. Shop Drawings: Indicate tile layout, patterns, color arrangement, perimeter conditions, junctions with dissimilar materials, and setting details.
- D. Samples: Mount tile and apply grout on two plywood panels, minimum 18 by 18 inches in size illustrating pattern, color variations, and grout joint size variations.
- E. Manufacturer's Certificate: Certify that products meet or exceed specified requirements.
- F. Master Grade Certificate: Submit for each type of tile, signed by the tile manufacturer and tile installer.
 - 1. Prior to shipment of tile to jobsite, deliver Master Grade Certificates to Architect, complying with TCNA/ANSI A137.1.
- G. Installer's Qualification Statement:
 - 1. Submit documentation of National Tile Contractors Association (NTCA) or Tile Contractors' Association of America (TCAA) accreditation.
 - 2. Submit documentation of completion of apprenticeship and certification programs.
- H. Maintenance Data: Include recommended cleaning methods, cleaning materials, and stain removal methods.
- I. Maintenance Materials: Furnish the following for District's use in maintenance of project.
 - 1. See Section 01 60 00 - Product Requirements, for additional provisions.
 - 2. Extra Tile: One box, minimum of 24 pieces of each size, color, and surface finish combination.

1.06 QUALITY ASSURANCE

- A. Maintain one copy of ANSI A108/A118/A136, TCNA (HB), and TCNA (HB-GP) on-site.
- B. Manufacturer Qualifications: Company specializing in manufacturing the types of products specified in this section, with minimum five years of documented experience.
- C. Installer Qualifications:
 - 1. Company specializing in performing tile installation, with minimum of five years of documented experience.
 - 2. Installer Certification:
 - a. Ceramic Tile Education Foundation (CTEF): Certified Tile Installer (CTI).

- b. Apprenticeship Program: Installer has achieved Journeyworker status through an apprenticeship from the International Union of Bricklayers and Allied Craftworkers (IUBAC) or a U.S. Department of Labor (DOL)-recognized program.
- c. Advanced Certifications for Tile Installers (ACT): Certification in the installation of membranes, mortar bed (mud) floors, mortar (mud) walls, large format tile, gauged porcelain tile/panels/slabs, and grouts.

1.07 MOCK-UPS

- A. See Section 01 40 00 - Quality Requirements for general requirements for mock-up.
- B. Construct tile mock-up where indicated on drawings, incorporating all components specified for the location.
 - 1. Minimum size of mock-up is indicated on drawings.
 - 2. Approved mock-up may remain as part of work.

1.08 DELIVERY, STORAGE, AND HANDLING

- A. Protect adhesives from freezing or overheating in accordance with manufacturer's instructions.

1.09 FIELD CONDITIONS

- A. Do not install solvent-based products in an unventilated environment.
- B. Maintain ambient and substrate temperature above 50 degrees F and below 100 degrees F during installation and curing of setting materials.

PART 2 PRODUCTS

2.01 REGULATORY REQUIREMENTS

- A. Requirements for Persons with Disabilities: Provide ceramic tile flooring meeting slip-resistant requirements of California Code of Regulations (CCR), Title 24, Part 2, Chapter 11B and ADA Standards, latest amendment.
 - 1. Tile flooring surface shall be stable, firm, and slip resistant. CBC Section 11B-302.1 General.
 - 2. Tile flooring Surface shall demonstrate a dynamic coefficient of friction of at least 0.42 wet per DCOF AcuTest ANSI A137.1 Section 9.6 and ANSI/NFSI B101.3(using a BOT-3000 testing unit) will be accepted as meeting the intent of slip resistance; CBC 11B-302 Floor or Ground Surfaces and ADA Standards.
 - a. Ramp surface: Provide wet DCOF value of 0.46.

2.02 TILE

- A. Manufacturers:
 - 1. American Olean Corporation: www.americanolean.com/#sle.
 - 2. Crossville, Inc. : www.crossvilleinc.com.
 - 3. Dal-Tile Corporation: www.daltile.com/#sle.

4. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- B. Porcelain Tile: ANSI A137.1 standard grade.
 1. Moisture Absorption: 0 to 0.5 percent as tested in accordance with ASTM C373.
 2. Size: as indicated on Drawings, nominal.
 3. Thickness: 3/8 inch.
 4. Edges: Interlocking shape.
 5. Surface Finish: Unglazed.
 - a. Dynamic Wet Slip Resistance DCOF AcuTest: 0.42
 6. Color(s): To be selected by Architect from manufacturer's standard range.
 7. Trim Units: Matching bullnose, cove base, and cove shapes in sizes coordinated with field tile.

2.03 TRIM AND ACCESSORIES

- A. Ceramic Trim: Matching bullnose, double bullnose, cove base, and cove ceramic shapes in sizes coordinated with field tile.
 1. Applications:
 - a. Open Edges: Bullnose.
 - b. Inside Corners: Jointed.
 - c. Floor to Wall Joints: Cove base.
 2. Manufacturers: Same as for tile.
- B. Non-Ceramic Trim: Satin natural anodized extruded aluminum, style and dimensions to suit application, for setting using tile mortar or adhesive.
 1. Applications:
 - a. Open edges of wall tile.
 - b. Floor-to-wall joints.
 2. Products:
 - a. Blanke Corporation; Blanke - Trims and Profiles: www.blankecorp.com/#sle.
 - 1) Local Representative: Rick Coury, Tile Industry Sales, Inc. coury@earthlink.net; 714.915.1995.
 - b. Genesis APS International: www.genesis-aps.com/#sle.
 - c. LATICRETE International, Inc: www.laticrete.com/#sle.
 - d. Schluter-Systems: www.schluter.com/#sle.
 - e. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.

2.04 SETTING MATERIALS

- A. Provide setting and grout materials from same manufacturer.
- B. Improved Latex-Portland Cement Mortar Bond Coat: ANSI A118.15.
 1. Applications: Use this type of bond coat where Large and Heavy Tile (LHT) mortar is indicated.

2. Products:
 - a. ARDEX Engineered Cements; S 28: www.ardexamericas.com/#sle.
 - b. Custom Building Products; Complete Contact-LFT Premium Rapid Setting Large Format Tile Mortar, with Multi-Surface Bonding Primer: www.custombuildingproducts.com/#sle.
 - c. LATICRETE International, Inc; MULTIMAX LITE: www.laticrete.com/#sle.
 - d. Mapei Corporation; Ultraflex LFT: www.mapei.com/#sle.
 - e. Merkrete, by Parex USA, Inc: www.merkrete.com/#sle.
 - f. Sika Corp; SikaTile 450 LHT Secure Set: www.sika.com/#sle.
 - g. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- C. Epoxy Adhesive and Mortar Bond Coat: ANSI A118.3.
 1. Applications: Where indicated on drawings.
 2. Products:
 - a. Custom Building Products; EBM-Lite Epoxy Bonding Mortar: www.custombuildingproducts.com/#sle.
 - b. LATICRETE International, Inc; LATICRETE LATAPOXY 300 Adhesive: www.laticrete.com/#sle.
 - c. Mapei Corporation; Kerapoxy 410: www.mapei.com/#sle.
 - d. Merkrete, by Parex USA, Inc; Merkrete Pro Epoxy: www.merkrete.com/#sle.
 - e. Sika Corp; SikaTile 825 Epoxy: www.sika.com/#sle.
 - f. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.

2.05 GROUTS

- A. Provide setting and grout materials from same manufacturer.
- B. Manufacturers:
 1. Basis of Design: Custom Building Products: www.custombuildingproducts.com/#sle.
 2. ARDEX Engineered Cements: www.ardexamericas.com/#sle.
 3. Bonsal American, Inc; ProSpec Sanded Tile Grout 700: www.prospec.com
 4. LATICRETE International, Inc: www.laticrete.com/#sle.
 5. Mapei Corporation: www.mapei.com/#sle.
 6. Merkrete, by Parex USA, Inc; Merkrete Duracolor Non-Sanded Color Grout: www.merkrete.com/#sle.
 7. Sika Corp; SikaTile 800 Sanded/UnSanded Grout: www.sika.com/#sle.
 8. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- C. High Performance Polymer Modified Grout: ANSI A118.7 polymer modified cement grout.
 1. Applications: Use this type of grout where indicated on exterior over plaster.
 2. Use sanded grout for joints 1/8 inch wide and larger; use unsanded grout for joints less than 1/8 inch wide.

3. Color(s): As selected by Architect from manufacturer's full line.
4. Products:
 - a. Basis of Design: Custom Building Products; Fusion Pro Single Component Grout: www.custombuildingproducts.com/#sle.
 - b. ARDEX Engineered Cements; ARDEX FL: www.ardexamericas.com/#sle.
 - c. Custom Building Products; Prism Color Consistent Grout: www.custombuildingproducts.com/#sle.
 - d. LATICRETE International, Inc; LATICRETE PERMACOLOR Grout: www.laticrete.com/#sle.
 - e. Mapei Corporation; Ultracolor Plus FA: www.mapei.com/#sle.
 - f. Merkrete, by Parex USA, Inc; Merkrete Pro Grout Plus: www.merkrete.com/#sle.
 - g. Sika Corp; SikaTile Secure Grout: www.sika.com/#sle.
 - h. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.

2.06 MAINTENANCE MATERIALS

- A. Tile Sealant: Gunnable, silicone, siliconized acrylic, or urethane sealant; moisture and mildew resistant type.
 1. Applications: Between tile and plumbing fixtures.
 2. Color(s): As selected by Architect from manufacturer's full line.
 3. Products:
 - a. ARDEX Engineered Cements; ARDEX SX: www.ardexamericas.com/#sle.
 - b. Custom Building Products; Commercial 100% Silicone Caulk: www.custombuildingproducts.com/#sle.
 - c. LATICRETE International, Inc; LATICRETE LATASIL: www.laticrete.com/#sle.
 - d. Mapei Corporation; Mapesil T Plus: www.mapei.com/#sle.
 - e. Merkrete, by Parex USA, Inc; Merkrete MK-100SC 100% Silicone Caulk: www.merkrete.com/#sle.
 - f. Sika Corp; Sikasil N Plus: www.sika.com/#sle.
 - g. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- B. Grout Sealer: Liquid-applied, moisture and stain protection for existing or new Portland cement grout.
 1. Composition: Water-based colorless silicone.
 2. Products:
 - a. Specified Manufacturer: Aqua-Mix: www.custombuildingproducts.com; local representative Dale Roberts (951) 255-0243.
 - b. MAPEI Corporation; UltraCare Grout Sealer: www.mapei.com.
 - c. Merkrete, by Parex USA, Inc; Merkrete Revive: www.merkrete.com/#sle.
 - d. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- C. Tile Sealer: Stain protection for ceramic tile and natural stone tile.

1. Products:
 - a. Custom Building Products; Aqua Mix Enrich 'N' Seal: www.custombuildingproducts.com/#sle.
 - b. MAPEI Corporation; UltraCare Enhancing Plus Stone Sealer: www.mapei.com.
 - c. Rust-Oleum Corporation; Miracle Sealants 511 Impregnator Natural Looking Penetrating Sealer: www.rustoleum.com/#sle.
 - d. STONETECH, a Division of LATICRETE International, Inc; STONETECH BulletProof Stone Sealer: www.laticrete.com/#sle.
 - e. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- D. Grout Release: Temporary, water-soluble pre-grout coating.
 1. Products:
 - a. Custom Building Products; Aqua Mix Grout Release: www.custombuildingproducts.com/#sle.
 - b. MAPEI Corporation; UltraCare Grout Release: www.mapei.com.
 - c. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.

2.07 ACCESSORY MATERIALS

- A. Membrane at Walls: Placed behind the backer board.
 1. Material: No. 15 asphalt saturated felt.
- B. Backer Board: Cementitious type complying with ANSI A118.9; high density, glass fiber reinforced, 7/16 inch thick; 2 inch wide coated glass fiber tape for joints and corners.
 1. Products:
 - a. Custom Building Products; WonderBoard Lite Backerboard: www.custombuildingproducts.com/#sle.
 - b. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- C. Mesh Tape: 2 inch wide self-adhesive fiberglass mesh tape.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that wall surfaces are smooth and flat within the tolerances specified for that type of work, are dust-free, and are ready to receive tile.

3.02 PREPARATION

- A. Protect surrounding work from damage.
- B. Shade work from direct sunlight during tile installation as needed to prevent rapid evaporation caused by excessive heat.
- C. Vacuum clean surfaces and damp clean.
- D. Seal substrate surface cracks with filler. Level existing substrate surfaces to acceptable flatness tolerances.

- E. Install backer board in accordance with ANSI A108.11 and board manufacturer's instructions. Tape joints and corners, cover with skim coat of setting material to a feather edge.
- F. Prepare substrate surfaces for adhesive installation in accordance with adhesive manufacturer's instructions.

3.03 INSTALLATION - GENERAL

- A. Lay tile to pattern indicated. Do not interrupt tile pattern through openings.
- B. Cut and fit tile to penetrations through tile, leaving sealant joint space. Form corners and bases neatly. Align floor and base joints.
- C. Place tile joints uniform in width, subject to variance in tolerance allowed in tile size. Make grout joints without voids, cracks, excess mortar or excess grout, or too little grout.
- D. Form internal angles square and external angles bullnosed.
- E. Install non-ceramic trim in accordance with manufacturer's instructions.
- F. Sound tile after setting. Replace hollow sounding units.
- G. Keep control and expansion joints free of mortar, grout, and adhesive.
- H. Prior to grouting, allow installation to completely cure; minimum of 48 hours.
- I. Grout tile joints unless otherwise indicated. Use standard grout unless otherwise indicated.
- J. At changes in plane and tile-to-tile control joints, use tile sealant instead of grout, with either bond breaker tape or backer rod as appropriate to prevent three-sided bonding.

3.04 INSTALLATION - FLOORS - FLOATING

- A. Install in accordance with manufacturer's instructions.
- B. Grout with standard grout as specified above.

3.05 INSTALLATION - WALL TILE

- A. Over cementitious backer units on studs, install in accordance with TCNA (HB) Method W244, using membrane at toilet rooms.

3.06 GROUTING

- A. Joint Width: As follows unless indicated otherwise on Drawings.
 - 1. Glazed Wall Tile, Unmounted: As determined by spacing lugs.
 - 2. Porcelain Floor Tile: 1/4 inch.
 - 3. Mounted Tile: As determined by factory-produced spacing.
 - 4. Trim and Accessories: Match adjoining tile units.
- B. Wall Tile Grouting: TCNA/ANSI A108.10, latex-portland cement.
- C. Floor Tile Grouting: TCNA/ANSI A108.10, latex-portland cement.
- D. Do not begin grouting tiles until they are firmly set and a minimum of 48 hours of curing has occurred.
- E. Remove spacers, ropes, glue, and similar foreign matter prior to grouting.

FOR REFERENCE ONLY

- F. When using proprietary grout, comply with manufacturer's instructions and recommendations unless otherwise more stringent requirements are specified.
- G. Force maximum amount of approved grout into joints in accordance with pertinent recommendations contained in TCNA/ANSI A108.10.
- H. Fill joints of cushion-edge tile to depth of cushion; fill joints of square-edge tile flush with tile surface.
- I. Fill all gaps and skips.
- J. Do not permit mortar or mounting mesh to show through grouted joints.
- K. Provide hard finished grout which is uniform in color, smooth, and without voids, pin holes, or low spots.
- L. Leave tile clean.

3.07 TOLERANCES

- A. Subsurface Guidelines: Refer to TCNA (HB) for a complete guidelines.

Mortar Bed	1/4 inch: 10 feet
Thin Bed w/ cementitious bonding material w/ Tiles <15"	1/4 inch: 10 feet from plane Maximum 1/16 inch variation in 12 inches from high points.
Thin Bed w/ cementitious bonding material w/ Tiles any side >15"	1/8 inch: 10 feet from plane Maximum 1/16 inch variation in 24 inches from high points.
Thin Bed w/ organic adhesive bonding material w/ Tiles any side >15"	1/16 inch in 3 feet No abrupt irregularities >1/32 inch

- B. Lippage Guidelines: Refer to TCNA (HB) for a complete guidelines.

Tile Type	Tile Size (in.)	Joint Width (in.)	Allowable Lippage (in.)
Glazed Wall/ Mosaics	1 x 1 to 6 x 6	1/16 to 1/8	1/32
Quarry	6 x 6 to 8 x 8	1/4 or greater	1/16
Pressed Floor and Porcelain Tiles	All	1/16 to less than 1/4	1/32
Pressed Floor and Porcelain Tiles	All	1/4 or greater	1/16

3.08 JOINT SEALANT

- A. Apply sealant after tile is grouted, grout is cured and tile field is thoroughly clean and dry.
- B. Seal between tile and all penetrating elements.
- C. Seal perimeter of tile field where tile base is not provided.
- D. Sealant Locations shall include:
 - 1. Around plumbing penetrations.

- 2. Around door frames and other items set in wall.
- E. Refer to Section 07 92 00 - Joint Sealants for additional requirements.

3.09 GROUT SEALER

- A. Clean grout and apply sealer in accordance with manufacturer's instructions and recommendations.

3.10 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements, for additional requirements.
- B. Provide manufacturer's field representative to inspect waterproofing.
- C. Repair or remove and reinstall as required.
- D. Repeat until a satisfactory result is achieved.

3.11 CLEANING

- A. Clean tile and grout surfaces.

3.12 PROTECTION

- A. Do not permit traffic over finished floor surface for 4 days after installation.

END OF SECTION

SECTION 09 51 00 ACOUSTICAL CEILINGS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Suspended metal grid ceiling system.
- B. Acoustical units; ACT-1.

1.02 RELATED REQUIREMENTS

- A. Section 01 61 16 - Volatile Organic Compound (VOC) Content Restrictions.
- B. Section 07 21 00 - Thermal Insulation: Acoustical insulation.
- C. Division 23 - Heating, Ventilating, and Air-Conditioning (HVAC) - Air Outlets and Inlets: Air diffusion devices in ceiling.
- D. Division 26 - Electrical - Interior Lighting: Light fixtures in ceiling system.

1.03 REFERENCE STANDARDS

- A. ASCE 7 - Minimum Design Loads and Associated Criteria for Buildings and Other Structures.
- B. ASTM A653/A653M - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process.
- C. ASTM C635/C635M - Standard Specification for Manufacture, Performance, and Testing of Metal Suspension Systems for Acoustical Tile and Lay-in Panel Ceilings.
- D. ASTM C636/C636M - Standard Practice for Installation of Metal Ceiling Suspension Systems for Acoustical Tile and Lay-In Panels.
- E. ASTM C645 - Standard Specification for Nonstructural Steel Framing Members.
- F. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials.
- G. ASTM E580/E580M - Standard Practice for Installation of Ceiling Suspension Systems for Acoustical Tile and Lay-in Panels in Areas Subject to Earthquake Ground Motions.
- H. ASTM E1264 - Standard Classification for Acoustical Ceiling Products.
- I. CHPS (HPPD) - High Performance Products Database.
- J. UL (GGG) - GREENGUARD Gold Certified Products.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Sequence work to ensure acoustical ceilings are not installed until building is enclosed, sufficient heat is provided, dust generating activities have terminated, and overhead work is completed, tested, and approved.
- B. Do not install acoustical units until after interior wet work is dry.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.

FOR REFERENCE ONLY

- B. Shop Drawings: Indicate grid layout and related dimensioning, junctions with other ceiling finishes, and mechanical and electrical items installed in the ceiling.
- C. Product Data: Provide data on suspension system components and acoustical units.
- D. Evaluation Service Reports: Show compliance with specified requirements.
 - 1. Submit copies of the suspension system manufacturer's current ICC Evaluation Service Report.
- E. Samples: Submit two samples 12 by 12 inch in size illustrating material and finish of acoustical units.
- F. Samples: Submit two samples each, 12 inches long, of suspension system main runner, cross runner, and perimeter molding.
- G. Manufacturer's Installation Instructions: Indicate special procedures and perimeter conditions requiring special attention.
- H. Manufacturer's qualification statement.
- I. Maintenance Materials: Furnish the following for District's use in maintenance of project.
 - 1. See Section 01 60 00 - Product Requirements, for additional provisions.
 - 2. Exposed Suspension System Components: Furnish quantity of each exposed suspension component equal to 1.0 percent of amount installed.
 - 3. Extra Acoustical Units: Quantity equal to 5 percent of total installed.

1.06 QUALITY ASSURANCE

- A. Suspension System Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum three years documented experience.
- B. Acoustical Unit Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum three years documented experience.

1.07 FIELD CONDITIONS

- A. Maintain uniform temperature of minimum 60 degrees F, and maximum humidity of 40 percent prior to, during, and after acoustical unit installation.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Acoustic Tiles/Panels:
 - 1. Armstrong World Industries, Inc: www.armstrong.com/#sle.
 - 2. CertainTeed Corporation: www.certainteed.com/#sle.
 - 3. USG Corporation: www.usg.com/#sle.
 - 4. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Suspension Systems:
 - 1. Same as for acoustical units.
 - 2. Rockfon, LLC: www.rockfon.com/#sle.

3. Substitutions: See Section 01 60 00 - Product Requirements.

2.02 PERFORMANCE REQUIREMENTS

- A. Flame Spread Rating: Provide acoustical ceiling units bearing the label of Underwriters' Laboratories, or other testing agency acceptable to the State Fire Marshal, indicating that the units provide the specified flame spread rating.
 1. Class A Flame spread rating 0-15, smoke developed 0-15 per ASTM E84 for each acoustical tile type.
- B. Seismic Performance: Ceiling systems designed to withstand the effects of earthquake motions determined according to ASCE 7 for Seismic Design Category D, E, or F and complying with the following:
 1. Local authorities having jurisdiction.
 2. ICC-ES Evaluation Report No. ESR-1308.
 3. Seismic Requirements: Furnish and install suspension systems in accordance with the suspension system manufacturer's current ICC Evaluation Service Report; the California Building Code (CBC), Title 24 Part 2, Section 1617A.1.21; CBC Title 24 Part 2, Chapter 25.
 - a. Include the following Interpretation of Regulations, issued by the Division of the State Architect (DSA).
 - 1) IR A-5: Acceptance of Products, Materials, and Evaluation Reports.
 - 2) IR 16-9: Pendant Luminaires.
 - 3) IR 25-2: Suspended Lay-In Panel Ceiling; Revised 3/18/22.
 - 4) IR 25-1: Maximum Allowable Load for Ceiling Wires.

2.03 ACOUSTICAL UNITS

- A. Acoustical Units - General: ASTM E1264, Class A.
 1. VOC Content: Certified as Low Emission by one of the following:
 - a. Product listing in UL (GGG).
 - b. Product listing in CHPS (HPPD).
- B. Total System Weight: Less than 4 PSF.
- C. Acoustical Panels, Type for food service: Mineral fiber with scrubbable finish, with the following characteristics:
 1. Classification: ASTM E1264 Type IX.
 - a. Form: 2, water felted.
 - b. Pattern: "G" - smooth.
 2. Size: 24 by 48 inch.
 3. Thickness: 5/8 inches.
 4. Light Reflectance: 89 percent, determined in accordance with ASTM E1264.
 5. Ceiling Attenuation Class (CAC): 33, determined in accordance with ASTM E1264.
 6. Panel Edge: Square.
 7. Suspension System Type TBAR-1: Exposed grid.

8. Basis of Design Product: Kitchen Zone, model no. 672 as manufactured by Armstrong World Industries, or equal.

2.04 SUSPENSION SYSTEM(S)

- A. Metal Suspension Systems - General: Complying with ASTM C635/C635M; die cut and interlocking components, with perimeter moldings, hold down clips, stabilizer bars, clips, and splices as required.
 1. Materials:
 - a. Steel Grid: ASTM A653/A653M, G30 coating, unless otherwise indicated.
- B. Exposed Suspension System, Type TBAR-1: Hot-dipped galvanized steel grid with cap.
 1. Application(s): Seismic.
 2. Profile: Tee; 15/16 inch face width. (9/16 inch may be acceptable in selected locations)
 - a. Main Runners:
 - 1) Armstrong: Heavy Duty Prelude XL 7301, exposed T.
 - b. Cross Tees - "Stake-on end", Stepped End:
 - 1) Armstrong: XL7328 (24 inch grid), XL7341 (48 inch grid).
 - c. Edge Trim:
 - 1) Armstrong Angle Molding: 7800, 7/8", Prelude 7871 Shadow molding with
 3. Finish: Baked enamel.
 4. Color: White, unless noted otherwise.
 5. Products:
 - a. Armstrong World Industries, Inc: www.armstrongceilings.com/#sle.
 - b. CertainTeed Corporation: www.certainteed.com.
 - c. Rockfon: www.rockfon.com.
 - d. USG Corporation; Donn Brand ZXLA 15/16 inch Acoustical Suspension System: www.usg.com/ceilings/#sle.
 - 1) ICC ESR-1222 and LARR 25764.
 - e. Substitutions: See Section 01 60 00 - Product Requirements.
- C. Drywall Suspension System: Hot-dipped galvanized steel grid and cap.
 1. Structural Classification: Heavy-duty, when tested in accordance with ASTM C635/C635M.
 - a. ICC ESR-1289, 8900 Series Ceiling System.
 2. Profile: Tee; 1-1/2 inch face width.
 3. Finish: G40 Galvanized per ASTM C645.
 4. Basis of Design Product: HD8906 HD Drywall Main Beam, XL8945P Cross Runner, with KAM21020EQ Knurled Angle (Channel) Molding as manufactured by Armstrong World Industries, or equal.

2.05 ACCESSORIES

- A. Support Channels and Hangers: Galvanized steel; size and type to suit application, seismic requirements, and ceiling system flatness requirement specified.
- B. Hanger Wire: 12 gauge, 0.105 inch galvanized steel wire.
- C. Hold-Down Clips: Manufacturer's standard clips to suit application.
- D. Seismic Clips: Manufacturer's standard clips for seismic conditions and to suit application.
 - 1. Conform to seismic requirements indicated in the ESR approval documents.
- E. Perimeter Moldings: Same metal and finish as grid.
 - 1. Size: As required for installation conditions and specified Seismic Design Category.
- F. Acoustical Insulation: ASTM C665 friction fit type, unfaced batts.
 - 1. Thickness: 2 inch.
 - 2. Size: To fit acoustical suspension system.
- G. Touch-up Paint: Type and color to match acoustical and grid units.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify existing conditions before starting work.
- B. Verify that layout of hangers will not interfere with other work.

3.02 PREPARATION

- A. Install after major above-ceiling work is complete.
 - 1. Complete and obtain approval of mechanical, electrical and other work above the ceiling line, before start of acoustical ceiling installation.
- B. Coordinate the location of hangers with other work.

3.03 INSTALLATION - SUSPENSION SYSTEM

- A. Install suspension system in accordance with ASTM C636/C636M, ASTM E580/E580M, and manufacturer's instructions and as supplemented in this section.
 - 1. Conform to DSA IR 25-2 Metal Suspension Systems for Lay-In Panel Ceilings.
- B. Rigidly secure system, including integral mechanical and electrical components, for maximum deflection of 1:360.
- C. Lay out system to a balanced grid design with edge units no less than 50 percent of acoustical unit size.
- D. Perimeter Molding: Install at intersection of ceiling and vertical surfaces and at junctions with other interruptions.
 - 1. Use longest practical lengths.
- E. Seismic Suspension System, Seismic Design Categories D, E, F: Hang suspension system with grid ends attached to the perimeter molding on two adjacent walls; on opposite walls, maintain a 3/4 inch clearance between grid ends and wall.

- F. Where ducts or other equipment prevent the regular spacing of hangers, reinforce the nearest affected hangers and related carrying channels to span the extra distance.
- G. Do not support components on main runners or cross runners if weight causes total dead load to exceed deflection capability.
- H. Support fixture loads using supplementary hangers located within 6 inches of each corner, or support components independently.
- I. Do not eccentrically load system or induce rotation of runners.

3.04 INSTALLATION - ACOUSTICAL UNITS

- A. Install acoustical units in accordance with manufacturer's instructions.
- B. Fit acoustical units in place, free from damaged edges or other defects detrimental to appearance and function.
- C. Fit border trim neatly against abutting surfaces.
- D. Install acoustical units level, in uniform plane, and free from twist, warp, and dents.
- E. Cutting Acoustical Units:
 - 1. Cut to fit irregular grid and perimeter edge trim.
 - 2. Make field cut edges of same profile as factory edges.
 - 3. Double cut and field paint exposed reveal edges.
- F. Install hold-down clips on panels within 20 ft of an exterior door.

3.05 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements, for additional requirements.
- B. Coordination of Other Tests and Inspections: District will employ independent testing agency to test and/or inspect anchors; provide access and assistance as required to accommodate timely performance.
- C. Testing (per DSA IR 25-2.13): All field testing must be performed in the presence of the project inspector or a special inspector.
 - 1. New Installations:
 - a. Post-installed anchors in concrete used to support hanger wires shall be tested at a frequency of 10 percent.
 - 1) Power actuated fasteners in concrete shall be field tested for 200 lbs. in tension. All other post-installed anchors in concrete shall be tested in accordance with CBC Section 1910A.5.
 - b. Post-installed anchors in concrete used to attach bracing wires shall be tested at a frequency of 50 percent in accordance with CBC Section 1910A.5.
 - 2. Re-Use of Existing Ceiling Hanger Wires and Bracing Wires:
 - a. All existing ceiling hanger wire/anchor assemblies must be tested to 200 lbs.
 - b. All existing bracing wire/anchor assemblies must be field tested to 440 lbs.
 - c. Where a new wire is spliced to an existing wire, each spliced wire/anchor assembly must be field tested to the loads given for existing assemblies above.

3.06 TOLERANCES

- A. Maximum Variation from Flat and Level Surface: 1/8 inch in 10 feet.
- B. Maximum Variation from Plumb of Grid Members Caused by Eccentric Loads: 2 degrees.

3.07 ADJUSTING AND CLEANING

- A. Replace loose and damaged tile and panels when directed.
- B. Touch-up all damaged finish.
- C. Leave all surfaces clean and free from markings and other disfigurements.
- D. Remove all debris resulting from the work of this section.

END OF SECTION

SECTION 09 65 00 RESILIENT FLOORING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Resilient base. RB-1
- B. Installation accessories.

1.02 RELATED REQUIREMENTS

- A. Section 01 61 16 - Volatile Organic Compound (VOC) Content Restrictions.

1.03 REFERENCE STANDARDS

- A. ADA Standards - 2010 ADA Standards for Accessible Design.
- B. ASTM E648 - Standard Test Method for Critical Radiant Flux of Floor-Covering Systems Using a Radiant Heat Energy Source.
- C. ASTM F150 - Standard Test Method for Electrical Resistance of Conductive and Static Dissipative Resilient Flooring.
- D. NFPA 253 - Standard Method of Test for Critical Radiant Flux of Floor Covering Systems Using a Radiant Heat Energy Source.
- E. RFCI (RWP) - Recommended Work Practices for Removal of Resilient Floor Coverings.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide data on specified products, describing physical and performance characteristics; including sizes, patterns and colors available; and installation instructions.
- C. Manufacturer's Qualification Statement.
- D. Installer's Qualification Statement.
- E. Maintenance Data: Include maintenance procedures, recommended maintenance materials, and suggested schedule for cleaning, stripping, and re-waxing.
- F. Maintenance Materials: Furnish the following for District's use in maintenance of project.
 - 1. See Section 01 60 00 - Product Requirements, for additional provisions.
 - 2. Extra Wall Base: 50 linear feet of each type and color.

1.05 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing specified with minimum three years documented experience.
- B. Installer Qualifications: Company specializing in installing specified with minimum three years documented experience.
- C. Testing Agency Qualifications: Independent firm specializing in performing concrete slab moisture testing and inspections of the type specified in this section.

1.06 DELIVERY, STORAGE, AND HANDLING

- A. Upon receipt, immediately remove any shrink-wrap and check materials for damage and the correct style, color, quantity and run numbers.
- B. Store all materials off of the floor in an acclimatized, weather-tight space.
- C. Maintain temperature in storage area between 55 degrees F and 90 degrees F.

1.07 FIELD CONDITIONS

- A. Store materials for not less than 48 hours prior to installation in area of installation at a temperature of 70 degrees F to achieve temperature stability. Thereafter, maintain conditions above 55 degrees F.

PART 2 PRODUCTS

2.01 REGULATORY REQUIREMENTS

- A. Provide products complying with the most stringent requirements of local, state, and federal regulations; where requirements of the contract documents exceed those of regulations, comply with the contract documents.
- B. Requirements for Physically Disabled: Provide flooring meeting slip-resistant requirements of California Code of Regulations (CCR), Title 24, Part 2, Chapter 11B and ADA Standards, latest amendment.
 - 1. Flooring surface shall be stable, firm, and slip resistant. CBC Section 11B-302.1 General.
 - 2. Flooring surface shall demonstrate a dynamic coefficient of friction of at least 0.42 per DCOF AcuTest ANSI 137.1 Section 9.6 and ANSI B101.3 (using a BOT-3000 testing unit) will be accepted as meeting the intent of slip resistance; CBC 11B-302 Floor or Ground Surfaces and ADA Standards.
 - a. Ramp surface: Provide DCOF value of 0.46.
 - 3. Provide minimum 2-inch contrasting color (70% recommended) warning stripe of material at least as slip resistant as the other treads of the stairs, 1-inch maximum from edge of nosing and top landing. CBC 11B-5041.4.
 - a. At interior stairs, provide warning stripe at top landing and bottom tread nosing only.
 - 4. Treads, Risers, and Nosings: CBC Section 11B-504
 - a. Interior stairs shall have the upper approach and lower tread of each flight marked by a stripe providing clear visual contrast. Exterior stairs shall have the upper approach and all treads marked by a stripe providing clear visual contrast.
 - b. The stripe providing clear visual contrast shall be a minimum of 2 inches wide to a maximum of 4 inches wide placed parallel to, and not more than 1 inch from, the nose of the step or upper approach. The stripe shall extend the full width of the step or upper approach and shall be of material that is at least as slip resistant as the other treads of the stair. A painted stripe shall be acceptable. Grooves shall not be used to satisfy this requirement.

- c. The radius of curvature at the leading edge of the tread shall be no greater than 1/2 inch. Nosings that project beyond risers shall have the underside of the leading edge curved or beveled. The maximum angle for a riser to slope under the tread shall be 30 degrees from vertical. Nosings shall extend 1-1/4 inch maximum over the tread below.
 - d. Treads shall be 11 inches deep minimum. Risers shall be 7 inches high maximum and 4 inches high minimum. All steps on a flight of stairs shall have uniform riser heights and uniform tread depths. Open risers are not permitted .
- C. Comply with CalGreen Building Standards: 80 percent of the installed resilient flooring shall meet one of the following:
- 1. VOC Content: Certified as Low Emission by one of the following :
 - a. SCS Floorscore; www.scs-certified.com. CalGreen 5.504.4.6.1.
 - b. Compliant with the VOC emission limits and testing requirements specified in the California Department of Public Health's 2010 "Standard Method for the Testing and Evaluation Chambers", Version 1.1, February 2010. CalGreen 5.504.4.6.2.
 - c. Compliant with the Collaborative for High Performance Schools California (CA-CHPS) Criteria Interpretation for EQ 7.0 and EQ 7.1 (formerly EQ 2.2) dated July 2012 and listed in the CHPS High Performance Product Database; www.chps.net/manual/lem_table.htm. CalGreen 5.504.4.6.3.
 - d. Products certified under UL GreenGuard Gold; www.greenguard.org. CalGreen 5.504.4.6.4.

2.02 RESILIENT BASE

- A. Resilient Base - Type RB-1: ASTM F1861, Type TS rubber, vulcanized thermoset; Style B, Cove.
- 1. Manufacturers:
 - a. Armstrong; Wall Base: www.armstrongflooring.com.
 - b. Johnsonite, a Tarkett Company: www.johnsonite.com.
 - c. Mannington Commercial; Burke: www.manningtoncommercial.com#sle.
 - d. Roppe Corporation: www.roppe.com/#sle.
 - e. Substitutions: See Section 01 60 00 - Product Requirements.
 - 2. Critical Radiant Flux (CRF): Minimum 0.45 watt per square centimeter, when tested in accordance with NFPA 253, ASTM E 648, ASTM E 648, or NFPA 253.
 - 3. Height: 4 inches.
 - 4. Thickness: 0.125 inch.
 - 5. Finish: Satin.
 - 6. Length: Roll.
 - 7. Color: To be selected by Architect from manufacturer's full range.
 - 8. Accessories: Premolded external corners and internal corners.

2.03 ACCESSORIES

- A. Primers, Adhesives, and Seam Sealer: Waterproof; types recommended by manufacturer.

1. VOC Content Limits: As specified in Section 01 61 16.
- B. Filler for Coved Base: Plastic.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that surfaces are flat to tolerances acceptable to flooring manufacturer, free of cracks that might telegraph through flooring, clean, dry, and free of curing compounds, surface hardeners, and other chemicals that might interfere with bonding of flooring to substrate.
- B. Environmental Condition: Comply with flooring manufacturer's instructions and recommendations.
 1. Verify that ambient and surface temperatures and humidity conditions are in compliance.
- C. Material Inspection:
 1. In accordance with manufacturer's installation requirements, visually inspect materials prior to installation.
 2. Material with visual defects shall not be installed.
 3. Labor costs required to replace material installed with visual defects shall be the responsibility of the installation contractor.

3.02 PREPARATION

- A. Clean substrate.

3.03 INSTALLATION - GENERAL

- A. Install in accordance with manufacturer's written instructions.
 1. Compliance: Comply with manufacturer's product data, including product technical bulletins, product catalog installation instructions, and product carton instructions for installation.
- B. Adhesive-Applied Installation:
 1. Spread only enough adhesive to permit installation of materials before initial set.
 2. Fit joints and butt seams tightly.
- C. Install feature strips where indicated.

3.04 INSTALLATION - RESILIENT BASE

- A. Fit joints tightly and make vertical. Maintain minimum dimension of 18 inches between joints.
- B. Miter internal corners. At external corners, use premolded units. At exposed ends, use premolded units.
- C. Install base on solid backing. Bond tightly to wall and floor surfaces.
- D. Scribe and fit to door frames and other interruptions.

3.05 FIELD QUALITY REQUIREMENTS

- A. Manufacturer's Field Services: Upon District's request and with at least 72 hours notice, provide manufacturer's field service consisting of product use recommendations and periodic site visit for inspection of product installation in accordance with manufacturer's instructions.

3.06 CLEANING

- A. Remove excess adhesive from floor, base, and wall surfaces without damage.
- B. Clean in accordance with manufacturer's written instructions.
- C. Installation Clean-Up: Upon completion of installation in a room or area, clean flooring and adjacent surfaces.
 - 1. Sweep or vacuum floor thoroughly.

END OF SECTION

SECTION 09 67 00 FLUID-APPLIED FLOORING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Fluid-applied flooring and base.

1.02 RELATED REQUIREMENTS

- A. Section 01 61 16 - Volatile Organic Compound (VOC) Content Restrictions.
- B. Section 07 92 00 - Joint Sealants: Sealing joints between fluid-applied flooring and adjacent construction and fixtures.
- C. Section 09 05 61 - Common Work Results for Flooring Preparation: Removal of existing floor coverings, cleaning, and preparation.
- D. Section 09 05 61 - Common Work Results for Flooring Preparation: Concrete slab moisture and alkalinity testing and remediation procedures.

1.03 REFERENCE STANDARDS

- A. ADA Standards - 2010 ADA Standards for Accessible Design.
- B. ANSI/NFSI B101.3 - Test Method for Measuring the Wet DCOF of Hard Surface Walkways.
- C. ASTM D635 - Standard Test Method for Rate of Burning and/or Extent and Time of Burning of Plastics in a Horizontal Position.
- D. {RSTEMP#10005085}
- E. ICRI 310.2R - Selecting and Specifying Concrete Surface Preparation for Sealers, Coatings, Polymer Overlays, and Concrete Repair.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide data on specified products, describing physical and performance characteristics; sizes, patterns and colors available.
- C. Samples: Submit two samples, 8 by 8 inch in size illustrating color and pattern for each floor material for each color specified.
- D. Concrete Subfloor Test Report: Submit a copy of the moisture and alkalinity (pH) test reports.
- E. Manufacturer's Installation Instructions: Indicate special procedures, perimeter conditions requiring special attention, and application rate for each coat.
- F. Manufacturer's Qualification Statement.
- G. Applicator's Qualification Statement.
- H. Maintenance Data: Include maintenance procedures, recommended maintenance materials, procedures for stain removal, repairing surface, and suggested schedule for cleaning.
- I. Maintenance Materials: Furnish the following for District's use in maintenance of project.

FOR REFERENCE ONLY

1. See Section 01 60 00 - Product Requirements, for additional provisions.
2. Extra Top Coat Materials: 2 gallons.

1.05 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing products specified in this section with minimum three years documented experience.
- B. Applicator Qualifications: Company specializing in performing the work of this section.
 1. Minimum three years of documented experience.
 2. Approved by manufacturer.
- C. Supervisor Qualifications: Trained by product manufacturer.

1.06 MOCK-UPS

- A. See Section 01 40 00 - Quality Requirements for additional requirements.
- B. Construct mock-up(s) of fluid applied flooring to serve as basis for evaluation of texture and workmanship.
 1. Number of Mock-Ups to be Prepared: One.
 2. Use same materials and methods for use in the work.
 3. Use approved design samples as basis for mock-ups.
 4. Locate where directed.
 5. Minimum Size: 48 inches by 48 inches.
- C. Obtain approval of mock-up by Architect before proceeding with work.
- D. Approved mock-up may remain as part of the work.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Store resin materials in a dry, secure area.
- B. Store materials for three days prior to installation in area of installation to achieve temperature stability.

1.08 FIELD CONDITIONS

- A. Maintain minimum temperature in storage area of 55 degrees F.
- B. Store materials in area of installation for minimum period of 24 hours prior to installation.
- C. Maintain ambient temperature required by manufacturer 72 hours prior to, during, and 24 hours after installation of materials.

PART 2 PRODUCTS

2.01 REGULATORY REQUIREMENTS

- A. All products used Must comply with VOC requirements listed in Section 01 61 16 - Volatile Organic Compound (VOC) Content Restrictions.

- B. Requirements for persons with disabilities: Provide flooring meeting slip-resistant requirements of California Code of Regulations (CCR), Title 24, Part 2, {RS#10005085} and ADA Standards, latest amendment.
1. Flooring surface shall be stable, firm, and slip resistant. CBC Section 11B-302.1 General.
 2. Flooring Surface shall demonstrate a dynamic coefficient of friction of at least 0.42 per DCOF AcuTest ANSI/NFSI B101.3 (using a BOT-3000 testing unit) will be accepted as meeting the intent of slip resistance; CBC 11B-302 Floor or Ground Surfaces and ADA Standards.
 - a. Ramp surface: Provide DCOF value of 0.46.

2.02 MANUFACTURERS

- A. Fluid-Applied Flooring:
1. Concrete Solutions by Rhino Linings: www.concretesolutions.com.
 2. Crossfield Products Corp: www.crossfieldproducts.com/#sle.
 3. Elite Crete Systems: www.elitecrete.com/#sle.
 4. DUR-A-FLEX. Inc.; Dur-A-Quartz: www.dur-a-flex.com.
 5. Sherwin-Williams Company; Armorseal 100% Solids Epoxy/Polyurethane: www.protective.sherwin-williams.com.
 6. Sherwin-Williams Company: General Polymers Brand: www.generalpolymers.com.
 7. Stonhard, an RPM Company: www.stonhard.com.
 8. Tnemec Company, Inc: www.tnemec.com/#sle.
 9. Substitutions: See Section 01 60 00 - Product Requirements.

2.03 FLUID-APPLIED FLOORING SYSTEMS

- A. Fluid-Applied Flooring Type EPOXY-1: Epoxy base coat(s) with embedded quartz aggregate.
1. Aggregate: Quartz granules.
 2. Top Coat: Polyurethane.
 3. System Thickness: 1/8 inch, nominal, dry film thickness (DFT).
 4. Texture: Smooth.
 5. Sheen: Matte.
 6. Flammability (ASTM D635): Self-Extinguishing.
 7. Color: As indicated on Drawings.
 8. Basis of Design Product: DUR-A-QUARTZ as manufactured by DUR-A-FLEX. Inc, or approved equal.
 9. Products:
 - a. DUR-A-FLEX. Inc.; Dur-A-Quartz: www.dur-a-flex.com.
 - b. Sherwin-Williams Company: General Polymers Brand: www.generalpolymers.com.
 - c. Sika Corporation; Sikafloor Quartzite Broadcast System: www.sikafloorusa.com/#sle.

- d. Stonhard; Stonshield SLT: www.stonhard.com/#sle.
- e. TNEMEC; 1/8" Deco-Tread Quartz System: www.tnemecc.com/#sle.
- f. Westcoat Specialty Coating Systems; DOUBLE BROADCAST EPOXY: www.westcoat.com/#sle.
- g. Substitutions: See Section 01 60 00 - Product Requirements.

2.04 ACCESSORIES

- A. Base Caps: Zinc with projecting base of 1/8 inch; color as selected.
- B. Fillet Strips: Molded of flooring resin material.
- C. Subfloor Filler: Type recommended by fluid-applied flooring manufacturer.
- D. Primer: Type recommended by fluid-applied flooring manufacturer.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that subfloor surfaces are smooth and flat within the tolerances specified for that type of work and are ready to receive flooring.
- B. Verify that wall surfaces are smooth and flat within the tolerances specified for that type of work, are dust-free, and are ready to receive flooring.
- C. Verify that subfloor surfaces are dust-free and free of substances that could impair bonding of materials to subfloor surfaces.
- D. Cementitious Subfloor Surfaces: Verify that substrates are ready for fluid-applied flooring installation by testing for moisture and alkalinity (pH).
 - 1. Test in accordance with Section 09 05 61.
 - 2. Obtain instructions if test results are not within limits recommended by fluid-applied flooring manufacturer.
 - 3. Follow moisture and alkalinity remediation procedures in Section 09 05 61.
- E. Verify that required floor-mounted utilities are in correct location.

3.02 PREPARATION

- A. Remove subfloor ridges and bumps. Fill low spots, cracks, joints, holes, and other defects with subfloor filler.
- B. Prepare concrete surfaces according to ICRI 310.2R, CSP 3.
- C. Apply, trowel, and float filler to achieve smooth, flat, hard surface. Grind irregularities above the surface level. Prohibit traffic until filler is cured.
- D. Vacuum clean substrate.
- E. Apply primer to surfaces required by flooring manufacturer.

3.03 INSTALLATION - ACCESSORIES

- A. Install access panel recess frames.
- B. Install fillet strips at base of walls where flooring is to be extended up wall as base.

- C. Install terminating cap strip at top of base; attach securely to wall substrate.

3.04 INSTALLATION - FLOORING

- A. Apply in accordance with manufacturer's instructions.
- B. Apply each coat to minimum thickness required by manufacturer.
- C. Finish to smooth level surface.
- D. Cove at vertical surfaces.

3.05 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements, for additional requirements.

3.06 PROTECTION

- A. Prohibit traffic on floor finish for 48 hours after installation.
- B. Barricade area to protect flooring until fully cured.

END OF SECTION

SECTION 09 90 13 PAINTING EXISTING FACILITIES

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes:
 - 1. Re-painting interior and exterior surfaces.
- B. Related Requirements:
 - 1. Section 07 92 00 - Joint Sealants.
 - 2. Section 09 91 13 - Exterior Painting.
 - 3. Section 09 91 23 - Interior Painting
 - 4. Section 09 96 00 - High-Performance Coatings
 - 5. Section 09 96 23 - Graffiti-Resistant Coatings.

1.02 DEFINITION OF TERMS

- A. Work shall include labor, material, equipment and scaffolding required for cleaning and preparation of surfaces to receive painters finish and for painting and varnishing, as herein specified. Perform work unless specifically noted otherwise.
- B. Painting shall include complete preparation and finish or refinishing in accordance with requirements specified herein. Drywall shall be treated same as specified for plaster.
- C. Wherever woodwork is specified to be refinished, it will include wood finish member (trim), movable cabinets with doors and center cut doors, windows and sash, screen doors, screens, sash poles, movable and fixed bulletin boards and chalkboards, etcetera.
- D. Plastic, impregnated plywood, hardwood, metal, asbestos board (if painted), and mastic coated wood surfaces shall be treated in same manner as specified for "woodwork".
- E. Whenever "Paint or Enamel" is referred to in these specifications, it shall be taken to mean types of waterborne materials and water reducible materials.
- F. Whenever "edges" are referred to in these specifications, it shall be taken to mean every edge (which include tops and bottoms).

1.03 SUBMITTALS

- A. Submit in accordance with Section 01 30 00 - Administrative Requirements.
 - 1. Submit a complete list of materials to be furnished stating supplier and distributor's names with product recommendations.
 - 2. Submit manufacturer's standard color samples for each type of paint specified. Once colors have been selected, submit six samples of each color selected for each type of paint, on standard 8 ½ by 11 spray-out panel.
 - 3. Before any coating is applied, submit to Project Inspector samples of each color to be used on contract. If more than one batch of material and color is to be used, samples from each batch shall be submitted.

- B. Paint and Enamel Spray-Outs:
 - 1. Submit samples of Paint and Enamel on standard 8 ½ by 11 Leneta Opacity-Display Charts. Each display chart shall have color in full coverage. Sample shall be prepared using material from batch to be used on actual job. Identify school on which paint is to be used, batch number, color number, type of material, name of manufacturer and name of Contractor.
 - 2. Furnish samples of colors to Project Inspector. Samples shall be kept on the job until painting is completed.
 - 3. Contractor is responsible for finish color on surface to be painted; where different materials of same color are specified to be applied on same, or adjoining surfaces, final color match shall match color sample on those surfaces.
- C. Elastomeric coating shall be submitted in duplicate samples of texture coating. Samples shall be not less than 2 ½-inch by 3 ½-inch in size and on adequate backing.
- D. Provide the current SCAQMD permit for each HEPA Vacuum and Portable Mechanical Ventilation System before they are brought onto the Project site.
- E. Materials and color samples shall be approved before a job start meeting will be scheduled.

1.04 QUALITY ASSURANCE

- A. Certification of Materials: With every delivery of paint materials manufacturer shall certify, on form supplied by OWNER that materials comply with requirements of this Section.
- B. Paint materials shall be approved by District's version of Office of Environmental Health and Safety (OEHS) Chemical Evaluation Program and comply with applicable requirements of Food and Drug Administration's (FDA) Lead Law and South Coast Air Quality Management District (SCAQMD).
- C. Painters working on Lead related work shall be trained at a minimum, in EPA's Renovation, Repair and Painting (RRP) Rule.
- D. Work shall be done by skilled and experienced painters in a professional manner. Painters must wear presentable white uniforms consistent with industry standard and personal ID Badges.

1.05 REGULATORY REQUIREMENTS

- A. Workers shall be trained in EPA's (Environmental Protection Agency); Renovation, Repair and Painting (RRP), the lead-related construction course that satisfies the requirements specified in 40 CFR, Part 745, Section 745.90.
- B. The Lead Related Construction Work, specified herein, shall be performed by a company, partnership, corporation, sole proprietorship or individual doing business, association, or other business entity; a Federal, State, Tribal, or local government agency; or a nonprofit organization, shall satisfy the requirements specified in 40 CFR, Part 745, Section 745.89, as a Lead-Safe Certified Firm.

FOR REFERENCE ONLY

- C. Prior to commencement of Asbestos Related Construction Work, personnel required to construct and enter the Work Area or handle Asbestos Containing Materials shall have received adequate training, minimum of 16 hours of O&M training comprised of 2 hours of Awareness Training and 14 hours of Special O&M Training, in accordance with the requirements by 40 CFR, Part 763, Subpart E (ASHERA) and Title 8, Section 1529, of the California Code of Regulations.
- D. Paint materials shall comply with Food and Drug Administration's (FDA) Lead Law and current rules and regulations of local, state and federal agencies governing use of paint materials.
- E. Paint color requirements for CALOSHA: CALOSHA requires the following items be painted as prescribed:
 - 1. Gas Mains and Valves: "Gun metal gray" (medium gray).
 - 2. Fire Valves and Risers shall be painted OSHA's "safety red".

1.06 DELIVERY, STORAGE AND HANDLING

- A. Deliver materials to project site in original unbroken containers bearing manufacturer's name, brand number, batch number, and Safety Data Sheets.
- B. Open and mix ingredients on premises in presence of Project Inspector. Immediately remove rejected materials from premises.

1.07 METAL STORAGE CONTAINER

- A. Storage and Mixing of Materials: Store materials and mix only in spaces designated for purpose by Project Inspector. Keep such spaces clean and take necessary precautions to prevent fire. Hang out oily rags singly in open air. Stack paint containers so that manufacturer's labels are clearly displayed.
- B. Paint, combustible materials, gasoline driven equipment, etcetera shall not be stored or left in any school building overnight.
- C. In event that equipment and material storage sheds must be placed on asphalt pavement less than six months old, each wheel, leg or other supporting member shall be centered on a 4-foot by 8-foot by $\frac{3}{4}$ inch thick sheet of plywood. Shed shall be set down in such a manner as to prevent damage to pavement. Contractor RACTOR shall be responsible for any damage to pavement caused by improper placement of shed.

1.08 ENVIRONMENTAL CONDITIONS

- A. Temperature: Do not apply exterior paint in damp, rainy weather or until surface has dried from effects of such weather. Do not apply paint, interior or exterior, when temperature is below 55 degrees F., humidity is above 80%, or above manufacturer's stated recommended temperature, or when dust conditions are unfavorable to proper workmanship.

1.09 WARRANTY

- A. Manufacturer shall provide a three year material warranty from date of Substantial Completion.
- B. Contractor warrants work executed and materials furnished under Contract shall be free from defects of materials and application for a period of three years from date of Substantial Completion.

- C. Elastomeric coating shall be warranted for a period of five years from date of Substantial Completion.

1.10 PROTECTION

- A. Fire alarm boxes, fire sprinkler heads, smoke detectors and intrusion alarm systems shall be uncovered and available to perform function that it was designed for each and every night.
- B. Pressure relief grilles with barometric damper leading to a corridor or an exterior shall be masked off before spraying and then uncovered immediately after spraying.
- C. Conspicuously post sufficient "Wet Paint" signs continuously to alert public and school personnel to existing conditions until paint is completely dried.
- D. Provide and maintain barriers, guards, lights, warning signs, etcetera for complete protection and as directed by the Project Inspector.
- E. Do not impede emergency egress.

1.11 MISCELLANEOUS

- A. Provide and maintain barriers, guards, lights, warning signs, etcetera for complete protection and as directed by the Construction Manager. Provide access to doors and openings. Do not store equipment or material near openings or traffic lanes that could be hazardous during an emergency.

1.12 SCAFFOLDING

- A. Scaffolding and aerial lifts shall be made available to Construction Manager, without cost, to make repairs. Construction Manager will coordinate its work with that of Contractor's to avoid delays to the work.

1.13 SCHEDULING OF WORK

- A. Schedule work through the Construction Manager.

PART 2 - PRODUCTS

2.01 PAINT MATERIALS

- A. Factory mix paint materials to correct color, gloss, and consistency for installation to maximum extent feasible.
- B. Paint materials: by one manufacturer.
- C. Paint materials: "Premium Plus or Ultra Premium Grade".
- D. Acceptable manufacturers, unless otherwise noted:
 - 1. Dunn-Edwards Corporation Paints.
 - 2. Vista Paints.
 - 3. Behr
 - 4. Sherwin Williams.
 - 5. PPG Paints.
 - 6. Substitutions: See Section 01 60 00 - Product Requirements.

- E. Gloss degree standards (MPI):
 - 1. At 60 Degrees: Semi-gloss 35 to 70 units.
 - 2. MPI Gloss Level 5

PART 3 – EXECUTION

3.01 REMOVE AND REINSTALL

- A. Remove coat hooks, name plates, label frames, sash lifts, sash locks, pencil sharpeners, flag brackets, drawer handles and locks, window coverings, switch and receptacle plates, removable bulletin boards, mirrors, maps and thermometer. Reinstall all of the above after painting is completed.
- B. Remove exposed nails, hooks, tacks, screws, staples and pins in surface to be painted and patch holes with a matching material. Remove interior and exterior obsolete screens, grille hangers, fasteners and patch holes.
- C. Paper labels: Soaked off and glue residue from tape removed.
- D. Remove metal or plastic room numbers, letters, signs, and, after painting is complete, clean and reinstall them neatly.
- E. Sash locks shall be reset in accordance with instructions for locking doors and windows each night.

3.02 REPLACEMENT SCREWS AND HARDWARE

- A. Replace hardware using new screws, of same diameter, but one size longer than those removed. Screws used must be of finish design and material to match removed hardware.
- B. Remove paint from hardware, including paint from previous painting.

3.03 GENERAL PREPARATION OF EXISTING PAINTED SURFACES

- A. Previously painted surfaces will be assumed to contain lead.
- B. Trenching: Before any cleaning or sandblasting operation is started, trench soil at base of building to a depth of six inches and eight inches wide. Refill trench after completing painting application and allowing sufficient drying time.
- C. Insure a consistently uniform horizontal, vertical and curved surface, with a maximum deformation of 1/8 inch in a five foot span on an exterior stucco/masonry finish. For stucco/masonry repair, apply an exterior patching material, bringing the surface flush with the existing finish while matching the existing building textured finish.
- D. Glass, fiberglass and polycarbonate on exterior are to be traced neat and clean with approximately, but no more than 1/16 inch overlay. Paint specks, smears or splatters must be immediately removed and surface cleaned.
- E. Miscellaneous Exterior Surfaces; Freestanding exterior school signs, windbreaks, baffles, benches, scoreboards, fences and gates (excluding chain link), decorative panels, interior and exterior surfaces of display cases, storage and supply cabinets, including both sides and edges are to be prepared and primed as specified under "Doors." Provide the number of coats of paint as detailed under "Colors and Number of Paint Coats."

FOR REFERENCE ONLY

- F. Examine surfaces to receive paint finish. Surfaces which are not properly prepared, and cleaned or which are not in condition to receive finish specified, shall be corrected before paint is applied. Painting shall not be done on existing painted surfaces until surfaces are approved by the Project Inspector.
- G. Remove items fastened to existing painted surfaces and patch holes with a material and re-fasten in original location upon completion of painting work.
- H. Prepare existing painted surfaces indicated to be painted, as follows:
 - 1. Wash wood, plaster and metal surfaces with TSP (tri-sodium phosphate) substitute to remove dirt, grease and other foreign materials and rinsed with clean water and then sand papered and dusted off. Completely remove wax from surfaces before washing, which includes base, shoe base, and concrete base.
 - 2. Checked, cracked, blistered, scaled, peeling, and alligatored paint on wood and metal surfaces; removed paint down to original finished surface, then hand-sand and dusted clean.
 - a. Surfaces are then be considered as new work.
 - b. Hand sand smooth woodwork after each and every coat, except last coat. Coats to be free from dust, dirt or other imperfections.
 - c. Steel sash and aluminum sash to be painted must be steel-wooled and dusted off. Hand sand smooth sash putty and dusted off.
 - d. Remove lint and grease from screens, vents, hoods, et cetera that are to be painted.

3.04 OTHER SURFACE PREPARATION REQUIREMENTS

- A. Prepare existing painted surfaces and make ready to receive new coat of paint or other finish coating materials by any of following methods:
 - 1. Checked, cracked, blistered, scaled loose, and alligator paint on wood and metal surfaces are to be wet scraped and wet sanded to a smooth solid surface, H.E.P.A. vacuumed, wet wiped as specified per EPA RRP and then painted as specified. Perform wet scraping and or wet sanding only when school is not in session, and students and staff are not on site.
 - 2. Trenching: Before any cleaning or sandblasting operation is started, soil at base of building shall be trenched to a depth of six inches and eight inches wide. After completing painting application and allowing sufficient drying time, trench shall be refilled.
 - 3. Sandblasting and/or pressure washing shall not be allowed without prior approval from the Construction Manager. Only low pressure hydro-washing, below 750 psi, shall be allowed on all exterior surfaces.
 - 4. Hydro-washing: Exterior masonry and plaster on buildings, bungalows, pavilions, and appurtenances must be washed with a cleaner using hydro-washing equipment, or as directed by Project Inspector, to remove grease, dirt and foreign materials and then rinsed with clean water to remove residue. Surfaces must be allowed to dry for at least five days or as determined by Project Inspector. Care shall be taken to prevent water from entering buildings through vents, et cetera. Immediately following hydro-washing, areas surrounding buildings must be rinsed down. Ensure no rinse water enters storm drains.

FOR REFERENCE ONLY

- a. Exposed mastic, concrete, and/or plaster surfaces shall be cleaned with a cleaner, using hydro-cleaning equipment. This process is to remove dirt, foreign materials, grease, and oil and rinsed with clean water to remove residues.
 - b. Before hydro-washing efflorescence must be brushed off and surface treated with a 10 percent solution of Muriatic Acid, neutralized with a 10 percent solution of ammonia water and then rinsed with clean water.
 - c. Painted surfaces that will be directly or indirectly impacted by hydro-washing shall have paint stabilized to remove loose, flaky or peeling paint using the wet method. Wood, metal, and other exterior non-masonry/stucco surfaces shall be primed where stabilization has occurred prior to application of cleaner and hydro-washing.
 - d. Hydro-washing is not intended to remove loose, flaky or peeling paint or paint chips. Water generated from cleaning and hydro-washing process shall be collected and stored in DOT approved container and examined for the presence of paint chips. The visible paint chips shall be separated from the waste water and be disposed of as assumed RCRA hazardous waste or be characterized to determine disposal requirements. The remaining wastewater must be characterized for proper disposal in accordance with Specification 02-8333, Lead Abatement and Lead Related Construction Work.
 - e. At no time shall water from hydro-washing process be directed to soil, such as planted area, sewer system, storm drain, be allowed to flow off District property to adjoining public or private property, or to flow across asphalt or cement concrete and allowed to dry.
 - f. Hazardous waste generated by this process requires that the Office of Environmental Health and Safety (OEHS) be notified. Hazardous waste shall be being transported under a Uniform Hazardous Waste Manifest approved by OEHS prior to disposal. CONTRACTOR shall ensure the manifest is completed as required by code and then submit it to OEHS for approval. The Construction Manager will sign the manifest once it is accurately completed and approved by OEHS prior to transport.
5. Sandblasting: Shall be performed when school is not in session and when students are not present. Premises shall be left in a clean condition and ready for use by occupants by end of any day prior to beginning of school session. Work shall be coordinated with Project Inspector and the Construction Manager. Only wet blasting shall be allowed. Masonry or stucco surfaces shall be sandblasted to remove mastic, paint and other materials to original plaster brown coat or formed concrete surface. Rinse with clean water to remove residue. Adjacent surface, plants and shrubs shall be protected from damage due to sandblasting operations.
- a. Immediately upon completion of sandblasting operation, roof, gutters and areas around buildings, etcetera shall be cleaned of sand and debris resulting from sandblasting operation. No sand or debris shall be hosed or swept into drains.
 - b. Metal surfaces including decorative metal and fencing requiring sandblasting shall be sandblasted to white metal and primed same day with a metal primer per manufacturer's recommendation.

FOR REFERENCE ONLY

6. Sandblasting and Pressure Washing of materials containing asbestos or lead are abatement activities and will only be performed by companies and individuals with prior District approval.

3.05 CRACKS AND VOIDS

- A. Voids between wall and ceiling surfaces and wood or metal trim or scribed edges where finish exists or is specified to be applied and including picture molding, must be filled with putty, filler or latex sealing compound.
- B. Areas where finish plaster coat is loose must have that portion removed to a solid surface. Surfaces that are broken, cracked, or damaged and areas where finish plaster coat has been removed must be coated with compatible bonding agent. Surface will then be given a cement plaster finish coat consisting of one-part Plastic Portland Cement to three parts sand to match existing finish. Cracks shall be "V-ee'd" out, filled, finished flush with and textured to match adjoining surfaces, per Construction Manager's approval.
- C. Neutralize walls showing effects of alkali.

3.06 FILLER ON SIDING AND WOODWORK

- A. Checked and cracked portions of siding and woodwork (after surrounding areas have been prepared as specified above) shall be primed, smoothed with an exterior filling compound and then sanded smooth when dry. Filled areas must be spot primed. Filler shall not be used on handball walls or basketball backstops.

3.07 SEALING SASH, DOOR FRAMES

- A. Sealant that will interfere with proper application of coatings shall be removed. Seal around door and window frames, flashing, vents, separations between masonry or plaster and adjoining surfaces, etcetera, with a sealant compound recommended by manufacturer of coating to be used. Sealing and filling shall be done with sufficient pressure to force material to base of opening.

3.08 MASTIC REPAIR AND ELASTOMERIC REPAIR

- A. Surface must be clean, firm and free of oil, wax and chalk. Mildew must be killed. Surface must be rinsed and allowed to dry.
- B. Use primers as recommended by manufacturer for each substrate.
- C. May be applied with airless spray equipment, using a 22 to 34 orifice tip and do not apply when surface or air temperature is below 50 degrees F.
- D. Apply elastomeric with a ½ inch to 1 ½-inch roller cover or an air-atomized spray texture pump system. Do not over-roll.
- E. Spreading rate:

Fine texture:	Approximate mil thickness at 80 square feet per gallon	Wet	18 mils
		Dry	9 mils
Medium texture:	Approximate mil thickness at 60 square feet per gallon	Wet	18 mils
		Dry	9 mils
Heavy texture:	Approximate mil thickness at 40 square	Wet	39 mils

FOR REFERENCE ONLY

feet per gallon

Dry

26 mils

Note: Coverage will vary depending upon texture desired and surface. Direction will be given by an Construction Manager.

- F. Dry time
 - 1. To touch: 1 to 1 ½ hours
 - 2. To Recoat: 24 hours
- G. Finish will be uniform in texture and free of imperfections.
- H. Elastomeric coatings will receive at least two coats of paint.
- I. Hairline cracks: Two coats of elastomeric coating to bridge hairline cracks.
- J. Small to medium cracks and imperfections: elastomeric coating to fill and span cracks up to 1/32 inch. Cracks 1/32 inch width or greater shall be treated with an elastomeric sealant (recommended by paint manufacturer) prior to applying elastomeric coating.
- K. Medium to large cracks and imperfections: Cracks from 1/32 inch to 1/8 inch shall be treated with a brush-grade elastomeric sealant applied in a 2-inch wide band; crowned at center and feathered at edges to conceal repair.
- L. Large cracks: Cracks 1/8 inch to ½ inch shall receive a urethane sealant (recommended by paint manufacturer), “rake out” crack to conform to manufacturer’s specifications and applied as directed for medium to large cracks.
- M. Cracks, holes and damaged spots larger than ½ inches: Damaged areas shall be given a cement plaster finish coat consisting of one-part plastic Portland cement to three-parts plaster sand to match existing finish. When finished, it shall be flush with and match existing texture of adjoining surface.
- N. Texture match: Crack repairs shall be finished to match texture of adjoining surfaces, per Project Inspector’s approval. Hand held plaster hopper guns may be used. Exercise care to ensure that areas finished by hand held plaster machines match in color, texture and thickness to adjoining surfaces. A compatible bonding agent shall be used.

3.09 REPAIR OF PLASTER

- A. Exterior areas, where finish plaster coat is loose, shall have that portion removed to a solid surface. Surfaces that are broken, cracked, or damaged and areas where finish plaster coat has been removed shall be coated with compatible bonding agent. Surface will then be given a cement plaster finish coat consisting of one-part Plastic Portland Cement to three parts plaster sand to match existing finish. Cracks shall be “veed-out”, filled, finished flush with and textured to match adjoining surfaces, per Project Inspector’s approval.
 - 1. If existing plaster was a machine applied, dash coat, apply final application of finish coat over patched areas by machine to match existing adjacent machine texture. Use a finish plaster material with a bonding admixture mixed according to manufacturer's recommendation.
 - 2. Cracks, holes, and damaged spots larger than ½ inch, see Article Mastic Repair and Elastomeric Repair.

- B. Exterior plaster designated to be painted shall receive three coats. First coat shall be sealer. Second and third coats shall 100 percent acrylic semi-gloss enamel unless otherwise indicated.

3.10 REPAIR OF SPALLING CONCRETE

- A. Remove surface contamination, broken and spalled concrete to a sound concrete base. Concrete shall be removed to a depth of one-half inch minimum around rebar. Sides of areas to be repaired shall be straight, not tapered or sloped.
- B. Spalled or loose concrete shall be removed using an electric or compressed air chipping hammer.
- C. Clean exposed rebar by sand/media blasting, remove debris and dust and treat steel with a sealant compatible to patching materials same day. Project Inspector shall approve sealant application prior to any patching materials being applied.
- D. Repair concrete to match existing concrete surfaces using Sika Top 123 Gel Mortar, DAP Concrete Patch, Quikrete Fast-Setting Concrete, or equal.
- E. Sealant and patching materials shall be applied by qualified applicator.

3.11 SPRAYING MASONRY/CEMENT PLASTER

- A. Masonry/plaster material must be a 100 percent acrylic flat paint, color as directed. Material must be applied in strict conformity to manufacturer's directions. There must be at least 24 hours drying time between first coat which shall be factory tinted 10 percent to 15 percent lighter (or darker) in color than finish coat. Manufacturer shall be acquainted with conditions of surfaces to be refinished and provide written specifications for the job including special primers or additives needed for adhesion sealing of first coat of paint and general performance of materials. Finished surface must be uniform and free of imperfections. Each coat applied to surface must be sprayed using "Cross-Off" method of application by spraying horizontally with a 50 percent overlap on returns and doubling back with a vertical stroke with a 50 percent overlap on returns.

3.12 FILLER ON SIDING AND WOODWORK

- A. Checked and cracked portions of siding and woodwork (after surrounding areas have been prepared as specified above) shall be primed, smoothed with an exterior filling compound and then sanded smooth when dry. Filled areas must be spot primed. Filler shall not be used on handball walls or basketball backstops.

3.13 MIXING AND APPLICATION

- A. Colors of coatings shall be as directed by Project Inspector.
- B. Three coats of paint shall be applied as follows:
 - 1. First coat: primer or undercoat, shall be white or may be tinted up to 50% lighter or darker than the finish coat at the discretion of the installer.
 - 2. Second coat shall be factory tinted in range of 10 percent to 15 percent lighter or darker than finish coat.

3. Third coat shall be factory tinted to color selected but allowing for tint variations in more than one color for application to different surfaces. Color combinations in rooms and for surfaces shall be varied in accordance with color letter.
- C. Any number of colors may be used on any portion of work. Construction Manager reserves right to change colors before work is started in an area or on a particular surface.
- D. Various colors may require additional coats of paint complete coverage. No additional allowances will be made. Contractor is responsible for consulting color letter and knowing color and coverage.
- E. Surfaces to be finished and each coating shall be separately inspected by Project Inspector and checked for mill thickness. The requirements are two mils each coat wet and three mils dry after three coats. Notice that such work is ready for inspection shall be given to Project Inspector. Should such notice not be given before succeeding coat is put on, finish applied shall be removed or an additional coat shall be applied, as directed by Project Inspector. Allow at least one day drying time between coats for exterior work or as directed by Project Inspector for proper drying.

3.14 PAINT ROLLERS, BRUSH AND SPRAY

- A. First coat on wood overhang and ceilings must have material applied by roller and then must be brushed out in a professional manner to leave surface free of imperfections. Finish coat may be sprayed.
- B. Other surfaces shall have coatings applied with brushes of proper size.

3.15 PRIMING

- A. Surfaces from which paint finish have been removed down to original wood or metal surfaces shall be primed as follows:
 1. Wood shall be sealed or primed with a non-water borne material on both sides and edges. Wood completely sealed with a non-water borne material shall be top coated with a water borne material as specified herein. Finish material (water borne) shall be compatible with non-water borne primer per manufacturer's recommendations. Hardwood shall be filled and stained to an even color.
 2. Galvanized Metal: Clean oil and foreign material from surfaces. Apply a metal clean and etch pretreatment coating. Follow manufacturer's instructions for drying time, and then prime with one coat of metal primer.
 3. Ferrous and non-ferrous metal: Use a primer for ferrous and non-ferrous metal.

3.16 FIRE AND LIFE SAFETY EQUIPMENT

- A. Cal-OSHA requires the following equipment be painted as follows:
 1. Gas Mains and Valves: "gun metal gray" (medium gray).
 2. Fire Valves and Raisers: OSHA's "safety red".

3.17 DOORS

- A. Painted or refinished interior and exterior wood or metal doors must be finished on both sides and edges with three coats of paint consisting of first coat of primer, second coat and third coat of exterior semi-gloss enamel.

- B. Where doors open into rooms or spaces having different finishes, communicating doors must have edges finished according to industry standard or as directed by Project Inspector.
 - 1. Strike edge of door shall be same color as inside face of door.
 - 2. Hinged edge of door shall be same finish as outside face of door.
- C. Exterior hardwood doors and frames where varnish finish has been removed shall be built-up to match adjoining finish with stain, filler and one coat of exterior varnish. Then surfaces, including edges must be given specified number of coats of exterior varnish as detailed under "Stain and Varnish Finish."

3.18 RAMPS, STAIRS AND HANDRAILS

- A. Unpainted, painted and mastic coated classroom ramps, treads, risers and thresholds of building shall be prepared as specified herein and painted with two coats of Monochem DEX-COAT textured paint or equal.
- B. Handrails shall be finished same as specified for exterior wood doors using exterior semi-gloss enamel.

3.19 THRESHOLDS

- A. Painted thresholds to be prepared, primed, and receive two coats of a non-skid porch and deck paint.
- B. Natural finished wood thresholds to be prepared and receive three coats of a semi-gloss varnish.

3.20 WOODWORK

- A. Wood surfaces shall be prepared to receive new finish as specified under Articles Preparation of Surfaces and Priming. Wood surfaces shall be painted with three coats of paint consisting of first coat of primer, second coat and third coat of exterior semi-gloss enamel.

3.21 PAINTED METAL

- A. Exposed structural steel, miscellaneous/ornamental iron, sheet metal work, guards, steel sash, gates, painted aluminum, basketball rims, etcetera shall have surfaces cleaned and prepared as specified. The areas from which original painter's finish has been removed shall be spot primed with metal primer to match adjoining surfaces and then surfaces shall be given a prime coat of metal primer, second and third coats as specified. Copper pipe shall be painted with one coat of enamel undercoat per manufacturer's recommendation, a second and third coat of enamel as specified.
- B. Painted ornamental iron rails and gates, metal ceilings (metal decking, etcetera) stairs, pipe columns, and pipe rails shall be prepared and finished as specified herein. Metal decking and metal roll-up doors may be sprayed.
- C. Exterior surfaces (except bottom) of exterior metal storage containers, including both sides of door(s) and edges shall be prepared and painted with three coats of paint consisting of first coat of primer, second coat and third coat of exterior semi-gloss enamel. Exterior metal storage container(s) must be sprayed.

3.22 LIGHT FIXTURES

- A. Light fixtures (other than plated or bronzed) and bells to be primed and then painted with two coats of an enamel to match adjoining surface. Bell identification plates must have paint removed and be kept clean.

3.23 METAL SURFACES

- A. Clean by wire-brushing and sanding to remove foreign debris, loose paint, rust, etcetera. After removing loose paint, feather-edge sand surrounding areas of existing finish. Remove dust.
- B. Exterior bare metal surfaces shall be primed with a metal primer then painted with a first coat of enamel undercoat, then a second coat and third coat of exterior semi-gloss enamel.

3.24 PAINTING OF MECHANICAL WORK

- A. Exposed heating, ventilating, air conditioning, plumbing, electrical equipment, apparatus, piping, ducts, coverings, etcetera shall be cleaned, prepared and painted as specified herein for that item.
 - 1. In finished areas, these items must be finished with one coat of primer and two coats of enamel to match adjoining wall or ceiling finish as specified herein.
- B. Mechanical work not specifically mentioned must be painted as specified for other work of same character.
- C. Finished bronze, brass fittings, plated work, name plate and fusible links and chains must be cleaned of paint.

3.25 ELECTRICAL CABINETS

- A. Front side of doors and exposed lip around doors to electrical cabinets in finished areas must be finished same as walls.

3.26 LETTERING

- A. Lettering and numerals on glass, fiberglass, plaster, and surfaces to be refinished shall be reproduced in original locations and will be of size, color and design as directed by Project Inspector and Construction Manager. An experienced sign painter shall do lettering.

3.27 CLEANING

- A. Glass, polycarbonate and fiberglass on interior and exterior where painting has been done shall be cleaned of paint and varnish. Glass, fiberglass and polycarbonate that are scratched or damaged by painting work, shall be replaced with material to match original.
- B. Before applying finish coat of material to exterior sash with security grilles, Contractor shall clean window panes with a cleaner.
- C. Dispose of debris, waste or unused materials, off site. Use of school dumpsters is strictly prohibited.
- D. Remove paint from hardware, including paint from previous painting.
- E. Contractor shall free sash and leave it in an easy operating condition.

FOR REFERENCE ONLY

- F. Glass, fiberglass and polycarbonate on exterior shall be traced neat and clean with no more than 1/16 inch overlay. Paint specks, smears or splatters shall be immediately removed and surface cleaned.
- G. Rooms, Buildings, and Campuses must be cleaned of paint debris, including dust caused by painting project to approval of Project Inspector and Construction Manager.

3.28 POST OCCUPANCY WORK

- A. Two months after substantial completion, Construction Manager will arrange a date and time when the Contractor must return to the site to check and free sashes that were painted so they are in proper operating condition.

END OF SECTION

SECTION 09 91 13 EXTERIOR PAINTING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Surface preparation.
- B. Field application of paints.
- C. Scope: Finish exterior surfaces exposed to view, unless fully factory-finished and unless otherwise indicated, including the following:
 - 1. Exposed surfaces of steel lintels and ledge angles.
 - 2. Mechanical and Electrical:
 - a. On the roof and outdoors, paint equipment exposed to weather or to view, including factory-finished materials.
- D. Do Not Paint or Finish the Following Items:
 - 1. Items factory-finished unless otherwise indicated; materials and products having factory-applied primers are not considered factory finished.
 - 2. Items indicated to receive other finishes.
 - 3. Items indicated to remain unfinished.
 - 4. Fire rating labels, equipment serial number and capacity labels, and operating parts of equipment.
 - 5. Non-metallic roofing and flashing.
 - 6. Stainless steel, anodized aluminum, bronze, terne-coated stainless steel, zinc, and lead.
 - 7. Glass.
 - 8. Concealed pipes, ducts, and conduits.

1.02 RELATED REQUIREMENTS

- A. Section 01 61 16 - Volatile Organic Compound (VOC) Content Restrictions.
- B. Section 05 50 00 - Metal Fabrications: Shop-primed items.

1.03 DEFINITIONS

- A. Comply with ASTM D16 for interpretation of terms used in this section.

1.04 REFERENCE STANDARDS

- A. 40 CFR 59, Subpart D - National Volatile Organic Compound Emission Standards for Architectural Coatings; U.S. Environmental Protection Agency.
- B. ASTM D16 - Standard Terminology for Paint, Related Coatings, Materials, and Applications.
- C. ASTM D4258 - Standard Practice for Surface Cleaning Concrete for Coating.
- D. ASTM D4442 - Standard Test Methods for Direct Moisture Content Measurement of Wood and Wood-Based Materials.

- E. CARB (SCM) - Suggested Control Measure for Architectural Coatings; California Air Resources Board.
- F. SCAQMD 1113 - Architectural Coatings.
- G. SSPC-SP 1 - Solvent Cleaning.
- H. SSPC-SP 2 - Hand Tool Cleaning.
- I. SSPC-SP 6 - Commercial Blast Cleaning.
- J. SSPC-SP 13 - Surface Preparation of Concrete.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide complete list of products to be used, with the following information for each:
 - 1. Manufacturer's name, product name and/or catalog number, and general product category (e.g. "alkyd enamel").
 - 2. MPI product number (e.g. MPI #47).
 - 3. Cross-reference to specified paint system(s) product is to be used in; include description of each system.
 - 4. Manufacturer's installation instructions.
 - 5. If proposal of substitutions is allowed under submittal procedures, explanation of substitutions proposed.
- C. Samples: Submit three paper "draw down" samples, 8-1/2 by 11 inches in size, illustrating range of colors available for each finishing product specified.
 - 1. Where sheen is specified, submit samples in only that sheen.
 - 2. Where sheen is not specified, discuss sheen options with Architect before preparing samples, to eliminate sheens not required.
- D. Certification: By manufacturer that paints and finishes comply with VOC limits specified.
- E. Manufacturer's Instructions: Indicate special surface preparation procedures.
- F. Maintenance Data: Submit data including finish schedule showing where each product/color/finish was used, product technical data sheets, material safety data sheets (MSDS), care and cleaning instructions, touch-up procedures, repair of painted and finished surfaces, and color samples of each color and finish used.
- G. Maintenance Materials: Furnish the following for District's use in maintenance of project.
 - 1. See Section 01 60 00 - Product Requirements, for additional provisions.
 - 2. Extra Paint and Finish Materials: 1 gallon of each color; from the same product run, store where directed.
 - 3. Label each container with color in addition to the manufacturer's label.

1.06 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing the products specified, with minimum three years documented experience.

- B. Applicator Qualifications: Company specializing in performing the type of work specified with minimum three years documented experience, approved by manufacturer, and with minimum three years documented experience.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Deliver products to site in sealed and labeled containers; inspect to verify acceptability.
- B. Container Label: Include manufacturer's name, type of paint, brand name, lot number, brand code, coverage, surface preparation, drying time, cleanup requirements, color designation, and instructions for mixing and reducing.
- C. Paint Materials: Store at minimum ambient temperature of 45 degrees F and a maximum of 90 degrees F, in ventilated area, and as required by manufacturer's instructions.

1.08 FIELD CONDITIONS

- A. Do not apply materials when surface and ambient temperatures are outside the paint product manufacturer's temperature ranges.
- B. Follow manufacturer's recommended procedures for producing best results, including testing of substrates, moisture in substrates, and humidity and temperature limitations.
- C. Do not apply exterior paint and finishes during rain or snow, or when relative humidity is outside the humidity ranges required by the paint product manufacturer.
- D. Minimum Application Temperatures for Latex Paints: 50 degrees F for exterior; unless required otherwise by manufacturer's instructions.
- E. Provide lighting level of 80 ft candles measured mid-height at substrate surface.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Provide paints and finishes from the same manufacturer to the greatest extent possible.
 - 1. If a single manufacturer cannot provide specified products, minor exceptions will be permitted provided approval by Architect is obtained using the specified procedures for substitutions.
 - 2. Substitution of other products by the same manufacturer is preferred over substitution of products by a different manufacturer.
- B. Paints:
 - 1. Behr Process Corporation: www.behr.com/#sle.
 - a. Local representative Joe Esquer, 657.212.0111.
 - 2. Dunn-Edwards Corporation: www.dunnedwards.com,
 - a. Local representative Wanda Barragan 909.261.1289.
 - 3. PPG Paints: www.ppgpaints.com/#sle.
 - a. Local representative Susan L. Giampietro 949.410.2452.
 - 4. Sherwin-Williams Company: www.sherwin-williams.com/#sle.
 - a. Local representative John Dumesnil 619.665.9341.

5. Vista Paint Corporation: www.vistapaint.com/#sle.
 - a. Local representative Mark Brower 323.397.9000.
- C. Primer Sealers: Same manufacturer as top coats.
- D. Substitutions: See Section 01 60 00 - Product Requirements.

2.02 PAINTS AND FINISHES - GENERAL

- A. Paints and Finishes: Ready-mixed, unless required to be a field-catalyzed paint.
 1. Provide paints and finishes of a soft paste consistency, capable of being readily and uniformly dispersed to a homogeneous coating, with good flow and brushing properties, and capable of drying or curing free of streaks or sags.
 2. Provide materials that are compatible with one another and the substrates indicated under conditions of service and application, as demonstrated by manufacturer based on testing and field experience.
 3. For opaque finishes, tint each coat including primer coat and intermediate coats, one-half shade lighter than succeeding coat, with final finish coat as base color.
 4. Supply each paint material in quantity required to complete entire project's work from a single production run.
 5. Do not reduce, thin, or dilute paint or finishes or add materials unless such procedure is described explicitly in manufacturer's product instructions.
- B. No intentionally added cadmium.
- C. Volatile Organic Compound (VOC) Content: Comply with Section 01 61 16.
- D. Volatile Organic Compound (VOC) Content:
 1. Provide paints and finishes that comply with the most stringent requirements specified in the following:
 - a. 40 CFR 59, Subpart D--National Volatile Organic Compound Emission Standards for Architectural Coatings.
 - b. SCAQMD 1113 Rule.
 - c. CARB (SCM).
 - d. Architectural coatings VOC limits of California.
 2. Determination of VOC Content: Testing and calculation in accordance with 40 CFR 59, Subpart D (EPA Method 24), exclusive of colorants added to a tint base and water added at project site; or other method acceptable to authorities having jurisdiction.
- E. Flammability: Comply with applicable code for surface burning characteristics.
- F. Sheens: Provide the sheens specified; where sheen is not specified, sheen will be selected later by Architect from the manufacturer's full line.
- G. Colors: As indicated on drawings.
 1. Extend colors to surface edges; colors may change at any edge as directed by Architect.

2.03 PAINT SYSTEMS - EXTERIOR

- A. Exterior Surfaces to be Painted, Unless Otherwise Indicated: Including cement board, primed wood, and primed metal.
 - 1. One or two coats to cover and one coat primer.
 - 2. Top Coat(s): Exterior Latex.
 - 3. Top Coat Sheen:
 - a. Flat: MPI gloss level 1; use this sheen at all locations.
 - b. Semi-Gloss: MPI gloss level 5; use this sheen at trim.
 - 4. Primer: As recommended by top coat manufacturer for specific substrate.
- B. Masonry/Concrete and CMU Opaque, Latex, 3 Coat:
 - 1. One coat of latex primer sealer.
 - 2. Low-Sheen-Elastomeric: Two coats of latex-acrylic.
 - 3. Premium Flat: Two coats of latex-acrylic enamel.
- C. Ferrous Metals, Unprimed, Latex, 3 Coat:
 - 1. One coat of latex primer.
- D. Ferrous Metals, Primed, Latex, 2 Coat:
 - 1. Touch-up with rust-inhibitive primer recommended by top coat manufacturer.
- E. Ferrous Metals, Unprimed, High-Performance, 3 Coat:
 - 1. Pre-Treatment: As recommended by manufacturer
 - 2. One coat galvanize primer.
 - 3. Gloss: Two coats of alkyd enamel.

2.04 PRIMERS

- A. Primers: Provide the following unless other primer is required or recommended by manufacturer of top coats.
 - 1. Alkali Resistant Water Based Primer.
 - 2. Anti-Corrosive Alkyd Primer for Metal.
 - 3. Interior/Exterior Quick Dry Alkyd Primer for Metal.
 - 4. Alkyd Primer for Galvanized Metal.
 - 5. Water Based Primer for Galvanized Metal.
 - 6. Rust-Inhibitive Water Based Primer.
 - 7. Interior/Exterior Quick Dry Primer for Aluminum.
 - 8. Stain Blocking Primer.

2.05 ACCESSORY MATERIALS

- A. Accessory Materials: Provide primers, sealers, cleaning agents, cleaning cloths, sanding materials, and clean-up materials as required for final completion of painted surfaces.
- B. Patching Material: Latex filler.

- C. Fastener Head Cover Material: Latex filler.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Do not begin application of paints and finishes until substrates have been properly prepared.
- B. Verify that surfaces are ready to receive work as instructed by the product manufacturer.
- C. Examine surfaces scheduled to be finished prior to commencement of work. Report any condition that may potentially effect proper application.
- D. Test shop-applied primer for compatibility with subsequent cover materials.
- E. Measure moisture content of surfaces using an electronic moisture meter. Do not apply finishes unless moisture content of surfaces are below the following maximums:
 - 1. Fiber Cement Siding: 12 percent.
 - 2. Masonry, Concrete, and Concrete Masonry Units: 12 percent.
 - 3. Exterior Wood: 15 percent, measured in accordance with ASTM D4442.

3.02 PREPARATION

- A. Clean surfaces thoroughly and correct defects prior to application.
- B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.
- C. Remove or repair existing paints or finishes that exhibit surface defects.
- D. Remove or mask surface appurtenances, including electrical plates, hardware, light fixture trim, escutcheons, and fittings, prior to preparing surfaces for finishing.
- E. Seal surfaces that might cause bleed through or staining of topcoat.
- F. Remove mildew from impervious surfaces by scrubbing with solution of tetra-sodium phosphate and bleach. Rinse with clean water and allow surface to dry.
- G. Concrete:
 - 1. Remove release agents, curing compounds, efflorescence, and chalk. Do not coat surfaces if moisture content or alkalinity of surfaces to be coated exceeds that permitted in manufacturer's written instructions.
 - 2. Clean surfaces with pressurized water. Use pressure range of 1,500 to 4,000 psi at 6 to 12 inches. Allow to dry.
 - 3. Clean concrete according to ASTM D4258. Allow to dry.
 - 4. Prepare surface as recommended by top coat manufacturer and according to SSPC-SP 13.
- H. Fiber Cement Siding: Remove dirt, dust and other foreign matter with a stiff fiber brush. Do not coat surfaces if moisture content or alkalinity of surfaces to be coated exceeds that permitted in manufacturer's written instructions.
- I. Galvanized Surfaces:
 - 1. Remove surface contamination and oils and wash with solvent according to SSPC-SP 1.
 - 2. Prepare surface according to SSPC-SP 2.

- J. Ferrous Metal:
 - 1. Solvent clean according to SSPC-SP 1.
 - 2. Shop-Primed Surfaces: Sand and scrape to remove loose primer and rust. Feather edges to make touch-up patches inconspicuous. Clean surfaces with solvent. Prime bare steel surfaces. Re-prime entire shop-primed item.
 - 3. Remove rust, loose mill scale, and other foreign substances using methods recommended in writing by paint manufacturer and blast cleaning according to SSPC-SP 6 Commercial Blast Cleaning. Protect from corrosion until coated.
- K. Exterior Wood Surfaces to Receive Opaque Finish: Remove dust, grit, and foreign matter. Seal knots, pitch streaks, and sappy sections. Fill nail holes with tinted exterior calking compound after prime coat has been applied. Back prime concealed surfaces before installation.
- L. Metal Doors to be Painted: Prime metal door top and bottom edge surfaces.

3.03 APPLICATION

- A. Remove unfinished louvers, grilles, covers, and access panels on mechanical and electrical components and paint separately.
- B. Exterior Wood to Receive Opaque Finish: If final painting must be delayed more than 2 weeks after installation of woodwork, apply primer within 2 weeks and final coating within 4 weeks.
- C. Apply products in accordance with manufacturer's written instructions.
- D. Where adjacent sealant is to be painted, do not apply finish coats until sealant is applied.
- E. Do not apply finishes to surfaces that are not dry. Allow applied coats to dry before next coat is applied.
- F. Apply each coat to uniform appearance.
- G. Dark Colors and Deep Clear Colors: Regardless of number of coats specified, apply additional coats until complete hide is achieved.
- H. Sand metal surfaces lightly between coats to achieve required finish.
- I. Vacuum clean surfaces of loose particles. Use tack cloth to remove dust and particles just prior to applying next coat.
- J. Reinstall electrical cover plates, hardware, light fixture trim, escutcheons, and fittings removed prior to finishing.

3.04 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements, for general requirements for field inspection.

3.05 CLEANING

- A. Collect waste material that could constitute a fire hazard, place in closed metal containers, and remove daily from site.

3.06 PROTECTION

- A. Protect finishes until completion of project.

FOR REFERENCE ONLY

B. Touch-up damaged finishes after Substantial Completion.

END OF SECTION

FOR REFERENCE ONLY

SECTION 09 91 23 INTERIOR PAINTING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Surface preparation.
- B. Field application of paints.
- C. Scope: Finish interior surfaces exposed to view, unless fully factory-finished and unless otherwise indicated.
 - 1. Mechanical and Electrical:
 - a. In finished areas, paint insulated and exposed pipes, conduit, boxes, insulated and exposed ducts, hangers, brackets, collars and supports, mechanical equipment, and electrical equipment, unless otherwise indicated.
- D. Do Not Paint or Finish the Following Items:
 - 1. Items factory-finished unless otherwise indicated; materials and products having factory-applied primers are not considered factory finished.
 - 2. Items indicated to receive other finishes.
 - 3. Items indicated to remain unfinished.
 - 4. Fire rating labels, equipment serial number and capacity labels, bar code labels, and operating parts of equipment.
 - 5. Floors, unless specifically indicated.
 - 6. Glass.
 - 7. Concealed pipes, ducts, and conduits.

1.02 DEFINITIONS

- A. Comply with ASTM D16 for interpretation of terms used in this section.

1.03 REFERENCE STANDARDS

- A. 40 CFR 59, Subpart D - National Volatile Organic Compound Emission Standards for Architectural Coatings; U.S. Environmental Protection Agency.
- B. ASTM D16 - Standard Terminology for Paint, Related Coatings, Materials, and Applications.
- C. ASTM D4442 - Standard Test Methods for Direct Moisture Content Measurement of Wood and Wood-Based Materials.
- D. CARB (SCM) - Suggested Control Measure for Architectural Coatings; California Air Resources Board.
- E. MPI (APSM) - Master Painters Institute Architectural Painting Specification Manual.
- F. SCAQMD 1113 - Architectural Coatings.
- G. SSPC-SP 1 - Solvent Cleaning.

- H. SSPC-SP 2 - Hand Tool Cleaning.
- I. SSPC-SP 6 - Commercial Blast Cleaning.
- J. SSPC-SP 13 - Surface Preparation of Concrete.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide complete list of products to be used, with the following information for each:
 - 1. Manufacturer's name, product name and/or catalog number, and general product category (e.g., "alkyd enamel").
 - 2. MPI product number (e.g., MPI #47).
 - 3. Cross-reference to specified paint system products to be used in project; include description of each system.
 - 4. Manufacturer's installation instructions.
 - 5. If proposal of substitutions is allowed under submittal procedures, explanation of substitutions proposed.
- C. Samples: Submit three paper "draw down" samples, 8-1/2 by 11 inches in size, illustrating range of colors available for each finishing product specified.
 - 1. Where sheen is specified, submit samples in only that sheen.
 - 2. Where sheen is not specified, discuss sheen options with Architect before preparing samples, to eliminate sheens not required.
- D. Certification: By manufacturer that paints and finishes comply with VOC limits specified.
- E. Manufacturer's Instructions: Indicate special surface preparation procedures.
- F. Maintenance Data: Submit data including finish schedule showing where each product/color/finish was used, product technical data sheets, material safety data sheets (MSDS), care and cleaning instructions, touch-up procedures, repair of painted and finished surfaces, and color samples of each color and finish used.
- G. Maintenance Materials: Furnish the following for District's use in maintenance of project.
 - 1. See Section 01 60 00 - Product Requirements, for additional provisions.
 - 2. Extra Paint and Finish Materials: 1 gal of each color; from the same product run, store where directed.
 - 3. Label each container with color in addition to the manufacturer's label.

1.05 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing the products specified, with minimum three years documented experience.
- B. Applicator Qualifications: Company specializing in performing the type of work specified with minimum three years experience.

1.06 DELIVERY, STORAGE, AND HANDLING

- A. Deliver products to site in sealed and labeled containers; inspect to verify acceptability.

FOR REFERENCE ONLY

- B. Container Label: Include manufacturer's name, type of paint, brand name, lot number, brand code, coverage, surface preparation, drying time, cleanup requirements, color designation, and instructions for mixing and reducing.
- C. Paint Materials: Store at minimum ambient temperature of 45 degrees F and a maximum of 90 degrees F, in ventilated area, and as required by manufacturer's instructions.

1.07 FIELD CONDITIONS

- A. Do not apply materials when surface and ambient temperatures are outside the temperature ranges required by the paint product manufacturer.
- B. Follow manufacturer's recommended procedures for producing best results, including testing of substrates, moisture in substrates, and humidity and temperature limitations.
- C. Do not apply materials when relative humidity exceeds 85 percent, at temperatures less than 5 degrees F above the dew point, or to damp or wet surfaces.
- D. Minimum Application Temperatures for Paints: 50 degrees F for interiors unless required otherwise by manufacturer's instructions.
- E. Provide lighting level of 80 fc measured mid-height at substrate surface.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Provide paints and finishes from the same manufacturer to the greatest extent possible.
 - 1. If a single manufacturer cannot provide specified products; minor exceptions will be permitted provided approval by Architect is obtained using the specified procedures for substitutions.
 - 2. Substitution of other products by the same manufacturer is preferred over substitution of products by a different manufacturer.
- B. Paints:
 - 1. Behr Process Corporation: www.behr.com/#sle.
 - a. Local representative Joe Esquer, 657.212.0111.
 - 2. Dunn-Edwards Corporation: www.dunnedwards.com,
 - a. Local representative Wanda Barragan 909.261.1289.
 - 3. PPG Paints: www.ppgpaints.com/#sle.
 - a. Local representative Susan L. Giampietro 949.410.2452.
 - 4. Sherwin-Williams Company: www.sherwin-williams.com/#sle.
 - a. Local representative John Dumesnil 619.665.9341.
 - 5. Vista Paint Corporation: www.vistapaint.com/#sle.
 - a. Local representative Mark Brower 323.397.9000.
- C. Primer Sealers: Same manufacturer as top coats.
- D. Substitutions: See Section 01 60 00 - Product Requirements.

2.02 PAINTS AND FINISHES - GENERAL

- A. Paints and Finishes: Ready-mixed, unless intended to be a field-catalyzed paint.
 - 1. Provide paints and finishes of a soft paste consistency, capable of being readily and uniformly dispersed to a homogeneous coating, with good flow and brushing properties, and capable of drying or curing free of streaks or sags.
 - 2. Provide materials that are compatible with one another and the substrates indicated under conditions of service and application, as demonstrated by manufacturer based on testing and field experience.
 - 3. For opaque finishes, tint each coat including primer coat and intermediate coats, one-half shade lighter than succeeding coat, with final finish coat as base color.
 - 4. Supply each paint material in quantity required to complete entire project's work from a single production run.
 - 5. Do not reduce, thin, or dilute paint or finishes or add materials unless such procedure is specifically described in manufacturer's product instructions.
- B. No intentionally added cadmium.
- C. Volatile Organic Compound (VOC) Content:
 - 1. Provide paints and finishes that comply with the most stringent requirements specified in the following:
 - a. 40 CFR 59, Subpart D--National Volatile Organic Compound Emission Standards for Architectural Coatings.
 - b. SCAQMD 1113 Rule.
 - c. CARB (SCM).
 - d. Ozone Transport Commission (OTC) Model Rule, Architectural, Industrial, and Maintenance Coatings; www.otcair.org; specifically:
 - 1) Opaque, Flat: 50 g/L, maximum.
 - 2) Opaque, Nonflat: 150 g/L, maximum.
 - 3) Opaque, High Gloss: 250 g/L, maximum.
 - e. Architectural coatings VOC limits of California.
 - 2. Determination of VOC Content: Testing and calculation in accordance with 40 CFR 59, Subpart D (EPA Method 24), exclusive of colorants added to a tint base and water added at project site; or other method acceptable to authorities having jurisdiction.
- D. Flammability: Comply with applicable code for surface burning characteristics.
- E. Sheens: Provide the sheens specified; where sheen is not specified, sheen will be selected later by Architect from the manufacturer's full line.
- F. Colors: As indicated on drawings.
 - 1. Extend colors to surface edges; colors may change at any edge as directed by Architect.
 - 2. In finished areas, finish pipes, ducts, conduit, and equipment the same color as the wall/ceiling under which they are mounted.

2.03 PAINT SYSTEMS - INTERIOR

- A. Paint I-OP - Interior Surfaces to be Painted, Unless Otherwise Indicated: Including gypsum board, concrete, concrete masonry units, brick, wood, plaster, uncoated steel, shop primed steel, galvanized steel, and aluminum.
 - 1. Two top coats and one coat primer.
 - 2. Top Coat(s): Interior Latex.
 - 3. Top Coat Sheen:
 - a. Flat: MPI gloss level 1; use this sheen for ceilings and other overhead surfaces.
 - b. Eggshell: MPI gloss level 3; use this sheen at all locations.
 - c. Semi-Gloss: MPI gloss level 5; use this sheen at all locations.
- B. Medium Duty Door/Trim: For surfaces subject to frequent contact by occupants, including metals and wood:
 - 1. Medium duty applications include doors, door frames, railings, handrails, and guardrails.
 - 2. Two top coats and one coat primer.
- C. Medium Duty Vertical and Overhead: Including gypsum board, concrete, uncoated steel, shop primed steel, galvanized steel, and aluminum.
 - 1. Two top coats and one coat primer.
- D. Dry Fall: Metals; exposed structure and overhead-mounted services in utilitarian spaces, including shop primed steel deck, structural steel, metal fabrications, galvanized ducts, galvanized conduit, and galvanized piping.
 - 1. Shop primer by others.
 - 2. One top coat.
 - 3. Top Coat: Latex Dry Fall.
- E. Ferrous Metals, Unprimed, Latex, 3 Coat:
 - 1. One coat of latex primer.
 - 2. Semi-gloss: Two coats of latex enamel.
- F. Ferrous Metals, Primed, Latex, 2 Coat:
 - 1. Touch-up with latex primer.
 - 2. Semi-gloss: Two coats of latex enamel.
- G. Galvanized Metals, Latex, 3 Coat:
 - 1. One coat galvanize primer.
 - 2. Semi-gloss: Two coats of latex enamel.
- H. Aluminum, Unprimed, Latex, 3 Coat:
 - 1. One coat etching primer.
 - 2. Semi-gloss: Two coats of latex enamel.

2.04 PRIMERS

- A. Primers: Provide the following unless other primer is required or recommended by manufacturer of top coats.
 - 1. Interior Institutional Low Odor/VOC Primer Sealer.
 - 2. Interior/Exterior Latex Block Filler.
 - 3. Interior Latex Primer Sealer.
 - 4. Interior Drywall Primer Sealer.
 - 5. Anti-Corrosive Alkyd Primer for Metal.
 - 6. Interior Rust-Inhibitive Water Based Primer.
 - 7. Interior Water Based Primer for Galvanized Metal.
 - 8. Interior/Exterior Quick Dry Primer for Aluminum.
 - 9. Interior Alkyd Enamel Undercoat.
 - 10. Stain Blocking Primer.
 - 11. Stain Blocking Primer, Water Based.

2.05 ACCESSORY MATERIALS

- A. Accessory Materials: Provide primers, sealers, cleaning agents, cleaning cloths, sanding materials, and clean-up materials as required for final completion of painted surfaces.
- B. Patching Material: Latex filler.
- C. Fastener Head Cover Material: Latex filler.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Do not begin application of paints and finishes until substrates have been adequately prepared.
- B. Verify that surfaces are ready to receive work as instructed by the product manufacturer.
- C. Examine surfaces scheduled to be finished prior to commencement of work. Report any condition that may potentially affect proper application.
- D. Test shop-applied primer for compatibility with subsequent cover materials.
- E. Measure moisture content of surfaces using an electronic moisture meter. Do not apply finishes unless moisture content of surfaces is below the following maximums:
 - 1. Gypsum Wallboard: 12 percent.
 - 2. Plaster and Stucco: 12 percent.
 - 3. Masonry, Concrete, and Concrete Masonry Units: 12 percent.
 - 4. Interior Wood: 15 percent, measured in accordance with ASTM D4442.

3.02 PREPARATION

- A. Clean surfaces thoroughly and correct defects prior to application.

FOR REFERENCE ONLY

- B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.
- C. Remove or mask surface appurtenances, including electrical plates, hardware, light fixture trim, escutcheons, and fittings, prior to preparing surfaces or finishing.
- D. Seal surfaces that might cause bleed through or staining of topcoat.
- E. Concrete:
 - 1. Remove release agents, curing compounds, efflorescence, and chalk. Do not coat surfaces if moisture content or alkalinity of surfaces to be coated exceeds that permitted in manufacturer's written instructions.
 - 2. Prepare surface as recommended by top coat manufacturer and according to SSPC-SP 13.
- F. Masonry:
 - 1. Remove efflorescence and chalk. Do not coat surfaces if moisture content, alkalinity of surfaces, or if alkalinity of mortar joints exceed that permitted in manufacturer's written instructions. Allow to dry.
 - 2. Prepare surface as recommended by top coat manufacturer.
- G. Gypsum Board: Fill minor defects with filler compound. Spot prime defects after repair.
- H. Plaster: Fill hairline cracks, small holes, and imperfections with latex patching plaster. Make smooth and flush with adjacent surfaces. Wash and neutralize high-alkali surfaces.
- I. Aluminum: Remove surface contamination and oils and wash with solvent according to SSPC-SP 1.
- J. Galvanized Surfaces:
 - 1. Remove surface contamination and oils and wash with solvent according to SSPC-SP 1.
 - 2. Prepare surface according to SSPC-SP 2.
- K. Ferrous Metal:
 - 1. Solvent clean according to SSPC-SP 1.
 - 2. Shop-Primed Surfaces: Sand and scrape to remove loose primer and rust. Feather edges to make touch-up patches inconspicuous. Clean surfaces with solvent. Prime bare steel surfaces. Re-prime entire shop-primed item.
 - 3. Remove rust, loose mill scale, and other foreign substances using methods recommended in writing by paint manufacturer and blast cleaning according to SSPC-SP 6 Commercial Blast Cleaning. Protect from corrosion until coated.
- L. Wood Surfaces to Receive Opaque Finish: Wipe off dust and grit prior to priming. Seal knots, pitch streaks, and sappy sections with sealer. Fill nail holes and cracks after primer has dried; sand between coats. Back prime concealed surfaces before installation.
- M. Wood Doors to be Field-Finished: Seal wood door top and bottom edge surfaces with clear sealer.
- N. Metal Doors to be Painted: Prime metal door top and bottom edge surfaces.

3.03 APPLICATION

- A. Remove unfinished louvers, grilles, covers, and access panels on mechanical and electrical components and paint separately.

FOR REFERENCE ONLY

- B. Apply products in accordance with manufacturer's written instructions and recommendations in "MPI Architectural Painting Specification Manual".
- C. Where adjacent sealant is to be painted, do not apply finish coats until sealant is applied.
- D. Do not apply finishes to surfaces that are not dry. Allow applied coats to dry before next coat is applied.
- E. Apply each coat to uniform appearance in thicknesses specified by manufacturer.
- F. Dark Colors and Deep Clear Colors: Regardless of number of coats specified, apply as many coats as necessary for complete hide.
- G. Sand wood and metal surfaces lightly between coats to achieve required finish.
- H. Vacuum clean surfaces of loose particles. Use tack cloth to remove dust and particles just prior to applying next coat.
- I. Reinstall electrical cover plates, hardware, light fixture trim, escutcheons, and fittings removed prior to finishing.

3.04 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements, for general requirements for field inspection.
- B. District will provide field inspection.

3.05 CLEANING

- A. Collect waste material that could constitute a fire hazard, place in closed metal containers, and remove daily from site.

3.06 PROTECTION

- A. Protect finishes until completion of project.
- B. Touch-up damaged finishes after Substantial Completion.

END OF SECTION

SECTION 09 96 00 HIGH-PERFORMANCE COATINGS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. High performance coatings.
 - 1. Exterior Steel: exterior steel, hollow metal doors and frames, metal copings/flashings (not prefinished), and equipment screens,
- B. Surface preparation.

1.02 RELATED REQUIREMENTS

- A. Section 01 61 16 - Volatile Organic Compound (VOC) Content Restrictions.
- B. Section 09 91 13 - Exterior Painting.
- C. Section 09 91 23 - Interior Painting: Requirements for mechanical and electrical equipment surfaces.

1.03 REFERENCE STANDARDS

- A. 40 CFR 59, Subpart D - National Volatile Organic Compound Emission Standards for Architectural Coatings; U.S. Environmental Protection Agency.
- B. ASTM D2486 - Standard Test Methods for Scrub Resistance of Wall Paints.
- C. ASTM D4587 - Standard Practice for Fluorescent UV-Condensation Exposures of Paint and Related Coatings.
- D. CARB (SCM) - Suggested Control Measure for Architectural Coatings; California Air Resources Board.
- E. MPI (APL) - Master Painters Institute Approved Products List; Master Painters and Decorators Association.
- F. MPI (APSM) - Master Painters Institute Architectural Painting Specification Manual.
- G. SCAQMD 1113 - Architectural Coatings.
- H. SSPC-SP 1 - Solvent Cleaning.
- I. SSPC-SP 2 - Hand Tool Cleaning.
- J. SSPC-SP 6/NACE No.3 - Commercial Blast Cleaning.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Preinstallation Meeting: Conduct a preinstallation meeting at least one week prior to the start of the work of this section; require attendance by all affected installers.
 - 1. Require attendance of parties directly affecting work of this section, including Contractor, Architect, applicator, and manufacturer's representative. Review the following:
 - a. Environmental requirements.

- b. Protection of surfaces not scheduled to be coated.
- c. Surface preparation.
- d. Application.
- e. Repair.
- f. Field quality control.
- g. Cleaning.
- h. Protection of coating systems.
- i. One-year inspection.
- j. Coordination with other work.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide complete list of all products to be used, with the following information for each:
 - 1. Manufacturer's name, product name and/or catalog number, and general product category (e.g. "alkyd enamel").
 - 2. MPI product number (e.g. MPI #47).
 - 3. Cross-reference to specified coating system(s) product is to be used in; include description of each system.
 - 4. Manufacturer's installation instructions.
 - 5. If proposal of substitutions is allowed under submittal procedures, explanation of all substitutions proposed.
- C. Samples: Submit two samples 8 by 8 inch in size illustrating colors available for selection.
- D. Manufacturer's Certificate: Certify that high-performance coatings comply with VOC limits specified.
- E. Manufacturer's Certificate: Certify that products meet or exceed specified requirements.
- F. Manufacturer's Installation Instructions: Indicate special procedures and perimeter conditions requiring special attention.
- G. Maintenance Data: Include cleaning procedures and repair and patching techniques.
 - 1. Submit data including finish schedule showing where each product/color/finish was used, product technical data sheets, material safety data sheets (MSDS), care and cleaning instructions, touch-up procedures, repair of painted and coated surfaces, and color samples of each color and finish used.
- H. Maintenance Materials: Furnish the following for District's use in maintenance of project.
 - 1. See Section 01 60 00 - Product Requirements, for additional provisions.
 - 2. Extra Coating Materials: 1 gallon of each type and color.
 - 3. Label each container with manufacturer's name, product number, color number, and room names and numbers where used.

1.06 QUALITY ASSURANCE

- A. Maintain one copy of each referenced document that applies to application on site.
- B. Manufacturer Qualifications: Company specializing in manufacturing the Products specified in this section with minimum three years documented experience.
- C. Applicator Qualifications: Company specializing in performing the work of this section approved by manufacturer.

1.07 MOCK-UPS

- A. See Section 01 40 00 - Quality Requirements for general requirements for mock-ups.
- B. Locate where directed.
- C. Mock-up may remain as part of the work.

1.08 DELIVERY, STORAGE, AND HANDLING

- A. Deliver products to site in sealed and labeled containers; inspect to verify acceptability.
- B. Container Label: Include manufacturer's name, type of coating, brand name, lot number, brand code, coverage, surface preparation, drying time, cleanup requirements, color designation, and instructions for mixing and reducing.
- C. Coating Materials: Store at minimum ambient temperature of 45 degrees F and a maximum of 90 degrees F, in ventilated area, and as required by manufacturer's instructions.

1.09 FIELD CONDITIONS

- A. Follow manufacturer's recommended procedures for producing best results, including testing of substrates, moisture in substrates, and humidity and temperature limitations.
- B. Do not apply exterior coatings during rain or snow, or when relative humidity is outside the humidity ranges required by the coating product manufacturer.
- C. Do not install materials when temperature is below 55 degrees F or above 90 degrees F.
- D. Maintain this temperature range, 24 hours before, during, and 72 hours after installation of coating.
- E. Provide lighting level of 80 ft candles measured mid-height at substrate surface.
- F. Restrict traffic from area where coating is being applied or is curing.

1.10 WARRANTY

- A. See Section 01 78 00 - Closeout Submittals for additional warranty requirements.
- B. Correct defective Work within a five year period after Date of Substantial Completion.
- C. Warranty: Include coverage for bond to substrate.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Provide high performance coating products from the same manufacturer to the greatest extent possible.

FOR REFERENCE ONLY

1. In the event that a single manufacturer cannot provide specified products, minor exceptions will be permitted provided approval by Architect is obtained using the specified procedures for substitutions.
 2. Substitution of other products by the same manufacturer is preferred over substitution of products by a different manufacturer.
- B. High-Performance Coatings:
1. Behr Paint Corp.: www.behr.com.
 2. Carboline: www.carboline.com.
 3. Dunn Edwards : www.dunnedwards.com.
 4. PPG Paints: www.ppgpaints.com/#sle.
 5. Sherwin-Williams Company: www.protective.sherwin-williams.com/industries/#sle.
 6. Tnemec Company, Inc: www.tnemec.com/#sle.
 7. Substitutions: Section 01 60 00 - Product Requirements.

2.02 HIGH-PERFORMANCE COATINGS

- A. Provide coating systems that meet the following minimum performance criteria, unless more stringent criteria are specified:
1. Surface Burning Characteristics: Flame spread/Smoke developed index of 0/0, maximum, when tested in accordance with ASTM E84.
 2. Lead Content: None.
 3. No intentionally added cadmium.
 4. Scrubbability: Excellent, when tested in accordance with ASTM D2486.
 5. Gloss and Color Retention: Excellent, when tested in accordance with ASTM D4587.

2.03 TOP COAT MATERIALS

- A. Coatings - General: Provide complete multi-coat systems formulated and recommended by manufacturer for the applications indicated, in the thicknesses indicated; number of coats specified does not include primer or filler coat.
1. Lead Content: Not greater than 0.06 percent by weight of total nonvolatile content.
 2. Chromium Content, as Hexavalent Chromium, Zinc Chromate, or Strontium Chromate: None.
 3. Volatile Organic Compound (VOC) Content: See Section 01 61 16.
 4. Volatile Organic Compound (VOC) Content:
 - a. Provide coatings that comply with the most stringent requirements specified in the following:
 - 1) 40 CFR 59, Subpart D--National Volatile Organic Compound Emission Standards for Architectural Coatings.
 - 2) SCAQMD 1113 Rule.
 - 3) CARB (SCM).
 - 4) Architectural coatings VOC limits of California.

FOR REFERENCE ONLY

- b. Determination of VOC Content: Testing and calculation in accordance with 40 CFR 59, Subpart D (EPA Method 24), exclusive of colorants added to a tint base and water added at project site; or other method acceptable to authorities having jurisdiction.
5. Colors: As indicated.
- B. Urethane Coating:
 1. Number of Coats: Two.
 2. Product Characteristics:
 - a. Comply with the performance requirements specified above for moderate exposure.
 3. Top Coat(s): Acrylic Urethane, Water Based, Two-Component.
 - a. Sheen: High Gloss.
 - b. Products:
 - 1) Sherwin-Williams; Pro Industrial Waterbased Acrolon 100: www.protective.sherwin-williams.com/#sle.
 - 2) Dunn Edwards; Endura-Coat ENCT60: www.dunnedwards.com.
 - 3) Benjamin Moore; Ultra Spec HP D.T.M. Acrylic Gloss HP28: www.benjaminmoore.com.
 - 4) Tnemec Company, Inc; Series 1080 Endurashield: www.tnemec.com/#sle.
 - 5) Substitutions: Section 01 60 00 - Product Requirements.
 4. Primer: As recommended by coating manufacturer for specific substrate.

2.04 PRIMERS

- A. Primers: Provide the following unless other primer is required or recommended by coating manufacturer.
 1. Rust-Inhibitive, Water Based; MPI #107.
 - a. Products:
 - 1) Benjamin Moore; Ultra Spec HP Acrylic Metal Primer HP04: www.benjaminmoore.com.
 - 2) Dunn Edwards; EnduraPrime ENPR00: www.dunnedwards.com.
 - 3) Sherwin-Williams; Pro Industrial Pro-Cryl Universal Primer: www.protective.sherwin-williams.com/#sle. (MPI #107)
 - 4) Tnemec Company, Inc; Series 115 Uni-Bond DF: www.tnemec.com/#sle.
 - 5) Substitutions: Section 01 60 00 - Product Requirements.

2.05 ACCESSORY MATERIALS

- A. Accessory Materials: Provide primers, sealers, cleaning agents, cleaning cloths, sanding materials, and clean-up materials as required for final completion of coated surfaces.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify existing conditions before starting work.
- B. Do not begin application of coatings until substrates have been properly prepared.
- C. Verify that substrate surfaces are ready to receive work as instructed by the coating manufacturer. Obtain and follow manufacturer's instructions for examination and testing of substrates.
- D. Examine surfaces scheduled to be finished prior to commencement of work. Report any condition that may potentially affect proper application.
- E. If substrate preparation is the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.
- F. Test shop-applied primer for compatibility with subsequent cover materials.
- G. Proceed with coating application only after unacceptable conditions have been corrected.
 - 1. Commencing coating application constitutes Contractor's acceptance of substrates and conditions.

3.02 PREPARATION

- A. Clean surfaces of loose foreign matter.
- B. Remove substances that would bleed through finished coatings. If unremovable, seal surface with shellac.
- C. Remove finish hardware, fixture covers, and accessories and store.
- D. Galvanized Surfaces:
 - 1. Remove surface contamination and oils and wash with solvent according to SSPC-SP 1.
 - 2. Prepare surface according to SSPC-SP 2.
- E. Ferrous Metal:
 - 1. Solvent clean according to SSPC-SP 1.
 - 2. Shop-Primed Surfaces: Sand and scrape to remove loose primer and rust. Feather edges to make touch-up patches inconspicuous. Clean surfaces with solvent. Prime bare steel surfaces. Re-prime entire shop-primed item.
 - 3. Remove rust, loose mill scale, and other foreign substances using methods recommended in writing by paint manufacturer and blast cleaning in accordance with SSPC-SP 6/NACE No.3, and protect from corrosion until coated.

3.03 PRIMING

- A. Apply primer to all surfaces, unless specifically not required by coating manufacturer. Apply in accordance with coating manufacturer's instructions.

3.04 COATING APPLICATION

- A. Apply coatings in accordance with manufacturer's written instructions, to thicknesses specified and recommendations in MPI - Architectural Painting and Specification Manual.

- B. Apply in uniform thickness coats, without runs, drips, pinholes, brush marks, or variations in color, texture, or finish. Finish edges, crevices, corners, and other changes in dimension with full coating thickness.

3.05 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements for general requirements for field inspection.
- B. District will provide field inspection.
- C. Dry Film Thickness Testing: District will engage the services of a qualified testing and inspecting agency to inspect and test coatings for dry film thickness.

3.06 CLEANING

- A. Collect waste material that could constitute a fire hazard, place in closed metal containers, and remove daily from site.
- B. Clean surfaces immediately of overspray, splatter, and excess material.
- C. After coating has cured, clean and replace finish hardware, fixtures, and fittings previously removed.

3.07 PROTECTION

- A. Protect finished work from damage.

END OF SECTION

SECTION 09 96 23 GRAFFITI-RESISTANT COATINGS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Graffiti-Resistant Coatings applied to exterior and interior masonry, plaster/stucco, and concrete surfaces.

1.02 RELATED REQUIREMENTS

- A. Section 01 61 16 - Volatile Organic Compound (VOC) Content Restrictions.
- B. Section 03 30 00 - Cast-in-Place Concrete.
- C. Section 04 20 00 - Unit Masonry.
- D. Section 07 19 00 - Water Repellents: Coating applied under graffiti-resistant coating.
- E. Section 07 92 00 - Joint Sealants.
- F. Section 09 24 00 - Cement Plastering.

1.03 REFERENCE STANDARDS

- A. ASTM C140/C140M - Standard Test Methods for Sampling and Testing Concrete Masonry Units and Related Units.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Preinstallation Meeting: Convene a meeting at least one week prior to starting work; require attendance of affected installers; invite Architect and District.

1.05 SUBMITTALS

- A. See Section 01 3000 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide product description.
- C. Manufacturer's Installation Instructions: Indicate special procedures and conditions requiring special attention; cautionary procedures required during application.
- D. Manufacturer's Field Reports: Report whether manufacturer's "best practices" are being followed; if not, state corrective recommendations. Email report to Architect the same day as inspection occurs; mail report on manufacturer's letterhead to Architect within 2 days after inspection.
- E. Maintenance Materials: Furnish the following for District's use in maintenance of project.
 - 1. See Section 01 6000 - Product Requirements, for additional provisions.
 - 2. Extra Graffiti-Resistant Coating Material: Five gallons of the type installed.
 - 3. Cleaner: Provide 5 one gallon containers of manufacturer's specified cleaner only for applied areas under 5,000 square feet, and 10 one gallon containers for applied areas over 5,000 square feet.

1.06 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing the Products specified in this section with minimum ten years documented experience.
- B. Installer Qualifications: Company specializing in performing the work of this section approved by manufacturer.
- C. District reserves the right to provide continuous independent inspection of surface preparation and application of graffiti-resistant coating.

1.07 MOCK-UP

- A. Prepare a representative surface 36 by 36 inch in size using specified materials and preparation and application methods on surfaces identical to those to be coated; approved mock-up constitutes standard for workmanship.
 - 1. Allow sample area to cure and attack with indelible makers and spray paint.
 - 2. Installer to notify Architect, Contractor, Owner Representative, and manufacturer 72 hours prior to a cleaning demonstration.
- B. For proposed substitutions, prepare side-by-side mock-ups of specified and substitute products.
- C. Locate where directed.
- D. Mock-up may remain as part of the Work.

1.08 DELIVERY, STORAGE, AND HANDLING

- A. Deliver products to project site in unopened packaging until ready for installation.
 - 1. Container labeling to include manufacturer's name, type of coating brand name, brand code, coverage, surface preparation, cure time, cleanup, and instructions for mixing.
- B. Store components under a dry covered area and elevated above grade.
- C. Store materials in well ventilated area, no less than 45°F and no more than 90°F, unless otherwise allowed by manufacturer.

1.09 FIELD CONDITIONS

- A. Protect liquid materials from freezing.
- B. Do not apply graffiti-resistant coating when ambient temperature is lower than 50 degrees F or higher than 90 degrees F.
- C. Do not apply graffiti-resistant coatings when wind velocity is higher than 10 mph.
- D. Do not apply coatings during rain, or if rain is imminent within 48 hours.

1.10 WARRANTY

- A. See Section 01 7800 - Closeout Submittals, for additional warranty requirements.
- B. Correct defective Work within a one year period after Date of Substantial Completion.
- C. Provide two year manufacturer warranty for labor.
- D. Provide ten year manufacturer warranty for materials.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Acrylic Graffiti-Resistant Coatings (Non-Sacrificial):
 - 1. MonoPole Inc.; Permashield Base (Sealer) with Premium 5600 (low-Luster): www.monopoleinc.com.
 - 2. Coval Molecular Coatings; Coval Anti-Graffiti Coat: covalmolecular.com.
 - 3. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Fluorosilane Graffiti-Resistant Coatings:
 - 1. Chemical Products Industries, Inc.; StainGuard-WB: www.chemicalproductsokc.com.
 - 2. Evonik Degussa Corporation; Protectosil® Anti-Graffiti: www.protectosil.com.
 - 3. Substitutions: See Section 01 60 00 - Product Requirements.
- C. Silane/Siloxane Graffiti-Resistant Coatings:
 - 1. Sherwin-Williams Company; Anti-Graffiti Coating: www.sherwin-williams.com.
 - 2. PROSOCO, Inc.; Blok-Guard® & Grafti Control Ultra 15: www.prosoco.com.
 - 3. RainGuard Products Co.; VandlGuard Ten (2 coats) and VandlGuard Finish Coat, Non-Sacrificial; www.rainguard.com.
 - 4. SEI Chemical; SCS-002SP Sealer and GPA-300 Graffiti Proofer (Non-Sacrificial): www.seichemical.com.
 - 5. Substitutions: See Section 01 60 00 - Product Requirements.

2.02 MATERIALS

- A. Exact product to be used will be determined by side-by-side mock-up testing of at least 3 products meeting specified requirements; prepare mock ups as specified above; submit cost breakdown for each product used in mock-up, including both unit and total costs.
- B. Graffiti-Resistant Coating: Non-sacrificial, non-glossy, colorless, penetrating, water-vapor-permeable, non-yellowing, that dries invisibly leaving appearance of substrate unchanged.
 - 1. Applications: All applicable vertical surfaces up to 12 feet above finish grade and non-traffic horizontal surfaces.
 - 2. Minimum Number of Coats: Two.
 - 3. No intentionally added cadmium.
 - 4. VOC Content: As specified in Section 01 6116.
 - 5. Moisture Absorption When Applied to Masonry: 5 percent, maximum, when tested in accordance with ASTM C140/C140M using masonry sample completely coated with graffiti-resistant coating.
 - 6. Maintains dry appearance when wetted.
 - 7. Products (or equal): Water-based acrylic
 - a. Monopole, Inc.; Permanent Graffiti Control:
 - 1) Permashield Base 6100.

- 2) Permashield Premium 5600 (Top Coat - Matte Finish).
 - 3) Cleaner: Citrus Clean Super - 9800
 - b. Substitutions: See Section 01 60 00 - Product Requirements.
8. Compatibility: Anti-Graffiti coating shall be compatible with all standard paintable polymer type caulking and sealing materials and certified by manufacturer as suitable for use.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify existing conditions before starting work.
- B. Verify joint sealants are installed and cured.
- C. Verify surfaces to be coated are dry, clean, and free of efflorescence, oil, or other matter detrimental to application of graffiti-resistant coating.

3.02 PREPARATION

- A. Protection of Adjacent Work:
 1. Protect adjacent landscaping, property, and vehicles from drips and overspray.
 2. Protect adjacent surfaces not intended to receive graffiti-resistant coating.
- B. Prepare surfaces to be coated as recommended by graffiti-resistant coating manufacturer for best results.
 1. Graffiti-Resistant coating over paint.
 - a. Primer as recommended by manufacturer of coating. Paint cure time as recommended by paint manufacturer prior to coating.
 2. Graffiti-Resistant coating over unsealed concrete, brick, stucco, stone or block masonry units.
 - a. Provide compatible water repellent sealer as indicated in Section 07 19 00 - Water Repellents, as recommended by manufacturer.
 3. Graffiti-Resistant coating over substrates or finishes not mentioned above.
 - a. Consult manufacturer for recommendations.
- C. Do not start work until masonry mortar substrate is cured a minimum of 60 days.
- D. Remove oil and foreign substances with a chemical solvent that will not affect graffiti-resistant coating.
- E. Allow surfaces to dry completely to degree recommended by graffiti-resistant coating manufacturer before starting coating work.

3.03 APPLICATION

- A. Apply at rate recommended by manufacturer, continuously over entire surface.
- B. Apply two coats, minimum.
- C. Remove graffiti-resistant coating from unintended surfaces immediately by a method instructed by graffiti-resistant coating manufacturer.

FOR REFERENCE ONLY

- D. Provide manufacturer's field service representative to inspect preparation and application work continuously during entire application period to ensure that manufacturer's "best practices" for preparation and application are being followed.

END OF SECTION

FOR REFERENCE ONLY

SECTION 10 11 00 VISUAL DISPLAY UNITS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Porcelain enamel steel markerboards.

1.02 RELATED REQUIREMENTS

- A. Section 06 10 00 - Rough Carpentry: Blocking and supports.

1.03 REFERENCE STANDARDS

- A. ANSI A208.1 - American National Standard for Particleboard.
- B. ASTM A424/A424M - Standard Specification for Steel, Sheet, for Porcelain Enameling.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide manufacturer's data on porcelain enamel steel markerboard, tackboard, tackboard surface covering, trim, and accessories.
- C. Shop Drawings: Indicate wall elevations, dimensions, joint locations , special anchor details.
- D. Samples: Color charts for selection of color and texture of porcelain enamel steel markerboard, tackboard, tackboard surface covering, and trim.
- E. Test Reports: Show compliance to specified surface burning characteristics requirements.
- F. Manufacturer's printed installation instructions.
- G. Manufacturer's Qualification Statement.
- H. Maintenance Data: Include data on regular cleaning, stain removal .

1.05 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum three years documented experience.

1.06 WARRANTY

- A. See Section 01 78 00 - Closeout Submittals, for additional warranty requirements.
- B. Provide five year warranty for markerboard to include warranty against discoloration due to cleaning, crazing or cracking, and staining.

PART 2 PRODUCTS

2.01 VISUAL DISPLAY UNITS

- A. Porcelain Enamel Steel Markerboards:
 - 1. Manufacturers:

FOR REFERENCE ONLY

- a. Basis of Design Product: LCS Deluxe Porcelain Whiteboards as manufactured by Claridge Products and Equipment, Inc, or approved equal.
 - b. A-1 Visual Systems Co.: www.a-1visualsystems.com.
 - c. ADP Lemco, Inc: www.adplemco.com/#sle.
 - d. ASI Visual Display Products: www.asi-visualdisplayproducts.com/#sle.
 - e. Chatfield-Clarke: www.chafield-clarke.com.
 - f. Claridge Products and Equipment, Inc: www.claridgeproducts.com/#sle.
 - g. Egan Visual Corporation; Egan Visual WhiteBoards: www.egan.com/#sle.
 - h. Nelson Adams NACO: www.nelsonadamsnaco.com/#sle.
 - i. Platinum Visual Systems: pvusa.com.
 - j. Polyvision Corporation: www.polyvision.com/#sle.
 - k. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
2. Color: White.
 3. Steel Face Sheet Thickness: 24 gauge, 0.0239 inch .
 4. Core: Particleboard, manufacturer's standard thickness, laminated to face sheet.
 5. Backing: Galvanized steel sheet, laminated to core.
 6. Size: As indicated on drawings.
 7. Frame: Extruded aluminum , with concealed fasteners.
 8. Frame Profile: As indicated on drawings.
 9. Frame Finish: Anodized, natural.
 10. Accessories: Provide marker tray.

2.02 MATERIALS

- A. Porcelain Enameled Steel Sheet: ASTM A424/A424M, Type I, Commercial Steel, with fired-on vitreous finish.
- B. Particleboard: ANSI A208.1; wood chips, set with waterproof resin binder, sanded faces.
- C. Steel Sheet Backing: 28 gauge, 0.0149 inch, galvanized.
- D. Adhesives: Type used by manufacturer.

2.03 ACCESSORIES

- A. Map Supports: Formed aluminum sliding hooks and roller brackets to fit map rail.
- B. Temporary Protective Cover: Sheet polyethylene, 8 mil thick.
- C. Cleaning Instruction Plate: Provide instructions for chalkboard cleaning on a metal plate fastened to perimeter frame near chalkrail.
- D. Marker Tray: Aluminum, manufacturer's standard profile, one piece full length of markerboard, molded ends, concealed fasteners, same finish as frame.
- E. Mounting Brackets: Concealed.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that field measurements are as indicated.
- B. Verify that internal wall blocking is ready to receive work and positioning dimensions are as indicated on shop drawings.

3.02 PREPARATION

- A. Acclimatize tackable wall panels by removing from packaging in installation area not less than 24 hours before application.
- B. Remove switchplates, wall plates, and surface-mounted fixtures where tackable wall paneling is applied. Reinstall items on completion of installation.
- C. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.

3.03 INSTALLATION

- A. Install boards in accordance with manufacturer's instructions.
- B. Install with top of marker tray at 30 inches above finished floor.
- C. Secure units level and plumb.
- D. Carefully cut holes in boards for thermostats, wall switches, and outlets.

3.04 CLEANING

- A. Clean board surfaces in accordance with manufacturer's instructions.
- B. Cover with protective cover, taped to frame.
- C. Remove temporary protective cover at Final Inspection.

END OF SECTION

SECTION 10 14 23 PANEL SIGNAGE

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Panel signage.
- B. Traffic and parking control, and site informational signage

1.02 REFERENCE STANDARDS

- A. 36 CFR 1191 - Americans with Disabilities Act (ADA) Accessibility Guidelines for Buildings and Facilities; Architectural Barriers Act (ABA) Accessibility Guidelines.
- B. ADA Standards - 2010 ADA Standards for Accessible Design.
- C. ASTM C94/C94M - Standard Specification for Ready-Mixed Concrete.
- D. {RSTEMP#10005050}
- E. {RSTEMP#10005085}
- F. CBC Chapter 11B - California Building Code-Chapter 11B.

1.03 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Manufacturer's product literature for each type of panel sign, indicating styles, font, foreground and background colors, locations, and overall dimensions of each sign.
- C. Shop Drawings:
 - 1. Include dimensions, locations, elevations, materials, text and graphic layout, attachment details, and schedules.
 - 2. Schedule: Provide information sufficient to completely define each panel sign for fabrication, including room number, room name, other text to be applied, sign and letter sizes, fonts, and colors.
 - a. When room numbers to appear on signs differ from those on drawings, include the drawing room number on schedule.
 - b. When content of signs is indicated to be determined later, request such information from District through Architect at least 2 months prior to start of fabrication; upon request, submit preliminary schedule.
 - c. Submit for approval by District through Architect prior to fabrication.
- D. Samples: Submit two samples of each type of sign, of size similar to that required for project, indicating sign style, font, and method of attachment.
- E. Verification Samples: Submit samples showing colors, materials, and finishes specified.
- F. Manufacturer's Installation Instructions: Include installation templates and attachment devices.
- G. Manufacturer's qualification statement.

- H. Maintenance Materials: Furnish the following for District's use in maintenance of project.
 - 1. See Section 01 60 00 - Product Requirements for additional provisions.

1.04 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum three years of documented experience.

1.05 DELIVERY, STORAGE, AND HANDLING

- A. Package signs as required to prevent damage before installation.
- B. Package room and door signs in sequential order of installation, labeled by floor or building.
- C. Store under cover and elevated above grade.
- D. Store tape adhesive at normal room temperature.

1.06 FIELD CONDITIONS

- A. Do not install tape adhesive when ambient temperature is lower than recommended by manufacturer.
- B. Maintain minimum ambient temperature during and after installation.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Panel Signage:
 - 1. ASI Sign Systems, Inc.: www.asisignage.com.
 - 2. Best Sign Systems, Inc: www.bestsigns.com/#sle.
 - 3. FASTSIGNS International, Inc: www.fastsigns.com/#sle.
 - 4. Inpro Corporation: www.inprocorp.com/#sle.
 - 5. Mohawk Sign Systems, Inc: www.mohawksign.com/#sle.
 - 6. Seton Identification Products: www.seton.com/aec/#sle.
 - 7. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.

2.02 REGULATORY REQUIREMENTS

- A. Accessibility Requirements: Comply with ADA Standards, CBC Chapter 11B, and applicable building codes, unless otherwise indicated; in the event of conflicting requirements, comply with the most restrictive requirements.
 - 1. Requirements for Persons with Disabilities: Provide identifying devices meeting the requirements for the physically disabled of the following codes:
 - a. California Building Code (CBC) Title 24, Part 2; Chapter 11B, Accessibility.
 - b. Code of Federal Regulations 36 CFR 1191 - Americans with Disabilities Act (ADA) Accessibility Guidelines for Buildings and Facilities.
 - c. Accessible Means of Egress Signage: CBC1009.
 - 1) Directional Signage: CBC 1009.10.

FOR REFERENCE ONLY

- (a) Provide directional signage complying with {RS#10005085}-703.5 indicating the location of all other means of egress and which are accessible means of egress:
 - (1) At exits serving a required accessible space but not providing an approved accessible means of egress.
2. Raised characters: Comply with {RS#10005085}-703.2.
 - a. Depth: It shall be 1/32 inch minimum above their background and shall be sans serif uppercase and be duplicated in Braille.
 - b. Height: It shall be 5/8 inch minimum and 2 inches maximum based on the height of the uppercase letter "I". {RS#10005085}-703.2.5
 - c. Finish and contrast: Characters and their background shall have a non-glare finish. Character shall contrast with their background with either light characters on a dark background or dark characters on a light background. {RS#10005085}-703.5.1
 - d. Proportions: It shall be selected from fonts where the width of the uppercase letter "O" is 60 % minimum and 110 % maximum of the height of the uppercase letter "I". Stroke thickness of the uppercase letter "I" shall be 15% maximum of the height of the character. {RS#10005085}-703.2.4 and 11B-703.2.6; If characters are both visual and raised, provide stroke width min. 10% and max. 15% of the character "I".
 - e. Character Spacing: Spacing between individual tactile characters shall comply with {RS#10005085}-703.2.7.
 - 1) 11B-703.2.8 Line spacing. Spacing between the baselines of separate lines of raised characters within a message shall be 135 percent minimum and 170 percent maximum of the raised character height.
 - f. Format: Text shall be in a horizontal format. {RS#10005085}-703.2.9.
 - g. Braille: It shall be contracted (Grade 2) and shall comply with {RS#10005085}-703.3 and 11B-703.4. Braille dots shall have a domed and rounded shape and shall comply with CBCTable and Figure 11B-703.3.1. Duplicate all characters on sign.
 - h. Mounting height: Tactile sign on signs shall be located 48 inches minimum to the baseline of the lowest Braille cells and 60 inches maximum to the baseline of the highest line of raised characters above the finish floor or ground surface. {RS#10005085} and Figure 11B-703.4.1.
 - i. Mounting location: A tactile sign shall be located per {RS#10005085} and Figure 11B-703.4.2 as follows:
 - 1) alongside a single door on the latch side.
 - 2) on the inactive leaf of a double door with one active leaf.
 - 3) to the right of the right hand door at double doors with two active leaves.
 - 4) on the nearest adjacent wall where there is no wall space at the latch side of a single door or at the right side of double doors with two active leaves.
 - 5) so that a clear floor space of 18 x 18 inch minimum, centered on the tactile characters, is beyond the arc of any door swing between the closed position and 45 degree open position.

3. Visual characters shall comply with {RS#10005085}-703.5 and shall be 40 inches minimum above finish floor or ground.
 - a. Visual character stroke thickness of the uppercase letter "I" shall be 10% minimum and 20% maximum of the height of the character. {RS#10005085}-703.5.7.
 - b. Line Spacing between the baselines of characters within a message shall be 135% minimum and 170% maximum of the character height per {RS#10005085}-703.5.9.
 - c. Character Spacing between individual adjacent characters shall be 10% minimum and 35% maximum of character height per {RS#10005085}-703.5.8.
4. Pictograms shall comply with {RS#10005085}-703.6.
5. Symbol of accessibility shall comply with {RS#10005085}-703.7.
6. Variable message signs shall comply with {RS#10005085}-703.8.

2.03 PANEL SIGNAGE

- A. Panel Signage:
 1. Application: Room and door signs.
 2. Description: Flat signs with engraved panel media, tactile characters.
 3. Sign Size: As indicated on drawings.
 4. Total Thickness: 1/8 inch.
 5. Sign Edges: Squared.
 6. Letter Edges: Squared.
 7. Corners: Squared.
 8. Color and Font, unless otherwise indicated:
 - a. Character Font: Helvetica, Arial, or other sans serif font.
 - b. Character Case: Upper and lower case (title case).
 - c. Background Color: As scheduled.
 - d. Character Color: Contrasting color.
 9. Material: Laminated colored plastic engraved through face to expose core as background color.
 10. Profile: Flat panel in aluminum frame.
 - a. Frame Finish: Black anodized.
 11. Tactile Letters: Raised 1/32 inch minimum.
 12. Braille: Grade II, ADA-compliant.
 13. One-Sided Wall Mounting: Concealed screws.

2.04 SIGNAGE APPLICATIONS

- A. Room and Door Signs:
 1. Rest Rooms: Identify with pictograms, the names "MEN" and "WOMEN", room numbers to be determined later, and braille.

FOR REFERENCE ONLY

- a. Identify all single user toilet facilities as gender neutral facilities by a door symbol that complies with {RS#10005085}-216.8 and 11B-703.7.2.6.3.
 - 1) No pictogram, text, or braille is required.
 - 2) Tactile jamb signage shall comply with appropriate technical requirements of {RS#10005085}-703.
 - (a) Examples of appropriate designations are "ALL-GENDER RESTROOM", "RESTROOM", or "UNISEX RESTROOM". DSA BU-17.
 - (b) Provide "RESTROOM" as the signage text, unless indicated otherwise on Drawings.
 - 3) See Drawings for actual sign to be provided.
 - b. Geometric Symbols: The symbol color shall contrast with door or wall.
 - 1) Comply with {RS#10005085}-216.8.1 at the entrances to toilet and bathing rooms.
 - 2) Comply with {RS#10005085}-703.7.2.6.
 - (a) Men's: An equilateral triangle, ¼ inch thick edges with edges 12 inches long and a vertex pointing upward.
 - (b) Women's: A circle, ¼ inch thick and 12 inches in diameter.
 - (c) Unisex (All Gender): A circle, ¼ inch thick and 12 inches in diameter with a equilateral triangle, ¼ inch thick edges with edges 12 inches long and a vertex pointing upward, superimposed on and geometrically inscribed within the circle and within the 12 inch diameter. The vertex of the triangle shall be located ¼ inch from the edge of the circle. The triangle shall contrast with the circle symbol, either light on a dark background or dark on a light background. The circle symbol shall contrast with the door.
 - (1) No pictogram is to be provided.
 - (d) Mount within 1 inch of the centerline of the door at minimum 58 inches and 60 inches maximum from the centerline of the symbol to the finished floor surface.
2. Exits: Provide raised character and Braille exit signs per CBC Section 1013.4 at the following locations:

<u>Text</u>	<u>Location</u>
EXIT	Grade level exit door.
EXIT STAIR DOWN, EXIT STAIR UP	Exit door to exit stair.
EXIT RAMP DOWN, EXIT RAMP UP	Exit door to exit ramp.
EXIT ROUTE	Exit door to exit enclosure, exit passageway, exit corridor, or exit hallway.
TO EXIT	Exit door to horizontal exit.
EXIT WITH ALARM	Exit doors with an alarm.
EXIT ONLY or EXIT STAIR ONLY	Exit doors and stair exit doors which lock from outside and does not allow a return

- B. Interior Directional and Informational Panel Signs:
1. Assistive Listening Devices, include International Symbol of Access for Hearing Loss complying with {RS#10005085} Figure 11B-703.7.2.4..
 - a. Include International Symbol of Access for Hearing Loss, {RS#10005085} Figure 11B-703.7.2.4, with text "Assistive-Listening System Available". Use upper and lower case characters.
 2. Occupant Load Signs:
 - a. Provide maximum occupancy load signs. Post in a conspicuous place near the main exit or exit access doorway from the room or space of rooms and areas indicated in the drawings.
 - b. Minimum size: 4 inches high by 8 inches wide, 7/8 inch high letters, 1 inch high numerals.
 - c. Sign to read: "MAXIMUM OCCUPANCY LOAD XXX". Indicate occupant load shown on drawings.
- C. Traffic Signs: To match campus standards; locate where indicated on drawings.
1. Manufacturers:
 - a. Hawkins Traffic Safety Supply, Inc.: www.hawkinstraffic.com.
 - b. Safeway Sign Company: www.safewaysign.com.
 - c. Western Highway Products, Inc.: www.westernhighway.com.
 - d. Substitutions: See Section 01 6000 - Product Requirements.
 2. Plaque Signs: Provide manufacturer's standard silk-screened signs, baked-on enamel applied over Diamond Grade (DG), (10-year projected life) retro-reflectorized backing; on aluminum or 16 gage galvanized steel sheet. Provide with anti-graffiti protective overlay film. Produce smooth, even, level sign surfaces, constructed to remain flat under installed condition within a tolerance of plus or minus 1/16-inch measured diagonally. Provide two holes for post mounting.
 - a. Parking Stall Signs: Sign text, accessible parking control shall comply with requirements of State of California Code of Regulations (CCR) - Title 24, Part 2, {RS#10005085}-502.6 in addition to requirements of State of California, Department of Transportation (CALTRANS) and regulations of local authorities having jurisdiction.
 - 1) Single post mount, not less than 70 square inches with white reflectorized copy on blue background conforming to No. 15090, SAE AMS-STD-595 (FED-STD-595C). Sign shall display a profile view of a wheelchair with occupant in white on blue background.
 - (a) Provide an additional sign below the accessible sign with the text "Minimum Fine \$250".
 - 2) Position one sign at the end of each parking space designated for disabled usage.
 - 3) One in every six spaces ({RS#10005085}-208.2.4), but not less than one, provide a 12 inch by 3-1/4 inch "Van Accessible" sign below the symbol of accessibility, wording per {RS#10005085}-502.6, 36 CFR 1191, and ADA Standards.

FOR REFERENCE ONLY

- 4) Sign shall be mounted 80 inches from bottom of sign to finish grade of parking space or centered on wall at interior end of parking space at a minimum height of 60 inches above the parking space, finished grade, ground or sidewalk, to the bottom of the sign.
3. Support Posts:
 - a. Galvanized steel pipe, minimum 2-1/2 inch diameter or as indicated, with caps.
 - b. Concrete: Ready-mixed, complying with ASTM C94/C94M; normal Portland cement; 3,500 psi strength at 28 days, 3 inch slump; 3/4 inch nominal size aggregate.
4. Accessories: Provide welded galvanized steel fittings and galvanized or stainless steel bolts, nuts and washers.
5. Fasteners: Provide tamper-proof galvanized steel fasteners.
 - a. Tufnut System (714) 962-5838, Allegheny Bolt (Tampruf brand; (516) 568-1052 or equal.

2.05 FABRICATION

- A. Provide signs and supports factory-prefabricated and pre-finished, ready for assembly and installation.

2.06 ACCESSORIES

- A. Concealed Screws: Noncorroding metal; stainless steel, galvanized steel, chrome plated, or other.
- B. Exposed Screws: Stainless steel.
- C. Tape Adhesive: Double-sided tape, permanent adhesive.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that substrate surfaces are ready to receive work.
- B. Notify Architect if conditions are not suitable for installation of signs; do not proceed until conditions are satisfactory.

3.02 INSTALLATION AT BUILDIN

- A. Install in accordance with manufacturer's instructions.
- B. Install with horizontal edges level.
- C. Locate panel signs and mount at heights indicated on drawings and in accordance with ADA Standards, CBC Chapter 11B, and applicable building codes.
 1. Room and Door Signs: Locate on wall at latch side of door (per {RS#10005085}-703.4.2) a minimum of 48 inches to the baseline of the lowest braille cells; with baseline of highest line of raised character text at maximum 60 inches above finished floor.
 - a. Comply with {RS#10005085}-703.4.1 and {RS#10005085} -703.4.2
- D. Protect from damage until final inspection; repair or replace damaged items.

3.03 SITE AND TRAFFIC SIGN INSTALLATION

- A. Locate informational signage as verified in field by District. Verify and coordinate sign locations to prevent conflict with underground utilities.
- B. Locate accessible car and van parking stall and drive approach signs where shown on Drawings and as required by applicable ordinances and regulations of authorities having jurisdiction. Verify and coordinate sign locations to prevent conflict with underground utilities.
- C. Excavate for sign support footings to depth as shown on Drawings or, if not shown, as recommended by manufacturer. Provide forms for concrete not supported by compacted soil.
- D. Set posts in concrete base, minimum 12 inch diameter and 18 inches deep; unless indicated otherwise on Drawings.
 - 1. Set sign support post plumb and so sign face will be perpendicular to stall or parallel to curb face, as applicable.
 - a. Set posts into pipe sleeve inserts set and anchored into concrete.
 - b. Fill annular space between posts and sleeves with grouting compound.
 - 2. Signs set in asphaltic paving surfaces or concrete sidewalks shall be mounted in core drilled holes minimum 8 inch diameter, 18 inches deep with top of base flush to finish.
 - 3. Firmly attach signs mounted to walls with appropriate expansion anchors or bolting, adhesive not permitted.
 - 4. Seal all holes water tight.
- E. Install plaque signage to posts, with panel facing traffic as necessary.

3.04 FIELD QUALITY CONTROL

- A. Inspect signs for information content, appearance, location and Braille per as noted in Section 01 45 33 - Code-Required Special Inspections.

3.05 ADJUST AND CLEAN

- A. Repair damage to signs incurred during installation. Replace signs which cannot be repaired to new condition. Clean glass, frames, and other sign surfaces, adjust hardware for proper operation.

END OF SECTION

SECTION 10 21 13.19 PLASTIC TOILET COMPARTMENTS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Solid plastic toilet compartments.
- B. Urinal and vestibule screens.

1.02 RELATED REQUIREMENTS

- A. Section 05 50 00 - Metal Fabrications: Concealed steel support members.
- B. Section 09 21 16 - Gypsum Board Assemblies: Concealed supports, included in wall framing and plates and above ceiling framing.
- C. Section 10 28 00 - Toilet Accessories.

1.03 REFERENCE STANDARDS

- A. 36 CFR 1191 - Americans with Disabilities Act (ADA) Accessibility Guidelines for Buildings and Facilities; Architectural Barriers Act (ABA) Accessibility Guidelines.
- B. ADA Standards - 2010 ADA Standards for Accessible Design.
- C. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials.
- D. {RSTEMP#10005050}
- E. {RSTEMP#10005085}
- F. NFPA 286 - Standard Methods of Fire Tests for Evaluating Contribution of Wall and Ceiling Interior Finish to Room Fire Growth.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordination: Coordinate the work with placement of support framing and anchors in walls and ceilings.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide data on panel construction, hardware, and accessories.
 - 1. If other than specified manufacturer or specified product, submit catalog data.
- C. Shop Drawings: Indicate partition plan, elevation views, dimensions, details of wall supports, door swings.
 - 1. Show plan and elevation views for each room. Indicate types and thicknesses of materials and assemblies.
 - 2. Attachment details.
- D. Samples: Submit two samples of partition panels, 2 by 2 inch in size illustrating panel finish, color, and sheen.

- E. Manufacturer's Installation Instructions: Indicate special procedures.

1.06 WARRANTY

- A. All components shall have a 15 year limited warranty.

1.07 PACKAGING, DELIVERY, STORAGE AND HANDLING

- A. Packaging: Maintain factory packaging and protective coverings.
- B. Storage: Store panels to prevent impact and moisture damage.

1.08 PROJECT CONDITIONS

- A. Field Measurements: Verify field design and field dimensions before submitting shop drawings and before fabrication.
- B. Environmental Conditions: Maintain humidity and temperature in ranges required by manufacturer.

1.09 SEQUENCING AND SCHEDULING

- A. Complete tile and painting Work before toilet partition installations.
- B. Coordinate dimensions and locations of cut-outs and panel reinforcement with approved toilet accessories.
- C. Coordinate backing and blocking provisions in walls.

PART 2 PRODUCTS

2.01 REGULATORY REQUIREMENTS

- A. Code compliance of these systems must be verified prior to use. They may be no longer available and are not yet proven to be compliant with NFPA 286, per {RS#10005050} Sections **803.1.2, 803.11**, 2604.2.4.
- B. Installation shall meet requirements for the physically disabled of the California Code of Regulations (CCR) Title 24 Part 2 and latest amendments to the ADA Standards and 36 CFR 1191.
- C. California Building Code (CBC) disabled accessibility regulations.
 - 1. Wheelchair accessible compartment shall comply with CBC {RS#10005085}-604.8.1.
 - 2. Toe clearance for at least one side partition of a wheelchair accessible compartment shall comply with {RS#10005085} Figure 604.8.1.4.
 - a. It shall be 9 inches high minimum above the finish floor and 6 inches deep minimum beyond the compartment side face of the partition, exclusive of partition support members.
 - b. It shall be 12 inches high minimum above the finish floor for children's use.
 - c. Partition components at toe clearances shall be smooth without sharp edges or abrasive surfaces.
 - d. Toe clearance is not required in a compartment greater than 66 inches wide.

3. Ambulatory accessible compartments shall be provided where there are six or more toilet compartments, or where the combination of of urinals and water closets totals six or more fixtures.
 - a. Such compartment shall be provided in the same quantity as wheelchair accessible compartments per {RS#10005085}-213.3.1 and shall comply with {RS#10005085}-604.8.2.
4. Door and door hardware for accessible compartments shall be self-closing and shall comply with {RS#10005085}-404 except that if the approach is on the latch side of an ambulatory compartment door, clearance between the door side of the compartment and any obstruction shall be 44 inches minimum. {RS#10005085} Figure 604.8.2.
5. A door pull complying with {RS#10005085}-404.2.7 shall be placed on both sides of the accessible compartment door near the latch.
6. Ambulatory Accessible Toilet Compartment doors shall not swing into the clear floor space or clearance required for any fixture or into the minimum required compartment area. {RS#10005085}-604.8.2.2.

2.02 PLASTIC TOILET COMPARTMENTS

- A. Basis of Design Product: Hiny Hiders Partitions as manufactured by Scranton Products, www.scrantonproducts.com/#sle, or approved equal.
- B. Solid Plastic Toilet Compartments: Factory fabricated doors, pilasters, and divider panels made of solid molded high density polyethylene (HDPE), tested in accordance with NFPA 286; floor-mounted headrail-braced.
 1. Color: Single color as selected, in each space.
 2. Flame Spread Rating (ASTM E84):
 - a. Class B flame spread 26-75 and smoke developed of 0-450.
 3. Doors, Panels, and Pilasters: Standard panel edge.
 4. Doors:
 - a. Thickness: 1 inch.
 - b. Width: 24 inch.
 - c. Width for Handicapped Use: 36 inch, out-swinging.
 - d. Height: 66 inch.
 5. Panels:
 - a. Thickness: 1 inch.
 - b. Height: 66 inch.
 - 1) Provide 9 inch high foot clearance at accessible toilet stalls.
 - c. Depth: As indicated on drawings.
 6. Pilasters:
 - a. Thickness: 1 inch.
 - b. Width: As required to fit space; minimum 3 inch.

FOR REFERENCE ONLY

7. Screens: Without doors; to match compartments; mounted to wall with continuous panel brackets.
 - a. Aluminum heat sink fastened to bottom edges
 - b. Urinal Screens: 24 inches wide by 42 inches high.
 - 1) Mount 14 inches above floor.

2.03 ACCESSORIES

- A. Pilaster Shoes: Stainless steel, satin finish, 3 inches high; concealing floor fastenings.
 1. Provide adjustment for floor variations with screw jack through steel saddles integral with pilaster.
 2. Provide ceiling attachment using two adjustable hanging studs, attached to above-ceiling framing.
- B. Head Rails: Extruded aluminum, anti-grip profile.
 1. Size: Manufacturer's standard size.
- C. Wall and Pilaster Brackets: Stainless steel; continuous type.
- D. Attachments, Screws, and Bolts: Stainless steel, tamper proof type.
 1. For attaching panels and pilasters to brackets: Through-bolts and nuts; tamper proof.
 2. Secure to pilasters with a stainless steel tamper resistant Torx head sex bolt.
- E. Hinges: Stainless steel, manufacturer's standard finish.
 1. Continuous-type hinge, self closing.
- F. Door Hardware: Anodized aluminum, manufacturer's standard finish.
 1. Door Latch: Slide type with exterior emergency access feature.
 - a. Latch Mechanism: Stainless Steel Slide Bolt Latch and Housing: Heavy-duty stainless steel type 304. The latch and housing to have a bright finish. The slide bolt and button to have a black anodized finish.
 - b. Latch Mechanism: Occupancy Indicator Latch and Housing:
 - 1) Material: Satin stainless steel.
 - 2) Occupancy indicators: Green for occupied and red not occupied.
 - 3) Slide bolt and button.
 2. Door Strike and Keeper with Rubber Bumper: Mount on pilaster in alignment with door latch.
 - a. Heavy-duty extruded aluminum 6436-T5 alloy with a bright dip anodized finish. Secure to pilasters with stainless steel tamper resistant Torx head sex bolts. Bumper made of extruded black vinyl.
 - b. Style: 6 inches aluminum.
 - c. Inswing Keeper Basis of Design : Hiny Hider Aluminum 6" Inswing Strike And Keeper For 1" Post as manufactured by Scranton Products, or approved equal.
 - d. Outswing Keeper Basis of Design : Hiny Hider Aluminum 6" Outswing Keeper Bumper For 1" as manufactured by Scranton Products, or approved equal.

3. Provide second {RS#10005085} and ADA Standards door pull for outswinging doors at accessible doors.
 - a. Surface mounted U-shaped or wire pulls on both sides of accessible compartment doors.
 - b. Chrome Plated Double Door Pull 5-1/2", for 1 inch thick doors.
 - c. Overall width is 6-3/4 inches with 5-7/8 inch hole spacing.
- G. Coat Hook: One per compartment, mounted on door.
 1. Mount such that no portion is over 40 inches above finish floor , at accessible stall, and 48 inches above finish floor at non-accessible stall.
- H. Toilet Partition Suspension Members: As specified in Section 05 50 00.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that field measurements are as indicated.
- B. Verify correct spacing of and between plumbing fixtures.
- C. Verify correct location of built-in framing, anchorage, and bracing.

3.02 INSTALLATION

- A. Install partitions secure, rigid, plumb, and level in accordance with manufacturer's instructions.
- B. Maintain 3/8 inch to 1/2 inch space between wall and panels and between wall and end pilasters.
- C. Attach panel brackets securely to walls using anchor devices.
- D. Attach panels and pilasters to brackets. Locate head rail joints at pilaster center lines.
- E. Field touch-up of scratches or damaged finish will not be permitted. Replace damaged or scratched materials with new materials.

3.03 TOLERANCES

- A. Alignment Tolerance: Plus or minus 1/16 inch, in any direction.
- B. Maximum Variation From True Position: 1/4 inch.
- C. Maximum Variation From Plumb: 1/8 inch.

3.04 ADJUSTING

- A. Operation: Doors shall operate smoothly and evenly.
- B. Adjust and align hardware to uniform clearance at vertical edge of doors, not exceeding 3/16 inch.
- C. Adjust hinges to position doors in partial opening position when unlatched. Return outswinging doors to closed position.
 1. Adjust doors to remain open at approximately 30 degrees.
- D. Adjust adjacent components for consistency of line or plane.

FOR REFERENCE ONLY

- E. Field Operation and Alignment Check: Demonstrate compliance with specified tolerance and operation requirements.
 - 1. Should check reveal misalignment, improper operation or inadequate anchorage, realign, adjust and re-anchor the entire installation to Architect's satisfaction.
 - 2. Replace deformed, marred, damaged or dented parts at no change in Contract Time or Sum.

3.05 CLEANING

- A. Cleaning After Installation: Clean exposed surfaces of panel systems using materials and methods recommended by manufacturer.
- B. Protection: Provide protection as necessary to prevent damage during remainder of construction period.
- C. Final Cleaning: Clean partitions to dust-free condition prior to Final Acceptance.

END OF SECTION

SECTION 10 26 00 WALL AND DOOR PROTECTION

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Corner guards. CG-1

1.02 RELATED REQUIREMENTS

- A. Section 05 50 00 - Metal Fabrications: Anchors for attachment of work of this section, concealed in wall.

1.03 REFERENCE STANDARDS

- A. ASTM D256 - Standard Test Methods for Determining the Izod Pendulum Impact Resistance of Plastics.
- B. ASTM D543 - Standard Practices for Evaluating the Resistance of Plastics to Chemical Reagents.
- C. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials.
- D. ASTM F476 - Standard Test Methods for Security of Swinging Door Assemblies.
- E. ASTM G21 - Standard Practice for Determining Resistance of Synthetic Polymeric Materials to Fungi.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Indicate physical dimensions, features, anchorage details, and rough-in measurements.
- C. Samples: Submit samples illustrating component design, configurations, joinery, color and finish.
 - 1. Submit two sections of corner guards, 24 inches long.
- D. Manufacturer's Instructions: Indicate special procedures, perimeter conditions requiring special attention.
- E. Warranty Documentation: Submit manufacturer warranty and ensure that forms have been completed in District's name and registered with manufacturer.
- F. Maintenance Materials: Furnish the following for District's use in maintenance of project:
 - 1. See Section 01 60 00 - Product Requirements, for additional provisions.
- G. Maintenance Data: Manufacturer's instructions for care and cleaning of each type of product. Include information about both recommended and potentially detrimental cleaning materials and methods.

1.05 DELIVERY, STORAGE, AND HANDLING

- A. Deliver wall and door protection items in original, undamaged protective packaging. Label items to designate installation locations.
- B. Protect work from moisture damage.
- C. Protect work from UV light damage.
- D. Do not deliver products to project site until areas for storage and installation are fully enclosed, and interior temperature and humidity are in compliance with manufacturer's recommendations for each type of item.

1.06 WARRANTY

- A. See Section 01 78 00 - Closeout Submittals for additional warranty requirements.
- B. Manufacturer Warranty: Provide 5-year manufacturer warranty for metal crash rails. Complete forms in District's name and register with manufacturer.
 - 1. Failures include, but are not limited to, the following:
 - a. Deterioration of materials beyond that expected of normal use, as intended by manufacturer.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Corner Guards:
 - 1. Babcock-Davis: www.babcockdavis.com/#sle.
 - 2. Construction Specialties, Inc: www.c-sgroup.com/#sle.
 - 3. Inpro: www.inprocorp.com/#sle.
 - 4. Koroseal Interior Products: www.koroseal.com/#sle.
 - 5. Substitutions: See Section 01 60 00 - Product Requirements.

2.02 PERFORMANCE CRITERIA

- A. Impact Strength: Unless otherwise noted, provide protection products and assemblies that have been successfully tested for compliance with applicable provisions of ASTM D256 and/or ASTM F476.
- B. Chemical and Stain Resistance: Unless otherwise noted, provide protection products and assemblies with chemical and stain resistance complying with applicable provisions of ASTM D543.
- C. Fungal Resistance: Unless otherwise noted, provide protection products and assemblies which pass ASTM G21 testing.

2.03 PRODUCT TYPES

- A. Corner Guards - Surface Mounted:
 - 1. Material: Type 304 stainless steel, No. 4 finish, 16 gauge, 0.0625 inch thick.

2. Performance: Resist lateral impact force of 100 lbs at any point without damage or permanent set.
 3. Surface Burning Characteristics: Provide assemblies with flame spread index of 25 or less and smoke developed index of 450 or less, when tested in accordance with ASTM E84.
 4. Width of Wings: 2 inches.
 5. Corner: Square.
 6. Color: #4 Satin finish.
 7. Length: One piece.
- B. Adhesives and Primers: As recommended by manufacturer.
- C. Mounting Brackets and Attachment Hardware: Appropriate to component and substrate.

2.04 FABRICATION

- A. Fabricate components with tight joints, corners and seams.
- B. Pre-drill holes for attachment.
- C. Form end trim closure by capping and finishing smooth.

2.05 SOURCE QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements, for additional requirements.
- B. Provide wall and door protection systems of each type from a single source and manufacturer.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that rough openings, concealed blocking, and anchors are correctly sized and located.
- B. Verify that field measurements are as indicated on drawings.
- C. Verify that substrate surfaces for adhered items are clean and smooth.
- D. Start of installation constitutes acceptance of project conditions.

3.02 INSTALLATION

- A. Install components in accordance with manufacturer's instructions, level and plumb, secured rigidly in position to supporting construction.
- B. Position corner guard 4 inches above finished floor to ceiling.

3.03 TOLERANCES

- A. Maximum Variation From Required Height: 1/4 inch.
- B. Maximum Variation From Level or Plane For Visible Length: 1/4 inch.

3.04 CLEANING

- A. See Section 01 74 19 - Construction Waste Management and Disposal, for additional requirements.

FOR REFERENCE ONLY

- B. Clean wall and door protection items of excess adhesive, dust, dirt, and other contaminants.

END OF SECTION

FOR REFERENCE ONLY

SECTION 10 28 00 TOILET ACCESSORIES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Commercial toilet accessories.
- B. Under-lavatory pipe supply covers.
- C. Utility room accessories.

1.02 RELATED REQUIREMENTS

- A. Section 10 21 13.17 - Phenolic Toilet Compartments
- B. Section 10 21 13.19 - Plastic Toilet Compartments.
- C. Section 22 40 00 - Plumbing Fixtures: Under-lavatory pipe and supply covers.

1.03 REFERENCE STANDARDS

- A. ADA Standards - 2010 ADA Standards for Accessible Design.
- B. ASTM A269/A269M - Standard Specification for Seamless and Welded Austenitic Stainless Steel Tubing for General Service.
- C. ASTM A666 - Standard Specification for Annealed or Cold-Worked Austenitic Stainless Steel Sheet, Strip, Plate, and Flat Bar.
- D. ASTM B456 - Standard Specification for Electrodeposited Coatings of Copper Plus Nickel Plus Chromium and Nickel Plus Chromium.
- E. ASTM C1036 - Standard Specification for Flat Glass.
- F. ASTM C1048 - Standard Specification for Heat-Strengthened and Fully Tempered Flat Glass.
- G. ASTM C1503 - Standard Specification for Silvered Flat Glass Mirror.
- H. {RSTEMP#10005085}
- I. DSA IR 16-12 - Grab Bar Design and Connections.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordinate the work with the placement of internal wall reinforcement, concealed ceiling supports, and reinforcement of toilet partitions to receive anchor attachments.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Submit data on accessories describing size, finish, details of function, and attachment methods.
- C. Manufacturer's Installation Instructions: Indicate special procedures and conditions requiring special attention.
- D. Maintenance Materials: Furnish the following for District's use in maintenance of project:

FOR REFERENCE ONLY

1. See Section 01 60 00 - Product Requirements, for additional provisions.
2. Tools: One each of every special tool required for maintenance of fasteners and operable parts.

PART 2 PRODUCTS

2.01 REGULATORY REQUIREMENTS

- A. Provide toilet accessories meeting the requirements for the persons with disabilities of the California Building Code (CBC), Title 24 Part 2, {RS#10005085}, and 2010 ADA Standards, as amended.
- B. Accessible requirements:
 1. Elements of sanitary facilities shall be mounted at locations in compliance with {RS#10005085}-602 through 11B-612.
 2. Grab bars in toilet facilities and bathing facilities shall comply with {RS#10005085}-609.
 - a. Grab bars and any wall or other surfaces adjacent to grab bars shall be free of sharp or abrasive elements and shall have rounded edges.
 - b. The space around the grab bars shall be as follows:
 - 1) 1-1/2 inches between the grab bar and the wall. {RS#10005085}-609.3.
 - 2) 1-1/2 inches minimum between the grab bar and projecting objects below and at the ends.
 - 3) 12 inches minimum between the grab bar and projecting objects above.
 3. Toilet accessories required to be accessible shall be mounted with any operable part at maximum 40 inches above the finish floor. {RS#10005085}-603.5.
 4. The grab bar shall not project more than 3 inches into the 48 inches minimum clear space required in front of the water closet. {RS#10005085}-609.3.
 5. Toilet tissue dispensers are to be continuous flow type. {RS#10005085}-604.7.
 6. Toilet paper and feminine napkin disposals located on the grab bar side of the accessible toilet room or stall shall not project more than the grab bar or 3 inches from the finished wall surface nor be located closer than 1-1/2 inches clear of the tangent point of the grab bar. (Legacy DSA Interpretation.)
 - a. Accessories surface mounted above grab bar will restrict usability.
 7. All other accessories shall not project more than 4 inches from wall surface, but cannot encroach into any required clear space.
 8. Shower controls shall comply with {RS#10005085}-608.5.
 9. Shower seats shall comply with {RS#10005085}-610.3 Shower compartment seats.

2.02 MANUFACTURERS

- A. Commercial Toilet, Shower, and Bath Accessories:
 1. American Specialties, Inc: www.americanspecialties.com/#sle.
 2. Bobrick Washroom Equipment, Inc.: www.bobrick.com.

3. Bradley Corporation: www.bradleycorp.com/#sle.
 4. Gamco: www.gamcousa.com.
 5. Georgia-Pacific Professional: www.blue-connect.com/#sle.
 6. Kimberly-Clark: www.KCprofessional.com.
 7. Or Equal Substitutions: Section 01 60 00 - Product Requirements.
- B. Provide products of each category type by single manufacturer.

2.03 MATERIALS

- A. Accessories - General: Shop assembled, free of dents and scratches and packaged complete with anchors and fittings, steel anchor plates, adapters, and anchor components for installation.
1. Grind welded joints smooth.
 2. Fabricate units made of metal sheet of seamless sheets with flat surfaces.
- B. Stainless Steel Sheet: ASTM A666, Type 304.
- C. Stainless Steel Tubing: ASTM A269/A269M, Grade TP304 or TP316.
- D. Mirror Glass: Annealed float glass, ASTM C1036 Type I, Class 1, Quality Q2, with silvering, protective and physical characteristics complying with ASTM C1503.
- E. Mirror Glass: Tempered safety glass, ASTM C1048; and ASTM C1036 Type I, Class 1, Quality Q2, with silvering as required.
- F. Adhesive: Two component epoxy type, waterproof.
- G. Fasteners, Screws, and Bolts: Stainless steel except where fully concealed may be hot dip galvanized; tamper-proof; security type.
- H. Expansion Shields: Fiber, lead, or rubber as recommended by accessory manufacturer for component and substrate.

2.04 FINISHES

- A. Stainless Steel: Satin finish, unless otherwise noted.
- B. Chrome/Nickel Plating: ASTM B456, SC 2, polished finish, unless otherwise noted.

2.05 COMMERCIAL TOILET ACCESSORIES

- A. Toilet Paper Dispenser: Double roll, recessed, stainless steel unit with pivot hinge, tumbler lock.
1. Product: See schedule on Drawings.
 2. Basis of Design Product: Recessed Multi-Roll Toilet Tissue Dispenser B-3888 as manufactured by Bobrick Washroom Equipment, Inc., or approved equal.
- B. Toilet Paper Dispenser: Double roll, surface-mounted, stainless steel unit. Provide at semi-ambulatory toilet compartment with adjacent non-accessible compartment and where indicated.
1. Basis of Design Product: B-386 as manufactured by Bobrick Washroom Equipment, Inc., or approved equal.

FOR REFERENCE ONLY

- C. Combination Towel Dispenser/Waste Receptacle: Recessed with projecting waste receptacle, stainless steel; seamless wall flanges, continuous piano hinges.
 - 1. Waste receptacle liner: Reusable, heavy-duty vinyl.
 - 2. Towel dispenser capacity: 600 C-fold.
 - 3. Waste receptacle capacity: 12 gallons.
 - 4. Product: See schedule on Drawings.
 - 5. Basis of Design Product: Classic Series Recessed Convertible Paper Towel Dispenser and Waste Receptacle B-3944 as manufactured by Bobrick Washroom Equipment, Inc., or approved equal.
- D. Automated Soap Dispenser: Liquid soap dispenser, wall-mounted, with stainless steel cover and window to gauge soap level, tumbler lock.
- E. Soap Dispenser: Liquid soap dispenser, wall-mounted, surface, with stainless steel cover and horizontal stainless steel tank and working parts; push type soap valve, check valve, and window gauge refill indicator, tumbler lock.
 - 1. Minimum Capacity: 48 ounces.
 - 2. Product: See schedule on Drawings.
 - 3. Basis of Design Product: Classic Series Surface Mounted Soap Dispenser B-2111 as manufactured by Bobrick Washroom Equipment, Inc., or approved equal.
- F. Mirrors: Stainless steel framed, 1/4 inch thick annealed float glass; ASTM C1036.
 - 1. Annealed Float Glass: Silvering, protective and physical characteristics in compliance with ASTM C1503.
 - 2. Size: As indicated on drawings.
 - 3. Frame: 0.05 inch angle shapes, with mitered and welded and ground corners, and tamperproof hanging system; satin finish.
 - 4. Backing: Full-mirror sized, minimum 0.03 inch galvanized steel sheet and nonabsorptive filler material.
 - 5. Shelf: Stainless steel; gauge and finish to match mirror frame, turned down edges, welded to frame; 5 inches deep, full width of mirror.
- G. Seat Cover Dispenser: Stainless steel, surface-mounted, reloading by concealed opening at base, tumbler lock.
 - 1. Minimum capacity: 250 seat covers.
 - 2. Product: See schedule on Drawings.
 - 3. Basis of Design Product: Classic Series Surface Mounted Seat Cover Dispenser B-221 as manufactured by Bobrick Washroom Equipment, Inc., or approved equal.
- H. Grab Bars: Stainless steel, peened surface.
 - 1. Standard Duty Grab Bars:
 - a. Push/Pull Point Load: 250 pound-force, minimum.
 - b. Dimensions: 1-1/2 inch outside diameter, minimum 0.05 inch wall thickness, exposed flange mounting, 1-1/2 inch clearance between wall and inside of grab bar.

- c. Finish: Satin, with peened gripping surface (suffix.99).
- d. Length and Configuration: As indicated on drawings. Comply with {RS#10005085}-604.5.
 - 1) Minimum Length for Side Wall of Water Closet: 48 inches.
 - (a) At prefabricated partition, provide mid-span support of less than 36 inches with a ASTM A666, Type-304, 16 gauge, 0.0625 inch stainless steel with satin-finish back up plate and through-bolts at each mounting location. {RS#10005085}-604.5.1 and DSA IR 16-12
 - 2) Minimum Length for Rear Wall of Water Closet: 42 inches.
- e. Product: See schedule on Drawings.
- I. Sanitary Napkin Disposal Unit: Stainless steel, surface-mounted, self-closing door, locking bottom panel with full-length stainless steel piano-type hinge, removable receptacle.
 - 1. Product: See schedule on Drawings.
 - 2. Basis of Design Product: Recessed Sanitary Napkin Disposal B-353 as manufactured by Bobrick Washroom Equipment, Inc., or approved equal.

2.06 UNDER-LAVATORY PIPE AND SUPPLY COVERS

- A. Specified in 22 40 00 - Plumbing Fixtures.

2.07 UTILITY ROOM ACCESSORIES

- A. Utility Shelf:
 - 1. Description: With exposed edges turned down not less than 1/2 inch (13 mm) and supported by two triangular brackets welded to shelf underside.
 - 2. Size: 36 inches (914 mm) long by 8 inches (203 mm) deep.
 - 3. Material and Finish: Not less than nominal 0.05-inch- (1.3-mm-) thick stainless steel, No. 4 finish (satin).
 - 4. Product: See schedule on Drawings.
- B. Combination Utility Shelf/Mop and Broom Holder: 0.05 inch thick stainless steel, Type 304, with 1/2 inch returned edges, 0.06 inch steel wall brackets.
 - 1. Drying rod: Stainless steel, 1/4 inch diameter.
 - 2. Hooks: Two, 0.06 inch stainless steel rag hooks at shelf front.
 - 3. Mop/broom holders: Three spring-loaded rubber cam holders at shelf front.
 - 4. Length: 36 inches.
 - 5. Product: See schedule on Drawings.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify existing conditions before starting work.
- B. Verify exact location of accessories for installation.

FOR REFERENCE ONLY

- C. Before covering wall framing with gypsum board, examine framing to ensure that backing plates and grab bar mounting kits have been installed behind surface mounted accessories in such positions as to receive all attachment screws.
- D. Verify that pipes, vents, conduits and other construction features do not protrude into rough wall opening space required for recessed accessories.
- E. Verify that field measurements are as indicated on drawings.
- F. Verify installation of blocking, reinforcing plates, and concealed anchors in walls and ceilings.

3.02 PREPARATION

- A. Deliver inserts and rough-in frames to site for timely installation.
- B. Provide templates and rough-in measurements as required.

3.03 INSTALLATION

- A. Install accessories in accordance with manufacturers' instructions in locations indicated on drawings.
 - 1. Exception: Install surface mounted accessories other than grab bars with screws, molly or toggle bolts only to studs or through backing plates attached directly to studs.
 - 2. At combination units placed behind a grab bar set the perimeter trim tight against the backing board.
 - a. Face of this unit shall not project beyond the tile or applied finish face. Maintain the required 1-1/2 inch clearance.
 - b. Coordinate surrounding finish trim with bullnose tile, radius, or sloped profile trim.
- B. Install plumb and level, securely and rigidly anchored to substrate.
- C. Mounting Heights: As required by accessibility regulations, unless otherwise indicated.
 - 1. Grab Bars: As indicated on drawings.
 - a. Adult mounting height to be between minimum 33 inches to maximum 36 inches to top tangent point. CBC 11B-609.4 Position of Grab Bars.
 - 2. Mirrors: 40 inch, measured from floor to bottom of mirrored surface.
 - 3. Seat Cover Dispenser:
 - a. Shall not be located closer than 1-1/2 inches clear of the tangent point of the grab bar.
 - b. If surface mounted and located under the grab bar provide a minimum 5 inches clear under unit for refilling.
 - 4. Clothes Bumper/Coat Hook: 40 to 48 inches. CBC 11B-603.4 Coat hooks, shelves and medicine cabinets
 - 5. Shelf with Mop and Broom Holders: 40 to 48 inches. CBC 11B-603.4 Coat hooks, shelves and medicine cabinets
 - 6. Other Accessories: As indicated on drawings.

3.04 PROTECTION

- A. Protect installed accessories from damage due to subsequent construction operations.

3.05 SCHEDULE

A. Product Applications (Basis of Design)

1. **Single Occupant, accessible toilet room:**

- a. Framed Mirrors (sizes as indicated on Drawings)
 - 1) B-165 Channel Frame Glass.
 - 2) B-166 Channel Frame Glass with shelf.
 - 3) B-1556 Polished Stainless Steel Mirror.
- b. Unframed Mirror: See Section 08 83 00 - Mirrors.
- c. B-3888 Toilet Tissue Dispenser, recessed (two-roll, continuous flow).
- d. B-3094 Recessed Unisex/Female Tissue Dispenser, Sanitary Disposal.
- e. B-353 and B-354 Recessed Mounted Sanitary Napkin Disposal.
- f. B-221 Surface Mounted Seat Cover Dispenser.
- g. B-301 Recessed Mounted Seat Cover (in single accessible toilet.).
- h. B-2112 Soap Dispenser (Liquid), Surface Mounted.
- i. B-XXX Soap Dispenser (Liquid), Counter Mounted.
- j. B-359 Paper Towel Dispenser (Recessed)
- k. B-262 Paper Towel Dispenser (Surface Mounted).
- l. Paper Towel Dispenser / Waste Receptacle Combination
 - B-369 Recessed.
 - B-3944 Semi-recessed.
 - B-3699 Surface Mounted.
- m. B-37063 Sanitary Napkin Dispenser.

2. **Multi-Occupant with accessible toilet compartment(s):**

- a. Framed Mirrors (sizes as indicated on Drawings)
 - 1) B-165 Channel Frame Glass.
 - 2) B-166 Channel Frame Glass with shelf.
 - 3) B-1556 Polished Stainless Steel Mirror.
- b. Unframed Mirror: See Section 08 83 00 - Mirrors.
- c. B-3888 Toilet Tissue Dispenser, recessed (two-roll, continuous flow).
- d. B-2888 Toilet Tissue Dispenser (Standard stalls) (multi-roll, Surface Mounted).
- e. Jumbo Toilet Tissue Dispenser (Standard stalls) (multi-roll, Surface Mounted).
- f. B-386 Toilet Tissue Dispenser (Semi-Ambulatory) (multi-roll, Partition Mounted).
- g. B-3094 Recessed Unisex/Female Tissue Dispenser, Sanitary Disposal.
- h. B-353 Recessed Mounted Sanitary Napkin Disposal.
- i. B-254 Surface Mounted Sanitary Napkin Disposal.
- j. B-221 Surface Mounted Seat Cover Dispenser.

FOR REFERENCE ONLY

- k. B-301 Recessed Mounted Seat Cover (in single accessible compartment.).
 - l. Male toilet compartment (Combo seat cover, tissue dispenser):
 - 1) B-3471 Partition mounted.
 - B-34715 For unit to mount on left side of toilet (when seated on toilet).
 - 2) B-347 Center in partition for standard comp.
 - m. Female toilet compartment (seat cover, tissue dispenser, sanitary disposal):
 - 1) B-3571 Partition mounted.
 - B-35715 For unit to mount on left side of toilet (when seated on toilet).
 - 2) B-357 Center in partition for standard compartment.
 - n. B-2112 Soap Dispenser (Liquid), Surface Mounted
 - o. B-xxx Soap Dispenser (Liquid), Counter Mounted.
 - p. B-359 Paper Towel Dispenser (Recessed).
 - q. B-262 Paper Towel Dispenser (Surface Mounted).
 - r. Paper Towel Dispenser / Waste Receptacle Combination
 - B-369 Recessed.
 - B-3944 Semi-recessed.
 - B-3699 Surface Mounted.
 - s. B-37063 Sanitary Napkin Dispenser.
3. **Showers:**
- a. B-5181 Folding Shower Seat.
 - b. B-6806 (1-1/2 inch dia.) Grab Bar
 - c. Shower Curtain: See Section 10 21 23 - Cubicle Curtains and Track.
4. **General:**
- a. B-6806 Grab Bars 1-1/2 inches.
 - b. B-5806 Grab Bars 1-1/4 inches.
 - c. Protection for Disabled-Person at lavatories: LavGuard2 manufactured by Truebro, Inc.
 - d. Protection for Disabled-Person at counter sinks: BasinGuard manufactured by Truebro, Inc. UL Listing MH25426
 - e. B-262 Paper Towel Dispenser (Surface Mounted).
 - f. B-2116 Clothes Hook .
 - g. B-398 Medicine Cabinet, Recessed.
 - h. Electric Hand Dryers
5. **Maintenance:**
- a. B-223 Mop Rack (length as indicated on Drawings).

FOR REFERENCE ONLY

- b. B-3706-50 Napkin Dispenser (recessed).

END OF SECTION

SECTION 10 44 00 FIRE PROTECTION SPECIALTIES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Fire extinguishers.
- B. Fire blankets.
 - 1. At kitchens with open flame.
- C. Fire extinguisher cabinets.
- D. Accessories.

1.02 RELATED REQUIREMENTS

- A. Section 06 10 00 - Rough Carpentry: Wood blocking product and execution requirements.

1.03 REFERENCE STANDARDS

- A. FM (AG) - FM Approval Guide.
- B. Fire Extinguishers Standard: California Fire Code (CFC) section 906.
- C. Title 19 California Code of Regulations.
- D. ADA Standards - 2010 ADA Standards for Accessible Design.
- E. ANSI/UL 711 - Rating and Fire Testing of Fire Extinguishers.
- F. NFPA 10 - Standard for Portable Fire Extinguishers.
- G. NFPA 286 - Standard Methods of Fire Tests for Evaluating Contribution of Wall and Ceiling Interior Finish to Room Fire Growth.
- H. UL (DIR) - Online Certifications Directory.
- I. UL 300 - Standard for Fire Testing of Fire Extinguishing Systems for Protection of Commercial Cooking Equipment.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide extinguisher operational features, extinguisher ratings and classifications, color and finish, anchorage details, and installation instructions.
- C. Shop Drawings: Indicate locations of cabinets and cabinet physical dimensions.
- D. Manufacturer's Installation Instructions: Indicate special criteria and wall opening coordination requirements.
 - 1. Submit for fire extinguishers and cabinets, and indicate compliance with local and State fire regulations for extinguisher mounting heights and locations.
- E. Manufacturer's Certificate: Certify that products meet or exceed specified requirements.
- F. Maintenance Data: Include test, refill or recharge schedules and re-certification requirements.

1.05 FIELD CONDITIONS

- A. Do not install extinguishers when ambient temperature may cause freezing of extinguisher ingredients.

PART 2 PRODUCTS

2.01 REGULATORY REQUIREMENTS

- A. Conform to all requirements of the local and State Fire Marshal. Conform to all applicable requirements of the California Building Code (CBC), CFC, ADA Standards, and Title 19 CCR.
 - 1. Fire Extinguisher cabinets must comply with CBC Chapter 11B-305 Clear floor or ground space, 11B-307 Protruding Objects, CBC Chapter 11B-308 Reach Ranges, CBC Chapter 11B-309/811.4 Operable Parts, CBC Chapter 11B-403 Walking Surfaces, CBC Chapter 11B-811.3 Height.
 - 2. Comply with CBC Chapter 11B-205 Operable Parts and 309 Operable Parts; Controls and operating mechanisms shall be operable with one hand and shall not require tight grasping, pinching or twisting of the wrist. The force required to activate controls shall be no greater than 5 lbf (22.2 N) of force. CBC Chapter 11B-309.4 Operation.
- B. Fire Extinguisher Requirements: Conform to NFPA 10, California Fire Code and Title 19 requirements for portable fire extinguishers.
- C. Current listing by California State Fire Marshal.

2.02 MANUFACTURERS

- A. Fire Extinguishers:
 - 1. Activar Construction Products Group, Inc. - JL Industries; Cosmic Extinguisher - Multipurpose Chemical: www.activarcpg.com/#sle.
 - 2. Amerex; www.amerex-fire.com.
 - 3. Ansul, Inc. Sentry: www.ansul.com.
 - 4. Kidde, a unit of United Technologies Corp: www.kidde.com.
 - 5. Larsen's Manufacturing Co; Model No. MP5: www.larsensmfg.com.
 - 6. Nystrom, Inc: www.nystrom.com/sle.
 - 7. Potter-Roemer; Model 3005: www.potterroemer.com/#sle.
 - 8. Pyro-Chem, a Tyco Business: www.pyrochem.com/#sle.
 - 9. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Fire Extinguisher Cabinets and Accessories:
 - 1. Activar Construction Products Group, Inc. - JL Industries; Cosmopolitan Series: www.activarcpg.com/#sle.
 - 2. Kidde, a unit of United Technologies Corp: www.kidde.com.
 - 3. Larsen's Manufacturing Co: www.larsensmfg.com.
 - 4. Nystrom, Inc: www.nystrom.com.
 - 5. Potter-Roemer: www.potterroemer.com/#sle.

6. Strike First Corporation of America: www.strikefirstusa.com.
7. Substitutions: See Section 01 60 00 - Product Requirements.

2.03 FIRE EXTINGUISHERS

- A. Fire Extinguishers - General: Comply with product requirements of NFPA 10 and applicable codes, whichever is more stringent.
 1. Provide extinguishers labeled by UL (DIR) or FM (AG) for purpose specified and as indicated.
- B. Dry Chemical Type Fire Extinguishers: Carbon steel tank, with pressure gage. Fully serviced and tagged.
 1. Stored Pressure Operated: Deep Drawn.
 2. Class: 2-A: 20B:C.
 3. Size: 10 pound.
 4. Size and classification as scheduled.
 5. Finish: Baked polyester powder coat color as selected.
- C. Wet Chemical Type Fire Extinguishers: Stainless steel tank, with pressure gauge.
 1. Comply with CGA V-5 and CFC section 904.12.5.
 2. Class: K type.
 3. Size: 1.6 gallons.
 4. Size and classification as scheduled.
 5. Finish: Polished stainless steel.
 6. Temperature range: 32 degrees F to 120 degrees F.

2.04 FIRE EXTINGUISHER CABINETS

- A. Cabinet Construction: Non-fire rated.
 1. Formed stainless steel sheet; 0.036 inch thick base metal.
 2. Basis of Design Product; 6 inch stud: Cosmopolitan Stainless Steel FE Cabinet Recessed 1035V17LDVRF Flat Trim as manufactured by Activar, or approved equal.
 3. Basis of Design Product; 4 inch stud: Cosmopolitan Stainless Steel FE Cabinet Semi-Recessed 1036V17LDVRF 1-1/2" Square Trim as manufactured by Activar, or approved equal.
- B. Cabinet Configuration: Semi-recessed type.
 1. Size to accommodate accessories.
 2. Exterior nominal dimensions of 13-7/8 inch wide by 27-3/8 inch high by 6 inch deep.
 3. Trim: Flat rolled edge, with 13-7/8 inch wide face.
 4. Projected Trim: Returned to wall surface, with 3 inch projection, and 1.69 inch wide face.
 5. Provide cabinet enclosure with right angle inside corners and seams, and with formed perimeter trim and door stiles.

- C. Door: 0.036 inch metal thickness, reinforced for flatness and rigidity with roller type catch. Hinge doors for 180 degree opening with continuous piano hinge.
 - 1. Provide manufacturer's option for compliance with Americans with Disabilities Act (ADA) projection criteria and accessible handle.
 - 2. Latching and locking hardware operable with a single effort by lever-type hardware or other type hardware not requiring ability to grasp opening hardware and not requiring an opening force greater than 5 pounds.
- D. Door Style: Slot glazed style vertical duo-panel with glazing, continuous hinge, roller catch, zinc plated pull handle and cylinder lock.
 - 1. Door Glazing: Acrylic plastic, clear, 1/8 inch thick, flat shape and set in resilient channel glazing gasket.
- E. Cabinet Mounting Hardware: Appropriate to cabinet, with pre-drilled holes for placement of anchors.
- F. Fabrication: Weld, fill, and grind components smooth.
- G. Finish of Cabinet Exterior Trim and Door: No.4 - Brushed stainless steel.
- H. Finish of Cabinet Interior: White colored enamel.

2.05 ACCESSORIES

- A. Fire Blanket: Fire retardant treated wool; red, 62 by 84 inch size.
 - 1. Provide at locations where an open flame may occur, such as science rooms, CTE programs, and kitchens. (Per Education Code)
- B. Extinguisher Brackets: Formed steel, chrome-plated.
 - 1. Where indicated, at Custodial, Mechanical and Electric Rooms, provide surface mounted bracket with retainer straps.
 - 2. Provide brackets with 3-point connection within cabinets and for locations where fire extinguisher is wall-mounted without cabinet.
 - a. Bracket design shall prevent accidental dislodgement of extinguisher.
 - b. Provide size required for type and capacity of specified extinguisher.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify existing conditions before starting work.
- B. Verify rough openings for cabinet are correctly sized and located.

3.02 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Install cabinets in prepared recesses in walls. Verify recess dimensions for standard non-rated and fire rated where required.
- C. Install cabinets plumb and level in wall openings, 24 inches from finished floor to inside bottom of cabinet.

FOR REFERENCE ONLY

1. Cabinet installation shall conform to requirements of the Fire Marshal, CBC, and ADA for location and height of extinguisher.
 2. Place cabinet to position the extinguisher handle at maximum 48 inches AFF.
 3. Place Cabinet maximum 40 inches (1,016 mm) AFF to centerline of cabinet handle.
- D. Secure rigidly in place.
1. Use oval head fasteners with exposed surfaces of same finish as cabinet.
 2. Fasten cabinets to metal studs or framing with sheet metal screws
 3. Fasten cabinets to wood studs with full threaded wood screws or with sheet metal screws.
- E. Maintain acoustical integrity of walls by filling cavity around box with unfaced fiberglass insulation or by applying electrical outlet box acoustical sheeting to the back, top, bottom and sides.
- F. Place extinguishers in cabinets and on wall brackets.
1. Mount freestanding fire extinguishers on steel brackets on walls at locations indicated on drawings, with fire extinguisher handle located maximum 48-inches above finish floor. Mount steel brackets to solid backing.
 2. Mount fire extinguishers to brackets in all cabinets.
 3. Place fire extinguishers immediately prior to issuance of "Notice of Completion" or sooner if directed by Fire Marshal or District.

3.03 MAINTENANCE

- A. See Section 01 70 00 - Execution and Closeout Requirements, for additional requirements relating to maintenance service.
- B. Provide a separate maintenance contract for specified maintenance service.

3.04 SCHEDULES










- A. Provide extinguishers and cabinets in quantities and locations as indicated per Drawings, or as indicated by field inspection by Fire Marshall.
- B. Conform to CBC Section 906.
- C. Place the fire extinguishers based on the allowable maximum travel distance to extinguisher as indicated on Drawing and as follows:
 1. Class A = 75 feet
 2. Class B = CBC Table 906.3(2)

Hazard Type	Min. Extinguisher Rating	Max. Travel Distance
Light (Low)	5-B	30 Feet
	10-B	50 Feet
Ordinary (Moderate)	10-B	30 Feet
	20-B	50 Feet
Extra (High)	40-B	30 Feet
	80-B	50 Feet

FOR REFERENCE ONLY

3. Class C = 50 Feet
4. Class K = 30 Feet
 - a. Comply with CFC 906.4 for spacing and quantity.
 - 1) Maximum 30 feet from cooking device ("hazard").
- D. General Use: 1 Dry Chemical Type 2A-20BC, 10 lb. capacity, baked enamel finish extinguisher; Cabinet recessed mounting.
- E. Multi-Purpose Room: 1 Dry Chemical Type 4A-80BC, 10 lb. capacity, baked enamel finish extinguisher placed in specified cabinet.
- F. Kitchen: 1 fire blanket, 1 Dry Chemical Type 1A:K, 1.6 Gallon (6 liter) capacity, stainless steel finish extinguisher placed in specified cabinet.
 1. Ansul K-Guard Model K01-2 Hand Portable Extinguisher.
- G. Kitchens, Cabinet mounted:
 1. Type BC multi-purpose dry chemical with UL rating 40B:C, 5 pound size, with red glossy polyester coated steel cylinder, pressure gage, hose and horn, Maximum Height: 15 ¼-inch, Maximum Cylinder Diameter: 4 ½-inch . K type (wet chemical) for suppression system back-up. UL Rating 2A:K, 6 liters, 2 ½ gallons, with heavy duty stainless steel cylinder, internal diameter not to exceed 7 inches.

3.05 TYPES

Fire Class	Geometric Symbol	Pictogram	Intended Use	Mnemonic
A			Ordinary solid combustibles	A for "Ash"
B			Flammable liquids and gases	B for "Barrel"
C			Energized electrical equipment	C for "Current"
D		(none)	Combustible metals	D for "Dynamite"
K			Oils and fats	K for "Kitchen"

Fire extinguishing capacity is rated in accordance with ANSI/UL 711: Rating and Fire Testing of Fire Extinguishers.

The ratings are described using numbers preceding the class letter, such as 1-A:10-B:C.

The number preceding the A multiplied by 1.25 gives the equivalent extinguishing capability in gallons of water.

The number preceding the B indicates the size of fire in square feet that an ordinary user should be able to extinguish.

FOR REFERENCE ONLY

There is no additional rating for class C, as it only indicates that the extinguishing agent will not conduct electricity, and an extinguisher will never have a rating of just C.

END OF SECTION

SECTION 10 51 13 METAL LOCKERS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Metal lockers.

1.02 RELATED REQUIREMENTS

- A. Section 05 50 00 - Metal Fabrications.
- B. Section 06 10 00 - Rough Carpentry: Wood blocking and nailers.
- C. Section 09 21 16 - Gypsum Board Assemblies: Backing requirements.

1.03 REFERENCE STANDARDS

- A. ADA Standards - 2010 ADA Standards for Accessible Design.
- B. ASTM A1008/A1008M - Standard Specification for Steel, Sheet, Cold-Rolled, Carbon, Structural, High-Strength Low-Alloy, High-Strength Low-Alloy with Improved Formability, Required Hardness, Solution Hardened, and Bake Hardenable.
- C. {RSTEMP#10005085}

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Manufacturer's published data on locker construction, sizes, and accessories.
- C. Shop Drawings: Indicate locker plan layout, numbering plan.
 - 1. Submit with reference to Architect's detail numbers.
 - 2. Indicate lockers in detail, method of installation, fillers, trim, base and accessories, with actual dimensions of lockers for proper layout.
 - 3. Coordinate with available space to install lockers, as per field measurements.
- D. Color Selection samples: Provide three copies of manufacturer's standard color range (8 colors minimum).
 - 1. Provide one of the three copies on metal samples.
- E. Manufacturer's Installation Instructions: Indicate component installation assembly.

1.05 DELIVERY, STORAGE, AND HANDLING

- A. Protect locker finish and adjacent surfaces from damage.

1.06 WARRANTY

- A. See Section 01 78 00 - Closeout Submittals for additional warranty requirements.
- B. Manufacturer Warranty: Provide a lifetime warranty for materials and workmanship. Complete forms in District's name and register with manufacturer.

- C. Installer Warranty: Provide 2-year warranty for workmanship, excluding the finish and vandalism commencing on the Date of Final Inspection. Complete forms in District's name and register with installer.
- D. Finish Warranty: Provide 5-year manufacturer warranty against excessive degradation of exterior finish. Include provision for replacement of units with excessive fading, chalking, or flaking. Complete forms in District's name and register with warrantor.
 - 1. Excluding finish, vandalism and improper installation.

PART 2 PRODUCTS

2.01 REGULATORY REQUIREMENTS

- A. Provide lockers meeting the requirements for the physically disabled of the California Code of Regulations (CCR), Title 24, Part 2, and ADA Standards, as amended. {RS#10005085}-225.2.1 and 811.
 - 1. Where lockers are provided, at least 5%, but no fewer than one of each type must comply with {RS#10005085}-811.
 - 2. Provide latch and locking hardware that does not require twisting, pinching, or grasping to operate. {RS#10005085}-309.4.
 - 3. Provide shelf and pole at 48 inches maximum AFF and lower shelf at 15 inches minimum AFF. {RS#10005085}-308 and 811.3

2.02 LOCKER APPLICATIONS

- A. Wardrobe Lockers: Metal lockers, wall mounted with matching closed base.
 - 1. LOCK-1 District's Basis of Design Product: match existing as manufactured by Penco, or approved equal.
 - 2. Width: 15 inches.
 - 3. Depth: 15 inches.
 - 4. Height: 72 inches.
 - 5. Configuration: Two tier.
 - 6. Fittings: Size and configuration as indicated on drawings.
 - a. Hat shelf.
 - b. Single shoe shelf.
 - c. Coat rod.
 - d. Hooks: One single prong.
 - 7. Ventilation: Louvers at top and bottom of door panel.
 - 8. Locking: Padlock hasps, for padlocks provided by Owner.
 - a. Locking Action: Positive, automatic type, whereby locker may be locked when open, then closed without unlocking.
 - 9. Provide sloped top.
 - 10. Color: To be selected from manufacturer's full range by Architect.

2.03 METAL LOCKERS

- A. Accessibility: Design units indicated on drawings as 'accessible' to comply with CBC Ch. 11B and ADA Standards.
- B. Locker Case Construction:
 - 1. Heavy-Duty, Welded Construction: Made of formed and welded together sheet steel; metal edges finished smooth without burrs; baked enamel or powder coat finished inside and out.
 - a. Assembly: Do not use bolts, screws, or rivets to assemble locker bodies.
 - b. Locker Body Components: Formed and flanged from steel sheet of the following type and minimum thicknesses:
 - 1) Unperforated Steel Sheet: Commercial Steel (CS), Type B, supplied for exposed applications and complying with ASTM A1008/A1008M and the following:
 - (a) Uncoated.
 - 2) Body and Shelves: 16 gauge, 0.0598 inch.
 - 3) Backs: 18 gauge, 0.0478 inch.
 - 4) Reinforced Bottom:
 - (a) Provide 16 gauge spacer channel welded to locker bottom from front to back for a more secure installation Spacer channel to have full height 1/2-inch ID tube welded over anchor holes to eliminate deflection upon locker installation.
 - 5) Base: As indicated on Drawings.
 - (a) Height: 4 inches.
 - c. Frames: Formed channel shape, welded and ground flush, welded to body, resilient gaskets and latching for quiet operation.
 - d. Where ends or sides are exposed, provide flush panel closures.
 - e. Provide filler strips where indicated or required, securely attached to lockers.
- C. Doors: Channel edge; welded construction, manufacturer's standard stiffeners, grind and finish edges smooth.
 - 1. Door Thickness: 16 gauge, 0.0598 inch, minimum.
 - 2. Form recess for operating handle and locking device.
- D. Latches and Door Handles: Manufacturer's standard.
 - 1. Latching: Manufacturer's standard for locking arrangement selected.
 - a. Accessible Lockers: Three-point projecting turn handle.
 - 1) Provide {RS#10005085} and ADA Standards compliant lock/latch.
 - 2) Basis of Design Product: 163MKA Built-in Combination Lock for Lift Handle ADA lockers as manufactured by Master Lock, or approved equal.
 - b. Three-Point Lift Handle Gravity Latch: Pocket-mounted, provide for doors 18 inches or taller.

FOR REFERENCE ONLY

- 1) Handle Pocket, Recess: Stainless steel flush-mounted cup recessed into face of door.
 - 2) Handle: Steel finger lift mechanism with exposed portion encased in molded plastic trigger.
 - (a) Padlock Eye: Integral with lift trigger, sized for use with 9/32 inch diameter padlock shackles.
 - 3) Latching Mechanism: Spring activated nylon slide latch enclosed in steel latch channel allows closing of door while padlock or built-in lock is in position.
 - 4) Rubber bumpers riveted to door stops for silent operation.
- E. Cup, Pocket: Manufacturer's standard, with integral pull, and recessed surface punched for installation of lock, latch lift mechanism, and number plate.
- F. Hinges: Continuous piano hinge with powder coat finish to match locker color.
- G. Sloped Top: 20 gauge, 0.0359 inch, with closed ends.
- H. Trim: 20 gauge, 0.0359 inch.
- I. Coat Hooks: Stainless steel or zinc-plated steel.
- J. Number Plates: Provide rectangular shaped aluminum plates. Form numbers 1 inch high of block font style with ADA designation, in contrasting color.
- K. Locks: Locker manufacturer's standard type indicated in Applications article above.
- L. Locker Groups: Gang lockers in groups of two and assemble in factory for shipment as a single unit.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that prepared bases are in correct position and configuration.
- B. Verify bases and embedded anchors are properly sized.

3.02 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Place and secure on prepared base.
- C. Install lockers plumb and square.
- D. Secure lockers with anchor devices to suit substrate materials. Minimum Pullout Force: 100 pounds.
- E. Bolt adjoining locker units together to provide rigid installation.
 1. Connect at four points, two at top and two at bottom, using 1/4 inch bolts.
- F. Install end panels, filler panels, and sloped tops.
- G. Install fittings if not factory installed.
- H. Replace components that do not operate smoothly.

FOR REFERENCE ONLY

3.03 CLEANING

- A. Clean locker interiors and exterior surfaces.

END OF SECTION

SECTION 10 75 00 FLAGPOLES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Aluminum Flagpoles.

1.02 RELATED REQUIREMENTS

- A. Section 03 30 00 - Cast-in-Place Concrete: Concrete base and foundation construction.
- B. Section 01 10 00 - Summary: District furnished products; flags.
- C. Section 31 23 16 - Excavation: Foundation earthwork.

1.03 REFERENCE STANDARDS

- A. 36 CFR 1191 - Americans with Disabilities Act (ADA) Accessibility Guidelines for Buildings and Facilities; Architectural Barriers Act (ABA) Accessibility Guidelines.
- B. AASHTO M 36 - Standard Specification for Corrugated Steel Pipe, Metallic-Coated, for Sewers and Drains.
- C. ADA Standards - 2010 ADA Standards for Accessible Design.
- D. ASTM A123/A123M - Standard Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products.
- E. ASTM B221 - Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes.
- F. ASTM B221M - Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes (Metric).
- G. {RSTEMP#10005085}
- H. NAAMM FP 1001 - Guide Specifications for Design Loads of Metal Flagpoles.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide data on pole, accessories, and configurations for each type of flagpole required. Include data for fittings and accessories.
- C. Shop Drawings: Indicate detailed dimensions, base details, anchor requirements, and imposed loads.
- D. Calculations: Submit engineering calculations and design for flagpole foundation assembly and pole per loads of CBC Chapter 16A.
 - 1. Design criteria as appropriate to the locale of the Project: NAAMM FP 1001 .
 - 2. Furnish calculations and drawings in a form acceptable to Architect.
 - 3. Calculations and foundation design shall be prepared and signed by a civil or structural engineer currently registered to practice in the State of California.

- E. Certificate: Submit professional structural engineer's certification that design complies with requirements of the contract documents.
- F. Manufacturer's Instructions: Submit for each product specified in this section. Include instructions for examination, preparation, and protection of adjacent work.
- G. Maintenance Data: Provide lubrication and periodic maintenance requirement schedules and cleaning.

1.05 QUALITY ASSURANCE

- A. Manufacturer's Qualifications: Firm regularly engaged in manufacture of products specified in this section, and whose products have been in satisfactory use under similar service conditions for not less than 5 years.
- B. Installer's Qualifications: Firm regularly engaged, for the preceding five years, in the installation of flagpoles of equivalent type and physical characteristics to those required. If requested by Architect submit verifiable list of not less than five projects of equivalent type successfully completed within the preceding two years.

1.06 DELIVERY, STORAGE, AND HANDLING

- A. Spiral wrap flagpole with protective covering and pack in protective shipping tubes or containers.
- B. Protect flagpole and accessories from damage or moisture.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Flagpoles:
 - 1. Baartol Company, Inc., a division of Eder Flag Mfg. Co. Inc.; Architectural Series, Model EC("height"): www.ederflag.com
 - 2. Concord Industries, Inc: www.concordindustries.com.
 - 3. Morgan-Francis Flagpoles & Accessories: www.morgan-francis.com/#sle.
 - 4. Flagpole Warehouse Division of The Flag Company, Inc.: www.flagpolewarehouse.com.
 - 5. Pole-Tech Co., Inc: www.polettech.com.
 - 6. Substitutions: See Section 01 60 00 - Product Requirements.

2.02 FLAGPOLES

- A. Flagpoles: Designed in accordance with NAAMM FP 1001
 - 1. Material: Aluminum.
 - 2. Design: Cone tapered.
 - 3. Mounting: Ground mounted type.
 - 4. Outside Butt Diameter: 5 inches.
 - 5. Outside Tip Diameter: 3.5 inches.
 - 6. Nominal Wall Thickness: 0.188 inches.

7. Nominal Height: 21 ft; measured from nominal ground elevation.
 8. Halyard: Internal type, electric operation.
- B. Performance Requirements:
1. Wind Pressure Loading on Flagpole with Flag: Resistant without permanent deformation to 110 miles/hr wind speed, in accordance with NAAMM FP 1001; the factor of safety used is 2.5.
- C. Pole Construction: Construct pole and ship to site in one piece if possible. If more than one piece is necessary, provide snug- fitting, precision joints with self-aligning, internal splicing sleeve arrangement for weather-tight hairline field joints.

2.03 POLE MATERIALS

- A. Aluminum: ASTM B221 (ASTM B 221M) , 6063 alloy , T6 temper.

2.04 ACCESSORIES

- A. Finial Ball: Aluminum, 6 inch diameter, Gold anodized.
- B. Truck Assembly: Cast aluminum; revolving, stainless steel ball bearings, non-fouling.
- C. Winged Cleats: 9 inch size, aluminum with stainless steel fastenings, one per halyard.
1. Locate top of cleats maximum 47 inches above finish walking surface.
 2. Comply with CBC 11B-308, ADA Standards, and 36 CFR 1191.
 - a. DSA Note: A typical winged cleat, completely within 48 inches of the finish surface, is interpreted to meet the accessibility requirement of {RS#10005085}-309.4.
- D. Halyard: 5/16 inch diameter nylon, braided, white.
1. Provide 2 continuous halyards for each flagpole
 2. Halyard Flag Snaps: Provide 2 swivel snaps per halyard, chromium-plated bronze.
- E. Connecting Sleeve For Multiple Section Poles: Same material as pole, precision fit for field assembly of pole, concealed fasteners.
- F. Primer: Zinc chromate type.

2.05 MOUNTING COMPONENTS

- A. Foundation Tube Sleeve: AASHTO M 36, corrugated 16 gage, 0.0598 inch steel, galvanized, depth of 38-1/2 inches as indicated.
1. Steel centering wedges: Minimum 1/8 inch thick wedges, welded to sleeve plate inside foundation sleeve for the purpose of centering pole.
- B. Pole Base Attachment: Flush; steel base with base cover.
1. Foundation support plate: Square steel plate welded to electrical grounding spike at base of concrete foundation.
 - a. Minimum edge dimension of square plate: 6-inches.
 - b. Minimum thickness: 3/16 inch.
 2. Provide manufacturer's standard flash collar, finished to match flagpole.
- C. Lightning Ground Cable: Copper No. 6 AWG, soft drawn.

2.06 FINISHING

- A. Metal Surfaces in Contact With Concrete: Asphaltic paint.
- B. Concealed Steel Surfaces: Galvanized to ASTM A123/A123M requirements.
- C. Aluminum: Mill finish.
- D. Finial: Gold anodized finish.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that concrete foundation is ready to receive work and dimensions are as indicated on shop drawings.
- B. Verify an adjacent 30 x 48 inch clear firm, stable and level surface area for clear access. CBC Ch. 11B and ADA Standards.

3.02 PREPARATION

- A. Coat metal sleeve surfaces below grade and surfaces in contact with dissimilar materials with asphaltic paint.

3.03 REGULATORY REQUIREMENTS

- A. When flagpoles are provided for the raising and lowering of the flag, accessible operation is required. Flagpoles with accessible hardware, on an accessible route, within accessible reach from a firm stable and level, minimum 30"x48" clear floor space shall be provided. Note that a typical winged cleat, completely within 48" of the finish grade, is interpreted to meet the accessibility requirement of CBC Section 11B-309.4.

3.04 INSTALLATION

- A. Install flagpole , base assembly, and fittings in accordance with manufacturer's instructions.
- B. Electrically ground flagpole installation.
- C. Install foundation plate and centering wedges for flagpoles base set in concrete base and fasten.

3.05 TOLERANCES

- A. Maximum Variation From Plumb: 1 inch.

3.06 ADJUSTING

- A. Adjust operating devices so that halyard and flag function smoothly.

END OF SECTION

FOR REFERENCE ONLY

SECTION 11 40 00

FOODSERVICE EQUIPMENT

PART 1 - GENERAL

1.01 SUMMARY

- A. Foodservice Equipment, including storage, preparation and serving equipment, as indicated on the Foodservice Equipment drawings and in ARTICLE 3.06 - EQUIPMENT SCHEDULE, herein. The Foodservice Equipment drawings form part of these specifications.
- B. Stainless steel fabrications, including countertops, cabinetry and corner guards
- C. Plumbing, including faucets, drains and fittings for sinks built into Foodservice Equipment
- D. Exhaust Hoods and related Ventilation
- E. Walk-In Cooler and Freezer

1.02 RELATED SECTIONS

- A. Division 1 Section - Product Requirements: Conditions for acceptance of products by manufacturers and for substitutions. Unless specifically noted, no substitutions will be considered.
- B. Division 1 Section - Warranty
- C. Division 3 Section - Cast-In-Place Concrete: Concrete curbs, pads and depressions
- D. Division 5 Section - Metal Fabrications: Metal supports and anchors to concrete and masonry
- E. Division 7 Section - Joint Sealers/Sealants: Joint sealing for weather tightness, waterproofing and acoustical seals
- F. Divisions 22 & 23 Section - Basic Mechanical Requirements: General requirements, in addition to those specified, as applicable to plumbing, fire protection and ventilating work associated with foodservice equipment
- G. Divisions 22 & 23 Section - Supports, Anchors and Seals: General requirements for supports and anchors for pipe and duct systems for foodservice equipment
- H. Division 26 Section - Basic Electrical Requirements: General requirements, in addition to those specified, as applicable to electrical work associated with foodservice equipment

1.03 REFERENCE STANDARDS

- A. ASME BPVC-IV - Boiler and Pressure Vessel Code, Section IV - Rules for Construction of Heating Boilers; 2016.
- B. ASTM A1011/A1011M - Standard Specification for Steel, Sheet and Strip, Hot-Rolled, Carbon, Structural, High-Strength Low-Alloy, High-Strength Low-Alloy with Improved Formability, and Ultra-High Strength; 2016.
- C. ASTM A554 - Standard Specification for Welded Stainless Steel Mechanical Tubing; 2016.
- D. ASTM A653/A653M - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process; 2016.
- E. ASTM A666 - Standard Specification for Annealed or Cold-Worked Austenitic Stainless Steel Sheet, Strip, Plate, and Flat Bar; 2016.

Twin Rivers Unified School District Madison Elementary School Modernization RCA Project No. 1-104-02		Foodservice Equipment 11 40 00 - 1
---	--	---------------------------------------

FOR REFERENCE ONLY

- F. ASTM A924/A924M - Standard Specification for General Requirements for Sheet Steel, Metallic-Coated by the Hot-Dip Process; 2016.
- G. ASTM B209 - Standard Specification for Aluminum and Aluminum-Alloy Sheet and Plate; 2016.
- H. ASTM B221 - Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes; 2016.
- I. ASTM C920 - Standard Specification for Elastomeric Joint Sealants; 2016.
- J. NFPA 54 - National Fuel Gas Code; 2016.
- K. NFPA 70 - National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- L. NFPA 96 - Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations; 2016.
- M. NHLA G-101 - Rules for the Measurement & Inspection of Hardwood & Cypress; 2016.
- N. NSF 2 - Food Equipment; 2016.
- O. NSF 51 - Plastic Materials and Components Used in Food Equipment; 2016.
- P. NSF 7 - Commercial Refrigerators and Freezers; 2016.

1.04 SUBMITTALS

- A. General: The Foodservice Design Consultant's design documents are not acceptable as submittal set.
 - 1. Submit electronic version of each Drawing document. Prepare drawings at the following minimum scales:
 - a. Plans 1/4-inches = 1-foot-0-inches
 - b. Elevations 1/2-inches = 1-foot-0-inches
 - c. Sections 1/2-inches = 1-foot-0-inches
 - 2. Submit electronic set of Product Data.
 - 3. Forward complete submittal package to expedite review and avoid construction delay. Incomplete submittals will not be reviewed.
 - 4. After return of reviewed submittal, make revisions as necessary and resubmit as required.
 - 5. Submit certification of operational tests per PART 3.2 - FIELD QUALITY CONTROL, herein.
- B. Drawings:
 - 1. Submit dimensioned rough-in drawings of the project site showing Plumbing, HVAC and Electrical Service requirements. Drawings to indicate rough-in data for services based on specified equipment. Provide final exact locations, dimensions and characteristics of service and connections to suit requirements of Foodservice Equipment to be provided.
 - 2. Submit dimensioned fabrication drawings for custom fabricated equipment including plans, elevations, and sections, showing materials and gauges used.
 - 3. Wiring Diagrams: Submit details of wiring for power and control systems; differentiate between Manufacturer Installed wiring and Field Installed wiring.
- C. Product Data:

Twin Rivers Unified School District Madison Elementary School Modernization RCA Project No. 1-104-02		Foodservice Equipment 11 40 00 - 2
---	--	---------------------------------------

FOR REFERENCE ONLY

1. Cover Sheet: The Cover Sheet must contain the following information to be valid and complete:
 - a. Item number
 - b. Manufacturer
 - c. Model number
 - d. Quantity
 - e. Performance data
 - f. Construction methods and materials
 - g. Furnished accessories
 - h. Installation methods and instructions, including curbs, legs, casters, etc.
 - i. Power and fuel requirements with BTU ratings
 - j. Water and drainage requirements, including required PSI
 - k. Service connection requirements
 - l. Exterior finishes
 - m. Coordination notes to the Contractors not within the FSEC's scope of work
 2. Cut Sheets: A catalog Cut Sheet or brochure of all stock manufactured equipment (buy-outs) shall be collated with the aforementioned cover sheets.
 - a. Cut Sheet shall be an original or first generation copy.
 - b. Fax copies will not be accepted.
 - c. If a Cut Sheet or brochure is not obtainable for a specific buy-out item, insert a filler sheet with all required information in typewritten form.
 3. Maintenance Data: Provide operation manuals and maintenance data for Foodservice Equipment for inclusion in the Operation and Maintenance Manual.
 4. For District Furnished Equipment: The Contractor shall be responsible for providing the operation manuals and maintenance data. The Contractor shall coordinate with the District who will receive District Furnished Equipment.
- D. Samples: Submit 8-inch squares of materials and 12-inch lengths of running members and trim for all exposed finishes, and for custom fabricated equipment.

1.05 QUALITY ASSURANCE

- A. Manufacturers' Qualifications: Firms shall have been regularly engaged in the manufacture of Foodservice Equipment of the types, capacities, and sizes required, whose products have been in satisfactory use in similar service for no fewer than five (5) projects.
- B. Installer's Qualifications: Installer shall have completed no fewer than five (5) Foodservice Installations similar in material, design, and extent to that indicated for this Project, which have resulted in satisfactory in-service performance.
- C. Codes and Standards:
 1. NSF Standards: Comply with applicable National Sanitation Foundation (NSF) standards and recommended criteria including NSF 2 and NSF 7. Provide each principal item of Foodservice Equipment with a NSF Seal of Approval.

Twin Rivers Unified School District Madison Elementary School Modernization RCA Project No. 1-104-02		Foodservice Equipment 11 40 00 - 3
---	--	---------------------------------------

FOR REFERENCE ONLY

2. UL Labels: Provide Underwriters Laboratories, Inc. (UL) labels on prime electrical components of Foodservice Equipment. Provide UL "recognized marking" on other items with electrical components, signifying listing by UL, where available.
3. ANSI Standards: Comply with applicable American National Standards Institute (ANSI) standards for electric-powered and gas-burning appliances, for piping to compressed-gas cylinders, and for plumbing fittings including vacuum breakers and air gaps to prevent siphonage in water piping.
4. NFPA Codes: Install Foodservice Equipment in accordance with the following National Fire Protection Association (NFPA) codes:
 - a. NFPA 54 - National Fuel Gas Code.
 - b. NFPA 70 - National Electrical Code current adopted edition with State amendments.
 - c. NFPA 96 - Removal of Smoke and Grease-Laden Vapors from Commercial Cooking Equipment.
5. ASME Boiler Code: Construct steam-generating and closed steam-heating equipment to comply with American Society of Mechanical Engineers (ASME BPVC-IV) Boiler and Pressure Vessel Code; Section IV for units not exceeding 15 psi or 250 degrees F, or Section I for higher pressure/temperature units.
6. Refrigeration: Use current refrigeration on all self-contained and remote refrigerated items including, but not limited to ice machines, refrigerators and freezers. The refrigerant shall be current, new (not recycled), and readily available for a minimum of ten (10) years. For further clarification refer to PART 2.6 - REFRIGERATION EQUIPMENT, herein.
7. Accessibility
 - a. Where provided, check-out aisles, sales counters, food service lines, queues, and waiting lines shall comply with CBC Section 11B-227 and 11B-904.
 - b. Foodservice aisles shall be a minimum of 36 inches wide.
 - c. The top of tray slides shall be 28 inches minimum and 34 inches maximum above the finish floor or ground.
 - d. Foodservice equipment required to be accessible shall conform to all reach requirements in CBC Figures 11B-308.2.1 - 11B-308.3.2 (CBC Section 11B-308).
8. Space and elements within foodservice employee work areas shall meet the requirements of CBC Section 11B-203.9.
9. Lockers shall have latch and locking hardware that does not require tight grasping, tight pinching, or twisting of the wrist to operate. Provide shelf and pole at 48" max AFF and lower shelf at 15" min AFF (Reach requirements). Provide AT LEAST 5% of total lockers BUT NO FEWER THAN ONE OF EACH TYPE OF LOCKERS SHALL BE ACCESSIBLE per CBC Section 11B-811.
10. Guidelines for Seismic Restraint of Kitchen Equipment as published by SMACNA and approved by DSA.
11. Welding per California Fire Code Chapter 26

1.06 DELIVERY, STORAGE, AND HANDLING

- A. Delivery: Deliver Foodservice Equipment in containers designed to protect the equipment and finish until installation. Make arrangements to receive equipment, when required, at the project site or to hold in a warehouse until delivery can be made to the job site.
- B. Storage: Store Foodservice Equipment in the original containers and in a location to provide adequate protection to equipment while not interfering with other construction operations.
- C. Handling: Handle Foodservice Equipment carefully to avoid damage to components, enclosures, and finish. Do not install damaged Foodservice Equipment. Replace and return damaged components to the Manufacturer.
- D. District Furnished Equipment: The Contractor shall receive, accept and store the District Furnished Equipment until installation. The Contractor shall assume responsibility for the equipment and its condition upon receipt of the equipment by him or his representative.

1.07 PROJECT CONDITIONS

- A. Field Measurements: Take field measurements before ordering and fabrication, to assure accurate fit of fabricated equipment.
- B. Available Services: Verify electrical service characteristics and water, steam, and gas service pressures. Provide pressure-regulating valves where required for proper operation of equipment.

1.08 SUBSTITUTION

- A. Substitution of Materials and Equipment: Whenever a material, article, or piece of equipment is identified on the Drawings or in the Specifications by reference to manufacturers' or vendors' names, trade name, catalog numbers, or the like, it is so identified for the purpose of establishing a standard. Substitute items shall be submitted to District at least ten days before bid date for review and consideration. Items that are acceptable (with District's written approval) shall be so stated in an Addendum.

1.09 WARRANTIES

- A. Special Project Warranty: The Contractor shall ensure that the Manufacturer of Refrigeration Compressors shall provide a written warranty signed by the Manufacturer, agreeing to replace or repair, within a five-year warranty period, Refrigeration Compressors with inadequate and/or defective materials and/or workmanship, including leakage, breakage, improper assembly, or failure to perform as required, provided Manufacturer's instructions for handling, installing, protecting, and maintaining units have been adhered to during warranty period. Two-year Labor warranty shall also be provided.
- B. All Other Warranties: The warranty period for all items furnished (other than the aforementioned) shall be guaranteed against defects in workmanship and material for a minimum period of two (2) years. This warranty shall include both Parts and Labor.
- C. The Contractor shall be responsible for returning all warranty cards to the Manufacturers as required. Should he fail to return the warranty cards, the Contractor shall be responsible for providing the same warranty to the District as required by the Manufacturer.
- D. Refer to Division 1 Section - Warranty for warranty format.

Twin Rivers Unified School District Madison Elementary School Modernization RCA Project No. 1-104-02		Foodservice Equipment 11 40 00 - 5
---	--	---------------------------------------

PART 2 - PRODUCTS

2.01 MATERIALS

- A. Stock Manufactured Items: Refer to ARTICLE 3.06 - EQUIPMENT SCHEDULE, herein.
- B. Stainless Steel: Provide ASTM A666 / AISI Type 304 non-magnetic sheets, free of buckles, waves, and surface imperfections; Blend and regrain as required to effect matching and continuous finished product..
 - 1. Finish for exposed surfaces to be No. 4 polished, unless specified otherwise.
 - 2. Protective covering shall be provided on all polished surfaces of stainless steel sheet work, and retained and maintained until time of final testing, cleaning, start-up, and Substantial Completion.
- C. Galvanized Sheet Steel: Use only if specified; comply with ASTM specifications for 'zinc-coated' (galvanized) iron or steel sheets, coils and cut lengths; it shall be mild, low carbon steel, zinc coated; ASTM A653/A653M, except for extensive forming; ASTM A924/A924M, G90 zinc coating, chemical treatment. A-98 coating shall be 1.25 oz per square foot coating class, also known as 'commercial'.
- D. Sheet Steel: Provide ASTM A1011/A1011M hot-rolled carbon steel.
- E. Stainless Steel Tube: Provide ASTM A554, Type 304 with No. 4 polished finish. All tubing shall be round unless specified otherwise.
- F. Aluminum: Provide ASTM B209 sheet and plate, ASTM B221 extrusions, 0.40-mil clear anodized finish where exposed, unless specified otherwise.
- G. White Metal: Provide corrosion-resistant metal containing not less than 21 percent nickel. Make castings free from pit marks, runs, checks, burrs, and other imperfections; rough grind, polish, and buff to bright luster.
 - 1. In lieu of white metal castings, Type 302 18-8 stainless steel die-cast or stamped may be used.
- H. Plastic Materials and Components: Except for Plastic Laminate, provide plastic materials and components that comply with NSF 51.
- I. Hardwood Work Surfaces: Provide laminated edge-grained hard maple (Acer Saccharum), NHLA G-101 First Grade with knots, holes, and other blemishes culled out, kiln dried at 8 percent or less moisture, waterproof glued, machined, sanded, and finished with NSF-approved oil sealer. Provide minimum 2-1/4-inch thickness unless specified otherwise.
- J. Sound Deadening: Provide coating of sound deadening material at underside of all stainless steel tops, drainboards, dishtables, and sinks. Sound deadening material to consist of NSF component smooth flowing Latex Sound Deadener, which is non-aging, does not become brittle and may be painted when dry.
- K. Sealants: Provide ASTM C920, Type S, Grade NS, Class 25, Use NT. When fully cured and washed, sealant shall meet the requirements of the Food and Drug Administration Regulation 21 CFR 177.2600 for use in areas where sealant comes in contact with food.
 - 1. The District will select the color from the manufacturer's standard colors.
 - 2. Backer Rod shall be closed-cell polyethylene rod stock, larger than joint width.

- L. Gaskets: Provide solid or hollow (not cellular) neoprene or PVC light gray gaskets, minimum 40 Shore A hardness, self-adhesive or prepared for either adhesive application or mechanical anchorage.

2.02 WELDING

- A. Welding must comply with California Fire Code Chapter 26.
- B. All welding shall utilize the heliarc method with welding rod of the same composition as the sheets or parts to be joined.
- C. Welds shall be complete, strong and ductile with all excess metal ground and joints finished smooth to match adjoining surfaces.
- D. Welds shall be free of mechanical imperfections such as gas holes, pits, cracks, etc., and shall be continuously welded so that the fixtures shall appear as one-piece construction.
- E. Butt welds made by spot solder and finished by grinding shall not be acceptable.
- F. Spot welds shall have a maximum space of at least 1/4-inch length of the welding material at a maximum space of 4-inches from center to center. Weld spacing at the ends of the channel battens shall not exceed 2-inch centers.
- G. In no case shall soldering be considered as a replacement for welding, nor shall any soldering operation be done where dependence is placed on stability and strength of the joint.
- H. Welds made of spot welding straps under seams and filling in with solder will not be acceptable.
- I. Fixtures shall be shop fabricated of one piece and shipped to the job completely assembled whenever possible. Equipment too large to transport or enter the building as one piece shall be constructed so that the field joints can be welded at the job site.
- J. All body joints made in the field shall be closely butted together, pulled together in the field and tightly belted on the inside or a concealed location.
- K. All exposed joints shall be ground flush with adjoining material and finished to harmonize therewith.
- L. Whenever material has been sunk or depressed by welding operation, such depression shall be suitably hammered and peened flush with the adjoining surface and, if necessary, again ground to eliminate low spots. In all cases, the grain of rough grinding shall be removed by successive fine polishing operations.
- M. All unexposed welded joints on undershelves of tables or counters in stainless steel construction shall be suitably coated at the factory with an approved metallic based paint.
- N. After galvanized steel members have been welded, all welds and areas where galvanizing has been damaged shall have a zinc dust coating applied.
- O. Butt joints and contact joints, wherever they occur, shall be close fitting and shall not require a filler. Wherever sheared edges occur, they shall be free of burrs, fins, and irregular projections, and shall be finished to obviate all danger of cutting or laceration when the hand is drawn over them. In no case shall overlapping materials be acceptable where miters or bull nosed corners occur.
- P. The grain of polishing shall run in the same direction on all horizontal and on all vertical surfaces of each item of fabricated equipment except in the case where the finish of the horizontal sections of each shall terminate in a mitered edge. Where sinks and adjacent drainboards are

equipped with a splash, the grain of polishing shall be consistent in the direction throughout the length of the splash and sink compartment.

- Q. Bolts, screws, nuts and washers shall be of steel, except where brass or stainless steel is fastened, in which case they shall be of brass or stainless steel, respectively. Screws shall be 2-inch long, pan head Philips No. 12. Where dissimilar metals are fastened, nuts, bolts, screws and washers shall be of similar grade metal. The spacing and extent of bolts and screws shall be such as to ensure suitable fastening and prevent buckling of the metals fastened.

2.03 ELECTRICAL

- A. Electrical Requirements: Confirm available Electrical Services, such as actual voltages available, number of phases, and number of wires, at the project site, before submitting product data and placing orders.
 - 1. Should requirements indicated on Drawings and in ARTICLE 3.06 - EQUIPMENT SCHEDULE, herein, be of larger sizes or higher standards than are required by manufacturer or by governing authorities having jurisdiction, requirements indicated on Drawings and in ARTICLE 3.06 - EQUIPMENT SCHEDULE, herein, shall govern.
 - 2. Should requirements indicated on Drawings and in ARTICLE 3.06 - EQUIPMENT SCHEDULE, herein, be of smaller sizes or lower standards than are required by manufacturer or by governing authorities having jurisdiction, requirements of manufacturer or of governing authorities having jurisdiction shall govern.
 - 3. All costs for compliance with requirements of manufacturer and of governing authorities having jurisdiction shall be included in the Contract Sum. Rulings and interpretations of code enforcing agencies shall be included in such requirements.
- B. Circuits and Rough-Ins:
 - 1. Permanent connections to the project site's Electrical Service shall be made in accordance with requirements as specified in DIVISION 26 - ELECTRICAL, and shall comply with California Electrical Code (CEC).
 - 2. Make connections only at a junction box, by conductors in metallic conduit. Minimum size of junction boxes (unless specified otherwise) shall be 4-11/16-inches square and 1-1/2-inches deep, with 1/2-inch and 3/4-inch knockouts.
 - 3. Utility chase areas accommodating junction and pull boxes shall be a minimum of 18-inches square.
 - 4. Coordinate exact locations, types, and quantities of conductors and sealing of fittings with Electrical Drawings and with ARTICLE 3.06 - EQUIPMENT SCHEDULE, herein.
 - 5. In cases where equipment is directly connected, provide a length of flexible steel, neoprene-jacketed, Seal-Tite conduit, Anaconda Type UA, or equal, complete with approved liquid-tight contactors on each end, designed to provide electrical grounding continuity; make input connection as short as possible, not to exceed 36-inches.
 - 6. Provide proper and complete grounding of all metallic Foodservice Equipment.
- C. Wiring:
 - 1. Exposed wet area applications shall be rigid galvanized steel conduit except for flexible connections. Thin wall conduit (EMT) shall not be used for wet area application. Exposed outlet boxes shall be cadmium-plated, cast steel with threaded hubs.

FOR REFERENCE ONLY

2. Exposed flexible connections shall be flexible steel, neoprene-jacketed, Seal-Tite conduit, Anaconda Type UA, or equal, complete with approved liquid-tight contactors on each end, designed to provide electrical grounding continuity.
 3. Wiring for built-in strip heaters and immersion type elements shall have UL-listed insulation, not less than 300 volt rated, with listed nickel wire. Extend wiring in raceways or conduits to the junction or pull boxes with not less than 600-volt rated insulated wire.
 4. Refrigerator and freezer cabinets: Provide conduit as necessary to connect internal components to the junction or pull boxes, and as follows.
 - a. Internal wiring shall be UL-listed, rubber-covered 600-volt rated conductor, except for door heaters which shall be chrome wire with silicone braided jacket having resistance of 10.4 watts per lineal foot.
 - b. For freezer applications, provide wiring in rigid or flexible Seal-Tite Flex or equal (no known equal) EMT.
 5. Outlets, including all convenience outlets, lighting receptacles (rubber or porcelain), and door switches shall be mounted within approved boxes. Convenience outlets for evaporators shall be twist-lock type. Solid connections for freezer evaporators shall be vapor tight.
 6. Door switches for hinged doors shall be Arrowhart No. 4039 or equal (no known equal); for sliding doors, provide UL-listed toggle switches.
 7. Heating element controls for custom fabricated equipment, such as custom fabricated plate warmers shall be provided as follows.
 - a. Uninsulated cabinets with or without doors: provide 3-level switch.
 - b. Open front cabinets with or without insulation: provide variable controller.
 - c. Insulated cabinets with doors: provide thermostat.
- D. Starters, Switches and Controls: Provide starters, motor controls, switches, remote controls, and transformers as necessary.
1. All switches shall be located out of the heat zone. If ambient temperature will be above 100 degrees Fahrenheit, provide for adequate ventilation.
 2. Each motor driven appliance or electrical heating unit shall have a heavy-duty control switch, magnetic contactor or starter. Provide electrical controls, switches or other components being furnished loose by the manufacturer.
 3. Provide starters for across-the-line start, with thermal overload protection and manual overload reset. Push button stations shall be mounted in starter covers, except where necessary for starters to be mounted in a remote location.
- E. Convenience and Power Outlets: Provide all cut-outs, outlet boxes, cover plates, and all service fittings as necessary in Custom Fabricated Foodservice Equipment as shown on document drawings and in ARTICLE 3.06 - EQUIPMENT SCHEDULE, herein; provide necessary conduits to extend to the junction box or pull box of the project site's Electrical System.
1. Outlets having a specific voltage for a single purpose application shall be of such design that plugs designed for other applications will not fit.
 2. Verify that outlets will match appliance plugs as indicated on Electrical Drawings and in ARTICLE 3.06 - EQUIPMENT SCHEDULE, herein. Replace cords and plugs if necessary.

FOR REFERENCE ONLY

3. Electrical outlet devices shall be National Electrical Manufacturers Association (NEMA) Specification Grade and manufactured by Hubbell, Square D, Bryant, General Electric, Pass and Seymour, Arrowhart or equal.
- F. Cords and Plugs: Provide UL-listed cords and plugs for stock manufactured and for custom fabricated equipment.
 1. Cords are to be rubber-covered, three-wire cord of appropriate current capacity and appropriate length to suit use.
 2. Plugs are to be three-prong, ground type of appropriate NEMA configuration for electrical characteristics of equipment and serving outlet.
- G. Light Fixtures: Where light fixtures are specified as integral with Foodservice Equipment, provide sockets, lamps and ballasts as appropriate. For fluorescent fixtures, provide DeLuxe Warm White lamps, unless specified otherwise.
- H. Internal Wiring of Custom Fabricated Fixtures or Equipment:
 1. Obtain and pay for all Permits and Fees for inspection and approval of Electrical Work built into custom fabricated fixtures or equipment, for which a permit is required. Proof of inspection shall be attached to, and visible on, fixture.
 2. All internal wiring built into, or forming an integral part of, a unit of custom fabricated fixtures or equipment shall be completely wired to a junction box built into the unit, ready for final connection to the project site's Electrical System as specified herein.
 3. Licensed Electricians shall perform all internal wiring of fixtures and equipment.
- I. The Electrical Contractor shall be responsible for all inter-connections between systems and the foodservice equipment. Refer to PART 3.1.H - FINAL CONNECTIONS, herein.

2.04 PLUMBING

- A. All dishwashers, hose reels, janitor sinks, garbage disposals, pre-rinse sprays and water supply units are to be fitted with mixing valve and pressure-reducing valve (per manufacturer requirements), to be supplied by the FSEC and installed by the Plumbing Contractor.
- B. All counter-top equipment requiring water connections must be provided with pressure-reducing valve per 2016 California Plumbing Code (CPC).
- C. Provide charcoal water filter for all ice and water stations, ice machines, tea and coffee machines.
- D. The Plumbing Contractor shall be responsible for all inter-connections between systems and the foodservice equipment. Refer to PART 3.1.H - FINAL CONNECTIONS, herein.
- E. The Plumbing Contractor shall install electrical shut-off gas valve(s), provided by the FSEC, in an accessible location above the ceiling.

2.05 HEATING EQUIPMENT

- A. Gas-Heated Appliances: All Gas-Operated and -Heated Equipment shall conform to applicable American Gas Association (AGA) standards and to all applicable Local and State Health Department regulations.
- B. Steam-Heated Appliances: All Steam-Heated Equipment shall be a self-contained assembly complete with control valves located in a readily accessible position.

Twin Rivers Unified School District Madison Elementary School Modernization RCA Project No. 1-104-02		Foodservice Equipment 11 40 00 - 10
---	--	--

- C. Heating Equipment Controls: ~~Wherever Thermostatic Controls for Gas-, Electric-, or Steam-~~ Heating Equipment are indicated or necessary, provide controls complete and of materials, size, or rating as required.
- D. Cleaning Provisions: Heating Equipment shall be readily removable for cleaning.

2.06 REFRIGERATION EQUIPMENT

- A. Refrigeration Equipment, General: Provide refrigeration condensing units of size and capacities as indicated, consisting of compressors, condensers, receivers, motors, mounting bases, vibration isolators, refrigeration components, safety devices, electrical controls, refrigerant, and protective controls. Units are to be charged with refrigerant, all factory assembled and tested.
 - 1. Refrigerant: Utilize refrigerant with an ozone depleting potential of 0. All refrigerants to meet all current codes. The following refrigerants are listed as minimums:
 - 2. R-404A Low to medium temperature
 - 3. R-134a Medium temperature
 - 4. R-22 High temperature
 - 5. Glycol Food grade
 - 6. Connections: Provide quick-connect-type piping connections to receive piping from evaporator coils.
 - 7. Outdoor Mounting: Provide weather-tight housing and low ambient controls for units mounted outdoors.
- B. Refrigerant Piping: Type ACR copper tubing, hard temper, with wrought fittings and silver solder joints. Insulate suction lines with 1/2-inch pre-molded foamed plastic insulation. Use a closed cell Armaflex with a 3/4" wall. Ensure the Heat Trace is installed prior to the insulation installation.
- C. Electrical Wiring: Provide required wiring between electrical rough-in and refrigeration units for proper operation.
- D. Plumbing Piping: Provide required water and drain piping between plumbing rough-in and refrigeration units for proper operation.
- E. Refrigeration Specialties: Provide as indicated refrigerant dryer, liquid line solenoid valve, suction line filter, expansion valve, and water regulating valve (for water-cooled condensers only).
 - 1. Provide pump down control circuit consisting of thermostat and solenoid valve.
 - 2. Maintain box temperature from thermostat and liquid line solenoid valve; control compressor from suction pressure.

2.07 EXHAUST HOODS

- A. Fabricated Exhaust Hoods: Fabricate to specified UL-listed manufacturers specifications. All hoods must comply with California Mechanical Code.
- B. Grease Removal: Provide removable grease baffles, with drip-channel gutters, drains, and collection basins unless specified otherwise.

Twin Rivers Unified School District Madison Elementary School Modernization RCA Project No. 1-104-02	Foodservice Equipment 11 40 00 - 11
---	--

FOR REFERENCE ONLY

- C. Light Fixtures: Provide LED light fixtures, with vapor-tight sealed lens, and stainless steel conduit where exposed for wiring.
- D. Exhaust Duct: Stainless steel with finish to match hood finish where exposed and galvanized steel where concealed. Provide one-hour rated shaft or equal for Type 1 hoods.
- E. Stainless Steel Wall Flashing: Provide floor-to-ceiling, full width wall flashing under all exhaust hoods where a non-combustible wall surface is required.
 - 1. Where walls enclose hoods, those walls shall be fully wrapped with stainless steel wall flashing.
 - 2. Wall flashing shall be a minimum Type 304, 18-gauge stainless steel.
 - 3. Sheets shall be set vertically with seams running perpendicular to the ceiling and floor.
 - 4. Joints shall be butt joints.
 - 5. Seams and ends shall be capped with appropriate stainless steel T-Molding or End Molding.
 - 6. Wall flashing shall extend a minimum of 3-inches above hood line and to below top of base molding.
 - 7. The FSEC shall provide appropriate holes (by hydraulic knockout) and utility cutouts no greater than 1/4-inch of stub-out size.
 - 8. Where electrical outlets require a square or rectangle cutout, the opening must be fully covered by the faceplate.
 - 9. Attach to walls with approved mastic.
- F. Trim: Provide and install stainless steel trim to ceiling and adjacent walls, fabricated of the same gauge and finish as the Exhaust Hood.
- G. The FSEC shall provide and install any additional support membrane to provide a complete installation of the exhaust hood. He shall also be responsible to weld collars to exhaust ducts.
- H. If make-up air duct is integral to exhaust hood, FSEC shall be responsible for final connection from ductwork to make-up air collar.

2.08 MANUFACTURED PRODUCTS

- A. Manufactured Products, General: Provide Manufacturer's standard materials and equipment as specified, complete with all necessary and recommended fittings, fixtures, and accessories.
 - Manufactured items shall comply with applicable Seismic requirements.
 - 1. Manufactured items shall conform to applicable NSF standards and to all applicable Local and State Health Department regulations.
 - 2. Comply with all applicable rules and regulations pertaining to adequate protection from and guarding of moving parts of otherwise hazardous equipment.
 - 3. Electric-Operated and Electric-Heated Equipment shall conform to NEMA standards and be UL-listed and UL-labeled.
 - 4. Standard Steam-Heated Equipment shall be manufactured in accordance with ASME code requirements and bear the ASME label.
 - 5. Gas-Burning Equipment shall be manufactured in compliance with applicable AGA standards and bear the AGA label. Burners for gas-heated equipment shall be equipped

Twin Rivers Unified School District Madison Elementary School Modernization RCA Project No. 1-104-02		Foodservice Equipment 11 40 00 - 12
---	--	--

FOR REFERENCE ONLY

with automatic lighters. ~~Oven burners and other concealed burners shall have automatic safety pilots.~~

6. Provide Pressure Regulators for all Gas-Operated and Gas-Heated Equipment as recommended by the manufacturer and to suit service pressures.
- B. Refrigerator Hardware: Heavy-duty die-cast zinc, chrome-plated and polished.
 1. Hinges shall be edge mounted, self-closing type.
 2. Latches shall be edge mounted, arranged for locking devices.
- C. Handles and Pulls: Provide stainless steel Handles with No. 4 finish, or die-cast zinc with polished chrome-plated finish. Provide die-stamped stainless steel Pulls, recessed rectangular type, with beveled edge frame.
- D. Door Slides: Provide stainless steel Door Slides with minimum load capacity of 100 lbs. per pair, and with positive doorstop. Provide stainless steel ball-bearing rollers.
- E. Hinges: Provide stainless steel Hinges, continuous type or butt type as indicated.
- F. Sliding Door Hardware: Provide extruded aluminum Door Track. Provide galvanized steel Door Sheave with nylon surface and ball-bearing inner races. Provide stainless steel Bottom Guide Pins, spring loaded.
- G. Adjustable Shelf Supports: Provide stainless steel Shelf Supports, snap-in type, and stainless steel Brackets with countersunk mounting holes.
- H. Catches: For hinged doors, provide permanent magnetic Catch of sufficient strength to hold door shut.
- I. Locks: Provide Manufacturer's standard brass 5-pin cabinet-type lock; provide two keys for each lock, keyed separately.
- J. Lever Drains: Provide 2-inch, heavy cast-bronze body, removable flat stainless steel strainer, twist handle waste outlet with support bracket and one-piece connected chrome-plated brass overflow.
- K. Casters: Provide minimum 5-inch diameter wheel casters, with 1-1/8-inch tread width, complying with NSF standards. Provide sealed, self-lubricating bearings, cadmium-plated or bright zinc-plated steel disc wheels, and solid neoprene or polyurethane non-marking tires. Provide foot brakes on two (2) casters of four (4) required per unit unless specified otherwise.

2.09 CUSTOM FABRICATED EQUIPMENT AND FIXTURES

Custom fabricated items shall comply with applicable Seismic requirements.

- A. General:
 1. Fasteners: No exposed screw or bolt heads will be acceptable. Rivets, if specified, shall be countersunk and ground flush, and of the same material as the pieces joined together. Butt joints made by riveting straps under seams and then filling with solder will not be accepted.
 2. Rolled Edges: Rolled Edges shall be approximately 1-1/2-inch diameter, with corners bull nosed, ground and polished.
 3. Bends: All horizontal and vertical corners shall be covered with radius bends of 1/2-inches or larger.

Twin Rivers Unified School District Madison Elementary School Modernization RCA Project No. 1-104-02		Foodservice Equipment 11 40 00 - 13
---	--	--

FOR REFERENCE ONLY

4. Corners: All corners shall be mitered and fully welded, ground, and polished. Butt joints at corners will not be accepted unless specified otherwise.
 5. Closures: Provide formed stainless steel to close and finish all fixtures, backsplashes, or shelves, or entire rear of unit, or the ends flush to walls or adjoining fixtures. Closures shall be no greater than 1/8-inch gap between splash and wall.
- B. Framing:
1. Mount tops on 1-1/2-inch by 1-1/2-inch by 1/8-inch galvanized angle iron, or 4-inch wide by 12-gauge galvanized channels.
 2. Mount dishtables and drainboards on 4-inch wide by 14-gauge stainless steel channels.
 3. Run framework around entire perimeter of unit, and cross brace on 30-inch centers.
 4. For dishtables and drainboards, run framing from front to back at each leg location, and run additional channel lengthwise, located at center of table width and welded to leg channels.
 5. Fasten framing to underside of top surfaces with 1/4-inch studs welded at approximately 12-inch centers.
 6. Provide each stud with suitable chrome-plated lock washers and cap nuts, and make stud lengths such that cap nuts can be made up tight bringing top down snugly to framing.
- C. Legs and Cross Rails:
1. Construct legs of 1-5/8-inch Outer Diameter, 16-gauge stainless steel tubing.
 2. Provide fully enclosed stainless steel bullet shaped adjustable feet of Type 302 or Type 304 stainless steel exterior, not less than 1-1/2-inches in diameter, threaded for adjustment of 1-inch up or down without any threads showing.
 3. Fasten leg to 4-inch high stainless steel enclosed gusset, with top completely sealed by means of stainless steel plate.
 4. Fasten legs to sinks by means of stainless steel enclosed gussets welded in place, sanitary type, stainless steel, reinforced with bushings and having set screws for securing legs.
 5. Fasten legs to metal tops and dishtables with stainless steel enclosed gussets, as above, welded to stainless steel channels 14-gauge or heavier.
 6. Fasten legs to wood top tables by means of welding to stainless steel channels anchored to top with screws.
 7. Weld gussets continuously to bottom of unit framing.
 8. All equipment longer than seven (7) feet shall be provided with a minimum of six (6) legs.
- D. Metal Tops:
1. Fabricate of 14-gauge stainless steel, one-piece welded construction, with exposed edges rolled and with corners bull nosed.
 2. Reinforce on underside with galvanized steel channels welded in place so tops can support heavy weights without deflection. Provide cross braces at not more than 30-inches on center.
 3. Where tops are adjacent to walls or adjoining equipment, provide integral splashes with all corners, both vertical and horizontal, coved a minimum of 1/2-inch radius.

FOR REFERENCE ONLY

4. Splashes shall be a minimum of 6-inches high including a 1-inch horizontal return to wall and 1-inch vertical drop (for 'Z' clip installation) and enclosed ends.
 5. Field joints in tops are to be sanitary, tight and without open seams, by means of welding or by properly designed draw fastenings, or commercial joint material to suit the purpose required; 1/8-inch tolerance for silicone maximum.
 6. For countertop equipment, provide hydraulic knock out and grommet for utility lines at counter top or sides or rear.
- E. Cabinet Bodies:
1. Fabricate of 18-gauge stainless steel, with end panels formed with round corners for free-standing units, and square corners for fixtures that adjoin walls or other fixtures.
 2. Provide 90-degree retentions on end panels at front and rear, turned in toward body of cabinet and welded for reinforcement.
 3. For cabinets with open shelving, provide double-wall inner panels.
 4. Weld ends to horizontal angle or channel members to form integral cabinet base.
 5. Provide backs of same material as ends, with vertical edges turned in to match edges of ends.
 6. Weld, making flush joints.
 7. Provide all cabinets with full-height corner bumpers, wrapped around corner 2" each side, and crimped to cabinet face.
- F. Dishtables and Drainboards:
1. Fabricate of 14-gauge stainless steel, with exposed edges formed into 1-1/2-inch by 190-degree rolled rim approximately 3-inches high.
 2. Provide built-in pitch to tubs of 1/2-inch minimum.
 3. Provide minimum 10-inch high backsplashes including 2-inch return on 45-degree angle, 1-inch horizontal return to wall and 1-inch vertical drop with offset (for 'Z' clip installation) and enclosed ends, or 1-1/2-inch diameter rolled rim, as indicated.
 4. Construct the front rim and backsplash of the drainboard on a continuous level plane with the sink it adjoins.
 5. Support drainboards 36-inches and longer with 1-5/8 inch outer diameter legs and gusset.
 6. Cove all corners, both vertical and horizontal, a minimum of 3/4-inch radius.
- G. Sinks:
1. Fabricate from 14-gauge stainless steel, with interior corners rounded to a 1-inch radius, both horizontally and vertically, forming cove in bottom.
 2. Construct sink with butt-edge joints welded, ground smooth and polished so joints are imperceptible.
 3. Finish sinks to match stainless steel top. Where sink bowls are exposed below countertop, finish sink exterior to match top.
 4. Divide multiple compartment sinks with double-wall, 16-gauge stainless steel partitions rounded to 1/2-inch radius on top and having corners rounded the same as other corners in sinks. Provide multiple compartment sinks with continuous face at exposed front.

FOR REFERENCE ONLY

5. Provide back, bottom, and front of one continuous piece with no overlapping joints or open spaces between compartments.
 6. Pitch bottom of each compartment, and crease to die-stamped recess to receive lever-type drain, without use of solder, rivets, or welding.
 7. Finish front and exposed ends of sink countertop with 1-1/2-inch, 190-degree rolled edge.
 8. Finish back and ends adjacent to walls or other fixtures with backsplash.
 9. Punch backsplash to receive wall-mounted faucets.
 10. For sinks in worktops, construct as above but omit roll edges and backsplashes. Fabricate bowl to be flush with work surface.
 11. Provide stainless steel wall flashing from finished floor to ceiling behind all sinks where FRP or ceramic tile is not indicated.
 12. Sink covers to be constructed of 14ga S/S construction with grommet finger hole. Covers will be fabricated to accommodate any overflow drain in sink and will fit flush over sink.
- H. Drains, Wastes and Faucets:
1. Provide 2-inch, heavy cast bronze body, with removable flat stainless steel strainer, twist handle waste outlet with support bracket and one-piece connected chrome-plated brass overflow.
 2. Provide 3-1/2-inch crumb cup waste outlets in all die-drawn inset type sinks.
 3. Faucets: As specified.
 4. Dipperwells: As specified.
- I. Undershelves:
1. Construct of 16-gauge stainless steel.
 2. Open Base Shelving: Edges shall be rolled down on open sides, with a 2-inch turn-up on rear and ends where adjacent to walls and other equipment.
 - a. Neatly notch corners and weld to legs.
 - b. Reinforce shelving longitudinally with 14-gauge formed channel welded to underside.
 - c. In fixtures with open bases, provide shelves notched a full 90 degrees and welded tightly to legs, with tight joints at all intersections of shelf and leg.
 3. Bottom Shelves: Extend forward and turn down at front so as to be flush with front facing of cabinet.
 4. Fixed Intermediate Shelves: Weld to front stiles and to 16-gauge stainless steel brackets so that shelf is 1-inch away from back and ends of cabinet.
 5. Adjustable Shelves: Channel on all four (4) sides, weld corners, and mount on removable stainless steel standards.
 6. Construct removable shelves as above, fit over cross rails and do not exceed shelving sections of 30-inches long; where one section abuts another, turn down edges 1-inch.
 7. Enclosed Base Shelving: Turn up at back and sides and feather slightly to insure a tight fit to enclosure panels.
- J. Overshelves:
1. Construct of 16-gauge stainless steel.

FOR REFERENCE ONLY

2. Set shelves mounted over equipment not adjacent to walls on 1-5/8-inch by 16-gauge stainless steel tubular standards fitted with stainless steel base flanges.
 3. Completely weld top of tubular standards to 16-gauge stainless support channels; run channels full width of overshef.
 4. Where overshelves are mounted above tables, run 1/2-inch steel tension rods through counter-tops, stanchions, and reinforcing angle framing, and secure with nuts and lock washers to assure stable sway-free structure.
 5. Where shelves are mounted over drainboards or dishtables, mount on upturned rolled edges omitting flanges, and scribe lower end of tube to match contour of roll. Secure as in table-mounted method.
- K. Cabinet Doors:
1. General:
 - a. Fabricate with double-pan construction of stainless steel with edges formed into a channel extending around all sides, forming doors 3/4-inch thick.
 - b. Fabricate outer pans of 18-gauge stainless steel with corners welded, ground smooth, and polished.
 - c. Include wood fiber sound deadening material within door assembly.
 - d. Fabricate inner pans of minimum 20-gauge stainless steel, fitted tightly into outer 18-gauge pan.
 - e. Fully weld pans together.
 - f. Where single pan-type doors are indicated, fabricate of 16-gauge stainless steel, reinforced and stiffened with closed hat sections to prevent flexing.
 2. Sliding Doors:
 - a. Mount doors on large ball bearing, quiet rollers in 14-gauge stainless overhead tracks. Provide resilient stops.
 - b. Construct sliding doors to be removable without use of tools, for cleaning purposes.
 - c. Provide U-shaped or Loop stainless steel handle on each door.
 - d. Where specified, provide doors with locks.
 - e. Exterior doors shall be provided with weatherproof cover.
 - f. All sliding doors to be provide with pushbutton activator.
 3. Hinged Doors:
 - a. Mount hinged doors on stainless steel, continuous-type hinges.
 - b. Construct hinged doors so that face is flush with cabinet body.
 - c. Provide each door with U-shaped or Loop stainless steel surface door pull and magnetic catches.
 - d. Where indicated, provide doors with locks.
 - e. Provide permanent magnetic catch of sufficient strength (5 lb max opening force) to hold door shut.
- L. Drawers:
1. Construct front of double-pan stainless steel, 16-gauge exterior and minimum 20-gauge interior.

FOR REFERENCE ONLY

2. Size: Minimum 5-inches deep, 1-inch thick, with other dimensions as specified and to suit installation.
3. Provide cylinder lock for drawers, unless specified otherwise.
4. Fasten drawer suspension guides to 18-gauge stainless steel housing suspended from angle framing under fixed top.
5. Mount drawers on fabricated 16-gauge stainless steel interlocking channel supports with large size, quiet ball-bearing wheel suspension and stops to prevent drawers from being pulled out of fixture.
6. Construct support slides so that drawers may be pulled out minimum of two-thirds of drawer length and support heavy loads without deflection. Drawers shall be easily removable without the use of tools.
7. Support slide to have minimum load capacity of 150 lbs per pair.
8. Provide recessed full-length stainless steel handle for each drawer.
9. For removable pan-type drawers, fabricate as a rigid self-supporting unit. Drawer body shall have flanged top for support in drawer frame and shall be as specified above. Provide replaceable, full neoprene bumpers.
10. For drawers in refrigerated sections, provide removable-type, perforated body, mounted on large ball-bearing wheels in flat tracks. Wheels shall be similar to heavy-duty urethane roller skate wheels. Wheels and bearings shall be corrosion-resistant, longwearing material, grease packed before assembly. For drawers in refrigerated sections, provide full-perimeter, soft gaskets.
11. Liner to be lift-out type, one-piece construction, and die stamped of 20-gauge stainless steel, with inside radiused corners.
12. Drawer pans shall be removable without removing frame from fixture.

M. Wall Shelves:

1. Construct of 16-gauge stainless steel with 1-1/2-inch roll on front and exposed ends, and with 2-inch turn-up on back and ends where adjacent to walls or other fixtures.
2. Miter and weld all corners.
3. Construct wall brackets of 14-gauge stainless steel with 1-1/2-inch flange at wall and completely welded to underside of shelf.
4. Fasten each bracket to wall with a minimum of two stainless steel pan head screws, Philips No. 12, 2-inch long.
5. Install so that shelf sets 1-inch away from wall.
6. Adjustable shelf supports shall be snap-in type with stainless steel brackets with countersunk mounting holes.
7. Wall backing is required.

N. Wall Backing: Where indicated on Foodservice Consultant's drawings, provide wall backing to run six inches beyond full length of equipment item at each side.

1. For Wood Frame Construction: The General Contractor shall provide and install wood blocking. Secure wall blocking in between studs.

Twin Rivers Unified School District Madison Elementary School Modernization RCA Project No. 1-104-02		Foodservice Equipment 11 40 00 - 18
---	--	--

FOR REFERENCE ONLY

2. For Metal Frame Construction: ~~The FSEC shall provide and the General Contractor shall install metal backing.~~ Metal backing shall be at least 14-ga galvanized steel. Secure wall backing to studs.
- O. Cold Pans:
1. Fabricate from 16-gauge stainless steel lining and 20-gauge stainless steel casing.
 2. Cove interior vertical and horizontal corners.
 3. Insulate sides, ends, and bottom with material thermally equal to 2-inch thickness of fiberglass.
 4. Sweat 1/2-inch-diameter copper cooling coils to underside cold pan, and seal in thermomastic material.
 5. Turn down countertop (and/or flange) 1-inch into pan; install completely concealed 1-inch-wide plastic breaker strip; install 1-inch chrome-plated drain with plug.
 6. Provide 1/2-inch high false bottom of 16-gauge perforated stainless steel in removable sections.
 7. All cold pans, ice pans, refrigerated pans and cabinets shall be provided with breaker strips where adjoining top of cabinet face materials to prevent transfer of cold.
 8. Where cold pans and other inserts are to be installed in cabinet bases, provide apron the full depth of insert and of same material as cabinet body with reinforced openings as required; form in openings on all sides.
- P. Insert Pans:
1. Include standard pans and adaptive dividers on all custom-fabricated insert pans (refrigerated, ambient and hot) to provide optimal use of the insert pans. Standard pan size to be determined prior to submittal of shop drawings.
- Q. Casters:
1. Heavy-duty, NSF-approved, sealed wheel and swivel ball bearings, solid or disc wheel, with greaseproof neoprene or polyurethane tire, and bright chrome plated finish on steel.
 2. Wheel diameter: 5-inch, minimum.
 3. Tread width: 1-3/16 inch, minimum.
 4. Capacity per caster: 250 pounds, minimum.
 5. Include stainless steel rotating wheel guard.
 6. A minimum of two (2) casters shall have brakes.
- R. Corner Guards: All exposed corners shall be provided with 14-gauge S/S corner guard, full height to ceiling. Guards to be full height corner bumpers, wrapped around corner 2 inches each side, and crimped to the face of the wall or fixture.
- S. Curbs: Construct of 16-gauge galvanized steel, fully welded and reinforced where necessary.
- T. Sneeze Guards:
1. Frame to be constructed of 1-1/2" Outer Diameter, stainless steel tubing; stainless steel fittings to be welded, ground smooth and polished; no exposed screw heads, bolt heads, or solder joints permitted.

FOR REFERENCE ONLY

2. Front and end panels to consist of 1/4" tempered glass trimmed by glazing into a 3/8" by 3/8" U-shaped stainless steel channel; panels to be removable from frame without tools.
 3. Shelves to consist of 3/8" tempered glass trimmed by a snug-fitting gasket seated firmly against round tubing frame.
- U. Wall Flashings: Provide wall flashings where indicated on Foodservice Consultant's drawings.
1. Wall flashing shall be a minimum Type 304, 18-gauge stainless steel.
 2. Sheets shall be set vertically with seams running perpendicular to the ceiling and floor.
 3. Joints shall be butt joints.
 4. Seams and ends shall be capped with appropriate stainless steel T-Molding or End Molding.
 5. Wall flashing shall extend a minimum of 12-inches below splash.
 6. The FSEC shall provide appropriate holes (by hydraulic knockout) and utility cutouts no greater than 1/4-inch of stub-out size.
 7. Where electrical outlets require a square or rectangle cutout, the opening must be fully covered by the faceplate.
 8. Attach to walls with approved mastic.
 9. Provide and install stainless steel trim to ceiling and adjacent walls, fabricated of the same gauge and finish.
 10. Where it is necessary to remove all or part of an existing wall flashing to allow modification work, replace with stainless steel wall flashing with appropriate molding.

PART 3 - EXECUTION

3.01 INSTALLATION

- A. Installation, General: Set each item of non-mobile and non-portable equipment securely in place, level, and adjust to correct height.
- All items shall comply with applicable Seismic requirements.
1. Anchor products to supporting substrate where indicated and where required for sustained operation and use without shifting or dislocation.
 2. Conceal anchorages where possible.
 3. Adjust countertops and other work surfaces to level tolerance of 1/16-inch maximum offset, and maximum variation from level or indicated slope of 1/16-inch per ft.
 4. Where indicated or required for safety of equipment operator, anchor equipment to floor or wall. Provide legs with adjustable flanged foot where equipment is indicated to be anchored to floor. Install two (2) anchors on each foot and cap off with stainless steel acorn nuts.
- B. Field Joints: Complete field-assembly joints (joints that cannot be completed in shop) by welding, bolting-and-gasketing, or similar methods as indicated.
1. Grind welds smooth and restore finish.
 2. Set or trim gaskets flush, except for T-gaskets as indicated.

Twin Rivers Unified School District Madison Elementary School Modernization RCA Project No. 1-104-02		Foodservice Equipment 11 40 00 - 20
---	--	--

FOR REFERENCE ONLY

- C. Enclosed Spaces: Treat spaces that are inaccessible after equipment installation by covering horizontal surfaces with powdered borax at rate of four (4) ounces per square foot.
- D. Closure Plates and Strips: Install where required, with joints coordinated with units of equipment.
- E. Knock outs: Provide hydraulic knock outs in foodservice equipment, where required, to run plumbing, electric, gas, or steam lines through equipment items for final connections.
- F. Sealants and Gaskets: Install completely around each unit to make joints airtight, watertight, vermin-proof, and sanitary for cleaning purposes.
 - 1. In general, make sealed joints not more than 1/8-inch wide, and stuff backer rod to shape sealant bead properly, at 1/4-inch depth.
 - 2. Shape exposed surfaces of sealant slightly concave, with edges flush with faces of materials at joint.
 - 3. At internal-corner joints, apply sealant or gaskets to form a sanitary cove, of not less than 3/8-inch radius.
 - 4. Provide sealant-filled or sealant-gasketed joints up to 1/2-inch joint width and metal closure strips for wider joints with sealant application each side of strip.
 - 5. Anchor gaskets mechanically or with adhesives to prevent displacement.
 - 6. All fixtures adjacent to wall shall be sealed to wall as specified.
- G. District Furnished/Contractor Installed Equipment:
 - 1. Existing Equipment: The Contractor shall be responsible for removing, cleaning, repairing (if required) and re-installing equipment designated as Existing Equipment, coordinating removal of Existing Equipment with the District. The Contractor shall be responsible for all connectors, valves, regulators, and hard and flexible connections to make the Existing Equipment operational per manufacturer's standards. The Contractor shall coordinate Existing Equipment requiring remote refrigeration with all refrigeration systems, ensuring that such Equipment is operational per manufacturer's standards.
 - 2. New Equipment: The Contractor shall receive, accept, and store District Furnished Equipment at approved, designated area on site. All freight damage will be noted and the Contractor shall file a claim for the damage on behalf of the District. The Contractor shall provide a storage trailer to store District Furnished Equipment if necessary.
 - 3. Final installation of the District Furnished Equipment is the responsibility of the Contractor, who shall be responsible for all connections, valves, regulators, and hard and flexible connections to make the District Furnished Equipment an operating system per manufacturer's standards. The Contractor shall coordinate District Furnished Equipment requiring remote refrigeration with all refrigeration systems, ensuring that such equipment is operational per manufacturer's standards.
 - 4. The District will supply to the Contractor current specification sheets, lists of provided equipment and scheduled shipment and arrival dates. The Contractor shall coordinate all required cutouts and electrical, plumbing, and mechanical coordination with the trades to allow for proper installation.
 - 5. The Contractor shall provide to the District a compact disk with electronic version of all Operation & Maintenance Manuals for new foodservice equipment.

Twin Rivers Unified School District Madison Elementary School Modernization RCA Project No. 1-104-02		Foodservice Equipment 11 40 00 - 21
---	--	--

H. Final Connections:

1. Final hook-ups are not part of the scope of work of the FSEC. All final hook-ups (plumbing, mechanical and electrical) shall be part of the General Contractor’s area of responsibility. The General Contractor shall make allowances for elbows, traps, etc., and shall make final connections on the job, supply all necessary valves, traps, steam traps, faucets, starting switches for motors, etc., except where specifically noted otherwise in the written specifications.
2. The Contractor shall be responsible for all inter-connections between systems and the foodservice equipment.

I. Installers shall be responsible for verifying dimensions.

3.02 FIELD QUALITY CONTROL

- A. Testing: Coordinate start-up of Foodservice Equipment when service lines have been tested, balanced, and adjusted for pressure, voltage, and similar considerations. Do not operate steam lines until they have been cleaned and treated for sanitation. Before testing, lubricate each equipment item in accordance with manufacturer's recommendations.
- B. Include in the testing all District Furnished Equipment and Existing Equipment.
- C. Test each item of operational equipment to demonstrate that it is operating properly and that controls and safety devices are functioning.
- D. Repair or replace equipment found to be defective in its operation, including units that are below capacity or operating with excessive noise or vibration.
- E. Testing is to include any service charges due to improper installation, lack of proper connectors, or missing equipment.

3.03 CLEANING

- A. After completion of installation and other major work in Foodservice areas, remove protective coverings, if any, and clean Foodservice Equipment, internally and externally.
 1. Restore exposed and semi-exposed finishes to remove abrasions and other damages; polish and buff exposed-metal surfaces and touch-up painted surfaces.
 2. Replace work that cannot be successfully restored.
- B. Final Cleaning: After testing and start-up, and before time of Substantial Completion, clean Foodservice Equipment, and leave in condition ready for use in Foodservice.

3.04 ADJUSTMENT OF EQUIPMENT AND DEMONSTRATION

- A. Turn on all mechanical equipment, test for leaks, poor connections, inadequate or faulty performance and correct if necessary; adjust for proper operation.
 1. All thermostatically controlled equipment and equipment with automatic features shall be operated for a sufficient length of time to prove controls are functioning as intended.
- B. At a time and date selected by the District, the FSEC shall arrange for a demonstration of all new mechanical equipment for the District and his appointed representatives. These demonstrations are to be conducted by factory-trained engineers of the various equipment manufacturers and shall be done in two stages: one for the operations people and the second

Twin Rivers Unified School District Madison Elementary School Modernization RCA Project No. 1-104-02	Foodservice Equipment 11 40 00 - 22
---	--

for maintenance personnel. A representative of the FSEC must be in attendance at all demonstrations.

- C. The FSEC shall provide the District with one copy of a video film in DVD format depicting the operations and maintenance on each piece of new foodservice equipment.
- D. The FSEC shall provide all necessary instructional training for all emergency equipment, gas turn-offs, fire extinguishers, high-temperature alarm system, etc., including, if any, emergency generating equipment.
- E. The FSEC shall provide all necessary instructional training for all safety equipment.

3.05 CLOSEOUT PROCEDURES

- A. Start-up of Foodservice Equipment
 - 1. Utilities (lighting of pilot lights, etc.) by General Contractor
 - 2. FSEC shall provide for Manufacturer’s Service Agent to ensure systems are properly connected and are operational per manufacturer’s required specification.
 - 3. FSEC shall provide for Manufacturer’s Representative to demonstrate how to properly operate all new foodservice equipment.
 - 4. FSEC shall provide manufacturer inspection certification for all new items for District’s acceptance, otherwise will consider not meeting the project specifications.
- B. Provide services of the Contractor’s technical representative and the Manufacturer’s technical representative (where required) to instruct District personnel in the operation and maintenance of new foodservice equipment
 - 1. Schedule training with the District.
 - 2. Provide at least 7-day notice of training date to the District.
- C. O&M Manuals: Provide a compact disk with electronic version of all Operation & Maintenance Manuals for new foodservice equipment.
- D. The Contractor shall provide a walk-through with the District prior to turning the project over to the District for operation.

FOR REFERENCE ONLY

3.06 EQUIPMENT SCHEDULE

- A. All dimensions are for reference only. Dimensions and site conditions must be field verified.
- B. All equipment shall comply with applicable California State Seismic requirements.
- C. Foodservice Equipment drawings are part of these specifications.
- D. Warranties: Five-year Compressor Warranty. Two-year Parts & Labor Warranty for all new equipment.
- E. All roll-in or roll-thru cabinets shall be trim to the wall with 6”H 16ga S/S cove base, 3/8” radius.
- F. All plumbing, electrical and gas lines shall be concealed within the building structure to the greatest extent possible. Exposed wiring to be enclosed in S/S casing.
- G. It shall be the responsibility of the FSEC to provide S/S covers for all exposed conduit, piping and refrigeration lines in the kitchen spaces.
- H. Outdoor Mounting: Provide weather-tight housing and low ambient controls for units mounted outdoors.
- I. Where indicated, or required for safety of equipment operator, anchor equipment to floor or wall. Provide legs with adjustable flanged foot where equipment is indicated to be anchored to floor. Install two (2) anchors on each foot and cap off with S/S acorn nuts.
- J. All gas appliances shall have gas hose with quick disconnect and seismic restraint (seismic restraints where applicable).
- K. All gas appliances with open burners installed in schools shall have Battery spark ignition
- L. All mobile units with water lines shall have water hose with quick disconnect and seismic restraint (seismic restraints where applicable).
- M. NSF Standards: Comply with applicable National Sanitation Foundation (NSF) standards and recommended criteria including NSF 2 and NSF 7. Provide each principal item of Foodservice Equipment with a NSF Seal of Approval.
- N. All Walk-In penetrations to be sealed and insulated with foamed insulation.
- O. Where screws are exposed, Stainless Steel Pan Head Screws are to be used. No round head screws to be utilized.

ITEM # 1 CORNER GUARDS & END CAPS
 Quantity: One (1)
 Manufacturer: Custom S/S

- 1. One (1) Furnish and install Corner Guards & End Caps per Plan, Details and General Specifications on Part 2 to Part 3 herein, including: 14ga S/S angle construction.
- 2. One (1) (LOT) CORNER GUARDS 2" x 2" angle x full height to ceiling. Provide for all exposed corners; mount bottom flush with top of coved base.
- 3. One (1) (LOT) END CAPS 2" x 2" angle x full wall height, similar to Corner Guards but shall extend to cover the full exposed face of the wall.

ITEM # 2 AIR COOLED ROOF MTD REFRIGERATION RACK
 Quantity: One (1)

Twin Rivers Unified School District Madison Elementary School Modernization RCA Project No. 1-104-02	Foodservice Equipment 11 40 00 - 24
---	--

FOR REFERENCE ONLY

Manufacturer: Coldzone
Model: MPL-2CZ

1. One (1) Model MPL-2CZ Furnish and Install MINI-PAK REFRIGERATION SYSTEM per plans, details and specifications on sheet FS06.1 including:

The outdoor air-cooled, refrigeration system is to be U.L. Listed and will be located on the roof of the building. This unit includes the outdoor weather housing, compressors, copper finned condenser core, electrical control panel, all housed within a single assembly and the evaporator coil assemblies, all with the required options and accessories. All of the component parts, options and accessories will be provided, mounted, piped and wired, as required by the manufacturer. The system shall be manufactured to operate at 208-230 volts/3 phase/60 hertz. The refrigeration system shall have the following compressors and evaporator coils:

The outdoor weather shall include a welded, de-burred and cleaned structural steel frame made of 12 gauge. The exterior housing and access MINI-PAK REFRIGERATION SYSTEM

The outdoor air-cooled, refrigeration system is to be U.L. Listed and will be located on the roof of the building. This unit includes the outdoor weather housing, compressors, copper tubes with aluminum fins, electrical control panel, all housed within a single assembly and the evaporator coil assemblies, all with the required options and accessories. All of the component parts, options and accessories will be provided, mounted, piped and wired, as required by the manufacturer. The system shall be manufactured to operate at 208-230 volts/3 phase/60 hertz. The outdoor weather shall include a welded, de-burred and cleaned structural steel frame made of 12 gauge. The exterior housing and access doors will be manufactured of a minimum of 16 gauge galvanized steel which has been assembled and cleaned. The frame and shall be painted with a primer coat of epoxy based paint and finished with a coat of polyurethane acrylic enamel.

COMPRESSOR AND CONDENSER SYSTEMS

All compressors will be Copeland hermetic, semi-hermetic or scroll. All compressors will be manufactured to operate with R-448A refrigerant. Each Compressor system shall be filled with refrigerant compatible refrigeration oil by the manufacturer and will include discharge and suction line vibration protection (vibrasorbors with Copelametic and Discus compressors), dual pressure control with stainless steel braided piping, liquid line filter-dryer, moisture indicating sight glass, flooded head pressure control valve and crankcase heater.

Each of these systems shall also include a receiver tank capable of accepting the entire systems refrigerant charge without exceeding 90% of its volumetric capacity. Each receiver will be provided with a pressure relief vent and, at its inlet and outlet and an isolation valve with a service port. Additionally, all compressor systems that will operate at suction temperatures below 0°F shall include a suction line accumulator.

The condenser system shall include the Multi-Circuited condenser, 3/4 horse power condenser fan motors with 24 inch fan blades mounted in a venturi contoured air-scoop protected by plastic coated fan guards, and flooded head pressure controls. The compressors and condenser circuits shall be sized to operate at an average temperature differential between the ambient and condensing temperatures of 20°F.

CONTROL PANEL

The control panel shall be protected include circuit breakers, start capacitors, and fan cycle control thermostats for each of the condenser fan motors. A fused disconnect will be located on the rack system. A wiring diagram of the refrigeration system shall be provided and mounted inside of the refrigerated system. All internal wiring shall be shown on the wiring diagram.

EVAPORATOR COILS

Evaporator coils shall be direct expansion type fabricated of cop-per tubes with aluminum fins.

Twin Rivers Unified School District Madison Elementary School Modernization RCA Project No. 1-104-02		Foodservice Equipment 11 40 00 - 25
---	--	--

FOR REFERENCE ONLY

All evaporator coils shall be provided with solenoid valve, thermo-static expansion valve, suction "P" trap, and thermostat—piped and wired to the junction box for positive pump-down filter/drier automatic oil level regulators for each compressor and interconnecting tubing per schematic diagram. The oil level control system shall incorporate isolation valves to facilitate serviceability and minimize system contamination.

2. I. GENERAL CONTRACTOR

1. Contractors shall verify all dimensions and coordinate with other trades.
2. General contractor shall prepare the platform, curbed openings and weatherproofing the same after installation.

II. REFRIGERATION CONTRACTOR

1. The complete system shall be evacuated with vacuum pump.
2. Charge, test and adjust each unit to assure proper operation.
3. All copper tubing to be refrigerant grade ACR. or type "I".
4. Silver solder and/or sil-fos shall be used for all refrigerant piping. Soft solder is not acceptable.
5. All piping to be pressure tested with nitrogen at 300 psi. After the condensing unit and coil have been connected, the balance of the system shall be leak tested with all valves open.
6. Refrigeration contractor to provide and install drain line heater in freezer to be connected by electrical contractor.

III. ELECTRICAL CONTRACTOR

1. Electrical contractor to connect drain line heater in freezer.
2. Electrical contractor to provide power for refrigeration package and evaporator coils.
3. All electrical wiring and installation shall be in accordance with the wiring diagram and local codes.

IV. PLUMBING CONTRACTOR

1. Plumbing contractor to provide ACR or type "I" copper drain lines for walk-in refrigeration and freezer, pitched 1/2" per foot of run. In freezer, unheated drain line must be outside of insulation to prevent freezing. Trap drain line outside of refrigerated space to avoid entrance of warm and moist air.
2. Plumbing contractor to provide individual drain line for each evaporator unless otherwise called for.
3. All plumbing installation shall be in accordance with local codes.

3. Unit Dimensions: 72" L x 36" W x 37" H
Unit Weight: 635 Lbs.

ITEM # 3 42" WALL MTD. AIR CURTAIN
Quantity: One (1)
Manufacturer: Berner
Model: SHD07-1042A

1. One (1) Model SHD07-1042A Sanitation Certified Series High Performance Air Curtain, 42" long, unheated, (1) 3/4 hp motor, for doors up to 7-feet high, specify exterior, indoor or exterior mounting, cULus, UL EPH Classified, MADE IN USA
2. One (1) If special freight fees are requested, (See below) all applicable fees will be added to the invoice; fees subject to change; contact factory for addition information.
3. One (1) Model A 120v/60/1-ph
4. One (1) White powder coat exterior finish, standard

Twin Rivers Unified School District Madison Elementary School Modernization RCA Project No. 1-104-02	Foodservice Equipment 11 40 00 - 26
---	--

FOR REFERENCE ONLY

5. One (1) Model 66ADS000DMB Mounting Bracket, for plunger door switch used with manual swing doors (field mounted)
6. One (1) Model WMP-WH Wall mounting plate, white (add suffix WMP-WH to desired length)

ITEM # 4 2-TIER CURB MTD. EMPLOYEE LOCKERS

Quantity: One (1)

Manufacturer: Penco Lockers

Model: 6231R

1. One (1) Model 6231R (LOT) Vanguard, Classic III Recessed Handle, 2-tier lockers 12"L x 12"W x 36"H per opening. Manufacturer's standard model with Slope Top, Padlock attachment (padlocks not included). Powder coat baked enamel finish - Color selection by the District.
2. Mount on galvanized curb.
3. ACCESSORIES: (1) ADA-compliant lockers - assign bottom center section and provide appropriate symbol sign on the door.
4. NOTE: Latch and locking hardware shall be operable with one hand, shall not require tight grasping, tight pinching, or twisting of the wrist to operate. Provide shelf and pole at 48" max AFF and lower shelf at 15" min AFF (Reach requirements).
Provide 5% of total lockers or one minimum accessible locker per CBC Section 11B-811.

ITEM # 5 MOBILE DRY STORAGE SHELVING UNIT (5-TIER)

Quantity: Eight (8)

Manufacturer: Metro

Model: NC

1. Eight (8) Model NC Super Adjustable Super Erecta® Shelf, wire, chrome-plated finish, corner release system. Size per Plan x 74-5/8"H.
2. Each Unit to contain (4) 74UP posts, (2) 5MP & (2) 5MPB casters.
3. Provide all necessary components for complete installation.

ITEM # 6 SPARE NO.

ITEM # 7 WALK IN FREEZER W/ TRIM

Quantity: One (1)

Manufacturer: Thermalrite Refrigeration

Model: WIF

1. One (1) Model WIF Furnish and Install Thermalrite Walk In Freezer with Trim size per Plan x 8'11" High O.D. A.F.F. UL-listed, NSF No. 7 approved prefabricated modular construction to hold -10 degrees F.
2. Panel insulation: 4" DURATHANE, high density all-urethane foamed-in-place (Class 1). Provide necessary labor, equipment and tools for complete installation to conform with drawings and written specifications including:
3. Entire assembly to be provided as floorless with flat bottom wall panels installed in a 9" building floor depression and held in place with wall anchors. Walls to be installed with (9" floor

FOR REFERENCE ONLY

- depression with 6" insulation). (3) layers of 2" urethane slab insulation with 10 mil polyethylene sheeting vapor barrier to be installed by FSEC. 15# tar paper to be provided (supplied by FSEC).
4. Wearing floor by GC (install after assembly of walk-in box): Poured Epoxy w/ 6" H Coved Base w/ 3/8" radius for the interior by General Contractor.
 5. Note: G.C. to provide and install backerboard for epoxy coved base adhesion
 6. Metal Finishes: Interior walls & exposed exterior shall be 20 GA. White Smooth Galvanized.; Unexposed exterior to be 26 Ga. Stucco Embossed Galvanized Steel. Exposed exterior walls to the interior of the building to be 20 GA Stainless.
 7. Exposed exterior to the Kitchen to be provided with 48" high AFF 14 Ga. S/S wainscot. Wainscot shall be mounted with adhesive and sealed with silicone. No external fasteners such as screws or pop rivets shall be applied as fastening for the wainscot.
 8. (1) 36" x 80" High 20 Ga. S/S flush mounted entrance door with hardware – NSF Listed. An armored anti-sweat heater cable shall be run in a breaker strip located behind a removable heavy gauge stainless steel trim for easy access to heater cable. Heater cable shall be run under threshold
 9. One (1) Kason Model K27C K27C handle with Mortise deadbolt latch & inside Safety Release.
 10. Three (3) Kason Model K1248 Doors provided with (3) spring-loaded hinges.
 11. One (1) Kason Model K1094 Hydraulic rack and pinion door closer.
 12. One (1) Kason Model 1806 LED light fixture w/ bulb, mounted at door
 13. 48" High AFF 14 Ga. Stainless Steel interior & exterior kickplates.
 14. 14"x24" heated peep window with heated frame, 43" max mounting height
 15. Vinyl strip curtains provided at doors, 8"W x .080" thick of overlapping strips, heavy-duty transparent PVC material.
 16. One (1) Kason Model 1810LX4000 (LOT) 48" LED light fixtures with bulbs. Quantities per plans. Wire thru door monitor/switch by EC.
 17. Seismic support package to be provided as detailed on provided plans
 18. Trim matching the walk-in finish and fabricated to fit building conditions shall be supplied to close all joints between walk-in and building walls. Enclosure panels matching the walk-in finish shall be supplied to close off space between top of walk-in and building ceiling.
 19. Exterior Trim: Colored stucco to match color of walk in per plans
 20. Exposed exterior to be provided with 42" high AFF 14 Ga. stainless steel wainscot. Wainscot shall be mounted with adhesive and sealed with silicone. No external fasteners such as screws or pop rivets shall be applied as fastening for the wainscot. Provide 14GA corner guards at corners.
 21. One (1) Model SMARTRITE Unit to be provided with Smartrite Walk-In Monitoring system.
 22. The walk-ins shall be supplied with a complete set of installation, operational and maintenance instructions to cover erection of the walk-in, installation operating procedures and routine maintenance schedule. It is the responsibility of the installation contractor to follow the complete instructions to ensure proper installation of the walk-in panels. Walk-ins shall be set up at the manufacturer's facility prior to shipment and a quality control inspection performed on the product. A digital photograph of the walk-ins set up must be included at the manufacturer's facility shall be provided for the Food Equipment Contractor's permanent records.
 23. NOTE: Verify field dimensions and site conditions prior to fabrication.

ITEM # 8

EVAP. COIL/REFRIGERATION SYSTEM - PART OF REFRIGERATION RACK

Twin Rivers Unified School District Madison Elementary School Modernization RCA Project No. 1-104-02	Foodservice Equipment 11 40 00 - 28
---	--

FOR REFERENCE ONLY

Quantity: One (1)
 Manufacturer: Coldzone
 Model: CL6E09ODDA

1. One (1) Model CUSTOM Furnish and install WIF Evaporator Coil with Reverse Cycle Defrost per Plan, Details and Specifications on sheet FS.06.1. FSEC to verify size of Suction and Liquid Line required.
2. A drain line heater shall be provided for each evaporator coil located within a compartment with an operating temperature at or below +32 degree F

ITEM # 9 MOBILE STORAGE SHELVING UNIT (4-TIER)

Quantity: Five (5)
 Manufacturer: Metro
 Model: NK3

1. Five (5) Model NK3 Super Adjustable Super Erecta® Shelf, wire, Size per Plan x 62-9/16"H. Each unit to contain (4) 63UPK3 posts, (2) 5PC & (2) 5PCB casters.
2. Provide all necessary components for complete installation.
3. Note: Field Verification Required

ITEM # 10 SPARE NO.

ITEM # 11 WALK IN COOLER W/ TRIM

Quantity: One (1)
 Manufacturer: Thermalrite Refrigeration
 Model: WIC

1. One (1) Model WIC Cooler size per Plan x 8'-11"H (O.D. height). UL-listed, NSF7-approved prefabricated Modular Thermal Barrier Panel Room to hold +36°F. Provide necessary labor, material, equipment and tools for complete installation to conform to drawings and specifications, including:
2. Panel insulation: 4" DURATHANE, high density all-urethane foamed-in-place (Class 1). Provide necessary labor, equipment and tools for complete installation to conform with drawings and written specifications including:
3. Entire assembly to be provided as floorless with flat bottom wall panels installed in a 9" building floor depression and held in place with wall anchors. Walls to be installed with (9" floor depression with 6" insulation). (3) layers of 2" urethane slab insulation with 10 mil polyethylene sheeting vapor barrier to be installed by FSEC. 15# tar paper to be provided (supplied by FSEC).
4. Wearing floor by GC (install after assembly of walk-in box): Poured Epoxy w/ 6" H Coved Base w/ 3/8" radius for the interior by General Contractor.
5. Note: G.C. to provide and install backerboard for epoxy coved base adhesion
6. Metal Finishes: Interior walls & exposed exterior shall be 20 GA. White Smooth Galvanized.; Unexposed exterior to be 26 Ga. Stucco Embossed Galvanized Steel. Exposed exterior walls to the interior of the building to be 20 GA Stainless.
7. Exposed exterior to the Kitchen to be provided with 48" high AFF 14 Ga. S/S wainscot. Wainscot shall be mounted with adhesive and sealed with silicone. No external fasteners such as screws or pop rivets shall be applied as fastening for the wainscot.

Twin Rivers Unified School District Madison Elementary School Modernization RCA Project No. 1-104-02	Foodservice Equipment 11 40 00 - 29
---	--

FOR REFERENCE ONLY

8. (1) 36" x 80" High 20 Ga. S/S flush mounted entrance door with hardware – NSF Listed. An armored anti-sweat heater cable shall be run in a breaker strip located behind a removable heavy gauge stainless steel trim for easy access to heater cable. Heater cable shall be run under threshold
9. One (1) Kason Model K27C K27C handle with Mortise deadbolt latch & inside Safety Release.
10. Three (3) Kason Model K1248 Doors provided with (3) spring-loaded hinges.
11. One (1) Kason Model K1094 Hydraulic rack and pinion door closer.
12. One (1) Kason Model 1806 LED light fixture w/ bulb, mounted at door
13. 48" High AFF 14 Ga. Stainless Steel interior & exterior kickplates.
14. 14"x24" heated peep window with heated frame, 43" max mounting height
15. Vinyl strip curtains provided at doors, 8"W x .080" thick of overlapping strips, heavy-duty transparent PVC material.
16. One (1) Kason Model 1810LX4000 (LOT) 48" LED light fixtures with bulbs. Quantities per plans. Wire thru door monitor/switch by EC.
17. Seismic support package to be provided as detailed on provided plans
18. Trim matching the walk-in finish and fabricated to fit building conditions shall be supplied to close all joints between walk-in and building walls. Enclosure panels matching the walk-in finish shall be supplied to close off space between top of walk-in and building ceiling.
19. Exterior Trim: Colored stucco to match color of walk in per plans
20. Exposed exterior to be provided with 42" high AFF 14 Ga. stainless steel wainscot. Wainscot shall be mounted with adhesive and sealed with silicone. No external fasteners such as screws or pop rivets shall be applied as fastening for the wainscot. Provide 14GA corner guards at corners.
21. One (1) Model SMARTRITE Unit to be provided with Smartrite Walk-In Monitoring system.
22. The walk-ins shall be supplied with a complete set of installation, operational and maintenance instructions to cover erection of the walk-in, installation operating procedures and routine maintenance schedule. It is the responsibility of the installation contractor to follow the complete instructions to ensure proper installation of the walk-in panels.
Walk-ins shall be set up at the manufacturer's facility prior to shipment and a quality control inspection performed on the product. A digital photograph of the walk-ins set up must be included at the manufacturer's facility shall be provided for the Food Equipment Contractor's permanent records.
23. NOTE: Verify field dimensions and site conditions prior to fabrication.

ITEM # 12 EVAP. COIL- REFRIGERATION SYSTEM-PART OF REFRIGERATION RACK
 Quantity: One (1)
 Manufacturer: Coldzone
 Model: CL6A073ADA

1. One (1) Model CUSTOM Furnish and Install WIC Evaporator Coil per Plan, Details and Specifications on sheet FS.06.1
FSEC to verify size of Suction and Liquid Line required.
2. A drain line heater shall be provided for each evaporator coil located within a compartment with an operating temperature at or below +32 degree F

ITEM # 13 MOBILE STORAGE SHELVING UNIT (4-TIER)

Twin Rivers Unified School District Madison Elementary School Modernization RCA Project No. 1-104-02	Foodservice Equipment 11 40 00 - 30
---	--

FOR REFERENCE ONLY

Quantity: Five (5)
 Manufacturer: Metro
 Model: NK3

1. Five (5) Model NK3 Super Adjustable Super Erecta® Shelf, wire, Size per Plan x 62-9/16"H.
2. Provide all necessary components for complete installation.
3. Each unit to contain (4) 63UPK3 posts, (2) 5PC & (2) 5PCB casters.
4. Note: Field Verification Required

ITEM # 14 SPARE NO.

ITEM # 15 TRASH CANS W/DOLLY & LID
 Quantity: One (1)
 Manufacturer: Rubbermaid Commercial Products
 Model: FG262000GRAY

1. One (1) Model FG262000GRAY ProSave® BRUTE® Container, without lid, 20 gallon, 19-1/2"D x 22-7/8"H, round, reinforced rims, built in handles, double rimmed base, high-impact plastic construction, gray, NSF, Made in USA
2. One (1) Model FG261960BLA BRUTE® Container Lid, 19-7/8"D x 1-1/4"H, for 20 gallon trash can, heavy duty plastic, black , NSF, Made in USA
3. One (1) Model FG264000BLA Brute® Dolly, 18-1/4"D x 6-5/8"H, heavy duty 3" casters, 250 lb. capacity, for 2620, 2632, 2643, 2655, black, NSF, Made in USA (CANNOT BREAK CASE)

ITEM # 16 L-SHAPED WALL SHELF
 Quantity: One (1)
 Manufacturer: Custom S/S

1. One (1) Furnish and install Wall Shelf per Plan, Details and General Specifications on Part 2 to Part 3 herein, including: 16ga #304 S/S with 1-1/2" sanitary downward rolled rim on front and 2" turn up edge where adjacent to wall. Mount 60" AFF. Provide wall brackets of 14ga #304 S/S and tac weld to the underside of the shelf.

ITEM # 17 L-SHAPED 3-COMPARTMENT POT & PAN ASSEMBLY
 Quantity: One (1)
 Manufacturer: Custom S/S
 Model: CUSTOM

1. One (1) Model CUSTOM Furnish and install Potwash assembly per Plan, Details and General Specifications on Part 2 to Part 3 herein, including: 14ga #304 S/S top with raised rolled edge. 10"H x 2" thick backsplash. 16ga #304 S/S tubular legs, 1-5/8" dia with 1" adjustable S/S bullet feet.
2. 3-Compartment Sink: 14ga #304 S/S, with coved interior corners, horizontal and vertical. Pitch to center drain. Provide drain and removable crumb cup. All welds to be ground smooth and polished. Able to accommodate 18" x 26" bun pans.
3. INDIRECT WASTE

FOR REFERENCE ONLY

ITEM # 18 3-COMPARTMENT POT AND PAN SINK-PART OF ITEM #17

Quantity: One (1)

Manufacturer: Custom

Model: CUSTOM

1. One (1) Model CUSTOM 3-Compartment Sink: 14ga #304 S/S, with coved interior corners, horizontal and vertical. Pitch to center drain. Provide drain and removable crumb cup. All welds to be ground smooth and polished. Able to accommodate 18" x 26" bun pans.

ITEM # 19 DRAIN, LEVER / TWIST WASTE

Quantity: Three (3)

Manufacturer: T&S Brass

Model: B-3952-01

1. Three (3) Model B-3952-01 Waste Valve, twist handle, 3-1/2" sink opening, 2" drain outlet with overflow assembly (replaces B-3917-01)

ITEM # 20 WALL / SPLASH MOUNT FAUCET

Quantity: Two (2)

Manufacturer: T&S Brass

Model: B-0290-04

1. Two (2) Model B-0290-04 Big-Flo Mixing Faucet, wall mount, 8" adjustable centers, 12" swing nozzle with plain end outlet, 4" wrist handles with color coded indexes, low-lead, 3/4" female NPT, ANSI, NSF, ADA Compliant

ITEM # 21 MOBILE TRANSPORT CART

Quantity: Two (2)

Manufacturer: Lakeside Manufacturing

Model: 311

1. Two (2) Model 311 Utility Cart, open, (3) shelf, shelf size 24"W x 15-1/2"D, stainless steel angle frame with push handle, 20 ga. stainless steel legs, 300 lb. capacity, 3-1/2" swivel casters, Made in USA
2. Two (2) Casters, 4", 2 with brakes

ITEM # 22 SPARE NO.

ITEM # 23 ACCESSIBLE HAND SINK W/ SOAP & TOWEL DISPENSER

Quantity: One (1)

Manufacturer: John Boos

Model: PBHS-ADA-P-STD

1. One (1) Model PBHS-ADA-P-STD Pro-Bowl Hand Sink, wall mount, 14"W x 16" front-to-back x 5" deep bowl, (1) set of splash mount faucet holes with 4" centers, 1-7/8" drain, drain basket

FOR REFERENCE ONLY

included, soap & towel dispenser, removable front panel, includes mounting bracket, stainless steel construction, ADA compliant, NSF, CSA-Sanitation (Goose neck faucet included)

2. One (1) Model PB-SMMK-90 Splash Mount Faucet Mounting Kit, includes (2) 1/2" supply nipples, (2) retainer nuts, (2) lock washers, (2) rubber washers and (2) male & female short 90° elbows
3. One (1) Model PB-PT1.5 P-Trap, 1-1/2" & tail pipe

ITEM # 24 15" WALL- MOUNTED FILL FAUCET W/ ELBOW

Quantity: One (1)

Manufacturer: T&S Brass

Model: B-0266

1. One (1) Model B-0266 Faucet, 15" long double joint swing nozzle, backsplash mounted, 8" centers, with lever handles, 1/2" NPT female inlet, quarter-turn Eterna cartridges, low lead, ADA Compliant
2. One (1) Model B-0230-K Installation Kit, (2) 1/2" NPT nipples, lock nuts & washers, (2) short "EII" 1/2" NPT female x male
3. One (1) Model B-0230-KIT Inlet Kit, 1/2" NPT nipple, close elbows, 24" flex supply hoses

ITEM # 25 MOBILE 36"- 6 OPEN BURNER RANGE W/ CABINET BASE

Quantity: One (1)

Manufacturer: Vulcan

Model: V6B36BF

1. One (1) Model V6B36BF V Series Heavy Duty Range, gas, 36", (6) 35,000 BTU open burners, flame safety devices, cast iron grates, cabinet base, stainless steel front, front top ledge, sides, base, burner box & stub back, 6" adjustable legs, 210,000 BTU, CSA, NSF
2. One (1) Natural gas (specify elevation if over 2,000 ft.)
3. One (1) Model PRESREG-NA11/4 1-1/4" NPT pressure regulator (Natural gas)
4. One (1) 1-1/4" rear gas connection, standard
5. One (1) Rear gas connection: cap & cover, both ends
6. One (1) (3) Manual rotary ignitor with flame safety devices, for open top burners, standard
7. One (1) Model 11/4QDH 4FT 1-1/4" dia. x 4' flex hose & quick disconnect with restraining device

ITEM # 26 COMBI OVEN W/ 2 RACKS AND WATER FILTER

Quantity: One (1)

Manufacturer: RATIONAL

Model: ICP 20-FULL NG 208/240V 1 PH (LM100GG)

1. One (1) Model ICP 20-FULL NG 208/240V 1 PH (LM100GG) (CG1GRRRA.0000245) iCombi Pro® 20-Full Size Combi Oven, natural gas, (20) 18" x 26" sheet pan or (40) 12" x 20" steam pan or (20) 2/1 GN pan capacity, mobile oven rack & (10) stainless steel grids included, intelligent cooking system with (4) assistants; iDensityControl, iCookingSuite, iProductionManager, & iCareSystem, (6) operating modes, (5) cooking methods, (3) manual operating modes, 85° to 572°F temperature range, quick clean, care control, eco mode, 6-point core temperature probe, retractable hand shower, Ethernet interface, Wi-Fi enabled, 303,500 BTU, 208/240v/60/1-ph, 6 ft. cord, 2.2 kW, CE, IPX5, cCSAus, NSF, ENERGY STAR®
2. One (1) NOTE: All discounts subject to approval by manufacturer

<p>Twin Rivers Unified School District Madison Elementary School Modernization RCA Project No. 1-104-02</p>		<p style="text-align: right;">Foodservice Equipment 11 40 00 - 33</p>
--	--	--

FOR REFERENCE ONLY

3. One (1) Model 9999.4105 K-12 ~~Extended Warranty: Extends the warranty for 12 months beyond~~ the Original Equipment Warranty to 3 years parts and labor. (NET)
4. One (1) Model CAP Chef Assistance Program, a RATIONAL certified Chef conducts 4 hours/location specialized application training with personnel, no charge
5. One (1) Model 9999.2212 RCI RATIONAL Certified Installation, new certified installation for each gas floor iCombi, 100 miles (200 round-trip) included. (See attached installation flyer for details) THIS ITEM IS NON-DISCOUNTABLE, USA ONLY (NET)
6. One (1) Model 8720.1561US Installation Kit, for gas iCombi/SCC/CMP 102G (208-240/60/1ph); gas iCombi/SCC/CMP 201G (120/60/1ph); gas iCombi/SCC/CMP 202G (208-240/60/1ph) THIS ITEM IS NON-DISCOUNTABLE, USA ONLY (NET)
7. One (1) Model 1900.1154US Water Filtration Single Cartridge System, for any iVario, single Combi model, or XS or half-size Combi-Duos, includes: (1) single head with pressure gauge, R95-CL filter & filter installation kit
8. One (1) Model 9999.2271 RCI RATIONAL Certified Installation, additional installation cost for a RATIONAL Water Filter System is available when purchased with Certified Installation of RATIONAL unit THIS ITEM IS NON-DISCOUNTABLE, USA ONLY (NET)
9. One (1) NOTE: The RATIONAL Water Filtration Systems helps provide consistent high quality water to your RATIONAL cooking systems. The patented carbon block technology reduces the effects of sediment, chloramines and chlorine while providing the required flow rates
10. One (1) Model 1900.1155US Water Filtration Cartridge, replacement or add on with additional Modular Head to Double Cartridge System, includes: (1) R95-CL filter
11. One (1) Model 56.01.535 Active Green Cleaner Tabs, for all iCombi Pro/Classic, 150 pieces/bucket (minimum order quantity- 2 ea, unless ordered with a unit) (NET)
12. One (1) Model 56.00.562 Care Tabs, bucket of 150 packets for all iCombi Pro/Classic models and SelfCooking Center® units from 10/2008, with CareControl - Serial SG, SH or SI series (minimum order quantity: 2pcs, unless ordered with a unit) (NET)
13. One (1) Model 60.76.318 External Core Temperature Probe, USB connection, 20-half and full size
14. One (1) Model 60.75.326 Condensation Breaker, accelerates the expulsion of steam and other vapors from the vent pipe up into exhaust hoods, stainless steel, for model 201 and 202
15. One (1) Model 8700.0317 Floor Fixing Set (contains 2 pieces), for 20 half-size and 20 full-size units and stationary stands. One set included with delivery of floor units. (two sets will be needed for base cabinets) may be used for seismic applications. 9 mm holes for bolting
16. One (1) Model 60.22.490 (Mobile Oven Rack, type 20-full size Pro/Classic, (20) 24" x 20" pan capacity, 2-1/2" spacing (Grid Shelves sold separately)
17. One (1) Model 60.22.392 Sheet Pan Adapter, top, for 20-full size mobile racks with (20) racks, allows use of full size sheet pans without stainless steel grid
18. One (1) Model 60.22.393 Sheet Pan Adapter, below, for 20-full size mobile racks with (20) racks, allows use of full size sheet pans without stainless steel grid
19. (10) Model 6010.2101 Gastronorm Grid Shelf, 2/1 size, 25-5/8" x 20-7/8", stainless steel

ITEM # 27 MOBILE DOUBLE CONVECTION OVEN
 Quantity: One (1)
 Manufacturer: Blodgett (Middleby)
 Model: DFG-100-ES DBL

Twin Rivers Unified School District Madison Elementary School Modernization RCA Project No. 1-104-02		Foodservice Equipment 11 40 00 - 34
---	--	--

FOR REFERENCE ONLY

1. One (1) Model DFG-100-ES DBL Convection Oven, gas, double-deck, standard depth, capacity (5) 18" x 26" pans per compartment, (SSD) solid state digital controls, 2-speed fans, interior light, simultaneous operated doors with glass, stainless steel front, sides & top, 6" stainless steel legs, flue connector, (2) 3/4 HP, 45,000 BTU each, cETL, NSF, CE, ENERGY STAR®
2. One (1) Quick Ship items have limited configurations & that standard configuration may not apply. Contact factory for details
3. One (1) NOTE: Draft diverter is not required for this oven
4. One (1) Natural gas
5. Two (2) 115v/60/1-ph, 8.0 amps, 3/4 hp, 2-wire with ground, NEMA 5-15P (per deck), standard
6. One (1) Model SSD Top Oven: Solid State digital with Pulse Plus® and Cook & Hold, standard
7. One (1) Model SSD Bottom Oven: Solid State digital with Pulse Plus® and Cook & Hold, standard
8. One (1) 6" plate casters (set)
9. One (1) NOTE: DO NOT deduct cost of standard legs
10. One (1) 48" flexible gas hose with quick disconnect & restraining device

ITEM # 28 EXHAUST HOOD TYPE 1
Quantity: One (1)
Manufacturer: Gaylord Industries
Model: EL-SD-SS-DCA-300-66

1. One (1) Model EL-SD-SS-DCA-300-66 Furnish and install UL-listed and NSF-approved ventilator per Plan, Details on sheets FS.10.1 including:
Furnish Gaylord Ventilator Model "EL" as shown on plans and in accordance with the following specifications:
GENERAL: Each ventilator shall be designed specifically for the cooking equipment being covered.
The ventilator shall include a stationary grease collecting gutter at the bottom of the grease filter, sloped to a drain at one end to a built-in stainless-steel grease drawer. The sloped gutter shall be concealed by an apron which extends the full length of the hood. Each ventilator shall contain one or more standard stainless steel baffle filters. The filters and grease drawer shall be easily removable.
HOOD CONTROLS: Each ventilator shall include Gaylord's patent pending Smart Read and React DCKV technology. Ventilator incorporates canopy mounted RTD's positioned strategically across the length of the hood to produce a contact closure to react to cooking activity to comply with IMC.
CAPTURE AND CONTAINMENT: The minimum airflow rates shall be 3rd party tested to ASTM 1704-09 by the Food Service Technology Center and published on their website for easy confirmation.
<http://www.fishnick.com/publications/appliancereports/hoods/>
CONSTRUCTION: The ventilator shall be of 300 stainless steel construction with a faceted front, not less than 18 gauge, with a number 4 finish on all exposed surfaces. The ventilator shall include a "Super Capture"™ lip on the front panel for efficient capture and containment. Continuous front and rear mounting brackets shall be provided to facilitate flexible mounting to the wall and hanging from the overhead building structure. Each duct collar shall include as standard a Slide Gate Balancing Damper (SD) that adjusts manually through access from within the canopy. Ventilators built in end-to-end multiple sections shall have as standard "Continuous Capture" from one end to the other to ease cleaning and improve capture and containment.

Twin Rivers Unified School District Madison Elementary School Modernization RCA Project No. 1-104-02		Foodservice Equipment 11 40 00 - 35
---	--	--

FOR REFERENCE ONLY

LIGHT FIXTURES: The ventilator shall be equipped with:

☑ Recessed LED Lights 17 Watts /Ft. Min.

Light fixtures shall be factory pre-wired to a single connection point. Ventilators built in multiple sections shall be furnished with coiled flex conduit for interconnecting sections.

ACCEPTANCE & APPROVALS: Each ventilator shall include a built-in 3" air space conforming to NFPA-96 and IMC when mounting against a limited combustible wall. Each ventilator shall be Listed to UL Standard 710, ULC S646 and NSF/ANSI 2, comply with all requirements of NFPA-96, IMC, UMC, BOCA, and SBCCI standards.

2. Hood bottom to be at 7'-0" AFF.
3. One (1) Model PBW PLENUM BOX for distributing low velocity make-up air down, immediately in front of the ventilator, as shown on the plans. Shall be capable of delivering up to 150 CFM per lineal foot of ventilator at a low velocity. Shall be designed to fit in front of the ventilator, either flush with the ceiling or dropped down in front of the ventilator. All exposed surfaces shall be S/S construction not less than 20ga. Shall have bottom discharge through removable S/S perforated panels and shall include internal baffling to provide even air distribution along the entire length of the unit. One or more flanged duct collars shall be provided as shown on the plans. Shall have two full-length mounting angles with 5/8" holes on 12" centers to accommodate hanging from the overhead.
4. LED Light Fixtures, QTY per plans, with switch (switching is part of electrical work, EC to interconnect exhaust fan on roof to switch at hood)

ITEM # 29 EXHAUST SYSTEM - PROVIDED BY THE HVAC

Quantity: One (1)

Manufacturer: Custom

1. One (1) Per Mechanical Engineer's specifications. EC to interconnect exhaust fan on roof with switch at hood, verify electrical requirements with HVAC.

ITEM # 30 MAKE-UP AIR SYSTEM - PROVIDED BY THE HVAC

Quantity: One (1)

Manufacturer: Custom

1. One (1) Per Mechanical Engineer's specifications. EC to interconnect supply fan on roof with switch at hood, verify electrical requirement with HVAC.

ITEM # 31 FIRE SUPPRESSION SYSTEM (PIPING SYSTEM)

Quantity: One (1)

Manufacturer: Ansul Fire Protection

Model: R-102 ASEF-3T

1. One (1) Model R-102 ASEF-3T Chemical Fire Protection System with Automan Regulated Release Assembly furnished and installed by hood manufacturer. Install in accordance with NFPA Bulletin 96, including all current amendments to protect hood and surface protection as required. All piping and conduit shall be run concealed in walls or above ceiling, except where exposure is necessary for functional reasons. Exposed piping shall be chrome plated. Include reset relay and manual remote pull station. System shall connect to electrical shut-off gas valve. All contactors are furnished by EC for shut down of electrical supply to all equipment in the

Twin Rivers Unified School District Madison Elementary School Modernization RCA Project No. 1-104-02		Foodservice Equipment 11 40 00 - 36
---	--	--

FOR REFERENCE ONLY

event of system activation. System control cabinet shall be installed in location shown.

ELECTRICAL: 120V/1ph. Shunt trip breaker for power shut down of all appliances below the exhaust hood shall be provided as part of EC work. If required by the District, EC to provide connection to the District's monitoring control panel.

MECHANICAL: PC to install the electrical shut-off gas valve provided by FSEC.

ITEM # 32 FIRE SUPPRESSION SYSTEM CONTROL AUTOMAN - PART OF #31

Quantity: One (1)

Manufacturer: Ansul Fire Protection

1. One (1) 120V/1ph

ITEM # 33 FIRE SUPPRESSION SYSTEM MANUAL PULL - PART OF #31

Quantity: One (1)

Manufacturer: Ansul Fire Protection

1. One (1) Manual fire alarm boxes shall comply with CBC Section 907.4.2, 1117B.6 and 1118B.

ITEM # 34 S/S WALL FLASHING W/ TRIM

Quantity: One (1)

Manufacturer: Custom S/S

Model: WALL FLSH, HD TR

1. One (1) Model WALL FLSH, HD TR Furnish and install Wall Flashing & Hood Trim per Plan, Details and General Specifications on Part 2 to Part 3 herein, including: Minimum 18ga #304 S/S. Sheets shall be set vertically with seams running perpendicular to the ceiling and floor. Seams and ends shall be capped with appropriate S/S T-molding or End molding. Attach to wall with approved mastic. Clad back wall and provide trim as required. All trim is to be turned-in, top and bottom, on a 90-degree angle and stacked on top of the hood...it shall not be lapped and tac-welded to the front face of the hood

ITEM # 35 1-SECTION PASS-THRU REFRIGERATOR

Quantity: One (1)

Manufacturer: Traulsen

Model: RHT132WPUT-FHS

1. One (1) Model RHT132WPUT-FHS Spec-Line Refrigerator, Pass-thru, one-section, self-contained refrigeration, StayClear™ Condenser, variable speed compressor, stainless steel exterior and interior, standard depth, wide full-height solid doors, both sides with EZ-Clean Gaskets, (3) adjustable wire shelves per section, microprocessor controls, 6" adjustable stainless steel legs, R-290 Hydrocarbon refrigerant, 1/2 HP, cULus, NSF
2. One (1) 115v/60/1-ph, 7.2 amps, cord with NEMA 5-15P, standard
3. One (1) Full height solid door, standard
4. One (1) Full height solid door, standard
5. One (1) Thermometer side door: hinged on right, standard
6. One (1) Rear door hinged on right, standard
7. Nine (9) Universal tray slides for (1) 18"x26" or (2) 14"x18" or (2) 12" x 20" pans -per pair

FOR REFERENCE ONLY

8. One (1) Casters, 6" high (set of 4)

ITEM # 36 ISLAND PREP TABLE W/ DRAWERS

Quantity: One (1)

Manufacturer: Custom S/S

1. One (1) Furnish and install Table with Marine Edge per Plan, Details and General Specifications on Part 2 to Part 3 herein, including:
14ga S/S top with marine edge. 8"Hx2" thick integral backsplash and side splash where adjacent to wall. 16ga S/S undershelves. 16ga #304 S/S tubular legs, 1-5/8" dia with 1" adjustable S/S bullet feet.
2. Two (2) Self-closing drawer with (4) 2" dia ball bearing rollers traveling on 16ga S/S slides, 18ga S/S enclosure, cylinder lock, recessed full-length S/S handle, and removable 20ga #304 S/S drawer pan, 20"x20"x5" deep, with coved corners.
3. One (1) All welds to be ground smooth and polished.
4. Note: To Include item #24: 2 compartment sink

ITEM # 37 2-COMPARTMENT SINK- PART OF ITEM 36

Quantity: One (1)

Manufacturer: Custom S/S

Model: CUSTOM

1. One (1) Model CUSTOM 2-Compartment Sink: 14ga #304 S/S with coved interior corners, horizontal and vertical. Pitch to center drain. Provide drain and removable crumb cup.
2. Two (2) Sink Covers & Storage: 14ga S/S construction with grommet finger hole. Covers will store below in a storage slot above the lower shelf.

ITEM # 38 TWIST WASTE W/ OVERFLOW

Quantity: Two (2)

Manufacturer: T&S Brass

Model: B-3952-01

1. Two (2) Model B-3952-01 Waste Valve, twist handle, 3-1/2" sink opening, 2" drain outlet with overflow assembly (replaces B-3917-01)

ITEM # 39 10" DECK MOUNTED FAUCET

Quantity: One (1)

Manufacturer: T&S Brass

Model: B-0226

1. One (1) Model B-0226 Mixing Faucet, deck mount, 10" swing nozzle, 4" centers with 1/2" IPS eccentric flanged female inlets, quarter-turn Eterna cartridges, lever handles, low lead, ADA Compliant
2. One (1) Model B-0425-M Supply Nipple Kit, includes (1) 1/2" NPT x 2" long inlet supply nipple, (1) 1/2" locknut washer & (1) 1/2" locknut, brass (2 each per master pack)

FOR REFERENCE ONLY

3. One (1) Model B-0425-KIT Inlet Kit with 24" supply hoses, Nipples, Washer and Locknuts that provide 1/2" NPT male outlet and 3/8" female compression inlet. Certified to ASME A112.18.1/CSA B125.1, NSF 61-Section 9 and NSF 372.

ITEM # 40 TABLE MTD OVERSHELF -PART OF ITEM #36

Quantity: One (1)

Manufacturer: Custom

Model: CUSTOM

1. One (1) Model CUSTOM Furnish and install Overshelf per Plan, Details and General Specifications on Part 2 to Part 3 herein, including: 16ga #304 S/S construction. Rolled rim (4) sides. Mount 54" AFF on 1-5/8" dia S/S tubular posts, embossed and fully welded to table top. Reinforce S/S as required.

ITEM # 41 1-SECTION PASS-THRU MOBILE HEATED CABINET

Quantity: One (1)

Manufacturer: Cres Cor

Model: H138PWS1834D

1. One (1) Model H138PWS1834D Cabinet, Mobile Heated, pass-thru, with AquaTemp™ humidity cabinet, insulated, top-mount heater assembly, solid state electronic control with digital display, recessed push/pull handles, channel pan slides hold (32) 18" x 26" pans on 1-1/2" centers, field reversible dutch doors, anti-microbial magnetic door latches, (4) 5" swivel casters (2) braked, stainless steel construction, NSF, cCSAus
2. One (1) 120v/60/1-ph, 2.0 kW, 16 amp, standard
3. Two (2) Left-hand door swing for front door (top & bottom) (per door)
4. Two (2) Left-hand door swing for rear doors (top & bottom) (per door)

ITEM # 42 MOBILE DRYING RACK W/ DRIP TRAY

Quantity: One (1)

Manufacturer: Metro

Model: PR48VX3-XDR

1. One (1) Model PR48VX3-XDR MetroMax® i Mobile Drying Rack Unit with Drip Tray, 48"W x 24"D x 68"H, 4-tier, for bulk drying & trays/cutting boards/sheet pans, includes: (3) open shelf frames, (1) shelf, (4) 63" mobile posts, (2) drop-ins, (1) cutting board/tray drying rack, (1) adjustable drip tray, (4) polymer swivel casters (2 with brakes), built in Microban® antimicrobial product protection, NSF

ITEM # 43 SPARE NO.

ITEM # 44 SPARE NO.

ITEM # 45 SPARE NO.

Twin Rivers Unified School District Madison Elementary School Modernization RCA Project No. 1-104-02		Foodservice Equipment 11 40 00 - 39
---	--	--

FOR REFERENCE ONLY

ITEM # 46 SPARE NO.

ITEM #47 SALAD BAR
Quantity: One (1)
Manufacturer: Duke Manufacturing
Model: TST-74SS

Furnish and set in place per manufacturer's standard specifications and the following:

1. Thurmaduke™ Solid Top Unit, 14ga stainless steel welded frame & supports, 20ga stainless steel body & bottom shelf, 5" dia. gray poly swivel casters & brakes, NSF
2. 14ga stainless steel countertop, extended 2" on both sides & 1" on both ends, 32" high, 34" deep, and 74" long
3. Countertop cutout, and prep to accept drop-in unit
4. Decor Panel on front & both ends, Formica (or equal) plastic laminate on 3/4" exterior grade wood backer, fully welded and polished low profile stainless steel edge trim, & 2" perimeter reveal around panel sections
5. Decor Panel & Hinged Doors on open side, Formica (or equal) plastic laminate on 3/4" exterior grade wood backer, fully welded and polished low profile stainless steel edge trim, slotted vented doors, concealed hinges, & ADA compliant door pulls
6. Electric receptacle in base, mounted & wired
7. Toe Plate, 16ga stainless steel kick plate, continuous style, mounted with magnets, and 2" bottom gap for air flow
8. 6 ft. cord & plug

ITEM #48 COLD FOOD WELL DROP-IN
Quantity: One (1)
Manufacturer: Duke Manufacturing
Model: ADI-4MD-N7

Furnish and set in place per manufacturer's standard specifications and the following:

1. Drop-In Cold Food Pan, refrigerated, 60-7/8"W x 25-1/2"D x 26"H, accommodates (4) 6" deep 12" x 20" pans, 300 series stainless steel top with overhang & locking tabs, 10" deep 300 series stainless steel interior liner, steel exterior housing, remote mounted on/off switch with stainless steel face plate, air-cooled condensing unit, (3) adapter bars included, R448a, cULus, UL EPH Classified, * No Drain *
2. 120v/60/1-ph, 6.78 amps, 1/2 HP, NEMA 5-15P
3. 300 Series One Piece Rim, 3/8"H, 90 degrees turn down edges, 16 gauge stainless steel

ITEM #49 SNEEZE GUARD, STATIONARY
Quantity: One (1)
Manufacturer: Duke Manufacturing
Model: TS422-74

Furnish and set in place per manufacturer's standard specifications and the following:

Twin Rivers Unified School District Madison Elementary School Modernization RCA Project No. 1-104-02		Foodservice Equipment 11 40 00 - 40
---	--	--

FOR REFERENCE ONLY

1. Contemporary Food Shield, 20-1/8"H, adjustable from full-service to self-service guard, single shelf, vertical fixed end closures, 1" dia. vertical stainless steel tube posts, stainless steel finish posts 3/8" glass over-shelf & guard with 1/4" glass ends (tempered and polished rounded edges), Back-to-Back Assembly for dual sided self-service
2. Special length over-shelf

ITEM # 50 STUDENT'S HOT/ COLD SERVING COUNTER
Quantity: One (1)
Manufacturer: Duke Manufacturing
Model: TST-74SS/ TST-18SS/ TST-60SS

Furnish and set in place per manufacturer's standard specifications and the following:

1. Thurmaduke™ Solid Top Unit, 14ga stainless steel welded frame & supports, 20ga stainless steel body & undershelves, NSF mounted on 4" high galvanized steel curb base
2. 14ga stainless steel countertop, continuous style over adjacent item, extended 4" on customer's side, 32" high, 36" deep, and 74" long
3. Countertop cutout, and prep to accept drop-in unit
4. Stainless steel control panel, modify apron/rail, cutouts, & switches mounted & wired
5. Decor Panel on front, Formica (or equal) plastic laminate on 3/4" exterior grade wood backer, fully welded and polished low profile stainless steel edge trim, & 2" perimeter reveal around panel sections
6. Louvered hinged doors on open side, stainless steel grilles, lift-off hinges and ADA compliant door pulls
7. Electric receptacles in base, mounted & wired
8. Wire chase, stainless steel & removable cover
9. Factory mount and wire drop-in unit & sneeze guard, remote switches in control panel
10. Thurmaduke™ Solid Top Unit, 14ga stainless steel welded frame & supports, 20ga stainless steel body & undershelves, NSF mounted on 4" high galvanized steel curb base
11. 14ga stainless steel countertop, continuous style over adjacent item, extended 4" on customer's side, 32" high, 36" deep, and 18" long
12. Decor Panel on front, Formica (or equal) plastic laminate on 3/4" exterior grade wood backer, fully welded and polished low profile stainless steel edge trim, & 2" perimeter reveal around panel sections
13. Hinged door on open side, stainless steel, lift-off hinges and ADA compliant door pull
14. Electric load center, panel box & cover, circuit breakers & panel schedule, stainless steel enclosure & removable access panel, and receptacles wired.
15. Thurmaduke™ Solid Top Unit, 14ga stainless steel welded frame & supports, 20ga stainless steel body & undershelves, NSF mounted on 4" high galvanized steel curb base
16. 14ga stainless steel countertop, continuous style over adjacent item, extended 4" on customer's side, 32" high, 36" deep, and 51" long
17. Countertop cutout, and prep to accept drop-in unit
18. Stainless steel control panel, modify apron/rail, cutouts, & switches mounted & wired
19. Decor Panel on front, Formica (or equal) plastic laminate on 3/4" exterior grade wood backer, fully welded and polished low profile stainless steel edge trim, & 2" perimeter reveal around panel sections
20. Louvered hinged doors on open side, stainless steel grilles, lift-off hinges and ADA compliant door pulls

Twin Rivers Unified School District Madison Elementary School Modernization RCA Project No. 1-104-02		Foodservice Equipment 11 40 00 - 41
---	--	--

FOR REFERENCE ONLY

21. Electric receptacles in base, mounted & wired
22. Wire chase, stainless steel & removable cover
23. Factory mount and wire drop-in unit & sneeze guard, remote switches in control panel

ITEM # 51 DROP IN RECESSED HOT/ FROST SHELF

Quantity: One (1)
Manufacturer: Duke Manufacturing
Model: RHF1-SL

Furnish and set in place per manufacturer's standard specifications and the following:

1. HotFrost™ Recessed Hot Frost, Hot/Cold switchable slimline drop-in unit, 29"W x 21"D, fits (1) 18 x 26" pan per shelf, programmable color touch screen control, stainless steel body and shelf, self-contained refrigeration, 120v/60/1-ph, 5.5 Amps, NEMA 5-15P
2. Stone inserts in recess, choice of 3 different colors, Dekton insert, select from Domoos, Zenith or Strato colors

ITEM #52 SNEEZE GUARD, STATIONARY

Quantity: One (1)
Manufacturer: Duke Manufacturing
Model: TS422-60

Furnish and set in place per manufacturer's standard specifications and the following:

1. Contemporary Food Shield, 19-1/2"D x 20-1/8"H, adjustable from full-service to self-service guard, single shelf, vertical fixed end closures, 1" dia. vertical stainless steel tube posts, stainless steel finish posts, 3/8" glass over-shelf & guard with 1/4" glass ends (tempered and polished rounded edges)
2. Special length over-shelf

ITEM # 53 DROP-IN 4-WELL HOT/COLD FOOD PANS

Quantity: One (1)
Manufacturer: Duke Manufacturing
Model: HCF-4

Furnish and set in place per manufacturer's standard specifications and the following:

1. Hot/Cold/Freeze Drop-In Food Well Unit, heated & refrigerated, 65" long, (4) 12" x 20" individual pans, 300 series stainless steel top rim, 5" deep 300 series stainless steel interior liners, steel exterior housing, individual wired remote digital controls for hot or cold operation, air-cooled condensing unit, individual drains manifolded to a valve, 6' cord & plug, UL, cULus, NSF #4 & 7
2. 120/208v/60/1-ph, 16.0 amps, NEMA L14-20P
3. No Drains

ITEM #54 SNEEZE GUARD, STATIONARY

Quantity: One (1)
Manufacturer: Duke Manufacturing
Model: TS422-74

Twin Rivers Unified School District Madison Elementary School Modernization RCA Project No. 1-104-02		Foodservice Equipment 11 40 00 - 42
---	--	--

FOR REFERENCE ONLY

Furnish and set in place per manufacturer's standard specifications and the following:

1. Contemporary Food Shield, 19-1/2"D x 20-1/8"H, adjustable from full-service to self-service guard, single shelf, vertical fixed end closures, 1" dia. vertical stainless steel tube posts, stainless steel finish posts, 3/8" glass over-shelf & guard with 1/4" glass ends (tempered and polished rounded edges)
2. Special length over-shelf

ITEM # 55 SPARE NO.

ITEM # 56 MOBILE MILK COOLER

Quantity: One (1)

Manufacturer: Beverage Air

Model: ST49HC-S

1. One (1) Model ST49HC-S School Milk Cooler, cold wall, normal temperature, 49"W x 31-1/4"D x 41-1/8"H, 18.97 cu. ft., dual access, flat top carton capacities, (12) 13" x 13" x 11" or (8) 19" x 13" x 11 case capacities, self-latching doors/lids with safety bumpers, cylinder lock, wire floor racks, electronic control, manual defrost, stainless steel interior & exterior, R290 Hydrocarbon refrigerant, 1/2 HP, cULus, UL EPH Classified, UL-Sanitation, Made in USA
2. One (1) Self-Contained refrigeration
3. One (1) 115v/60/1-ph, 3.7 amps, cord with NEMA 5-15P
4. One (1) 4" Heavy duty casters, (2) with brakes, standard

ITEM #57 ADA P.O.S. COUNTER

Quantity: One (1)

Manufacturer: Duke Manufacturing

Model: TST-46SS

Furnish and set in place per manufacturer's standard specifications and the following:

1. Thurmaduke™ Solid Top Unit, mobile Cashier Stand, 14ga stainless steel welded frame & supports, 20ga stainless steel body & undershelves, 5" dia. gray poly swivel casters & brakes, NSF
2. 14ga stainless steel countertop, 33.5" high, 42" deep, and 24" long
3. Cutout in countertop round with plastic grommet for cord pass
4. Cash drawer #HP-121 & stainless steel mounting bracket
5. Decor Panel on front & both ends, Formica (or equal) plastic laminate on 3/4" exterior grade wood backer, fully welded and polished low profile stainless steel edge trim
6. Open Base, wheelchair access & ADA compliant
7. Toe Plate, 16ga stainless steel kick plate, continuous style on front & ends, mounted with magnets, and 2" bottom gap for air flow
8. Electric receptacles in base, mounted & wired
9. 6 ft. cord & plug

ITEM # 58 POINT-OF-SALE UNIT -BY DISTRICT

Quantity: One (1)

Manufacturer: Custom

Twin Rivers Unified School District Madison Elementary School Modernization RCA Project No. 1-104-02	Foodservice Equipment 11 40 00 - 43
---	--

FOR REFERENCE ONLY

Model: CUSTOM
1. One (1) Model CUSTOM Provided by School District, Installed by General Contractor

ITEM # 59 CARD READERS-BY DISTRICT
Quantity: Two (2)
Manufacturer: Custom
Model: CUSTOM
1. Two (2) Model CUSTOM Provided by School District, Installed by General Contractor

ITEM # 60 SPARE NO.
ITEM # 61 SPARE NO.
ITEM # 62 SPARE NO.
ITEM # 63 SPARE NO.
ITEM # 64 SPARE NO.

ITEM # 65 WALL BACKING (NOT SHOWN ON FLOOR PLAN)
Quantity: One (1)
Manufacturer: Custom S/S
1. One (1) Furnish and install Wall Backing for Metal Frame Construction per Plan, Seismic Details and General Specifications on Part 2 to Part 3 herein, including: Minimum 12"W x height per Seismic sheet. Wall backing shall run 6" beyond full length of equipment item at each side. FSEC shall provide and GC shall install metal backing, min 14ga galvanized steel. Secure wall backing to studs.

END OF SECTION

Twin Rivers Unified School District Madison Elementary School Modernization RCA Project No. 1-104-02		Foodservice Equipment 11 40 00 - 44
---	--	--

SECTION 12 11 03 MURAL PAINTING AND FAUX FINISHES

PART 1 GENERAL

1.01 SUMMARY

- A. Specialty painting of mural by artisans.
- B. Mural to be painted on smooth trowel plaster on wall surfaces, where indicated on Drawings.
 - 1. Mural image to be provided by Architect or District.
- C. Painting of other building elements are specified in 09 91 13 - Exterior Painting, 09 91 23 - Interior Painting, 09 96 00 - High-Performance Coatings, and 09 96 23 - Graffiti-Resistant Coatings .
- D. Prepare and prime identified surfaces scheduled for paint.

1.02 RELATED REQUIREMENTS

- A. Section 01 61 16 - Volatile Organic Compound (VOC) Content Restrictions.
- B. Section 05 50 00 - Metal Fabrications: Shop-primed items.
- C. Section 09 91 13 - Exterior Painting.
- D. Section 09 91 23 - Interior Painting.

1.03 REFERENCE STANDARDS

- A. PDCA P1 - Touch Up Painting and Damage Repair: Financial Responsibility and Definition of a Properly Painted Surface.
- B. PDCA Standards - PDCA Industry Standards, Painting Contractors Association.
- C. SSPC-SP 2 - Hand Tool Cleaning.
- D. SSPC-SP 3 - Power Tool Cleaning.
- E. SSPC-SP 6 - Commercial Blast Cleaning.
- F. SSPC-SP 7 - Brush-Off Blast Cleaning.

1.04 DEFINITIONS

- A. System DFT: Dry film thickness of entire coating system unless otherwise noted.

1.05 SUBMITTALS

- A. General: Submit in accordance with Section 01 30 00 - Administrative Requirements.
- B. Product Data:
 - 1. Submit product data, including label analysis for each product proposed for use.
 - 2. Specifically include percent solids-by-volume, volatile organic compound (VOC) content in g/L, and lead content (percent of weight of dried film).
- C. Mural Shop Drawing: Scaled rendering with true representation of color and content placement.

- D. Color and Sheen Samples:
 - 1. Prepare multiple samples of each opaque finish coating specified in each color and sheen scheduled for appearance verification.
 - 2. Apply to 1/4 inch hardboard. Apply sufficient coating thickness to provide proper hiding and appearance.
 - 3. Label each sample to indicate material, color, and sheen.
 - 4. Mural: 24 by 24 inches, two different scenes - all colors and sheen.
- E. Submit following Informational Submittals:
 - 1. Certifications specified in Quality Assurance article.
 - 2. Qualification Data: Applicator's qualification data.
 - 3. Manufacturer's instructions.
- F. Closeout Submittals:
 - 1. Submit under provisions of Section 01 70 00 - Execution and Closeout Requirements.
 - 2. Warranty: Submit specified warranty.

1.06 QUALITY ASSURANCE

- A. Comply with PDCA Standards.
- B. Single Source Responsibility:
 - 1. Provide products of single manufacturer for use in each coating system.
 - 2. Do not mix products of different manufacturers without approval of Architect or Owner Representative and manufacturers involved.
 - 3. Provide manufacturer recommended materials (base and tints) for deep tone colors.
- C. Applicator Qualifications:
 - 1. Company specializing in commercial painting and finishing with 3 years documented experience.
 - 2. Employ artisans with specialized training and abilities for Mural and plaster painting.

1.07 FIELD SAMPLES

- A. General: Comply with requirements of Section 01 40 00 - Quality Requirements.
- B. Sample Installation: Duplicate finishes of approved coating system samples on wall surfaces and other interior and exterior components selected by Agency.
- C. Provide full-coat finish on at least 10 sq. ft. of surface until required color, sheen, and texture are obtained. Simulate finished lighting conditions for review of in-place work.

1.08 DELIVERY, STORAGE, AND HANDLING

- A. Deliver products to site in manufacturer's sealed and labeled containers; inspect to verify compliance with specified requirements.
- B. Label containers to indicate manufacturer's name, product name and type of coating, brand code or stock number, date of manufacture, coverage, surface preparation, drying time, cleanup, color designation and instructions for mixing and reducing.

- C. Store coating materials in tightly covered containers in well ventilated area at ambient temperatures of 45 degrees F minimum and 90 degrees F maximum, unless required otherwise by manufacturer. Maintain containers in clean condition, free of foreign materials and residue with labels in legible condition.
- D. Take precautionary measures to prevent fire hazards and spontaneous combustion.

1.09 PROJECT CONDITIONS

- A. Environmental Conditions: Comply with more restrictive of following or manufacturer's requirements under which systems can be applied.
 - 1. Do not apply coatings under any of following conditions:
 - a. When surfaces are damp or wet.
 - b. When relative humidity is less than 20 percent or exceeds 85 percent.
 - c. When temperature is less than 5 degrees F above dew point.
 - d. When dust may be generated before coatings have dried.
 - e. In direct sunlight.
 - f. When wind velocity is above 20 mph.

1.10 WARRANTY

- A. Comply with provisions of Section 01 78 00 - Closeout Submittals.
- B. Warrant installation to be free from defects in material and workmanship for 5 years.
- C. Repair or replace defects occurring during warranty period.
- D. Defects include but are not limited to pinholes, crazing or cracking, loss of adhesion to substrate, deficient thickness, improper materials and workmanship.

1.11 EXTRA STOCK MATERIAL

- A. Provide one unopened gallon container of each type of opaque top coating in each color and sheen used on Project.
- B. Store where directed with labels intact.

PART 2 PRODUCTS

2.01 SYSTEM REQUIREMENTS

- A. Interface with Adjacent Systems:
 - 1. Review other Sections specifying prime coats to ensure compatibility of total coating system for various substrates.
 - 2. Upon request from other trades, furnish information on characteristics of finish materials proposed for use to ensure compatibility of various coatings.
 - 3. Test compatibility of existing coatings, including shop applied primers and previously applied coatings, by applying specified special coating to small, inconspicuous area.
 - 4. If specified coating lifts or blisters existing coating, apply barrier or tie coat as recommended by coating manufacturer.

5. If no compatible barrier or tie coat exists, remove existing coating completely and apply coating system as specified for new work.

2.02 COATING MATERIALS - GENERAL

- A. Coatings:
 1. Ready-mixed, factory tinted, best professional grade produced by manufacturer.
 2. Use manufacturer's appropriate base materials to achieve required colors.
 3. Fully grind pigments to maintain soft paste consistency in vehicle.
 4. Capable of being dispersed into uniform, homogeneous mixture.
 5. Possess good flowing and brushing properties.
 6. Capable of drying or curing free of streaks or sags, and yielding specified finish.
 7. VOC content of field applied coatings shall comply with local governing authorities.

2.03 FINISH COATINGS SCHEDULE

- A. See Section 09 91 13 - Exterior Painting.

2.04 COLOR SCHEDULE

- A. Colors and sheen are indicated on Drawings.

2.05 PRIME COATINGS

- A. See Section 09 91 13 - Exterior Painting.

2.06 ACCESSORY MATERIALS

- A. Muriatic acid, mildewcide, TSP (tri-sodium phosphate), acidic-detergent, zinc sulfate, sodium metasilicate, and solvent: Commercially available, non-damaging to surface being cleaned; as specified in PDCA P1; acceptable to coating manufacturer.
- B. Metal Conditioner: Proprietary phosphoric acid based, etching type solution; acceptable to coating manufacturer.
- C. Rust Inhibitor: Water containing 0.32 percent of sodium nitrite and 1.28 percent by weight of secondary ammonium phosphate (dibasic); or water containing 0.2 percent by weight of chromic acid or sodium chromate or sodium dichromate or potassium dichromate.
- D. Spackling compound, putty, plastic wood filler, liquid de-glosser, latex patching plaster, latex base filler, thinners, and other materials not specifically indicated but required to achieve finishes specified: Pure, of highest commercial quality, compatible with coatings and acceptable to coating manufacturer.
- E. Do not use products of different manufacturers in combination.

2.07 MIXING

- A. Use factory prepared colors matching approved samples. Site tinting will not be permitted.
- B. Thoroughly mix and stir coatings before use to ensure homogeneous dispersion of ingredients. Prior to application, blend multiple containers of same material and color by pouring from one container to another several times to ensure uniform consistency, color, and smoothness.

- C. Mix only in clean mixing pails of material recommended by manufacturer to avoid contamination.
- D. Remove film which may form on surface of material in containers and strain material before using. Stir frequently during use to maintain pigments in suspension. Do not stir film into material.
- E. Apply coatings of consistency recommended by manufacturer. Thin only within recommended limits using thinners approved by coating manufacturer.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Examine conditions and proceed with work when conditions are acceptable. Beginning work shall indicate acceptance of substrates and underlying conditions.
- B. Measure moisture content of substrates using recently calibrated electronic moisture meter.
 - 1. Concrete and Plaster: 17 percent.
 - 2. Do not apply coatings if moisture content of surfaces exceeds lesser of percentages listed below or those required by coating manufacturer.
 - 3. If excess moisture content exists and cannot be reduced, obtain written approval of coating manufacturer before application of coatings.
- C. Prior to applying alkali and acid sensitive coatings, test surface pH with universal pH paper placed against wetted surface. Substrate pH shall not exceed pH of clean wash water.
- D. Beginning of execution constitutes acceptance of existing conditions.

3.02 PREPARATION - GENERAL

- A. Protect completed construction from damage. Furnish drop cloths, shields, and protective methods to prevent spray, splatter, or droppings from disfiguring other surfaces.
- B. Before beginning application of coatings, ensure surfaces are clean, dry, and free of dirt, dust, rust or rust scale, oil, grease, mold, mildew, algae, efflorescence, release agents, or any other foreign material which could adversely affect coating adhesion or finished appearance.

3.03 SURFACE PREPARATION FOR NEW WORK

- A. General:
 - 1. Correct minor defects.
 - 2. Remove temporary labels, wrappings, and protective coverings from surfaces to be coated.
 - 3. Seal stains, marks, and other imperfections which may bleed through surface finishes.
- B. Plaster:
 - 1. Allow surfaces to cure and dry completely prior to application of coatings; minimum of 28 days.
 - 2. Remove dirt, efflorescence, scale, loose sand, and powder by wire brushing or by other approved methods.

3. Remove oil and grease with solution of TSP, rinse, and allow to dry.
 4. Wash portland cement plaster to receive solvent reducible coatings with zinc sulfate solution, rinse, and allow to dry.
 5. Fill hairline cracks, small holes and imperfections with latex patching plaster. Make smooth and flush with adjacent surfaces.
- C. Steel - Uncoated:
1. Remove weld spatter by chipping or grinding.
 2. Clean interior and weather protected steel in accordance with SSPC-SP 2 and SSPC-SP 3. Clean areas of excessive corrosion or scale in accordance with SSPC-SP 7.
 3. Clean exterior steel permanently exposed to elements in accordance with SSPC-SP 6.
 4. Apply metal conditioner to bare surfaces in accordance with manufacturer's recommendations, paying particular attention to abrasions, welds, bolts, and nuts.
 - a. Allow to set as recommended by solution manufacturer.
 - b. Rinse with clean water with rust inhibitor mixed with water or applied immediately following rinse.
 - c. Allow to dry.
 5. Prime coat immediately.
- D. Steel - Prime Coated:
1. Remove loose primer and rust to feather-edge at adjacent sound primer by cleaning in accordance with SSPC-SP 2 and SSPC-SP 3.
 2. Apply metal conditioner to abrasions, welds, bolts, and nuts in accordance with manufacturer's recommendations.
 - a. Allow to set as recommended by manufacturer.
 - b. Rinse with clean water with rust inhibitor mixed with water or applied immediately following rinse.
 - c. Allow to dry.
 3. Prime coat bare areas immediately.
 4. Apply specified primer to bare steel and previously primed steel surfaces including steel stair stringers and metal fabrications.
- E. Steel - Galvanized:
1. Remove white rust by cleaning in accordance with SSPC-SP 2 and SSPC-SP 3. Exercise care not to remove galvanizing.
 2. Pretreat surfaces to receive solvent reducible coatings immediately.

3.04 APPLICATION

- A. General Requirements:
1. Coat all surfaces specified, scheduled, illustrated, and otherwise exposed unless specifically noted otherwise.
 2. Apply coatings of type, color, and sheen as selected.

FOR REFERENCE ONLY

3. Apply products in accordance with Division 01. Use application materials, equipment, and techniques as recommended by coating manufacturer and best suited for substrate and type of material being applied.
 4. Do not apply finishes to surfaces that are improperly prepared.
 5. Number of coats specified are minimum number acceptable.
 6. Apply coating systems to total dry film thickness scheduled.
 - a. Apply material at not less than manufacturer's recommended spreading rate.
 - b. Do not exceed maximum single coat thickness recommended by coating manufacturer.
 - c. Do not double-back with spray equipment building up film thickness of two coats in one pass.
 7. Ensure that edges, corners, crevices, welds, and exposed fasteners receive dry film thickness equivalent of flat surfaces.
 8. Finish edges of coatings adjoining other materials or colors sharp and clean, without overlapping.
- B. Prime Coats:
1. Apply initial coat to surfaces as soon as practical after preparation and before subsequent surface deterioration.
 2. Backprime exterior woodwork with specified primer.
 3. Backprime interior woodwork scheduled to receive transparent finish with gloss varnish reduced 25 percent with mineral spirits.
 4. Apply primer to wood and metal sash before field glazing.
- C. Intermediate and Top Coats:
1. Allow previously applied coat to dry before next coat is applied.
 2. Sand and dust lightly between coats as recommended by coating manufacturer.
 3. Apply each coat to achieve uniform finish, color, appearance, and coverage free of brush and roller marks, runs, misses, visible laps or shadows, hazing, bubbles, pin holes, or other defects.
 4. If stains, undercoats, or other conditions show through final topcoat, correct defects and apply additional topcoats until coating film is of uniform finish, color, and appearance.
- D. Finish Matching:
1. Finish closets same as adjoining rooms, unless otherwise specified.
 2. Finish tops, bottoms, and edges of doors same as door faces.
 - a. Apply sanding sealer to cut-outs.
 - b. When faces are different colors, finish edges of doors to match space from which they are visible when door is in partly open position.
 3. Finish other surfaces not specifically mentioned to match adjoining surfaces.
- E. Reinstall trim, fittings, and other items removed for finishing.

3.05 FIELD QUALITY CONTROL

- A. General: Comply with requirements of Section 01 40 00 - Quality Requirements.
- B. Periodically test film thickness of each coat with wet film gage to ensure coatings are being applied to proper thickness.
- C. Request review of each applied coat by Architect before application of successive coats. Only reviewed coats will be considered in determining number of coats applied.
- D. Immediately prior to Substantial Completion, perform detailed inspection of painted surfaces and repair or refinish abraded, stained, or otherwise disfigured surfaces.

3.06 CLEANING

- A. Promptly remove spilled, splashed, or spattered coatings. Clean spots, oil, and other soiling from finished surfaces using cleaning agents and methods which will not damage materials.
- B. If completed construction is damaged beyond normal cleaning or repair by painting operations, replace damaged items at no additional cost to Agency.
- C. Maintain premises and storage areas free of unnecessary accumulation of tools, equipment, surplus materials, and debris.
- D. Collect waste, cloths, and material which may constitute fire hazards and place in closed metal containers; remove from site daily along with empty containers.

3.07 PROTECTION

- A. Protect finished work in accordance with Division 1.
- B. Protect work of other trades against damage from coating activities. Correct damage by cleaning, repairing, replacing, and recoating as acceptable to Architect.
- C. Provide "Wet Paint" signs and other methods to protect newly coated surfaces. Remove when directed or when no longer needed.

END OF SECTION

SECTION 22 05 10 PLUMBING GENERAL PROVISIONS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. References.
- B. Description of Work.
- C. Drawings and Specifications.
- D. Industry Standards and Codes.
- E. Site Examination.
- F. Permits, Fees and Utility Connections.
- G. Coordination of Work.
- H. Progress of Work.
- I. Submittals
- J. Operation and Maintenance Manuals.
- K. Project Record Documents.
- L. Warranty.
- M. Quality and Care
- N. Access Doors.
- O. Starting Equipment and Systems.

1.02 RELATED SECTIONS

- A. The Contract Agreement, Bidding Documents and all Addenda issued prior to Contract Agreement execution form a part of these specifications and apply to all Contracts or Subcontracts relating to the mechanical systems.
- B. The requirements of this Section apply to all Work of Division 23.

1.03 REFERENCES

- A. ANSI - American National Standards Institute.
- B. ASTM - American Society for Testing Materials.
- C. CEC - California Electric Code.
- D. NEMA - National Electric Manufacturers' Association.
- E. NFPA - National Fire Protection Association.
- F. OSHA - Occupational Safety and Health Act.
- G. UL - Underwriters' Laboratories.
- H. See detailed References that are listed in individual sections.

1.04 DESCRIPTION OF WORK

- A. The work included in this division of the specifications consists of furnishing labor, tools, equipment, supplies and materials, unless otherwise specified, and in performing operations necessary for the installation of the complete Plumbing System as required by these specifications or shown on the Drawings, subject to the terms and conditions of the Contract Agreement.
- B. The work shall also include the completion of details of plumbing work not mentioned or shown which are necessary for the successful operation of mechanical systems described on the drawings or required by these specifications. Furnish and install any incidental work not shown or specified which is required to provide a complete and operational system.

1.05 DRAWINGS AND SPECIFICATIONS

- A. Drawings are schematic and diagrammatic. Drawings indicate the general arrangement of equipment, piping, and other plumbing work. Use judgement and care to install mechanical work to fit the job conditions within the building construction and finishes, and to function properly.
- B. The Contractor shall investigate the building conditions affecting the Work and shall arrange his work accordingly providing offsets, fittings, valves and accessories to fit the actual job conditions. The Contractor shall be responsible to field measure and confirm new and existing mechanical systems locations with respect to other architectural, structural, and electrical work, existing and new. Do not scale distances off of the mechanical drawings. Use actual building dimensions.
- C. The drawings and specifications are complimentary each to the other. What is required by one shall be as binding as if called for by both.
- D. Examine all drawings and specifications prior to bidding the Work. Report any discrepancies to the Engineer.

1.06 INDUSTRY STANDARDS AND CODES

- A. The Mechanical Contractor shall comply with the latest provisions of all codes, regulations, laws and ordinances applicable to the work involved. This does not relieve the Contractor from furnishing and installing work shown or specified which may exceed the requirements of such codes, regulations laws and ordinances.
- B. All materials, products, devices, fixtures forms or types of construction included in this project shall meet or exceed the published requirements of the publications listed below. These publications form a part of this specification.
 - 1. California Building Code, 2022.
 - 2. California Mechanical Code, 2022.
 - 3. California Plumbing Code, 2022.
 - 4. California Electrical Code, 2022.
 - 5. National Fire Protection Association.
 - 6. California Fire Code, 2022.
 - 7. California State Fire Marshal.
 - 8. Occupational Safety and Health Administration, including CAL-OSHA.

9. California Energy Code, 2022.
 10. California Green Building Standards Code, 2022.
 11. State of California Code of Regulations, Title 24.
 12. Other applicable state laws.
- C. Nothing in the Drawings or Specifications shall be construed to permit work that does not conform these codes. When Contract Documents differ from governing codes, furnish and install to the higher standard required at no extra charge. The Contract Documents are not intended to repeat the code requirements except where necessary for clarity.
- D. No material or product installed as a part of the Work shall contain asbestos in any form.
- E. Domestic water piping and components shall be provided and installed in accordance with California AB 1953 Legislation (effective January 1, 2010), which limits the allowable lead content in certain domestic water system components.

1.07 SITE EXAMINATION

- A. Contractor shall examine the site, verify dimensions and locations with Drawings, check utility connection locations, and familiarize himself with the existing conditions and limitations. No extras will be allowed because of the Contractor's misunderstanding of the amount of work involved or his lack of knowledge of any site condition which may affect his work. Any apparent variance of the drawings or specifications from the existing conditions at the site shall be called to the attention of the Engineer immediately.

1.08 PERMITS, FEES AND UTILITY SERVICES

- A. Contractor shall pay for and obtain all permits and service required in the installation of this work.
- B. Contractor shall arrange for all required inspections and will secure approvals from authorities having jurisdiction.

1.09 COORDINATION OF WORK

- A. It is recognized that the contract documents are diagrammatic in showing certain physical relationships which must be established within the mechanical work, and in its interface with other work and that such establishment is the exclusive responsibility of the contractor.
- B. The Contractor shall give careful consideration to the work of the General, Electrical and other contractors on the job and shall organize his work so that it will not interfere with the work of other trades. He shall consult the drawings and specifications for work of other trades for correcting information, and the pertinent drawings for details and dimensions.
- C. Arrange plumbing work in a neat, well-organized manner with the piping and similar services running parallel and/or perpendicular to primary lines of the building construction. Locate operating and control equipment properly to provide easy

access, and arrange entire mechanical work with adequate access for operation and maintenance.

- D. Verify the location of all equipment, plumbing devices, etc. and if interference develops, the Owner/Engineer's decision will be final and no additional compensation will be allowed for the moving of misplaced air devices or equipment.

1.10 PROGRESS OF WORK

- A. This Contractor shall organize his work so that the progress of the mechanical work will conform to the progress of the other trades, and shall complete the entire installation as soon as the conditions of the building will permit. Any cost resulting from defective or ill timed work performed under this section shall be borne by this Contractor.

1.11 STRUCTURAL DESIGN REQUIREMENTS AND SEISMIC RESTRAINTS

- A. Plumbing systems and equipment shall be anchored and seismically braced in accordance with all applicable codes and industry standards.
- B. Plumbing systems and equipment shall include, but are not limited to, all piping, water heaters, expansion tanks, air compressors, vacuum pumps, electrical and control panels, conduits and other components.
- C. For all non-standard installations not detailed in one of the approved systems, the Contractor shall provide details of supports, anchorages and restraints, including attachments to building structure, with supporting calculations all stamped and signed by a licensed professional structural engineer registered in the state in which the Work is performed.

1.12 SUBMITTALS

- A. See Section 013300 - Submittals, for additional submittal procedures.
- B. Product Data Submittals: Submit manufacturer's standard published data. Mark each copy to identify applicable products, models, options, and other data. Supplement manufacturers' standard data to provide information specific to this Project.
- C. Shop Drawing Submittals: Prepared specifically for this Project.
- D. Organize submittals in sequence according to Specification Section. Submit in bound document with tabs identifying each Specification Section. Provide a Table of Contents identifying the Specifications Sections being submitted and the contents within each tabbed section. Prepare Submittals in multiple volumes if required. Provide a complete Submittal package at one time. Do not submit individual Sections piecemeal.
- E. Indicate utility and electrical characteristics, utility connection requirements, and location of utility outlets for service for functional equipment and appliances.
- F. Furnish, upon request, installation instructions for all equipment and materials to Inspector of Record prior to installation.
- G. Maintain a copy of the fire penetration installation instructions on site for use by the Inspector of Record.

1.13 SUBSTITUTION PROCEDURES

- A. Instructions to Bidders specify time restrictions for submitting requests for substitutions during the bidding period. Comply with requirements specified in this section.
- B. LP Consulting Engineers, Inc. will consider requests for substitutions only within 7 days after date of Agreement.
- C. Substitutions may be considered when a product becomes unavailable through no fault of the .
- D. Failure by the Contractor to order materials or equipment in a timely manner will not constitute justification for a substitution.
- E. Document each request with complete data substantiating compliance of proposed substitution with Contract Documents.
- F. A request for substitution constitutes a representation that the submitter:
 - 1. Has investigated proposed product and determined that it meets or exceeds the quality level of the specified product.
 - 2. Will provide the same warranty for the substitution as for the specified product.
 - 3. Will coordinate installation and make changes to other Work which may be required for the Work to be complete with no additional cost to Owner.
 - 4. Waives claims for additional costs or time extension which may subsequently become apparent.
 - 5. Will reimburse Owner and LP Consulting Engineers, Inc. for review or redesign services associated with reapproval by authorities including obtaining reapproval by authorities.
- G. Substitutions will not be considered when they are indicated or implied on shop drawing or product data submittals, without separate written request, or when acceptance will require revision to the Contract Documents.
- H. If excessive review, as judged by the Engineer, is required caused by complicated, numerous or repetitive requests, Contractor shall reimburse Engineer and its Consultants for such review at their standard billing rates.
- I. Substitution Submittal Procedure:
 - 1. Submit three copies of request for substitution for consideration. Limit each request to one proposed substitution.
 - 2. Submit shop drawings, product data, and certified test results attesting to the proposed product equivalence. Burden of proof is on proposer.
 - 3. The LP Consulting Engineers, Inc. will notify in writing of decision to accept or reject request.
 - 4. Present each substitution individually. If a proposed substitute in not found to be acceptable, then the specified item shall be supplied.

1.14 OPERATION AND MAINTENANCE MANUALS

- A. See Section 01700 Closeout Submittals for Operation and Maintenance Manual requirements.

- B. Provide operating and maintenance instructions, diagrams and parts lists for all components of all mechanical systems and each piece of equipment furnished under these specifications.
- C. Operating and maintenance instructions shall be furnished for the following equipment and systems:
 - 1. Plumbing Systems.
 - 2. Medical Gas Equipment, Piping and Alarm Systems.
 - 3. Piping Systems.
 - 4. Temperature Controls Systems.
 - 5. Testing, Adjusting, and Balancing Reports.
- D. Provide manufacturer's model number, design data, capacities, etc. for each piece of plumbing equipment furnished as a part of the Work.
- E. The operating instructions shall include procedures for starting, stopping and emergency manual operation for all equipment and systems.
- F. Provide maintenance instructions of each item of individual equipment including applicable maintenance data as recommended by the manufacturer, including frequency of lubrication, lubricants, inspections required, adjustment procedures, belt and pulley sizes, etc.
- G. Provide manufacturer's parts bulletins with part numbers for each item of equipment included in the Work. Parts bulletins shall be specific to the equipment provided. Extraneous information that does not apply to the equipment provided shall be eliminated from the literature.
- H. Include copies of test reports (startup, check, etc.) and inspections performed for each piece of equipment provided in the Work.
- I. Warranty: Submit manufacturer warranty and ensure that forms have been completed in Owner's name and registered with manufacturer.
- J. Provide supplier and manufacturer contacts, telephone numbers and addresses in the front portion of the operation and maintenance manual.

1.15 PROJECT RECORD DOCUMENTS

- A. See Section 017700 - Closeout Procedures.
- B. Provide red-lined drawings accurately showing location of equipment and devices and size and routing of piping. Include notes explaining installed condition for complete understanding.

1.16 QUALITY ASSURANCE

- A. Monitor quality control over suppliers, manufacturers, products, services, site conditions, and workmanship, to produce Work of specified quality.
- B. Comply with manufacturers' instructions, including each step in sequence.
- C. Should manufacturers' instructions conflict with Contract Documents, request clarification from LP Consulting Engineers, Inc. before proceeding.

- D. Comply with specified standards as minimum quality for the Work except where more stringent tolerances, codes, or specified requirements indicate higher standards or more precise workmanship.
- E. Have Work performed by persons qualified to produce required and specified quality.
- F. Verify that field measurements are as indicated on shop drawings or as instructed by the manufacturer.
- G. Secure products in place with positive anchorage devices designed and sized to withstand stresses, vibration, physical distortion, and disfigurement.

1.17 PROJECT CONDITIONS

- A. Sequence installation to ensure utility connections are achieved in an orderly and expeditious manner.

1.18 WARRANTY

- A. See Section 01700 - Closeout Submittals, for additional warranty requirements.
- B. Correct defective Work within a one year period after Date of Substantial Completion.

PART 2 PRODUCTS

2.01 QUALITY AND CARE

- A. All materials shall be new and in perfect condition when installed unless specifically indicated otherwise. Materials shall be tested within the Continental United States by an independent, nationally recognized testing agency and shall be listed in accordance with testing agency requirements. When not otherwise specified, all material shall conform to applicable National Standards (ANSI).
- B. All capacities, sizes and efficiency ratings shown on the drawing are minimum. Gas meter and gas pressure reducing valve capacities are maximum allowable.
- C. Each category of material or equipment shall be of the same brand or manufacturer throughout the Work wherever possible.
- D. The quality of materials and equipment to be provided is defined by the brand names, manufacturers, model and catalog numbers listed on the Drawings and in the Specifications. Contractor shall provide each item listed, of the quality specified, or equal.
- E. Deliver, store, protect, and handle products in conformance with manufacturer's recommended practices as outlined in applicable Installation and Maintenance Manuals.
- F. Inspect and report concealed damage to carrier within their required time period.
- G. Store materials in a clean, dry space. Maintain factory protection and/or provide an additional heavy canvas or heavy plastic cover to protect from dirt, water, construction debris, and traffic.

- H. Equipment which has been damaged, exposed to weather or is, in the opinion of the Engineer or Owner, otherwise unsuitable because of improper fabrication, storage or installation shall be removed and replaced by this Contractor at his expense.

2.02 ACCESS DOORS

- A. Coordinate access door requirements with Section 08305. The more stringent requirements shall govern.
- B. Provide access doors where access through floors, walls or ceilings is required to access plumbing equipment and plumbing devices or other systems requiring access for maintenance, test or observation.
 - 1. Access doors requiring hand access or access for observation only shall be 14"x14" minimum usable opening.
 - 2. Access doors where entrance of a service person may be required shall be 24"x30" minimum usable opening.
- C. Established standard: Milcor of types listed below. Other acceptable manufacturers: Cesco, J.L. Industries, Karp, Larsen's, or equal. Comply with the following:
 - 1. Form doors and frames of welded, ground smooth steel construction, 14 gauge for doors, 16 gauge for frames. Provide prime coat finish except for stainless steel type.
 - 2. Concealed hinges to allow 175 degree opening.
 - 3. Locks: flush, screw driver operated cam lock(s).
 - 4. Provide anchoring devices suitable for the construction into which the doors are framed.
- D. Application (as applicable):
 - 1. In gypsum drywall walls and ceilings: Type DW.
 - 2. In ceramic tile walls: Type MS (stainless steel).
 - 3. In fire rated walls: Type Fire Rated (rating as required for wall or ceiling), self closing, 250 F in 30 min. temperature rating.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Access Doors
 - 1. Coordinate the exact location of access doors to provide proper access to the item concealed. Obtain written approval for access door locations from Architect.
 - 2. Coordinate installation of access doors with the trades performing the construction assemblies into which the access doors are placed.
 - 3. Install all access doors neatly and securely, to open and close completely, and to operate freely and without binding. Install rated doors in accordance with their listing requirements.
 - 4. Test operate all doors and make all adjustments required for satisfactory operation. Replace all damaged materials.
 - 5. Install in accordance with manufacturer's instructions.

3.02 FIELD QUALITY CONTROL

- A. Perform field inspection and testing in accordance with the requirements within this section.
- B. Test all piping with no leak or loss in pressure in accordance with the requirements within this section.

3.03 GENERAL TESTING REQUIREMENTS FOR MECHANICAL AND PLUMBING SYSTEMS

- A. Contractor shall assign a responsible person to be an independent representative to witness testing and to sign as witness of times, pressure and losses of testing media for all hydronic, duct and gas piping testing.
 - 1. Test all piping as noted below with no leak or loss of pressure. Repair or replace defective piping until tests are accomplished successfully.
 - 2. Submit to the Engineer for review a log of all tests made which shall include time, temperature, pressure, water makeup and other applicable readings, necessary to indicate the systems have been operated and tested in the manner outlined in the construction documents.
 - 3. After producing the specified test pressure, disconnect the pressurizing source; do not introduce further pressure for the duration of the test period, repair leaky piping and retest. Repeat the procedure until the entire system is proven tight.
- B. Test the following systems with the medium listed to the pressure indicated for the time period listed:
 - 1. Sanitary Sewer, Drain, Vent Piping: Pressure=10 Ft.Hd. / Medium= Water / Duration=4 Hours.
 - 2. Domestic Water Piping: Pressure=125 Psig / Medium= Water / Duration=4 Hours.
 - 3. Condensate drains: Pressure=10 Ft.Hd. / Medium=Water / Duration=4 Hours.
 - 4. Gas Piping: Pressure=60 Psig / Medium=Air and soap / Duration=8 Hours.

3.04 CUTTING AND PATCHING

- A. Submit written request in advance of cutting or alteration which affects:
 - 1. Structural integrity of any element of Project.
 - 2. Integrity of weather exposed or moisture resistant element.
 - 3. Efficiency, maintenance, or safety of any operational element.
 - 4. Visual qualities of sight exposed elements.
 - 5. Work of Owner or separate Contractor.
- B. Execute cutting and patching to complete the work, to uncover work to install improperly sequenced work, to remove and replace defective or non-conforming work, to remove samples of installed work for testing when requested, to provide openings in the work for penetration of mechanical and electrical work, to execute patching to complement adjacent work, and to fit Products together to integrate with other work.

- C. Execute work by methods to avoid damage to other work, and which will provide appropriate surfaces to receive patching and finishing. In existing work, minimize damage and restore to original condition.
- D. Cut rigid materials using masonry saw or core drill. Pneumatic tools not allowed without prior approval.
- E. Restore work with new Products in accordance with requirements of Contract Documents.
- F. Fit work air tight to pipes, sleeves, ducts, conduit, and other penetrations through surfaces.
- G. At penetrations of fire rated walls, partitions, ceiling, or floor construction, completely seal voids with fire rated material in accordance with Code requirements , to full thickness of the penetrated element.
- H. Refinish surfaces to match adjacent finish. For continuous surfaces, refinish to nearest intersection or natural break. For an assembly, refinish entire unit.

3.05 PRIMING AND PAINTING

- A. Apply primer to all exposed ferrous metals that are not factory primed, factory finished, galvanized, stainless steel or anodized. Exposed black steel piping shall be primed and finish painted, including gas piping outdoors.
 - 1. Primer shall be as recommended by the paint manufacturer for each specific application.
 - 2. Acceptable Products include: Fuller O'Brien Blox-Rust Metal All Purpose Primer, equivalent Rust-Oleum product, or equal. See Section 09900 for other acceptable products.
- B. Apply two coats of primer to metal surfaces of items to be insulated or jacketed, except piping, or factory primed or finished.
- C. Preparation:
 - 1. Do not start work until surfaces to be finished are in proper condition to produce finished surfaces of uniform, satisfactory appearance.
 - 2. Stains and Marks: Remove completely, if possible, using materials and methods recommended by coating manufacturer; seal stains and marks which cannot be completely removed using Devoe KILSTAIN primers, shellac, or other coating acceptable to paint manufacturer any marks or defects that might bleed through paint finishes.
 - 3. Remove mildew from impervious surfaces by scrubbing with solution of trisodium phosphate and bleach. Rinse with clean water and allow substrate to thoroughly dry.
 - 4. Galvanized Surfaces:
 - a. Remove surface contamination and oils by solvent cleaning in accordance with SSPC-SP 1 and allow to dry.
 - b. Apply Devoe MIRROLAC Galvanized Metal Primer in accordance with manufacturer instructions.
 - 5. Uncoated Steel And Iron Surfaces:

- a. Remove grease, rust, scale, and dust from steel and iron surfaces using solvent in accordance with SSPC-SP 1.
 - b. Where heavy coatings of scale or contaminants are evident, hand tool clean in accordance with SSPC-SP 2 or use other approved SSPC SP method as needed.
6. Shop Primed Steel Surfaces: Remove loose primer and dust. Sand and feather edges to smooth surface. Clean areas with solvent and spot prime bare metal surfaces with appropriate Devco MIRROLAC metal primer or primer recommended by manufacturer.
- D. Application:
1. Apply each coat to uniform coating thickness in accordance with manufacturer's instructions, not exceeding manufacturer's specified maximum spread rate for indicated surface; thins, brush marks, roller marks, orange-peel, or other application imperfections are not permitted.
 2. Allow manufacturer's specified drying time, and ensure correct coating adhesion, for each coat before applying next coat.
 3. Remove dust and other foreign materials from substrate immediately prior to applying each coat.
- E. Finish Painting: See Section 09900.

3.06 STARTING EQUIPMENT AND SYSTEMS/COMMISSIONING

- A. Start equipment and systems in accordance with manufacturer's written instructions..
- B. Adjust for proper operation within manufacturer's published tolerances.
- C. Demonstrate proper operation of equipment to Owner's designated representative.
- D. Description:
 1. Comply with all start up of mechanical and electrical equipment systems as required in the various sections and herein.
 2. Coordinate all testing and startup procedures with all other trades so that all non-plumbing and non-electrical work is completed and operational so that the specified testing can be performed.
- E. Preliminary Work:
 1. Prior to the startup, the Contractor shall ensure that the systems are ready to operate, and the following items have been completed and checked including but not limited to:
 - a. Proper motor and fan/pump rotation.
 - b. Flushing and cleaning of the system.
 - c. Wiring
 - d. Auxiliary connections
 - e. Lubrication.
 - f. Venting.
 - g. Controls.
 - h. Installation of filters and strainers.
 - i. Setting of relief and safety valves .

2. All electrical testing must be completed and test results submitted before equipment startup to avoid power interruptions during mechanical equipment startup and testing.
 3. The Contractor shall submit at least 30 days in advance a schedule listing the date of completion of his work as it will be ready for equipment startup of Electrical/Plumbing equipment. This schedule shall include work on a system by system, floor by floor basis.
 4. Two weeks prior to the startup of any major equipment, the Contractor shall certify in writing that the systems will be complete and ready for startup. Completeness shall not only include physical installation of individual pieces of equipment, but all related elements of other crafts to make all equipment operate as a system.
 - a. The startup checklist will cover all related crafts, e.g., controls, electrical, plumbing, and a clean environment for equipment startup.
 5. The Contractor shall schedule a tour with the Owner's representative and the Engineer to review startup conditions prior to equipment startup. This tour shall take place during the associated Engineer's regularly scheduled visit. This tour does not relieve the Contractor of any responsibilities to properly start equipment. The Engineer will issue a notice of deficiencies that will be required to be corrected prior to equipment startup. The Contractor will be required to reschedule a back check with the Engineer prior to attempting an equipment startup.
 6. Equipment of systems should not be started until systems and associated subsystems are completed. Verify that other continuing work could not possibly damage completed systems if they are in operation. Furnish signed off prestartup check sheet.
- F. Startup and Commissioning:
1. System Startup and Operation:
 - a. The Contractor shall provide all labor, materials and services necessary for the initial startup and operation of all systems and equipment furnished and installed under this section.
 - b. The Contractor and the factory representative shall check all equipment during initial startup to insure correct rotation, proper lubrication, adequate fluids or air flows, nonoverloading electrical characteristics, proper alignment and vibration isolation. Systems shall be checked for water flows throughout without blockages. Plumbing systems shall be checked for proper connections and positions, nonexcessive electrical characteristics and minimal vibration. Other miscellaneous equipment shall be started and operated as described above as applicable. Manufacturer's representative shall submit a preliminary written copy of equipment startup check sheet prior to leaving job site.

END OF SECTION

SECTION 22 05 16

EXPANSION FITTINGS AND LOOPS FOR PLUMBING PIPING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Flexible pipe connectors.
- B. Expansion/seismic loops and compensators.

1.02 RELATED REQUIREMENTS

- A. The Contract Agreement, Bidding Documents and all Addenda issued prior to Contract Agreement execution form a part of these specifications and apply to all Contracts or Subcontracts relating to the mechanical systems.
- B. The requirements of this Section apply to all Work of Division 22.
- C. Section 22 10 05 - Plumbing Piping.

1.03 REFERENCE STANDARDS

- A. EJMA (STDS) - EJMA Standards; Tenth Edition.

1.04 SUBMITTALS

- A. See Division 1 specifications for submittal procedures.
- B. Product Data:
 - 1. Flexible Pipe Connectors: Indicate maximum temperature and pressure rating, face-to-face length, live length, hose wall thickness, hose convolutions per foot and per assembly, fundamental frequency of assembly, braid structure, and total number of wires in braid.
 - 2. Expansion Loops/Joints: Indicate maximum temperature and pressure rating, and maximum expansion compensation.
- C. Maintenance Data: Include adjustment instructions.
- D. Project Record Documents: Record installed locations of flexible pipe connectors, expansion joints, anchors, and guides.

1.05 REGULATORY REQUIREMENTS

- A. Conform to UL and FM requirements.

PART 2 PRODUCTS

2.01 FLEXIBLE PIPE CONNECTORS - STEEL PIPING

- A. Manufacturers:
 - 1. Mercer Rubber Company: www.mercer-rubber.com/#sle.
 - 2. The Metraflex Company: www.metraflex.com/#sle.
- B. Inner Hose: Stainless steel.

- C. Exterior Sleeve: Single braided, stainless steel.
- D. Pressure Rating: 125 psi up to 12 inch.
- E. Maximum Service Temperature: 450 degrees F.
- F. Joint: Flanged or threaded with union.
- G. Size: Use pipe sized units.
- H. Maximum offset: 3/4 inch on each side of installed center line.

2.02 FLEXIBLE PIPE CONNECTORS - COPPER PIPING

- A. Manufacturers:
 - 1. Mercer Rubber Company: www.mercer-rubber.com/#sle.
 - 2. The Metraflex Company: www.metraflex.com/#sle.
- B. Inner Hose: Bronze.
- C. Exterior Sleeve: Braided bronze.
- D. Pressure Rating: 125 psi up to 2 inch.
- E. Maximum Service Temperature: 450 degrees F.
- F. Joint: Flanged or threaded with union.
- G. Size: Use pipe sized units.
- H. Maximum offset: 3/4 inch on each side of installed center line.
- I. Application: Copper piping.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Install in accordance with EJMA (Expansion Joint Manufacturers Association) Standards.
- C. Install flexible pipe connectors on pipes connected to vibration isolated equipment. Provide line size flexible connectors.
- D. Anchor pipe to building structure where indicated or required. Provide pipe guides so movement is directed along axis of pipe only. Erect piping such that strain and weight is not on cast connections or apparatus.
- E. Provide support and equipment required to control expansion and contraction of piping. Provide loops, pipe offsets, and swing joints, or expansion joints where required.
- F. Install seismic expansion loops at all points where piping crosses building expansion joints.

END OF SECTION

SECTION 22 05 23

GENERAL-DUTY VALVES FOR PLUMBING PIPING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Applications.
- B. Ball valves.
- C. Check valves.
- D. Gate valves.
- E. Lubricated plug valves.

1.02 RELATED REQUIREMENTS

- A. Section 22 05 53 - Identification for Plumbing Piping and Equipment.
- B. Section 22 07 19 - Plumbing Piping Insulation.
- C. Section 22 10 05 - Plumbing Piping.

1.03 ABBREVIATIONS AND ACRONYMS

- A. CWP: Cold working pressure.
- B. EPDM: Ethylene propylene copolymer rubber.
- C. NBR: Acrylonitrile-butadiene, Buna-N, or nitrile rubber.
- D. NRS: Non-rising stem.
- E. OS&Y: Outside screw and yoke.
- F. PTFE: Polytetrafluoroethylene.
- G. RS: Rising stem.
- H. SWP: Steam working pressure.
- I. TFE: Tetrafluoroethylene.
- J. WOG: Water, oil, and gas.

1.04 REFERENCE STANDARDS

- A. ASME B1.20.1 - Pipe Threads, General Purpose, Inch; 2013 (Reaffirmed 2018).
- B. ASME B16.1 - Gray Iron Pipe Flanges and Flanged Fittings: Classes 25, 125, and 250; 2020.
- C. ASME B16.5 - Pipe Flanges and Flanged Fittings: NPS 1/2 through NPS 24 Metric/Inch Standard; 2020.
- D. ASME B16.10 - Face-to-Face and End-to-End Dimensions of Valves; 2022.
- E. ASME B16.18 - Cast Copper Alloy Solder Joint Pressure Fittings; 2021.
- F. ASME B16.34 - Valves — Flanged, Threaded, and Welding End; 2020.

- G. ASME B31.9 - Building Services Piping; 2020.
- H. ASME BPVC-IX - Boiler and Pressure Vessel Code, Section IX - Qualification Standard for Welding, Brazing, and Fusing Procedures; Welders; Brazers; and Welding, Brazing, and Fusing Operators; 2023.
- I. ASTM A48/A48M - Standard Specification for Gray Iron Castings; 2022.
- J. ASTM A126 - Standard Specification for Gray Iron Castings for Valves, Flanges, and Pipe Fittings; 2004 (Reapproved 2019).
- K. ASTM B61 - Standard Specification for Steam or Valve Bronze Castings; 2015 (Reapproved 2021).
- L. ASTM B62 - Standard Specification for Composition Bronze or Ounce Metal Castings; 2017.
- M. AWWA C606 - Grooved and Shouldered Joints; 2022.
- N. MSS SP-45 - Drain and Bypass Connections; 2020.
- O. MSS SP-67 - Butterfly Valves; 2022.
- P. MSS SP-70 - Gray Iron Gate Valves, Flanged and Threaded Ends; 2011.
- Q. MSS SP-71 - Gray Iron Swing Check Valves, Flanged and Threaded Ends; 2018.
- R. MSS SP-72 - Ball Valves with Flanged or Butt-Welding Ends for General Service; 2010a.
- S. MSS SP-78 - Gray Iron Plug Valves, Flanged and Threaded Ends; 2011.
- T. MSS SP-80 - Bronze Gate, Globe, Angle, and Check Valves; 2019.
- U. MSS SP-85 - Gray Iron Globe and Angle Valves, Flanged and Threaded Ends; 2011.
- V. MSS SP-110 - Ball Valves Threaded, Socket-Welding, Solder Joint, Grooved and Flared Ends; 2010, with Errata .
- W. MSS SP-125 - Check Valves: Gray Iron and Ductile Iron, In-Line, Spring-Loaded, Center-Guided; 2018.
- X. NSF 61 - Drinking Water System Components - Health Effects; 2022, with Errata.
- Y. NSF 372 - Drinking Water System Components - Lead Content; 2022.

1.05 SUBMITTALS

- A. See Division 1 specifications for submittal procedures.
- B. Product Data: Provide data on valves including manufacturers catalog information. Submit performance ratings, rough-in details, weights, support requirements, and piping connections.
- C. Operation and Maintenance Data: Include manufacturer's descriptive literature, operating instructions, maintenance and repair data, and parts listings.
- D. Maintenance Materials: Furnish Owner with one wrench for every five plug valves, in each size of square plug valve head.

1.06 QUALITY ASSURANCE

- A. Manufacturer:

1. Company must specialize in manufacturing products specified in this section, with not less than three years of documented experience.
- B. Welding Materials and Procedures: Comply with ASME BPVC-IX.

PART 2 PRODUCTS

2.01 APPLICATIONS

- A. Provide the following valves for the applications if not indicated on drawings:
 1. Shutoff: Ball, butterfly, gate or plug.
 2. Throttling: Provide globe, angle, ball, or butterfly.
 3. Swing Check (Pump Outlet):
 - a. 2 inch and Smaller: Bronze swing check valves with bronze or nonmetallic disc.
 - b. 2-1/2 inch and Larger for Domestic Water: Iron swing check valves with closure control, metal or resilient seat check valves.
 - c. 2-1/2 inch and Larger for Sanitary Waste and Storm Drainage: Iron swing check valves with lever and weight or spring.
- B. Substitutions of valves with higher CWP classes or WSP ratings for same valve types are permitted when specified CWP ratings or WSP classes are not available.
- C. Required Valve End Connections for Non-Wafer Types:
 1. Steel Pipe:
 - a. 2 inch and Smaller: Threaded ends.
 - b. 2-1/2 inch to 4 inch: Grooved or flanged ends except where threaded valve-end option is indicated in valve schedules below.
 - c. Grooved-End Steel Piping: Grooved.
 2. Copper Tube:
 - a. 2 inch and Smaller: Threaded ends except where solder-joint valve-end option is indicated in valve schedules below.
 - b. 2-1/2 inch to 4 inch: Grooved or flanged ends except where threaded valve-end option is indicated in valve schedules below.
- D. Domestic, Hot and Cold Water Valves:
 1. All sizes:
 - a. Bronze and Brass: Provide with solder-joint or threaded ends.
 - b. Bronze Angle: Class 125, bronze disc.
 - c. Ball: Two piece, full port, brass with brass trim.
 - d. Bronze Swing Check: Class 125, bronze disc.
 - e. Bronze Gate: Class 125, NRS.
- E. Gas Valves:
 1. All sizes:
 - a. Bronze: Provide with threaded ends.
 - b. Ball: One piece, full port, bronze with bronze trim.
 - c. Lubricated Plug: Class 125, regular gland.

2.02 GENERAL REQUIREMENTS

- A. Valve Pressure and Temperature Ratings: No less than rating indicated; as required for system pressures and temperatures.
- B. Valve Sizes: Match upstream piping unless otherwise indicated.
- C. Valve Actuator Types:
 - 1. Gear Actuator: Quarter-turn valves 8 inch and larger.
 - 2. Handwheel: Valves other than quarter-turn types.
 - 3. Hand Lever: Quarter-turn valves 6 inch and smaller except plug valves.
 - 4. Wrench: Plug valves with square heads.
- D. Insulated Piping Valves: With 2 inch stem extensions and the following features:
 - 1. Gate Valves: Rising stem.
 - 2. Ball Valves: Extended operating handle of non-thermal-conductive material, and protective sleeve that allows operation of valve without breaking the vapor seal or disturbing insulation.
 - 3. Butterfly Valves: Extended neck.
 - 4. Memory Stops: Fully adjustable after insulation is installed.
- E. Valve-End Connections:
 - 1. Threaded End Valves: ASME B1.20.1.
 - 2. Flanges on Iron Valves: ASME B16.1 for flanges on iron valves.
 - 3. Pipe Flanges and Flanged Fittings 1/2 inch through 24 inch: ASME B16.5.
 - 4. Solder Joint Connections: ASME B16.18.
 - 5. Grooved End Connections: AWWA C606.
- F. General ASME Compliance:
 - 1. Ferrous Valve Dimensions and Design Criteria: ASME B16.10 and ASME B16.34.
 - 2. Solder-joint Connections: ASME B16.18.
 - 3. Building Services Piping Valves: ASME B31.9.
- G. Potable Water Use:
 - 1. Certified: Approved for use in compliance with NSF 61 and NSF 372.
 - 2. Lead-Free Certified: Wetted surface material includes less than 0.25 percent lead content.
- H. Valve Bypass and Drain Connections: MSS SP-45.

2.03 BRASS, BALL VALVES

- A. Two Piece, Full Port with Brass Trim and Threaded or Soldered Connections:
 - 1. Comply with MSS SP-110.
 - 2. Seats: PTFE.
 - 3. Ball: Chrome-plated brass.

2.04 BRONZE, BALL VALVES

- A. General:
 - 1. Fabricate from dezincification resistant material.
 - 2. Copper alloys containing more than 15 percent zinc are not permitted.

- B. Two Piece, Full Port with Bronze Trim:
 - 1. Comply with MSS SP-110.
 - 2. WSP Rating: 150 psi.
 - 3. WOG Rating: 600 psi.
 - 4. Body: Forged bronze or dezincified-brass alloy.
 - 5. Ends Connections: Pipe thread or solder.
 - 6. Seats: PTFE.
 - 7. Stem: Bronze, blowout proof.
 - 8. Ball: Chrome plated brass.

2.05 BRONZE, LIFT CHECK VALVES

- A. General:
 - 1. Fabricate from dezincification resistant material.
 - 2. Copper alloys containing more than 15 percent zinc are not permitted.
- B. Class 125:
 - 1. Comply with MSS SP-80, Type 1, Metal Disc to Metal Seat and Type 2, Nonmetallic Disc to Metal Seat.
 - 2. CWP Rating: 200 psi.
 - 3. Design: Vertical flow.
 - 4. Body: Comply with ASTM B61 or ASTM B62, bronze.
 - 5. End Connections: Threaded.

2.06 BRONZE, SWING CHECK VALVES

- A. General:
 - 1. Fabricate from dezincification resistant material.
 - 2. Copper alloys containing more than 15 percent zinc are not permitted.
- B. Class 125:
 - 1. Pressure and Temperature Rating: MSS SP-80, Type 3.
 - 2. Design: Y-pattern, horizontal or vertical flow.
 - 3. WOG Rating: 200 psi.
 - 4. Body: Bronze, ASTM B62.
 - 5. End Connections: Threaded.
 - 6. Disc: Bronze.

2.07 BRONZE, GATE VALVES

- A. General:
 - 1. Fabricate from dezincification resistant material.
 - 2. Copper alloys containing more than 15 percent zinc are not permitted.
- B. NRS (Non-rising Stem) or OS & Y (Rising Stem):
 - 1. Comply with MSS SP-80, Type I.
 - 2. Class 125: CWP Rating 200 psig.
 - 3. Body: ASTM B62, bronze with integral seat and screw-in bonnet.
 - 4. Ends: Threaded or solder joint joint.
 - 5. Stem: Bronze.

6. Disc: Solid wedge; bronze.
7. Packing: Asbestos free.
8. Handwheel: Malleable iron, bronze, or aluminum.

2.08 LUBRICATED PLUG VALVES

- A. Regular Gland with Flanged Ends:
 1. Comply with MSS SP-78, Type II.
 2. Class 125: CWP Rating: 200 psi.
 3. Body: ASTM A48/A48M or ASTM A126, cast iron with lubrication sealing system.
 4. Pattern: Regular or short.
 5. Plug: Cast iron or bronze with sealant groove.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Discard all packing materials and verify that valve interior, including threads and flanges are completely clean without signs of damage or degradation that could result in leakage.
- B. Verify valve parts to be fully operational in all positions from closed to fully open.
- C. Confirm gasket material to be suitable for the service, to be of correct size, and without defects that could compromise effectiveness.
- D. Should valve is determined to be defective, replace with new valve.

3.02 INSTALLATION

- A. Provide unions or flanges with valves to facilitate equipment removal and maintenance while maintaining system operation and full accessibility for servicing.
- B. Provide separate valve support as required and locate valve with stem at or above center of piping, maintaining unimpeded stem movement.
- C. Install check valves where necessary to maintain direction of flow as follows:
 1. Lift Check: Install with stem plumb and vertical.
 2. Swing Check: Install horizontal maintaining hinge pin level.

END OF SECTION

SECTION 22 05 29

HANGERS AND SUPPORTS FOR PLUMBING PIPING AND EQUIPMENT

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Strut systems for pipe or equipment support.
- B. Beam clamps.
- C. Pipe hangers.
- D. Pipe rollers and roller supports.
- E. Pipe supports, guides, shields, and saddles.
- F. Seismic bracing hardware.
- G. Nonpenetrating rooftop supports for low-slope roofs.
- H. Anchors and fasteners.

1.02 REFERENCE STANDARDS

- A. ASTM A123/A123M - Standard Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products; 2017.
- B. ASTM A153/A153M - Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware; 2023.
- C. ASTM A181/A181M - Standard Specification for Carbon Steel Forgings, for General-Purpose Piping; 2022.
- D. ASTM A36/A36M - Standard Specification for Carbon Structural Steel; 2019.
- E. ASTM A47/A47M - Standard Specification for Ferritic Malleable Iron Castings; 1999, with Editorial Revision (2022).
- F. ASTM A283/A283M - Standard Specification for Low and Intermediate Tensile Strength Carbon Steel Plates; 2018.
- G. ASTM A395/A395M - Standard Specification for Ferritic Ductile Iron Pressure-Retaining Castings for Use at Elevated Temperatures; 1999 (Reapproved 2022).
- H. ASTM A653/A653M - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process; 2022.
- I. ASTM A1011/A1011M - Standard Specification for Steel, Sheet and Strip, Hot-Rolled, Carbon, Structural, High-Strength Low-Alloy, High-Strength Low-Alloy with Improved Formability, and Ultra-High Strength; 2018a.
- J. ASTM B633 - Standard Specification for Electrodeposited Coatings of Zinc on Iron and Steel; 2023.
- K. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2023d.

- L. ASTM E96/E96M - Standard Test Methods for Gravimetric Determination of Water Vapor Transmission Rate of Materials; 2022a, with Editorial Revision (2023).
- M. MSS SP-58 - Pipe Hangers and Supports - Materials, Design, Manufacture, Selection, Application, and Installation; 2018, with Amendment (2019).
- N. NFPA 101 - Life Safety Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- O. UL 723 - Standard for Test for Surface Burning Characteristics of Building Materials; Current Edition, Including All Revisions.

1.03 SUBMITTALS

- A. See Division 1 specifications for submittal procedures.
- B. Product Data: Provide manufacturer's standard catalog pages and data sheets for metal channel (strut) framing systems, nonpenetrating rooftop supports, post-installed concrete and masonry anchors, and thermal insulated pipe supports.
- C. Evaluation Reports: For products specified as requiring evaluation and recognition by ICC Evaluation Service, LLC (ICC-ES), provide current ICC-ES evaluation reports upon request.

PART 2 PRODUCTS

2.01 GENERAL REQUIREMENTS

- A. Provide required hardware to hang or support piping, equipment, or fixtures with related accessories as necessary to complete installation of plumbing work.
- B. Provide hardware products listed, classified, and labeled as suitable for intended purpose.
- C. Where support and attachment component types and sizes are not indicated, select in accordance with manufacturer's application criteria as required for the load to be supported. Include consideration for vibration, equipment operation, and shock loads where applicable.
- D. Do not use wire, chain, perforated pipe strap, or wood for permanent supports unless specifically indicated or permitted.
- E. Fire Resistance: Provide hardware rated for 120 minutes resistance unless specifically indicated by the authority having jurisdiction.
- F. Materials for Metal Fabricated Supports: Comply with Section 05 50 00.
 - 1. Zinc-Plated Steel: Electroplated in accordance with ASTM B633 unless stated otherwise.
 - 2. Galvanized Steel: Hot-dip galvanized in accordance with ASTM A123/A123M or ASTM A153/A153M unless stated otherwise.
- G. Corrosion Resistance: Use corrosion-resistant metal-based materials fully compatible with exposed piping materials and suitable for the environment where installed.

2.02 STRUT SYSTEMS FOR PIPE OR EQUIPMENT SUPPORT

- A. Strut Channels:
 - 1. ASTM A653/A653M galvanized steel bracket with clamps for surface mounting of piping or plumbing equipment support.
 - 2. Channel or Bracket Kits: Include rods, brackets, end-fixed fittings, covers, clips, and other related hardware required to complete sectional trapeze section for piping or other support.
- B. Hanger Rods:
 - 1. Threaded zinc-plated steel unless otherwise indicated.
 - 2. Minimum Size, Unless Otherwise Indicated or Required:
 - a. Equipment Supports: 1/2 inch diameter.
 - b. Piping up to 4 inch: 3/8 inch diameter.
 - c. Piping larger than 4 inch: 1/2 inch diameter.
 - d. Trapeze Support for Multiple Pipes: 3/8 inch in length.
- C. Channel Nuts:
 - 1. Provide carbon steel channel nut with epoxy copper or zinc finish and long, regular, or short spring as indicated on drawings.

2.03 BEAM CLAMPS

- A. MSS SP-58 types 19 through 23, 25 or 27 through 30 based on required load.
- B. Provide clamps with hardened steel cup-point set screws and lock-nuts for anchoring in place.
- C. Material: ASTM A395/A395M ductile iron, ASTM A36/A36M carbon steel, ASTM A47/A47M malleable iron, ASTM A181/A181M forged steel, or ASTM A283/A283M steel.

2.04 PIPE HANGERS

- A. J-Hangers, Adjustable:
 - 1. MSS SP-58 type 5, zinc-plated ASTM A1011/A1011M steel or ASTM A653/A653M carbon steel.
 - 2. Felt-Lined: Provide for uninsulated pipe to reduce noise and prevent static issues.
- B. Swivel Ring Hangers, Adjustable:
 - 1. MSS SP-58 type 10, epoxy-painted, zinc-colored.
 - 2. Material: ASTM A395/A395M ductile iron, ASTM A36/A36M carbon steel, ASTM A47/A47M malleable iron, ASTM A181/A181M forged steel, or ASTM A283/A283M steel.
 - 3. Felt-Lined: Provide for uninsulated pipe to reduce noise and prevent static issues.
- C. Clevis Hangers, Adjustable:
 - 1. Copper Tube: MSS SP-58 type 1, epoxy-plated copper.
 - 2. Felt-Lined: MSS SP-58 type 1, zinc-plated, silicone-free carbon steel.

3. Light-Duty: MSS SP-58 type 1, zinc-colored, epoxy plated.
4. Standard-Duty: MSS SP-58 type 1, zinc-colored, epoxy plated.

2.05 PIPE CLAMPS

- A. Riser Clamps:
 1. For insulated pipe runs, provide two bolt-type clamps designed for installation under insulation.
 2. MSS SP-58 type 1 or 8, carbon steel or steel with epoxy plated, plain, stainless steel, or zinc plated finish.
 3. Medium Split Horizontal Pipe Clamp: MSS SP-58 type 4, carbon steel or stainless steel with epoxy plated, plain, stainless steel, or zinc plated finish.
 4. Copper Tube Pipe Clamp: MSS SP-58 type 8, epoxy plated copper.
- B. Extension Split Pipe Clamp:
 1. MSS SP-58 type 12, hinged split ring and yoke roller hanger with epoxy copper or plain finish.
 2. Material: ASTM A47/A47M malleable iron or ASTM A36/A36M carbon steel.
 3. Provide hanger rod and nuts of the same type and material for a given pipe run.
 4. Provide coated or plated hangers to isolate steel hangers from dissimilar metal tube or pipe.
- C. Offset Pipe Clamps: Double-leg design two-piece pipe clamp.
- D. Strut Clamps:
 1. Pipe Clamp: Two-piece rigid, universal, or outer diameter type, carbon steel with epoxy copper or zinc finish.
 2. Cushioned Pipe or Tubing Strut Clamp: Provide strut clamp with thermoplastic elastomer cushion having dielectric strength of 670 V/mil.
- E. Insulation Coupling:
 1. Two bolt-type clamps designed for installation under insulation.
 2. Material: Carbon steel with epoxy copper or zinc finish.

2.06 PIPE ROLLERS AND ROLLER SUPPORTS

- A. MSS SP-58 type 43 based on required load, nonconductive and corrosion resistant.
- B. Material: Zinc plated ASTM A36/A36M carbon steel or ASTM A47/A47M malleable iron.

2.07 PIPE SUPPORTS, GUIDES, SHIELDS, AND SADDLES

- A. Dielectric Barriers: Provide between metallic supports and metallic piping and associated items of dissimilar type; acceptable dielectric barriers include rubber or plastic sheets or coatings attached securely to pipe or item.
- B. Stanchions:
 1. Material: Malleable iron, ASTM A47/A47M; or carbon steel, ASTM A36/A36M.
 2. Provide coated or plated saddles to isolate steel hangers from dissimilar metal tube or pipe.

3. For pipe runs, use stanchions of same type and material where vertical adjustment is required for stationary pipe.
- C. U-Bolts:
1. MSS SP-58 type 24, carbon steel u-bolt for pipe support or anchoring.
- D. Pipe Alignment Guides, Galvanized steel:
1. Pipe Sizes 8 inch and Smaller: Spider or sleeve type.
 2. Pipe Sizes 10 inch and Larger: Roller type.
- E. Pipe Shields for Insulated Piping:
1. MSS SP-58 type 40, ASTM A1011/A1011M steel or ASTM A653/A653M carbon steel.
 2. General Construction and Requirements:
 - a. Surface Burning Characteristics: Comply with ASTM E84 or UL 723.
 - b. Shields Material: UV-resistant polypropylene with glass fill.
 - c. Maximum Insulated Pipe Outer Diameter: 12-5/8 inch.
 - d. Service Temperature: Minus 40 to 178 degrees F.
 - e. Pipe shields to be provided at hanger, support, and guide locations on pipe requiring insulation or additional support.
- F. Pipe Supports:
1. Material: ASTM A395/A395M ductile iron, ASTM A36/A36M carbon steel, ASTM A47/A47M malleable iron, ASTM A181/A181M forged steel, or ASTM A283/A283M steel.
 2. Liquid Temperatures Up to 122 degrees F:
 - a. Overhead Support: MSS SP-58 types 1, 3 through 12 clamps.
 - b. Support From Below: MSS SP-58 types 35 through 38.
 3. Operating Temperatures from 122 to 446 degrees F:
 - a. Overhead Support: MSS SP-58 type 1 or 3 through 12 clamps with appropriate saddle of MSS SP-58 type 40 for insulated pipe.
 - b. Roller Chair: MSS SP-58 types 41 or 43 through 46 roller chair support with appropriate saddle of MSS SP-58 type 39 for insulated pipe.
 - c. Sliding Support: MSS SP-58 types 35 through 38.
- G. Pipe Supports, Thermal Insulated:
1. General Requirements:
 - a. Insulated pipe supports to be provided at hanger, support, and guide locations on pipe requiring insulation or additional support.
 - b. Pipe insulation protection shields to be provided at the hanger points and guide locations on pipes requiring insulation as indicated on drawings.
 - c. Surface Burning Characteristics: Flame spread index/smoke developed index of 5/30, maximum, when tested in accordance with ASTM E84 or UL 723.
 - d. Provide pipe supports for 1/2 to 30 inch iron pipes.
 - e. Insulation inserts to consist of rigid phenolic foam insulation surrounded by 360 degree, PVC jacketing.

2. PVC Jacket:
 - a. Pipe insulation protection shields to be provided with ball bearing hinge and locking seam.
 - b. Minimum Service Temperature: Minus 40 degrees F.
 - c. Maximum Service Temperature: 180 degrees F.
 - d. Moisture Vapor Transmission: 0.0071 perm inch, when tested in accordance with ASTM E96/E96M.
 - e. Minimum Thickness: 60 mil, 0.06 inch.

2.08 SEISMIC BRACING HARDWARE

- A. Cable Sway Bracing Systems:
 1. Cable wire hanger with fix and release spring mechanism enclosed using zinc housing with 302 stainless steel components for pipe or equipment suspension to surface-mounted end-fixing fittings.
 2. Provide cable wire and end-fixing as required to hold minimum weight of 100 lb.

2.09 NONPENETRATING ROOFTOP SUPPORTS FOR LOW-SLOPE ROOFS

- A. Provide steel pedestals with thermoplastic or rubber base that rest on top of roofing membrane, not requiring any attachment to the roof structure and not penetrating the roofing assembly, with support fixtures as specified.
- B. Base Sizes: As required to distribute load sufficiently to prevent indentation of roofing assembly.
- C. Attachment/Support Fixtures: As recommended by manufacturer, same type as indicated for equivalent indoor hangers and supports.
- D. Mounting Height: Provide minimum clearance of 6 inches under supported component to top of roofing.

2.10 ANCHORS AND FASTENERS

- A. Unless otherwise indicated and where not otherwise restricted, use the anchor and fastener types indicated for the specified applications.
- B. Concrete: Use preset concrete inserts or expansion anchors.
- C. Solid or Grout-Filled Masonry: Use expansion anchors.
- D. Hollow Masonry: Use toggle bolts.
- E. Hollow Stud Walls: Use toggle bolts.
- F. Steel: Use beam clamps, machine bolts, or welded threaded studs.
- G. Sheet Metal: Use sheet metal screws.
- H. Wood: Use wood screws.
- I. Plastic and lead anchors are not permitted.
- J. Powder-actuated fasteners are not permitted.
- K. Hammer-driven anchors and fasteners are not permitted.

- L. Post-Installed Concrete and Masonry Anchors: Evaluated and recognized by ICC Evaluation Service, LLC (ICC-ES) for compliance with applicable building code.
- M. Preset Concrete Inserts: Continuous metal strut channel and spot inserts specifically designed to be cast in concrete ceilings, walls, and floors.
 - 1. Channel Material: Use galvanized steel.
 - 2. Manufacturer: Same as manufacturer of metal strut channel framing system.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that field measurements are as indicated.
- B. Verify that mounting surfaces are ready to receive support and attachment components.
- C. Verify that conditions are satisfactory for installation prior to starting work.

3.02 INSTALLATION

- A. Install products in accordance with manufacturer's instructions.
- B. Install anchors and fasteners in accordance with ICC Evaluation Services, LLC (ICC-ES) evaluation report conditions of use where applicable.
- C. Provide independent support from building structure. Do not provide support from piping, ductwork, conduit, or other systems.
- D. Unless specifically indicated or approved by LP Consulting Engineers, Inc., do not provide support from suspended ceiling support system or ceiling grid.
- E. Unless specifically indicated or approved by LP Consulting Engineers, Inc., do not provide support from roof deck.
- F. Do not penetrate or otherwise notch or cut structural members without approval of Structural Engineer.
- G. Provide thermal insulated pipe supports complete with hangers and accessories. Install thermal insulated pipe supports during the installation of the piping system.
- H. Equipment Support and Attachment:
 - 1. Use metal fabricated supports or supports assembled from metal channel (strut) to support equipment as required.
 - 2. Use metal channel (strut) secured to studs to support equipment surface-mounted on hollow stud walls when wall strength is not sufficient to resist pull-out.
 - 3. Use metal channel (strut) to support surface-mounted equipment in wet or damp locations to provide space between equipment and mounting surface.
 - 4. Securely fasten floor-mounted equipment. Do not install equipment such that it relies on its own weight for support.

- I. Preset Concrete Inserts: Use manufacturer-provided closure strips to inhibit concrete seepage during concrete pour.
- J. Secure fasteners according to manufacturer's recommended torque settings.
- K. Remove temporary supports.

3.03 FIELD QUALITY CONTROL

- A. Inspect support and attachment components for damage and defects.
- B. Repair cuts and abrasions in galvanized finishes using zinc-rich paint recommended by manufacturer. Replace components that exhibit signs of corrosion.
- C. Correct deficiencies and replace damaged or defective support and attachment components.

END OF SECTION

SECTION 22 05 53

IDENTIFICATION FOR PLUMBING PIPING AND EQUIPMENT

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Nameplates.
- B. Tags.
- C. Pipe markers.
- D. Underground warning tape.

1.02 RELATED REQUIREMENTS

- A. Refer to the General Conditions, Special Conditions and Division 1 General Requirements. The requirements of these sections apply to this section.

1.03 REFERENCE STANDARDS

- A. ASME A13.1 - Scheme for the Identification of Piping Systems; 2023.
- B. ASTM D709 - Standard Specification for Laminated Thermosetting Materials; 2017.

1.04 SUBMITTALS

- A. See Division 1 specifications for submittal procedures.
- B. List: Submit list of wording, symbols, letter size, and color coding for mechanical identification.
- C. Product Data: Provide manufacturers catalog literature for each product required.
- D. Manufacturer's Installation Instructions: Indicate special procedures, and installation.

PART 2 PRODUCTS

2.01 IDENTIFICATION APPLICATIONS

- A. Heat Transfer Equipment: Nameplates.
- B. Major Control Components: Nameplates.
- C. Piping: Pipe markers.
- D. Pumps: Nameplates.
- E. Small-sized Equipment: Tags.
- F. Tanks: Nameplates.
- G. Valves: Tags and ceiling tacks where located above lay-in ceiling.
- H. Water Treatment Devices: Nameplates.

2.02 MANUFACTURERS

- A. Brady Corp.

B. Seton Identification Products.

2.03 NAMEPLATES

- A. Description: Laminated piece with up to three lines of text.
 - 1. Letter Color: White.
 - 2. Letter Height: 1/4 inch.
 - 3. Background Color: Black.
 - 4. Plastic: Comply with ASTM D709.

2.04 TAGS

- A. Flexible: Vinyl with engraved black letters on light contrasting background color with up to three lines of text. Minimum tag size 1-1/2 inch in diameter.
- B. Metal: Brass, 19 gauge 1-1/2 inch in diameter with smooth edges, blank, smooth edges, and corrosion-resistant ball chain. Up to three lines of text.

2.05 PIPE MARKERS

- A. Comply with ASME A13.1.
- B. Plastic Tape Pipe Markers: Flexible, vinyl film tape with pressure sensitive adhesive backing and printed markings. Secure to pipe using two (2) bands of adhesive tape with flow arrows supplied by the manufacturer. Install securing bands completely around pipe and overlapped.
- C. Underground Flexible Marker: Bright-colored continuously printed ribbon tape, minimum 6 inches wide by 4 mil, 0.004 inch thick, manufactured for direct burial service.

2.06 UNDERGROUND WARNING TAPE

- A. Materials: Use non-detectable type polyethylene tape suitable for direct burial, unless otherwise indicated.
- B. Non-detectable Type Tape: 6 inches wide, with minimum thickness of 4 mil, 0.004 inch.
- C. Legend: Type of service, continuously repeated over full length of tape.

PART 3 EXECUTION

3.01 PREPARATION

- A. Degrease and clean surfaces to receive identification products.

3.02 INSTALLATION

- A. Install flexible nameplates with corrosive-resistant mechanical fasteners, or adhesive. Apply with sufficient adhesive to ensure permanent adhesion and seal with clear lacquer.
- B. Install tags in clear view and align with axis of piping

- C. Install plastic tape pipe marker around pipe in accordance with manufacturer's instructions.
- D. Identify domestic hot water heating equipment, including pumps, etc. with plastic nameplates.
- E. Identify valves in main and branch piping with tags.
- F. Identify piping, concealed or exposed, with plastic pipe markers. Identify service, flow direction, and pressure. Install in clear view and align with axis of piping. Locate identification not to exceed 20 feet (6 m) on straight runs including risers and drops, adjacent to each valve and Tee, at each side of penetration of structure or enclosure, and at each obstruction.
- G. Identify all medium pressure gas piping (over 11" W.C. to 5 PSI pressure) with pressure contained within piping system (for example: "MPG 5 PSI")

END OF SECTION

SECTION 22 07 19 PLUMBING PIPING INSULATION

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Flexible elastomeric cellular insulation.
- B. Piping insulation.
- C. Glass fiber insulation.
- D. Jacketing and accessories.

1.02 RELATED REQUIREMENTS

- A. Section 22 10 05 - Plumbing Piping: Placement of hangers and hanger inserts.

1.03 REFERENCE STANDARDS

- A. ASTM B209/B209M - Standard Specification for Aluminum and Aluminum-Alloy Sheet and Plate; 2021a.
- B. ASTM B209 - Standard Specification for Aluminum and Aluminum-Alloy Sheet and Plate; 2014.
- C. ASTM C177 - Standard Test Method for Steady-State Heat Flux Measurements and Thermal Transmission Properties by Means of the Guarded-Hot-Plate Apparatus; 2019, with Editorial Revision (2023).
- D. ASTM C518 - Standard Test Method for Steady-State Thermal Transmission Properties by Means of the Heat Flow Meter Apparatus; 2021.
- E. ASTM C533 - Standard Specification for Calcium Silicate Block and Pipe Thermal Insulation; 2017 (Reapproved 2023).
- F. ASTM C534/C534M - Standard Specification for Preformed Flexible Elastomeric Cellular Thermal Insulation in Sheet and Tubular Form; 2023.
- G. ASTM C547 - Standard Specification for Mineral Fiber Pipe Insulation; 2022a.
- H. ASTM C585 - Standard Practice for Inner and Outer Diameters of Thermal Insulation for Nominal Sizes of Pipe and Tubing; 2022.
- I. ASTM C795 - Standard Specification for Thermal Insulation for Use in Contact with Austenitic Stainless Steel; 2008 (Reapproved 2018).
- J. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2023d.
- K. ASTM E96/E96M - Standard Test Methods for Gravimetric Determination of Water Vapor Transmission Rate of Materials; 2022a, with Editorial Revision (2023).
- L. UL 723 - Standard for Test for Surface Burning Characteristics of Building Materials; Current Edition, Including All Revisions.

1.04 SUBMITTALS

- A. See Division 1 specifications for submittal procedures.
- B. Product Data: Provide product description, thermal characteristics, list of materials and thickness for each service, and locations.
- C. Manufacturer's Instructions: Indicate installation procedures that ensure acceptable workmanship and installation standards will be achieved.

1.05 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing the Products specified in this section with not less than three years of documented experience.
- B. Applicator Qualifications: Company specializing in performing the type of work specified in this section with minimum three years of experience.

1.06 DELIVERY, STORAGE, AND HANDLING

- A. Accept materials on site, labeled with manufacturer's identification, product density, and thickness.

1.07 FIELD CONDITIONS

- A. Maintain ambient conditions required by manufacturers of each product.
- B. Maintain temperature before, during, and after installation for minimum of 24 hours.

PART 2 PRODUCTS

2.01 REGULATORY REQUIREMENTS

- A. Surface Burning Characteristics: Flame spread index/Smoke developed index of 25/50, maximum, when tested in accordance with ASTM E84, UL 723, ASTM E84, or UL 723.

2.02 GLASS FIBER INSULATION

- A. Manufacturers:
 - 1. CertainTeed Corporation: www.certainteed.com.
 - 2. Johns Manville Corporation: www.jm.com/#sle.
 - 3. Knauf Insulation: www.knaufusa.com.
 - 4. Owens Corning Corporation; Fiberglas Pipe Insulation ASJ: www.ocbuildingspec.com/#sle.
- B. Insulation: ASTM C547 and ASTM C795; rigid molded, noncombustible.
 - 1. 'K' value: ASTM C 177, 0.22 to 0.28 at 100 degrees F.
 - 2. Maximum Service Temperature: 850 degrees F.
 - 3. Maximum Moisture Absorption: 0.2 percent by volume.
- C. Vapor Barrier Jacket: White Kraft paper with glass fiber yarn, bonded to aluminized film; moisture vapor transmission when tested in accordance with ASTM E96/E96M of 0.02 perm.

- D. Vapor Barrier Lap Adhesive: ~~Compatible with insulation.~~

2.03 FLEXIBLE ELASTOMERIC CELLULAR INSULATION

- A. Manufacturers:
1. Armacell LLC; AP Armaflex: www.armacell.us/#sle.
 2. K-Flex USA LLC; Insul-Tube: www.kflexusa.com/#sle.
 3. Owens Corning Flex Tubing
- B. Insulation: Preformed flexible elastomeric cellular rubber insulation complying with ASTM C 534 Grade 3; use molded tubular material wherever possible and sheet for equipment and other surfaces.
1. 'K' value: ASTM C 177; 0.27 at 75 degrees F.
 2. Minimum Service Temperature: Minus 40 degrees F.
 3. Maximum Service Temperature: 220 degrees F.
 4. Maximum Moisture Absorption - Pipe Insulation: 3.5 percent, by weight, when tested in accordance with ASTM D 1056.
 5. Water Vapor Permeability: 0.20 perm-inches, when tested in accordance with ASTM E 96.
 6. Connection: Waterproof vapor barrier adhesive.
- C. Elastomeric Foam Adhesive:
- D. Insulation Exposed to the Weather: Finish with two coats Armstrong white Armaflex finish. Provide aluminum jacketing.

2.04 JACKETING AND ACCESSORIES

- A. PVC Plastic Jacket:
1. Manufacturers:
 - a. Proto Corporation, Proto-Wrap 30 LoSmoke.
 - b. Johns Manville Corporation: www.jm.com.
 2. Jacket: One piece molded type fitting covers and sheet material, off-white color.
 - a. Minimum Service Temperature: 0 degrees F.
 - b. Maximum Service Temperature: 150 degrees F.
 - c. Moisture Vapor Permeability: 0.002 perm inch, maximum, when tested in accordance with ASTM E96/E96M.
 - d. Thickness: 10 mil, 0.010 inch.
 - e. Connections: Brush on welding adhesive.
 3. Covering Adhesive Mastic: Compatible with insulation.
- B. Aluminum Jacket:
1. Comply with ASTM B209/B209M, Temper H14, minimum thickness of 0.016 inch with factory-applied polyethylene and kraft paper moisture barrier on the inside surface.
 2. Thickness: 0.016 inch sheet.
 3. Finish: Embossed.
 4. Joining: Longitudinal slip joints and 2 inch laps.
 5. Fittings: 0.016 inch thick die-shaped fitting covers with factory-attached protective liner.

6. Metal Jacket Bands: 3/8 inch wide; 0.015 inch thick aluminum.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that piping has been tested before applying insulation materials.
- B. Verify that surfaces are clean and dry, with foreign material removed.

3.02 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Exposed Piping: Locate insulation and cover seams in least visible locations.
- C. Glass fiber insulated pipes conveying fluids below ambient temperature:
 1. Insulate fittings, joints, and valves with molded insulation of like material and thickness as adjacent pipe. Finish with molded PVC fitting covers.
- D. Glass fiber insulated pipes conveying fluids above ambient temperature:
 1. Insulate fittings, joints, and valves with insulation of like material and thickness as adjoining pipe. Finish with molded PVC fitting covers.
- E. Inserts and Shields:
 1. Application: Piping 1-1/2 inches diameter or larger.
 2. Shields: Galvanized steel between pipe hangers or pipe hanger rolls and inserts.
 3. Insert Location: Between support shield and piping and under the finish jacket.
 4. Insert Configuration: Minimum 6 inches long, of same thickness and contour as adjoining insulation; may be factory fabricated.
 5. Insert Material: Hydrous calcium silicate insulation or other heavy density insulating material suitable for the planned temperature range.
- F. Continue insulation through walls, sleeves, pipe hangers, and other pipe penetrations. Finish at supports, protrusions, and interruptions. At fire separations, use a UL rated fire penetration assembly, 3M or equal.
- G. Pipe in Supply Air Plenum or Finished Spaces: Finish with PVC jacket and fitting covers.
- H. Pipe Exposed in Mechanical Equipment Rooms or Finished Spaces: Finish with PVC jacket and fitting covers.
- I. Exterior Applications (exposed to the weather): Provide vapor barrier jacket. Insulate fittings, joints, and valves with insulation of like material and thickness as adjoining pipe, and finish with glass mesh reinforced vapor barrier cement. Cover with aluminum jacket with seams located on bottom side of horizontal piping.

3.03 SCHEDULES

- A. Plumbing Systems:
 1. Domestic Hot and Tempered Water Supply:
 - a. Glass Fiber Insulation:
 - 1) Pipe Size Range: 1-1/2 inch and larger.

- (a) Thickness: 2 inch.
- 2) Pipe Size Range: 1 inch and smaller.
 - (a) Thickness: 1-1/2 inch.
- 2. Domestic Cold Water Located in Unheated Areas:
 - a. Glass Fiber Insulation:
 - 1) Pipe Size Range: 1-1/2 inch and larger.
 - (a) Thickness: 1 inch.
 - 2) Pipe Size Range: 1 inch and smaller.
 - (a) Thickness: 3/4 inch.

END OF SECTION

SECTION 22 10 05 PLUMBING PIPING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Sanitary waste piping, buried within 5 feet of building.
- B. Sanitary waste piping, above grade.
- C. Drains.
- D. Domestic water piping, buried within 5 feet of building.
- E. Domestic water piping, above grade.
- F. Natural gas piping, above grade.
- G. Pipe flanges, unions, and couplings.
- H. Pipe hangers and supports.

1.02 RELATED REQUIREMENTS

- A. Section 22 05 29 - Hangers and Supports for Plumbing Piping and Equipment.
- B. Section 22 05 53 - Identification for Plumbing Piping and Equipment.
- C. Section 22 07 19 - Plumbing Piping Insulation.

1.03 REFERENCE STANDARDS

- A. ANSI LC 1/CSA 6.26 - Fuel Gas Piping Systems Using Corrugated Stainless Steel Tubing; 2019.
- B. ANSI Z21.22 - American National Standard for Relief Valves for Hot Water Supply Systems; 2015 (Reaffirmed 2020).
- C. ASME B16.3 - Malleable Iron Threaded Fittings: Classes 150 and 300; 2021.
- D. ASME B16.18 - Cast Copper Alloy Solder Joint Pressure Fittings; 2021.
- E. ASME B16.22 - Wrought Copper and Copper Alloy Solder-Joint Pressure Fittings; 2021.
- F. ASME B16.23 - Cast Copper Alloy Solder Joint Drainage Fittings: DWV; 2021.
- G. ASME B16.29 - Wrought Copper and Wrought Copper Alloy Solder-Joint Drainage Fittings—DWV; 2017.
- H. ASME B31.1 - Power Piping; 2022.
- I. ASME B31.9 - Building Services Piping; 2020.
- J. ASME BPVC-IV - Boiler and Pressure Vessel Code, Section IV - Rules for Construction of Heating Boilers; 2023.
- K. ASTM A53/A53M - Standard Specification for Pipe, Steel, Black and Hot-Dipped, Zinc-Coated, Welded and Seamless; 2022.
- L. ASTM A74 - Standard Specification for Cast Iron Soil Pipe and Fittings; 2021.

- M. ASTM A234/A234M - Standard Specification for Piping Fittings of Wrought Carbon Steel and Alloy Steel for Moderate and High Temperature Service; 2023a.
- N. ASTM B32 - Standard Specification for Solder Metal; 2020.
- O. ASTM B42 - Standard Specification for Seamless Copper Pipe, Standard Sizes; 2020.
- P. ASTM B88 - Standard Specification for Seamless Copper Water Tube; 2022.
- Q. ASTM B306 - Standard Specification for Copper Drainage Tube (DWV); 2020.
- R. ASTM B813 - Standard Specification for Liquid and Paste Fluxes for Soldering of Copper and Copper Alloy Tube; 2016.
- S. ASTM B828 - Standard Practice for Making Capillary Joints by Soldering of Copper and Copper Alloy Tube and Fittings; 2016.
- T. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2023d.
- U. AWS A5.8M/A5.8 - Specification for Filler Metals for Brazing and Braze Welding; 2019.
- V. AWWA C651 - Disinfecting Water Mains; 2014, with Addendum (2020).
- W. CISPI 301 - Standard Specification for Hubless Cast Iron Soil Pipe and Fittings for Sanitary and Storm Drain, Waste, and Vent Piping Applications; 2021.
- X. CISPI 310 - Specification for Coupling for Use in Connection with Hubless Cast Iron Soil Pipe and Fittings for Sanitary and Storm Drain, Waste, and Vent Piping Applications; 2020.
- Y. MSS SP-58 - Pipe Hangers and Supports - Materials, Design, Manufacture, Selection, Application, and Installation; 2018, with Amendment (2019).
- Z. MSS SP-67 - Butterfly Valves; 2022.
- AA. MSS SP-69 - Pipe Hangers and Supports - Selection and Application; Manufacturers Standardization Society of the Valve and Fittings Industry, Inc.; 2003.
- BB. MSS SP-89 - Pipe Hangers and Supports - Fabrication and Installation Practices; Manufacturers Standardization Society of the Valve and Fittings Industry, Inc.; 2003.
- CC. NSF 61 - Drinking Water System Components - Health Effects; 2022, with Errata.
- DD. NSF 372 - Drinking Water System Components - Lead Content; 2022.

1.04 SUBMITTALS

- A. See Division 1 specifications for submittal procedures.
- B. Product Data: Provide data on pipe materials, pipe fittings, valves, and accessories. Provide manufacturers catalog information. Indicate valve data and ratings.
- C. Project Record Documents: Record actual locations of valves.

1.05 QUALITY ASSURANCE

- A. Perform Work in accordance with State of California, standards.
- B. Valves: Manufacturer's name and pressure rating marked on valve body.

- C. Welding Materials and Procedures: Comply with ASME BPVC-IX and applicable state labor regulations.

1.06 REGULATORY REQUIREMENTS

- A. Perform Work in accordance with State of California plumbing code.
- B. Domestic water piping and components shall be provided and installed in accordance with California AB 1953 Legislation (effective January 1, 2010), which limits the allowable lead content in certain domestic water system components.
- C. Conform to applicable code for installation of backflow prevention devices.
- D. Provide certificate of compliance from authority having jurisdiction indicating approval of installation of backflow prevention devices.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Accept valves on site in shipping containers with labeling in place. Inspect for damage.
- B. Provide temporary protective coating on cast iron and steel valves.
- C. Provide temporary end caps and closures on piping and fittings. Maintain in place until installation.
- D. Protect piping systems from entry of foreign materials by temporary covers, completing sections of the work, and isolating parts of completed system.

PART 2 PRODUCTS

2.01 GENERAL REQUIREMENTS

- A. Potable Water Supply Systems: Provide piping, pipe fittings, and solder and flux (if used), that comply with NSF 61 and NSF 372 for maximum lead content; label pipe and fittings.

2.02 SANITARY SEWER PIPING, BURIED

- A. Cast Iron Pipe: CISPI 301, hubless.
 - 1. Fittings: Cast iron.
 - 2. Joints: CISPI 310, neoprene gasket and stainless steel clamp and shield assemblies. Heavy duty, Husky SD4000, .015 inch thick 304 stainless steel shield, 4-band coupling.
- B. PVC Pipe: Schedule 40 Solid Core. ASTM D1785, ASTM D2665.
 - 1. Fittings: PVC.
 - 2. Joints: Solvent welded, with ASTM D2564 solvent cement and ASTM F656 primer.

2.03 DRAIN PIPING, ABOVE GRADE

- A. Cast Iron Pipe: CISPI 301, hubless, service weight.
 - 1. Fittings: Cast iron.
 - 2. Joints: CISPI 310, neoprene gaskets and stainless steel clamp-and-shield assemblies.

- B. PVC Pipe: Schedule 40 Solid Core. ASTM D1785, ASTM D2665.
 - 1. Fittings: PVC.
 - 2. Joints: Solvent welded, with ASTM D2564 solvent cement and ASTM F656 primer.
- C. Copper Tube: ASTM B 306, DWV or ASTM B 88 (ASTM B 88M), Type M (C), Drawn (H).
 - 1. Application: Condensate drains inside building (non-acidic).
 - 2. Fittings: ASME B16.29, wrought copper, or ASME B16.23, solvent.
 - 3. Joints: ASTM B32, alloy Sn50 solder.
- D. Steel Pipe: ASTM A53/A53M Schedule 40, galvanized.
 - 1. Application: Condensate drains outside building (non-acidic).
 - 2. Threaded Joints: ASME B16.3 malleable iron fittings.
- E. PVC Pipe: ASTM D2665.
 - 1. Application: Condensate drains (acidic).
 - 2. Fittings: PVC.
 - 3. Joints: Solvent welded, with ASTM D2564 solvent cement.

2.04 WATER PIPING, BURIED

- A. Copper Pipe: ASTM B 42, hard drawn, Type K.
 - 1. Fittings: ASME B16.18, cast copper alloy or ASME B16.22 wrought copper and bronze.
 - 2. Joints: ASTM B32, alloy Sn95 solder.
 - 3. Joints: For sizes 2" and larger, AWS A5.8M/A5.8, BCuP copper and silver braze.

2.05 DOMESTIC WATER PIPING, ABOVE GRADE

- A. Copper Tube: ASTM B88 (ASTM B88M), Type L (B), Drawn (H).
 - 1. Fittings: ASME B16.18, cast copper alloy.
 - 2. Joints: For sizes 1-1/2" and smaller, ASTM B 32, alloy Sn95 solder.
 - 3. Joints: For sizes 2" and larger, AWS A5.8, BCuP5 silver braze.
- B. Provide full solder cup for all fittings.
- C. Schedule 40 Screwed Brass: Capped or plugged outlets.

2.06 NATURAL GAS PIPING, ABOVE GRADE

- A. Steel Pipe: ASTM A53/A53M Schedule 40 black.
 - 1. Pipe size 2" and smaller: Malleable iron threaded fittings.
 - 2. Pipe size 2-1/2" and larger: Steel butt welded fittings.
 - 3. Fittings: ASME B16.3, malleable iron, or ASTM A234/A234M, wrought steel welding type.
 - 4. Joints: Threaded or welded to ASME B31.1.
- B. Flexible Gas Piping:
 - 1. Corrugated Stainless Steel Tubing: Comply with ANSI LC 1/CSA 6.26.
 - 2. Comply with ASTM E84.
 - 3. Fittings: Provided by piping system manufacturer.

2.07 PIPE FLANGES, UNIONS, AND COUPLINGS

- A. Unions for Pipe Sizes 2 Inches and Under:
 - 1. Copper Tube and Pipe: Class 150 bronze unions with soldered joints.
- B. Flanges for Pipe Sizes Over 2 inch:
 - 1. Ferrous Pipe: Class 150 malleable iron threaded or forged steel slip-on flanges; preformed neoprene gaskets.
 - 2. Copper Tube and Pipe: Class 150 slip-on bronze flanges; preformed neoprene gaskets.
- C. Dielectric Connections: Union with galvanized or plated steel threaded end, copper solder end, water impervious isolation barrier.

2.08 PIPE HANGERS AND SUPPORTS

- A. See Section 22 05 29 for additional requirements.

2.09 PRESSURE RELIEF VALVES

- A. ANSI Z21.22, AGA certified, bronze body, teflon seat, steel stem and springs, automatic, direct pressure actuated.
- B. Temperature and Pressure:
 - 1. ANSI Z21.22, AGA certified, bronze body, teflon seat, stainless steel stem and springs, automatic, direct pressure actuated, temperature relief maximum 210 degrees F, capacity ASME BPVC-IV certified and labelled.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that excavations are to required grade, dry, and not over-excavated.

3.02 PREPARATION

- A. Ream pipe and tube ends. Remove burrs. Bevel plain end ferrous pipe.
- B. Remove scale and dirt, on inside and outside, before assembly.
- C. Prepare piping connections to equipment with flanges or unions.

3.03 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Provide non-conducting dielectric connections wherever jointing dissimilar metals.
- C. Route piping in orderly manner and maintain gradient. Route parallel and perpendicular to walls.
- D. Install piping to maintain headroom, conserve space, and not interfere with use of space.
- E. Group piping whenever practical at common elevations.
- F. Install piping to allow for expansion and contraction without stressing pipe, joints, or connected equipment.

- G. Provide clearance in hangers and from structure and other equipment for installation of insulation and access to valves and fittings.
- H. Provide access where valves and fittings are not exposed.
- I. Provide anodeless transition riser at gas piping transition from below grade to above grade.
- J. All natural gas piping exposed to outdoors shall be primed and painted, color by architect.
- K. All ABS and PVC pipe material exposed to outdoors shall be primed and painted, color by architect.
- L. Prepare exposed, unfinished pipe, fittings, supports, and accessories for finish painting.
- M. Install valves with stems upright or horizontal, not inverted. See Section 22 05 23.
- N. Install water piping to ASME B31.9.
- O. Copper Pipe and Tube: Make soldered joints in accordance with ASTM B828, using specified solder, and flux meeting ASTM B813; in potable water systems use flux also complying with NSF 61 and NSF 372.
- P. Sleeve pipes passing through partitions, walls, and floors.
- Q. Pipe Hangers and Supports:
 - 1. Install in accordance with ASME B31.9.
 - 2. Support horizontal piping as indicated.
 - 3. Install hangers to provide minimum 1/2 inch space between finished covering and adjacent work.
 - 4. Place hangers within 12 inches of each horizontal elbow.
 - 5. Use hangers with 1-1/2 inch minimum vertical adjustment. Design hangers for pipe movement without disengagement of supported pipe.
 - 6. Provide copper plated hangers and supports for copper piping.
 - 7. Prime coat exposed steel hangers and supports. Hangers and supports located in crawl spaces, pipe shafts, and suspended ceiling spaces are not considered exposed.
 - 8. Support cast iron drainage piping at every joint.

3.04 APPLICATION

- A. Install unions downstream of valves and at equipment or apparatus connections.
- B. Install brass male adapters each side of valves in copper piped system. Solder adapters to pipe.
- C. Install gate valves for shut-off and to isolate equipment, part of systems, or vertical risers.

3.05 TOLERANCES

- A. Drainage Piping: Establish invert elevations within 1/2 inch vertically of location indicated and slope to drain at minimum of 1/4 inch per foot slope.

- B. Water Piping: Slope at minimum of 1/32 inch per foot and arrange to drain at low points.

3.06 DISINFECTION OF DOMESTIC WATER PIPING SYSTEM

- A. Prior to starting work, verify system is complete, flushed, and clean.
- B. Ensure acidity (pH) of water to be treated is between 7.4 and 7.6 by adding alkali (caustic soda or soda ash) or acid (hydrochloric).
- C. Inject disinfectant, free chlorine in liquid, powder, tablet, or gas form throughout system to obtain 50 to 80 mg/L residual.
- D. Bleed water from outlets to ensure distribution and test for disinfectant residual at minimum 15 percent of outlets.
- E. Maintain disinfectant in system for 24 hours.
- F. If final disinfectant residual tests less than 25 mg/L, repeat treatment.
- G. Flush disinfectant from system until residual equal to that of incoming water or 1.0 mg/L.
- H. Take samples no sooner than 24 hours after flushing, from 10 percent of outlets and from water entry, and analyze in accordance with AWWA C651.

3.07 SCHEDULES

- A. Pipe Hanger Spacing:
 - 1. Metal Piping:
 - a. Pipe Size: 1/2 inch to 1-1/4 inch:
 - 1) Maximum Hanger Spacing: 6.5 ft.
 - 2) Hanger Rod Diameter: 3/8 inches.
 - b. Pipe Size: 1-1/2 inch to 2 inch:
 - 1) Maximum Hanger Spacing: 10 ft.
 - 2) Hanger Rod Diameter: 3/8 inch.
 - c. Pipe Size: 2-1/2 inch to 3 inch:
 - 1) Maximum Hanger Spacing: 10 ft.
 - 2) Hanger Rod Diameter: 1/2 inch.
 - d. Pipe Size: 4 inch to 6 inch:
 - 1) Maximum Hanger Spacing: 10 ft.
 - 2) Hanger Rod Diameter: 5/8 inch.

END OF SECTION

SECTION 22 10 06 PLUMBING PIPING SPECIALTIES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Floor drains.
- B. Cleanouts.
- C. Water hammer arrestors.
- D. Trap primers.

1.02 RELATED REQUIREMENTS

- A. Section 22 10 05 - Plumbing Piping.

1.03 REFERENCE STANDARDS

- A. ASME A112.6.3 - Floor and Trench Drains; 2019.
- B. ASSE 1019 - Performance Requirements for Wall Hydrant with Backflow Protection and Freeze Resistance; 2011 (Reaffirmed 2016).
- C. NSF 61 - Drinking Water System Components - Health Effects; 2022, with Errata.
- D. NSF 372 - Drinking Water System Components - Lead Content; 2022.
- E. PDI-WH 201 - Water Hammer Arresters; 2017.

1.04 SUBMITTALS

- A. See Division 1 specifications for submittal procedures.
- B. Product Data: Provide component sizes, rough-in requirements, service sizes, and finishes.
- C. Shop Drawings: Indicate dimensions, weights, and placement of openings and holes.
- D. Project Record Documents: Record actual locations of equipment, cleanouts, water hammer arrestors.
- E. Maintenance Data: Include installation instructions, spare parts lists, exploded assembly views.

1.05 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing the Products specified in this section with not less than three years documented experience.

1.06 REGULATORY REQUIREMENTS

- A. Perform Work in accordance with State of California plumbing code.
- B. Domestic water piping and components shall be provided and installed in accordance with California AB 1953 Legislation (effective January 1, 2010), which limits the allowable lead content in certain domestic water system components.

- C. Conform to applicable code for installation of backflow prevention devices.
- D. Provide certificate of compliance from authority having jurisdiction indicating approval of installation of backflow prevention devices.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Accept specialties on site in original factory packaging. Inspect for damage.

PART 2 PRODUCTS

2.01 GENERAL REQUIREMENTS

- A. Specialties in Potable Water Supply Systems: Provide products that comply with NSF 61 and NSF 372 for maximum lead content.

2.02 REFER TO PLUMBING SCHEDULE FOR PLUMBING PIPING SPECIALTIES NOT LISTED HEREIN.

2.03 DRAINS

- A. Manufacturers:
 - 1. Josam Company: www.josam.com/#sle.
 - 2. MIFAB, Inc: www.mifab.com/#sle.
 - 3. Jay R. Smith Manufacturing Company.
 - 4. Zurn Industries, LLC: www.zurn.com/#sle.
- B. Downspout Nozzles:
 - 1. Bronze round with straight bottom section. Zurn Z-199.
- C. Floor Drain (FD):
 - 1. ASME A112.6.3; lacquered cast iron or stainless steel, two piece body with double drainage flange, weep holes, reversible clamping collar, and round, adjustable nickel-bronze strainer.
 - 2. Provide accessories suitable for wood raised floor installation.
- D. Floor Sink (FS):
 - 1. Lacquered cast iron body with white acid resisting porcelain interior and top complete with aluminum anti-splash bottom dome strainer, square slotted medium duty half grate, anchor and seepage flange.

2.04 CLEANOUTS

- A. Manufacturers:
 - 1. Jay R. Smith Manufacturing Company: www.jayrsmith.com/#sle.
 - 2. Josam Company: www.josam.com/#sle.
 - 3. Zurn Industries, LLC: www.zurn.com/#sle.
- B. Cleanouts at Exterior Surfaced Areas:
 - 1. Round cast nickel bronze access frame and non-skid cover.
- C. Cleanouts at Exterior Unsurfaced Areas:
 - 1. Line type with lacquered cast iron body and round epoxy coated gasketed cover.

- D. Cleanouts at Interior Finished Floor Areas :
 - 1. Lacquered cast iron body with anchor flange, reversible clamping collar, threaded top assembly, and nickel bronze round gasketed scored cover in service areas and round or square nickel bronze gasketed depressed cover to accept floor finish in finished floor areas. Zurn ZN-1400.
- E. Cleanouts at Interior Finished Wall Areas:
 - 1. Line type with lacquered cast iron body and round epoxy coated gasketed cover, and round stainless steel access cover secured with machine screw. Zurn Z-1441 or Z-1443.
- F. Cleanouts in concealed aboveground cast iron soil or waste lines: Zurn Z-1440A with raised head ABS plastic plug.

2.05 TRAP PRIMERS

- A. Provide trap primers, 1/2 inch size, where indicated on drawings. Provide with built-in air gap and install 1/2" shutoff valve. PVC housings are not acceptable. Install trap primer line with 1/4" per foot slope to insure full drainage to floor drain or floor sink. Install tap primer behind wall with access door.
- B. Provide a distribution unit with feeder piping for a maximum of four (4) traps where multiple traps are serviced by a single trap primer.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Extend cleanouts to finished floor or wall surface as indicated on plans. Lubricate threaded cleanout plugs with mixture of graphite and linseed oil. Ensure clearance at cleanout for rodding of drainage system.
- C. Encase exterior cleanouts in concrete flush with grade.
- D. Install cleanouts in all horizontal soil and waste piping at 100 feet maximum spacing inside building, 100 feet maximum spacing outside building, at every 135 degree change of direction and where shown on Drawings.
- E. Install two way cleanout in building drain (waste line leaving the building) just outside of the building.
- F. Install cleanouts in waste drops from each urinal and sink.
- G. Install cleanouts in rain water (storm drain) drops 18 inches above finished floor. For concealed rainwater drops extend cleanout to building exterior for access.
- H. Install floor cleanouts at elevation to accommodate finished floor.
- I. Pipe relief from backflow preventer to nearest drain.

FOR REFERENCE ONLY

- J. Install water hammer arrestors complete with accessible isolation valve on hot and cold water supply piping to lavatoriessinks and washing machine outletswater closets and as shown on plans.

END OF SECTION

SECTION 22 30 00 PLUMBING EQUIPMENT

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Commercial gas-fired water heaters.
- B. In-line circulator pumps.
- C. Expansion Tanks.

1.02 REFERENCE STANDARDS

- A. ANSI Z21.10.1 - Gas Water Heaters, Volume I, Storage Water Heaters with Input Ratings of 75,000 Btu Per Hour or Less; 2019, with Errata (2020).
- B. ANSI Z21.10.3 - Gas-Fired Water Heaters, Volume III, Storage Water Heaters with Input Ratings Above 75,000 Btu Per Hour, Circulating and Instantaneous; 2019.
- C. ASHRAE Std 90.1 I-P - Energy Standard for Buildings Except Low-Rise Residential Buildings; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- D. ASME BPVC-VIII-1 - Boiler and Pressure Vessel Code, Section VIII, Division 1: Rules for Construction of Pressure Vessels; 2021.
- E. NFPA 70 - National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- F. UL 778 - Standard for Motor-Operated Water Pumps; Current Edition, Including All Revisions.
- G. UL 1453 - Standard for Electric Booster and Commercial Storage Tank Water Heaters; Current Edition, Including All Revisions.

1.03 SUBMITTALS

- A. See Division 1 specifications for submittal procedures.
- B. Product Data:
 - 1. Provide dimension drawings of water heaters indicating components and connections to other equipment and piping.
 - 2. Indicate pump type, capacity, power requirements.
 - 3. Provide certified pump curves showing pump performance characteristics with pump and system operating point plotted. Include NPSH curve when applicable.
 - 4. Provide electrical characteristics and connection requirements.
- C. Operation and Maintenance Data: Include operation, maintenance, and inspection data, replacement part numbers and availability, and service depot location and telephone number.
- D. Warranty Documentation: Submit manufacturer warranty and ensure that forms have been completed in Owner's name and registered with manufacturer.

1.04 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing the type of products specified in this section, with minimum three years of documented experience.
- B. Identification: Provide pumps with manufacturer's name, model number, and rating/capacity identified by permanently attached label.

1.05 DELIVERY, STORAGE, AND HANDLING

- A. Provide temporary inlet and outlet caps. Maintain caps in place until installation.

1.06 WARRANTY

- A. See Section 01700 - Contract Closeout, for additional warranty requirements.
- B. Provide five year manufacturer warranty for domestic water heaters.

PART 2 PRODUCTS

2.01 WATER HEATERS

- A. Commercial Gas-Fired Water Heaters:
 - 1. Manufacturers:
 - a. Bradford White Corporation: www.bradfordwhite.com/#sle.
 - b. A.O. Smith Water Products Co<>: www.hotwater.com/#sle..
 - c. State Water Heaters: www.statewaterheaters.com.
 - 2. Type: Automatic, natural gas-fired condensing type, vertical storage, power-direct vent.
 - 3. Minimum Efficiency Required: ASHRAE Std 90.1 I-P.
 - 4. Ultra Low-Nox type complying with SCAQMD Rule 1146.2.
 - 5. Shall meet thermal efficiency and standby loss requirements of the U.S. Department of Energy and current edition of ASHRAE/IES 90.1.
 - 6. Accessories:
 - a. Water Connections: Brass.
 - b. Dip Tube: Brass.
 - c. Drain valve.
 - d. Anode: Magnesium.
 - e. Temperature and Pressure Relief Valve: ASME labeled.
 - f. Acid Neutralizer Kit
 - g. Concentric Vent Kit

2.02 IN-LINE CIRCULATOR PUMPS

- A. Manufacturers:
 - 1. Armstrong Fluid Technology: www.armstrongfluidtechnology.com/#sle.
 - 2. Bell & Gossett, a xylem brand: www.bellgossett.com/#sle.
 - 3. Taco, Inc[<>]: www.tacomfort.com/#sle.

- B. Casing: Bronze, rated for 125 psig working pressure, with stainless steel rotor assembly.
- C. Impeller: Bronze.
- D. Shaft: Alloy steel with integral thrust collar and two oil lubricated bronze sleeve bearings.
- E. Seal: Carbon rotating against a stationary ceramic seat.
- F. Drive: Flexible coupling.

2.03 EXPANSION TANK

- A. Manufacturers:
 - 1. Amtrol Inc: www.amtrol.com/#sle.
 - 2. Bell & Gossett, a xylem brand: www.bellgossett.com/#sle.
 - 3. Taco, Inc: www.tacomfort.com/#sle.
- B. Construction: Welded steel, tested and stamped in accordance with ASME BPVC-VIII-1; supplied with National Board Form U-1, rated for working pressure of 125 psig, with flexible EPDM diaphragm sealed into tank, and steel legs or saddles.
- C. Accessories: Pressure gauge and air-charging fitting, tank drain; precharge to 38 psig.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install plumbing equipment in accordance with manufacturer's instructions, as required by code, and complying with conditions of certification, if any.
- B. Coordinate with plumbing piping and related fuel piping, gas venting, and electrical work to achieve operating system.
- C. Provide and install CPVC piping for combustion air intake and flue for gas fired water heaters where scheduled and as shown on the drawings. Install in accordance with manufacturer's installation instructions.
- D. Pumps:
 - 1. Provide line sized isolating valve and strainer on suction and line sized soft seated check valve and balancing valve on discharge.
 - 2. Decrease from line size with long radius reducing elbows or reducers. Support piping adjacent to pump such that no weight is carried on pump casings. Provide supports under elbows on pump suction and discharge line sizes 4 inches and over.
 - 3. Ensure pumps operate at specified system fluid temperatures without vapor binding and cavitation, are non-overloading in parallel or individual operation, and operate within 25 percent of midpoint of published maximum efficiency curve.

END OF SECTION

SECTION 22 40 00 PLUMBING FIXTURES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Flush valve water closets.
- B. Wall hung urinals.
- C. Lavatories.
- D. Indoor drinking fountains.
- E. Service sinks.

1.02 RELATED REQUIREMENTS

- A. Section 22 10 05 - Plumbing Piping.
- B. Section 22 10 06 - Plumbing Piping Specialties.

1.03 REFERENCE STANDARDS

- A. ASHRAE Std 18 - Methods of Testing for Rating Drinking-Water Coolers with Self-Contained Mechanical Refrigeration; 2008 (Reaffirmed 2013).
- B. ASME A112.6.1M - Floor-Affixed Supports for Off-the-Floor Plumbing Fixtures for Public Use; 1997 (Reaffirmed 2017).
- C. ASME A112.18.1 - Plumbing Supply Fittings; 2018, with Errata.
- D. ASME A112.19.2 - Ceramic Plumbing Fixtures; 2018, with Errata.
- E. ASME A112.19.5 - Flush Valves and Spuds for Water Closets, Urinals, and Tanks; 2022.
- F. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2023d.
- G. NSF 61 - Drinking Water System Components - Health Effects; 2022, with Errata.
- H. NSF 372 - Drinking Water System Components - Lead Content; 2022.

1.04 SUBMITTALS

- A. See Division 1 specifications for submittal procedures.
- B. Product Data: Provide catalog illustrations of fixtures, sizes, rough-in dimensions, utility sizes, trim, and finishes.
- C. Maintenance Data: Include fixture trim exploded view and replacement parts lists.
- D. Warranty: Submit manufacturer warranty and ensure forms have been completed in Owner's name and registered with manufacturer.

1.05 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing the type of products specified in this section, with minimum three years of documented experience.

1.06 REGULATORY REQUIREMENTS

- A. Perform Work in accordance with State of California plumbing code.
- B. Domestic water piping and components shall be provided and installed in accordance with California AB 1953 Legislation (effective January 1, 2010), which limits the allowable lead content in certain domestic water system components.
- C. Conform to applicable code for installation of backflow prevention devices.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Accept fixtures on-site in factory packaging. Inspect for damage.
- B. Protect installed fixtures from damage by securing areas and by leaving factory packaging in place to protect fixtures and prevent use.

1.08 WARRANTY

- A. See Section 01700 - Contract Closeout, for additional warranty requirements.
- B. Provide five year manufacturer warranty for electric water cooler.

PART 2 PRODUCTS

2.01 GENERAL REQUIREMENTS

- A. Potable Water Systems: Provide plumbing fittings and faucets that comply with NSF 61 and NSF 372 for maximum lead content; label pipe and fittings.

2.02 GENERAL REQUIREMENTS:

- A. Refer to Architectural drawings for exact locations, fixture mounting heights and ADA accessibility requirements.
- B. Insulate domestic hot water, tempered water and waste piping below handicapped plumbing fixtures with molded single piece removable insulation covers, foam, fire resistant, Truebro, or equal. Install insulation covers in accordance with ADA requirements.
- C. Provide 85% IPS red brass pipe for each connection to faucets, stops, hose bibs, and other fixtures/trim. Securely anchor brass pipe to structure. Install stop valves on water supply lines for each fixture, except hose bibbs.
- D. Provide compression shutoff control stop valves with IPS inlets and threaded brass nipples at pipe connection on water supplies to each fixture. Provide stops with lock shield loose key and key handle for each stop. For combination fixtures, provide with compression stop and IPS inlet on each water supply fitting.
- E. Provide cast brass escutcheons, except escutcheons exposed to view shall have chrome plated finish.

- F. Provide chromium-plated finish on fittings and accessories exposed to view.
- G. Fixture fittings and trim: Conform to ASME A112.18.1M and ASME A112.19.5, as applicable.
- H. Centerset faucets: Top-mounted with inlets on not greater than 4 inch centers, unless specified otherwise below.
- I. Separate faucets and combination supply fittings: Provide inlets on 8 inch centers.
- J. Zinc-alloy or plastic handles are not permitted for faucets and valves.
- K. Provide special roughing-in for wheelchair fixtures.
- L. Lavatory flow rates not to exceed 0.5 GPM.
- M. Water closet flush flow rates not to exceed 1.28 GPF.
- N. Urinal flush flow rates not to exceed 0.125 GPF.
- O. Provide water hammer arrestors at end of pipe runs to two or more fixtures, properly sized with sufficient displacement volume to dissipate calculated energy in the piping systems. Locate in accessible location or provide access panel with location approved by Architect.
- P. Fixture dimensions specified are nominal.

2.03 SEE PLUMBING SCHEDULE FOR FIXTURE REQUIREMENTS.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that walls and floor finishes are prepared and ready for installation of fixtures.
- B. Confirm that millwork is constructed with adequate provision for the installation of counter top lavatories and sinks.

3.02 PREPARATION

- A. Rough-in fixture piping connections in accordance with minimum sizes indicated in fixture rough-in schedule for particular fixtures.

3.03 INSTALLATION

- A. Install each fixture with trap, easily removable for servicing and cleaning.
- B. Provide chrome-plated rigid or flexible supplies to fixtures with loose key stops, reducers, and escutcheons.
- C. Install components level and plumb.
- D. Install and secure fixtures in place with wall carriers and bolts.
- E. Solidly attach water closets to floor with lag screws. Lead flashing is not intended to hold fixture in place.

3.04 ADJUSTING

- A. Adjust stops or valves for intended water flow rate to fixtures without splashing, noise, or overflow.

3.05 CLEANING

- A. Clean plumbing fixtures and equipment.

END OF SECTION

SECTION 23 05 10 MECHANICAL GENERAL PROVISIONS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. References.
- B. Description of Work.
- C. Drawings and Specifications.
- D. Industry Standards and Codes.
- E. Site Examination.
- F. Permits, Fees and Utility Connections.
- G. Coordination of Work.
- H. Progress of Work.
- I. Submittals
- J. Operation and Maintenance Manuals.
- K. Project Record Documents.
- L. Warranty.
- M. Quality and Care
- N. Access Doors.
- O. Starting Equipment and Systems.

1.02 RELATED SECTIONS

- A. The Contract Agreement, Bidding Documents and all Addenda issued prior to Contract Agreement execution form a part of these specifications and apply to all Contracts or Subcontracts relating to the mechanical systems.
- B. The requirements of this Section apply to all Work of Division 23.

1.03 REFERENCES

- A. ANSI - American National Standards Institute.
- B. ASTM - American Society for Testing Materials.
- C. CEC - California Electric Code.
- D. NEMA - National Electric Manufacturers' Association.
- E. NFPA - National Fire Protection Association.
- F. OSHA - Occupational Safety and Health Act.
- G. UL - Underwriters' Laboratories.
- H. See detailed References that are listed in individual sections.

1.04 DESCRIPTION OF WORK

- A. The work included in this division of the specifications consists of furnishing labor, tools, equipment, supplies and materials, unless otherwise specified, and in performing operations necessary for the installation of the complete Mechanical System as required by these specifications or shown on the Drawings, subject to the terms and conditions of the Contract Agreement.
- B. The work shall also include the completion of details of mechanical work not mentioned or shown which are necessary for the successful operation of mechanical systems described on the drawings or required by these specifications. Furnish and install any incidental work not shown or specified which is required to provide a complete and operational system.

1.05 DRAWINGS AND SPECIFICATIONS

- A. Drawings are schematic and diagrammatic. Drawings indicate the general arrangement of equipment, piping, ductwork and other mechanical work. Use judgement and care to install mechanical work to fit the job conditions within the building construction and finishes, and to function properly.
- B. The Contractor shall investigate the building conditions affecting the Work and shall arrange his work accordingly providing offsets, fittings, valves and accessories to fit the actual job conditions. The Contractor shall be responsible to field measure and confirm new and existing mechanical systems locations with respect to other architectural, structural, and electrical work, existing and new. Do not scale distances off of the mechanical drawings. Use actual building dimensions.
- C. The drawings and specifications are complimentary each to the other. What is required by one shall be as binding as if called for by both.
- D. Examine all drawings and specifications prior to bidding the Work. Report any discrepancies to the Engineer.

1.06 INDUSTRY STANDARDS AND CODES

- A. The Mechanical Contractor shall comply with the latest provisions of all codes, regulations, laws and ordinances applicable to the work involved. This does not relieve the Contractor from furnishing and installing work shown or specified which may exceed the requirements of such codes, regulations laws and ordinances.
- B. All materials, products, devices, fixtures forms or types of construction included in this project shall meet or exceed the published requirements of the publications listed below. These publications form a part of this specification.
 - 1. California Building Code, 2022.
 - 2. California Mechanical Code, 2022.
 - 3. California Plumbing Code, 2022.
 - 4. California Electrical Code, 2022.
 - 5. National Fire Protection Association.
 - 6. California Fire Code, 2022.
 - 7. California State Fire Marshal.
 - 8. Occupational Safety and Health Administration, including CAL-OSHA.

9. California Energy Code, 2022.
 10. California Green Building Standards Code, 2022.
 11. State of California Code of Regulations, Title 24.
 12. Other applicable state laws.
- C. Nothing in the Drawings or Specifications shall be construed to permit work that does not conform these codes. When Contract Documents differ from governing codes, furnish and install to the higher standard required at no extra charge. The Contract Documents are not intended to repeat the code requirements except where necessary for clarity.
- D. No material or product installed as a part of the Work shall contain asbestos in any form.

1.07 SITE EXAMINATION

- A. Contractor shall examine the site, verify dimensions and locations with Drawings, check utility connection locations, and familiarize himself with the existing conditions and limitations. No extras will be allowed because of the Contractor's misunderstanding of the amount of work involved or his lack of knowledge of any site condition which may affect his work. Any apparent variance of the drawings or specifications from the existing conditions at the site shall be called to the attention of the Engineer immediately.

1.08 PERMITS, FEES AND UTILITY SERVICES

- A. Contractor shall pay for and obtain all permits and service required in the installation of this work.
- B. Contractor shall arrange for all required inspections and will secure approvals from authorities having jurisdiction.

1.09 COORDINATION OF WORK

- A. It is recognized that the contract documents are diagrammatic in showing certain physical relationships which must be established within the mechanical work, and in its interface with other work and that such establishment is the exclusive responsibility of the contractor.
- B. The Contractor shall give careful consideration to the work of the General, Electrical and other contractors on the job and shall organize his work so that it will not interfere with the work of other trades. He shall consult the drawings and specifications for work of other trades for correcting information, and the pertinent drawings for details and dimensions.
- C. Arrange mechanical work in a neat, well-organized manner with the piping, conduit, and similar services running parallel and/or perpendicular to primary lines of the building construction. Locate operating and control equipment properly to provide easy access, and arrange entire mechanical work with adequate access for operation and maintenance.

- D. Verify the location of all equipment, and devices, etc. and if interference develops, the Owner/Engineer's decision will be final and no additional compensation will be allowed for the moving of misplaced air devices or equipment.

1.10 PROGRESS OF WORK

- A. This Contractor shall organize his work so that the progress of the mechanical work will conform to the progress of the other trades, and shall complete the entire installation as soon as the conditions of the building will permit. Any cost resulting from defective or ill timed work performed under this section shall be borne by this Contractor.

1.11 STRUCTURAL DESIGN REQUIREMENTS AND SEISMIC RESTRAINTS

- A. Mechanical systems and equipment shall be anchored and seismically braced in accordance with all applicable codes and industry standards.
- B. Mechanical systems and equipment shall include, but are not limited to, all piping, heating and ventilating equipment, electrical and control panels, conduits and other components.
- C. For all non-standard installations not detailed in one of the approved systems, the Contractor shall provide details of supports, anchorages and restraints, including attachments to building structure, with supporting calculations all stamped and signed by a licensed professional structural engineer registered in the state in which the Work is performed.

1.12 SUBMITTALS

- A. See Section 013300 - Submittal Procedures, for additional submittal procedures.
- B. Product Data Submittals: Submit manufacturer's standard published data. Mark each copy to identify applicable products, models, options, and other data. Supplement manufacturers' standard data to provide information specific to this Project.
- C. Shop Drawing Submittals: Prepared specifically for this Project.
- D. Organize submittals in sequence according to Specification Section. Submit in bound document with tabs identifying each Specification Section. Provide a Table of Contents identifying the Specifications Sections being submitted and the contents within each tabbed section. Prepare Submittals in multiple volumes if required. Provide a complete Submittal package at one time. Do not submit individual Sections piecemeal.
- E. Indicate utility and electrical characteristics, utility connection requirements, and location of utility outlets for service for functional equipment and appliances.
- F. Furnish, upon request, installation instructions for all equipment and materials to Inspector of Record prior to installation.
- G. Maintain a copy of the fire and smoke damper installation instructions on site for use by the Inspector of Record.

1.13 SUBSTITUTION PROCEDURES

- A. Instructions to Bidders specify time restrictions for submitting requests for substitutions during the bidding period. Comply with requirements specified in this section.
- B. LP Consulting Engineers, Inc. will consider requests for substitutions only within 7 days after date of Agreement.
- C. Substitutions may be considered when a product becomes unavailable through no fault of the .
- D. Failure by the Contractor to order materials or equipment in a timely manner will not constitute justification for a substitution.
- E. Document each request with complete data substantiating compliance of proposed substitution with Contract Documents.
- F. A request for substitution constitutes a representation that the submitter:
 - 1. Has investigated proposed product and determined that it meets or exceeds the quality level of the specified product.
 - 2. Will provide the same warranty for the substitution as for the specified product.
 - 3. Will coordinate installation and make changes to other Work which may be required for the Work to be complete with no additional cost to Owner.
 - 4. Waives claims for additional costs or time extension which may subsequently become apparent.
 - 5. Will reimburse Owner and LP Consulting Engineers, Inc. for review or redesign services associated with reapproval by authorities including obtaining reapproval by authorities.
- G. Substitutions will not be considered when they are indicated or implied on shop drawing or product data submittals, without separate written request, or when acceptance will require revision to the Contract Documents.
- H. If excessive review, as judged by the Engineer, is required caused by complicated, numerous or repetitive requests, Contractor shall reimburse Engineer and its Consultants for such review at their standard billing rates.
- I. Substitution Submittal Procedure:
 - 1. Submit three copies of request for substitution for consideration. Limit each request to one proposed substitution.
 - 2. Submit shop drawings, product data, and certified test results attesting to the proposed product equivalence. Burden of proof is on proposer.
 - 3. The LP Consulting Engineers, Inc. will notify in writing of decision to accept or reject request.
 - 4. Present each substitution individually. If a proposed substitute in not found to be acceptable, then the specified item shall be supplied.

1.14 OPERATION AND MAINTENANCE MANUALS

- A. See Section 01700 Closeout Submittals for Operation and Maintenance Manual requirements.

- B. Provide operating and maintenance instructions, diagrams and parts lists for all components of all mechanical systems and each piece of equipment furnished under these specifications.
- C. Operating and maintenance instructions shall be furnished for the following equipment and systems:
 - 1. Ventilating Systems.
 - 2. Air Conditioning Systems.
 - 3. Piping Systems.
 - 4. Temperature Controls Systems.
 - 5. Motors.
 - 6. Testing, Adjusting, and Balancing Reports.
- D. Provide manufacturer's model number, design data, capacities, etc. for each piece of mechanical equipment furnished as a part of the Work.
- E. The operating instructions shall include procedures for starting, stopping and emergency manual operation for all equipment and systems.
- F. Provide maintenance instructions of each item of individual equipment including applicable maintenance data as recommended by the manufacturer, including frequency of lubrication, lubricants, inspections required, adjustment procedures, belt and pulley sizes, etc.
- G. Provide manufacturer's parts bulletins with part numbers for each item of equipment included in the Work. Parts bulletins shall be specific to the equipment provided. Extraneous information that does not apply to the equipment provided shall be eliminated from the literature.
- H. Include copies of test reports (startup, check, etc.) and inspections performed for each piece of equipment provided in the Work.
- I. Warranty: Submit manufacturer warranty and ensure that forms have been completed in Owner's name and registered with manufacturer.
- J. Provide supplier and manufacturer contacts, telephone numbers and addresses in the front portion of the operation and maintenance manual.

1.15 PROJECT RECORD DOCUMENTS

- A. See Section 017700 - Closeout Procedures.
- B. Provide red-lined drawings accurately showing location of equipment and devices and size and routing of ductwork. Include notes explaining installed condition for complete understanding.

1.16 QUALITY ASSURANCE

- A. Monitor quality control over suppliers, manufacturers, products, services, site conditions, and workmanship, to produce Work of specified quality.
- B. Comply with manufacturers' instructions, including each step in sequence.
- C. Should manufacturers' instructions conflict with Contract Documents, request clarification from LP Consulting Engineers, Inc. before proceeding.

- D. Comply with specified standards as minimum quality for the Work except where more stringent tolerances, codes, or specified requirements indicate higher standards or more precise workmanship.
- E. Have Work performed by persons qualified to produce required and specified quality.
- F. Verify that field measurements are as indicated on shop drawings or as instructed by the manufacturer.
- G. Secure products in place with positive anchorage devices designed and sized to withstand stresses, vibration, physical distortion, and disfigurement.

1.17 PROJECT CONDITIONS

- A. Sequence installation to ensure utility connections are achieved in an orderly and expeditious manner.

1.18 WARRANTY

- A. See Section 017700 - Closeout Procedures, for additional warranty requirements.
- B. Correct defective Work within a one year period after Date of Substantial Completion.

PART 2 PRODUCTS

2.01 QUALITY AND CARE

- A. All materials shall be new and in perfect condition when installed unless specifically indicated otherwise. Materials shall be tested within the Continental United States by an independent, nationally recognized testing agency and shall be listed in accordance with testing agency requirements. When not otherwise specified, all material shall conform to applicable National Standards (ANSI).
- B. All capacities, sizes and efficiency ratings shown on the drawing are minimum.
- C. Each category of material or equipment shall be of the same brand or manufacturer throughout the Work wherever possible.
- D. The quality of materials and equipment to be provided is defined by the brand names, manufacturers, model and catalog numbers listed on the Drawings and in the Specifications. Contractor shall provide each item listed, of the quality specified, or equal.
- E. Deliver, store, protect, and handle products in conformance with manufacturer's recommended practices as outlined in applicable Installation and Maintenance Manuals.
- F. Inspect and report concealed damage to carrier within their required time period.
- G. Store materials in a clean, dry space. Maintain factory protection and/or provide an additional heavy canvas or heavy plastic cover to protect from dirt, water, construction debris, and traffic.
- H. Equipment which has been damaged, exposed to weather or is, in the opinion of the Engineer or Owner, otherwise unsuitable because of improper fabrication, storage or installation shall be removed and replaced by this Contractor at his expense.

2.02 ACCESS DOORS

- A. Coordinate access door requirements with Section 083113. The more stringent requirements shall govern.
- B. Provide access doors where access through floors, walls or ceilings is required to access mechanical, plumbing, control system components, fire dampers and fire alarm system components (such as smoke detectors, fire/smoke dampers, etc.) or other systems requiring access for maintenance, test or observation.
 - 1. Access doors requiring hand access or access for observation only shall be 14"x14" minimum usable opening.
 - 2. Access doors where entrance of a service person may be required shall be 24"x30" minimum usable opening.
- C. Established standard: Milcor of types listed below. Other acceptable manufacturers: Cesco, J.L. Industries, Karp, Larsen's, or equal. Comply with the following:
 - 1. Form doors and frames of welded, ground smooth steel construction, 14 gauge for doors, 16 gauge for frames. Provide prime coat finish except for stainless steel type.
 - 2. Concealed hinges to allow 175 degree opening.
 - 3. Locks: flush, screw driver operated cam lock(s).
 - 4. Provide anchoring devices suitable for the construction into which the doors are framed.
- D. Application (as applicable):
 - 1. In gypsum drywall walls and ceilings: Type DW.
 - 2. In ceramic tile walls: Type MS (stainless steel).
 - 3. In fire rated walls: Type Fire Rated (rating as required for wall or ceiling), self closing, 250 F in 30 min. temperature rating.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Access Doors
 - 1. Coordinate the exact location of access doors to provide proper access to the item concealed. Obtain written approval for access door locations from Architect.
 - 2. Coordinate installation of access doors with the trades performing the construction assemblies into which the access doors are placed.
 - 3. Install all access doors neatly and securely, to open and close completely, and to operate freely and without binding. Install rated doors in accordance with their listing requirements.
 - 4. Test operate all doors and make all adjustments required for satisfactory operation. Replace all damaged materials.
 - 5. Install in accordance with manufacturer's instructions.

3.02 FIELD QUALITY CONTROL

- A. Perform field inspection and testing in accordance with the requirements within this section.
- B. Test all piping with no leak or loss in pressure in accordance with the requirements within this section.

3.03 GENERAL TESTING REQUIREMENTS FOR MECHANICAL AND PLUMBING SYSTEMS

- A. Contractor shall assign a responsible person to be an independent representative to witness testing and to sign as witness of times, pressure and losses of testing media for all hydronic piping and duct testing.
 - 1. Test all piping as noted below with no leak or loss of pressure. Repair or replace defective piping until tests are accomplished successfully.
 - 2. Submit to the Engineer for review a log of all tests made which shall include time, temperature, pressure, water makeup and other applicable readings, necessary to indicate the systems have been operated and tested in the manner outlined in the construction documents.
 - 3. After producing the specified test pressure, disconnect the pressurizing source; do not introduce further pressure for the duration of the test period, repair leaky piping and retest. Repeat the procedure until the entire system is proven tight.
- B. Test the following systems with the medium listed to the pressure indicated for the time period listed:
 - 1. Hydronic Piping: Pressure=125 Psig / Medium= Water / Duration=4 Hours.

3.04 CUTTING AND PATCHING

- A. Submit written request in advance of cutting or alteration which affects:
 - 1. Structural integrity of any element of Project.
 - 2. Integrity of weather exposed or moisture resistant element.
 - 3. Efficiency, maintenance, or safety of any operational element.
 - 4. Visual qualities of sight exposed elements.
 - 5. Work of Owner or separate Contractor.
- B. Execute cutting and patching to complete the work, to uncover work to install improperly sequenced work, to remove and replace defective or non-conforming work, to remove samples of installed work for testing when requested, to provide openings in the work for penetration of mechanical and electrical work, to execute patching to complement adjacent work, and to fit Products together to integrate with other work.
- C. Execute work by methods to avoid damage to other work, and which will provide appropriate surfaces to receive patching and finishing. In existing work, minimize damage and restore to original condition.
- D. Cut rigid materials using masonry saw or core drill. Pneumatic tools not allowed without prior approval.

- E. Restore work with new Products in accordance with requirements of Contract Documents.
- F. Fit work air tight to pipes, sleeves, ducts, conduit, and other penetrations through surfaces.
- G. At penetrations of fire rated walls, partitions, ceiling, or floor construction, completely seal voids with fire rated material in accordance with Code requirements , to full thickness of the penetrated element.
- H. Refinish surfaces to match adjacent finish. For continuous surfaces, refinish to nearest intersection or natural break. For an assembly, refinish entire unit.

3.05 PRIMING AND PAINTING

- A. Apply primer to all exposed ferrous metals that are not factory primed, factory finished, galvanized, stainless steel or anodized. Exposed black steel piping shall be primed and finish painted to match Architectural finish requirements.
 - 1. Primer shall be as recommended by the paint manufacturer for each specific application.
 - 2. Acceptable Products include: Fuller O'Brien Blox-Rust Metal All Purpose Primer, equivalent Rust-Oleum product, or equal. See Section 092216 for other acceptable products.
- B. Apply two coats of primer to metal surfaces of items to be insulated or jacketed, except ductwork and piping, or factory primed or finished.
- C. Preparation:
 - 1. Do not start work until surfaces to be finished are in proper condition to produce finished surfaces of uniform, satisfactory appearance.
 - 2. Stains and Marks: Remove completely, if possible, using materials and methods recommended by coating manufacturer; seal stains and marks which cannot be completely removed using Devco KILSTAIN primers, shellac, or other coating acceptable to paint manufacturer any marks or defects that might bleed through paint finishes.
 - 3. Remove mildew from impervious surfaces by scrubbing with solution of trisodium phosphate and bleach. Rinse with clean water and allow substrate to thoroughly dry.
 - 4. Galvanized Surfaces:
 - a. Remove surface contamination and oils by solvent cleaning in accordance with SSPC-SP 1 and allow to dry.
 - b. Apply Devco MIRROLAC Galvanized Metal Primer in accordance with manufacturer instructions.
 - 5. Uncoated Steel And Iron Surfaces:
 - a. Remove grease, rust, scale, and dust from steel and iron surfaces using solvent in accordance with SSPC-SP 1.
 - b. Where heavy coatings of scale or contaminants are evident, hand tool clean in accordance with SSPC-SP 2 or use other approved SSPC SP method as needed.

6. ~~Shop Primed Steel Surfaces: Remove loose primer and dust. Sand and feather edges to smooth surface. Clean areas with solvent and spot prime bare metal surfaces with appropriate Devoe MIRROLAC metal primer or primer recommended by manufacturer.~~
- D. Application:
 1. Apply each coat to uniform coating thickness in accordance with manufacturer's instructions, not exceeding manufacturer's specified maximum spread rate for indicated surface; thins, brush marks, roller marks, orange-peel, or other application imperfections are not permitted.
 2. Allow manufacturer's specified drying time, and ensure correct coating adhesion, for each coat before applying next coat.
 3. Remove dust and other foreign materials from substrate immediately prior to applying each coat.
- E. Finish Painting: See Section 09900.

3.06 STARTING EQUIPMENT AND SYSTEMS/COMMISSIONING

- A. Start equipment and systems in accordance with manufacturer's written instructions..
- B. Adjust for proper operation within manufacturer's published tolerances.
- C. Demonstrate proper operation of equipment to Owner's designated representative.
- D. Description:
 1. Comply with all start up of mechanical and electrical equipment systems as required in the various sections and herein.
 2. Coordinate all testing and startup procedures with all other trades so that all non-mechanical and non-electrical work is completed and operational so that the specified testing can be performed.
- E. Preliminary Work:
 1. Prior to the startup, the Contractor shall ensure that the systems are ready to operate, and the following items have been completed and checked including but not limited to:
 - a. Proper motor and pump rotation.
 - b. Flushing and cleaning of the system.
 - c. Wiring
 - d. Auxiliary connections
 - e. Lubrication.
 - f. Venting.
 - g. Controls.
 - h. Installation of filters and strainers.
 - i. Setting of relief and safety valves .
 2. All electrical testing must be completed and test results submitted before equipment startup to avoid power interruptions during mechanical equipment startup and testing.
 3. The Contractor shall submit at least 10 days in advance a schedule listing the date of completion of his work as it will be ready for equipment startup of

Electrical/Mechanical equipment. This schedule shall include work on a system by system, floor by floor basis.

4. Two weeks prior to the startup of any major equipment, the Contractor shall certify in writing that the systems will be complete and ready for startup. Completeness shall not only include physical installation of individual pieces of equipment, but all related elements of other crafts to make all equipment operate as a system.
 - a. The startup checklist will cover all related crafts, e.g., controls, electrical, mechanical, and a clean environment for equipment startup.
 5. The Contractor shall schedule a tour with the Owner's representative and the Engineer to review startup conditions prior to equipment startup. This tour shall take place during the associated Engineer's regularly scheduled visit. This tour does not relieve the Contractor of any responsibilities to properly start equipment. The Engineer will issue a notice of deficiencies that will be required to be corrected prior to equipment startup. The Contractor will be required to reschedule a back check with the Engineer prior to attempting an equipment startup.
 6. Equipment of systems should not be started until systems and associated subsystems are completed. Verify that other continuing work could not possibly damage completed systems if they are in operation. Furnish signed off prestartup check sheet.
- F. Startup and Commissioning:
1. System Startup and Operation:
 - a. The Contractor shall provide all labor, materials and services necessary for the initial startup and operation of all systems and equipment furnished and installed under this section.
 - b. The Contractor and the factory representative shall check all equipment during initial startup to insure correct rotation, proper lubrication, adequate fluids or air flows, nonoverloading electrical characteristics, proper alignment and vibration isolation. Systems shall be checked for air and/or water flows throughout without blockages. Air handling systems shall be checked for proper damper connections and positions, aligned and adjusted belt drives, proper lubrication, temporary air filters installed, nonexcessive electrical characteristics and minimal vibration. Other miscellaneous equipment shall be started and operated as described above as applicable. Manufacturer's representative shall submit a preliminary written copy of equipment startup check sheet prior to leaving job site.

END OF SECTION

SECTION 23 05 29

HANGERS AND SUPPORTS FOR HVAC PIPING AND EQUIPMENT

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Strut systems for pipe or equipment support.
- B. Beam clamps.
- C. Pipe hangers.
- D. Pipe rollers and roller supports.
- E. Pipe supports, guides, shields, and saddles.
- F. Seismic bracing hardware.
- G. Anchors and fasteners.

1.02 REFERENCE STANDARDS

- A. ASTM A123/A123M - Standard Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products; 2017.
- B. ASTM A153/A153M - Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware; 2023.
- C. ASTM A181/A181M - Standard Specification for Carbon Steel Forgings, for General-Purpose Piping; 2022.
- D. ASTM A36/A36M - Standard Specification for Carbon Structural Steel; 2019.
- E. ASTM A47/A47M - Standard Specification for Ferritic Malleable Iron Castings; 1999, with Editorial Revision (2022).
- F. ASTM A283/A283M - Standard Specification for Low and Intermediate Tensile Strength Carbon Steel Plates; 2018.
- G. ASTM A395/A395M - Standard Specification for Ferritic Ductile Iron Pressure-Retaining Castings for Use at Elevated Temperatures; 1999 (Reapproved 2022).
- H. ASTM A653/A653M - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process; 2022.
- I. ASTM A1011/A1011M - Standard Specification for Steel, Sheet and Strip, Hot-Rolled, Carbon, Structural, High-Strength Low-Alloy, High-Strength Low-Alloy with Improved Formability, and Ultra-High Strength; 2018a.
- J. ASTM B633 - Standard Specification for Electrodeposited Coatings of Zinc on Iron and Steel; 2023.
- K. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2023d.
- L. ASTM E96/E96M - Standard Test Methods for Gravimetric Determination of Water Vapor Transmission Rate of Materials; 2022a, with Editorial Revision (2023).

- M. MSS SP-58 - Pipe Hangers and Supports - Materials, Design, Manufacture, Selection, Application, and Installation; 2018, with Amendment (2019).
- N. NFPA 101 - Life Safety Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- O. UL 723 - Standard for Test for Surface Burning Characteristics of Building Materials; Current Edition, Including All Revisions.

1.03 SUBMITTALS

- A. See Division 1 specifications for submittal procedures.
- B. Product Data: Provide manufacturer's standard catalog pages and data sheets for channel (strut) framing systems, nonpenetrating rooftop supports, post-installed concrete and masonry anchors, and thermal insulated pipe supports.
- C. Evaluation Reports: For products specified as requiring evaluation and recognition by ICC Evaluation Service, LLC (ICC-ES), provide current ICC-ES evaluation reports upon request.

PART 2 PRODUCTS

2.01 GENERAL REQUIREMENTS

- A. Provide required hardware to hang or support piping, equipment, or fixtures with related accessories as necessary to complete installation of mechanical work.
- B. Provide hardware products listed, classified, and labeled as suitable for intended purpose.
- C. Where support and attachment component types and sizes are not indicated, select in accordance with manufacturer's application criteria as required for the load to be supported. Include consideration for vibration, equipment operation, and shock loads where applicable.
- D. Do not use wire, chain, perforated pipe strap, or wood for permanent supports unless specifically indicated or permitted.
- E. Fire Resistance: Provide hardware rated for 120 minutes resistance unless specifically indicated by the authority having jurisdiction.
- F. Materials for Metal Fabricated Supports: Comply with Section 05 50 00.
 - 1. Galvanized Steel: Hot-dip galvanized in accordance with ASTM A123/A123M or ASTM A153/A153M unless stated otherwise.
- G. Corrosion Resistance: Use corrosion-resistant metal-based materials fully compatible with exposed piping materials and suitable for the environment where installed.
 - 1. Indoor Dry Locations: Use approved equivalent or galvanized steel unless otherwise indicated.
 - 2. Outdoor, Damp, or Wet-Indoor Locations: Use galvanized steel, stainless steel, or approved equivalent unless otherwise indicated.

2.02 STRUT SYSTEMS FOR PIPE OR EQUIPMENT SUPPORT

- A. Strut Channels:
 - 1. ASTM A653/A653M galvanized steel bracket with clamps for surface mounting of piping or plumbing equipment support.
 - 2. Channel or Bracket Kits: Include rods, brackets, end-fixed fittings, covers, clips, and other related hardware required to complete sectional trapeze section for piping or other support.
- B. Hanger Rods:
 - 1. Threaded zinc-plated steel unless otherwise indicated.
 - 2. Minimum Size, Unless Otherwise Indicated or Required:
 - a. Equipment Supports: 1/2 inch diameter.
 - b. Piping up to 4 inch: 3/8 inch diameter.
 - c. Piping larger than 4 inch: 1/2 inch diameter.
 - d. Trapeze Support for Multiple Pipes: 3/8 inch in length.
- C. Channel Nuts:
 - 1. Provide carbon steel channel nut with epoxy copper or zinc finish and long, regular, or short spring as indicated on drawings.

2.03 BEAM CLAMPS

- A. MSS SP-58 types 19 through 23, 25 or 27 through 30 based on required load.
- B. Provide clamps with hardened steel cup-point set screws and lock-nuts for anchoring in place.
- C. Material: ASTM A395/A395M ductile iron, ASTM A36/A36M carbon steel, ASTM A47/A47M malleable iron, ASTM A181/A181M forged steel, or ASTM A283/A283M steel.

2.04 PIPE HANGERS

- A. J-Hangers, Adjustable:
 - 1. MSS SP-58 type 5, zinc-plated ASTM A1011/A1011M steel or ASTM A653/A653M carbon steel.
 - 2. Felt-Lined: Provide for uninsulated pipe to reduce noise and prevent static issues.
- B. Swivel Ring Hangers, Adjustable:
 - 1. MSS SP-58 type 10, epoxy-painted, zinc-colored.
 - 2. Material: ASTM A395/A395M ductile iron, ASTM A36/A36M carbon steel, ASTM A47/A47M malleable iron, ASTM A181/A181M forged steel, or ASTM A283/A283M steel.
 - 3. Felt-Lined: Provide for uninsulated pipe to reduce noise and prevent static issues.
- C. Clevis Hangers, Adjustable:
 - 1. Copper Tube: MSS SP-58 type 1, epoxy-plated copper.
 - 2. Felt-Lined: MSS SP-58 type 1, zinc-plated, silicone-free carbon steel.
 - 3. Light-Duty: MSS SP-58 type 1, zinc-colored, epoxy plated.

4. Standard-Duty: MSS SP-58 type 1, zinc-colored, epoxy plated.

2.05 PIPE CLAMPS

- A. Riser Clamps:
 1. For insulated pipe runs, provide two bolt-type clamps designed for installation under insulation.
 2. MSS SP-58 type 1 or 8, carbon steel or steel with epoxy plated, plain, stainless steel, or zinc plated finish.
 3. Medium Split Horizontal Pipe Clamp: MSS SP-58 type 4, carbon steel or stainless steel with epoxy plated, plain, stainless steel, or zinc plated finish.
 4. Copper Tube Pipe Clamp: MSS SP-58 type 8, epoxy plated copper.
- B. Extension Split Pipe Clamp:
 1. MSS SP-58 type 12, hinged split ring and yoke roller hanger with epoxy copper or plain finish.
 2. Material: ASTM A47/A47M malleable iron or ASTM A36/A36M carbon steel.
 3. Provide hanger rod and nuts of the same type and material for a given pipe run.
 4. Provide coated or plated hangers to isolate steel hangers from dissimilar metal tube or pipe.
- C. Offset Pipe Clamps: Double-leg design two-piece pipe clamp.
- D. Strut Clamps:
 1. Pipe Clamp: Two-piece rigid, universal, or outer diameter type, carbon steel with epoxy copper or zinc finish.
 2. Cushioned Pipe or Tubing Strut Clamp: Provide strut clamp with thermoplastic elastomer cushion having dielectric strength of 670 V/mil.
- E. Insulation Coupling:
 1. Two bolt-type clamps designed for installation under insulation.
 2. Material: Carbon steel with epoxy copper or zinc finish.

2.06 PIPE SUPPORTS, GUIDES, SHIELDS, AND SADDLES

- A. Dielectric Barriers: Provide between metallic supports and metallic piping and associated items of dissimilar type; acceptable dielectric barriers include rubber or plastic sheets or coatings attached securely to pipe or item.
- B. Stanchions:
 1. Material: Malleable iron, ASTM A47/A47M; or carbon steel, ASTM A36/A36M.
 2. Provide coated or plated saddles to isolate steel hangers from dissimilar metal tube or pipe.
 3. For pipe runs, use stanchions of same type and material where vertical adjustment is required for stationary pipe.
- C. U-Bolts:
 1. MSS SP-58 type 24, carbon steel u-bolt for pipe support or anchoring.
- D. Pipe Alignment Guides, Galvanized steel:
 1. Pipe Sizes 8 inch and Smaller: Spider or sleeve type.
 2. Pipe Sizes 10 inch and Larger: Roller type.

- E. Pipe Shields for Insulated Piping:
 - 1. MSS SP-58 type 40, ASTM A1011/A1011M steel or ASTM A653/A653M carbon steel.
 - 2. General Construction and Requirements:
 - a. Surface Burning Characteristics: Comply with ASTM E84 or UL 723.
 - b. Shields Material: UV-resistant polypropylene with glass fill.
 - c. Maximum Insulated Pipe Outer Diameter: 12-5/8 inch.
 - d. Service Temperature: Minus 40 to 178 degrees F.
 - e. Pipe shields to be provided at hanger, support, and guide locations on pipe requiring insulation or additional support.
- F. Pipe Supports:
 - 1. Material: ASTM A395/A395M ductile iron, ASTM A36/A36M carbon steel, ASTM A47/A47M malleable iron, ASTM A181/A181M forged steel, or ASTM A283/A283M steel.
 - 2. Liquid Temperatures Up to 122 degrees F:
 - a. Overhead Support: MSS SP-58 types 1, 3 through 12 clamps.
 - b. Support From Below: MSS SP-58 types 35 through 38.
 - 3. Operating Temperatures from 122 to 446 degrees F:
 - a. Overhead Support: MSS SP-58 type 1 or 3 through 12 clamps with appropriate saddle of MSS SP-58 type 40 for insulated pipe.
 - b. Roller Chair: MSS SP-58 types 41 or 43 through 46 roller chair support with appropriate saddle of MSS SP-58 type 39 for insulated pipe.
 - c. Sliding Support: MSS SP-58 types 35 through 38.
- G. Pipe Supports, Thermal Insulated:
 - 1. General Requirements:
 - a. Insulated pipe supports to be provided at hanger, support, and guide locations on pipe requiring insulation or additional support.
 - b. Pipe insulation protection shields to be provided at the hanger points and guide locations on pipes requiring insulation as indicated on drawings.
 - c. Surface Burning Characteristics: Flame spread index/smoke developed index of 5/30, maximum, when tested in accordance with ASTM E84 or UL 723.
 - d. Provide pipe supports for 1/2 to 30 inch iron pipes.
 - e. Insulation inserts to consist of rigid phenolic foam insulation surrounded by 360 degree, PVC jacketing.
 - 2. PVC Jacket:
 - a. Pipe insulation protection shields to be provided with ball bearing hinge and locking seam.
 - b. Minimum Service Temperature: Minus 40 degrees F.
 - c. Maximum Service Temperature: 180 degrees F.
 - d. Moisture Vapor Transmission: 0.0071 perm inch, when tested in accordance with ASTM E96/E96M.
 - e. Minimum Thickness: 60 mil, 0.06 inch.

2.07 SEISMIC BRACING HARDWARE

- A. Cable Sway Bracing Systems:
 - 1. Cable wire hanger with fix and release spring mechanism enclosed using zinc housing with 302 stainless steel components for pipe or equipment suspension to surface-mounted end-fixing fittings.
 - 2. Provide cable wire and end-fixing as required to hold minimum weight of 100 lb.
- B. ANCHORS AND FASTENERS
- C. Unless otherwise indicated and where not otherwise restricted, use the anchor and fastener types indicated for the specified applications.
- D. Concrete: Use preset concrete inserts or expansion anchors.
- E. Solid or Grout-Filled Masonry: Use expansion anchors.
- F. Hollow Masonry: Use toggle bolts.
- G. Hollow Stud Walls: Use toggle bolts.
- H. Steel: Use beam clamps, machine bolts, or welded threaded studs.
- I. Sheet Metal: Use sheet metal screws.
- J. Wood: Use wood screws.
- K. Plastic and lead anchors are not permitted.
- L. Powder-actuated fasteners are not permitted.
- M. Hammer-driven anchors and fasteners are not permitted.
- N. Post-Installed Concrete and Masonry Anchors: Evaluated and recognized by ICC Evaluation Service, LLC (ICC-ES) for compliance with applicable building code.
- O. Preset Concrete Inserts: Continuous metal strut channel and spot inserts specifically designed to be cast in concrete ceilings, walls, and floors.
 - 1. Channel Material: Use galvanized steel.
 - 2. Manufacturer: Same as manufacturer of metal strut channel framing system.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that field measurements are as indicated.
- B. Verify that mounting surfaces are ready to receive support and attachment components.
- C. Verify that conditions are satisfactory for installation prior to starting work.

3.02 INSTALLATION

- A. Install products in accordance with manufacturer's instructions.
- B. Install anchors and fasteners in accordance with ICC Evaluation Services, LLC (ICC-ES) evaluation report conditions of use where applicable.
- C. Provide independent support from building structure. Do not provide support from piping, ductwork, conduit, or other systems.

- D. Unless specifically indicated or approved by LP Consulting Engineers, Inc., do not provide support from suspended ceiling support system or ceiling grid.
- E. Unless specifically indicated or approved by LP Consulting Engineers, Inc., do not provide support from roof deck.
- F. Do not penetrate or otherwise notch or cut structural members without approval of Structural Engineer.
- G. Provide thermal insulated pipe supports complete with hangers and accessories. Install thermal insulated pipe supports during the installation of the piping system.
- H. Equipment Support and Attachment:
 - 1. Use metal fabricated supports or supports assembled from metal channel (strut) to support equipment as required.
 - 2. Use metal channel (strut) secured to studs to support equipment surface-mounted on hollow stud walls when wall strength is not sufficient to resist pull-out.
 - 3. Use metal channel (strut) to support surface-mounted equipment in wet or damp locations to provide space between equipment and mounting surface.
 - 4. Securely fasten floor-mounted equipment. Do not install equipment such that it relies on its own weight for support.
- I. Preset Concrete Inserts: Use manufacturer-provided closure strips to inhibit concrete seepage during concrete pour.
- J. Secure fasteners according to manufacturer's recommended torque settings.
- K. Remove temporary supports.

3.03 FIELD QUALITY CONTROL

- A. Inspect support and attachment components for damage and defects.
- B. Repair cuts and abrasions in galvanized finishes using zinc-rich paint recommended by manufacturer. Replace components that exhibit signs of corrosion.
- C. Correct deficiencies and replace damaged or defective support and attachment components.

END OF SECTION

SECTION 23 05 53

IDENTIFICATION FOR HVAC PIPING AND EQUIPMENT

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Nameplates.

1.02 RELATED REQUIREMENTS

- A. Refer to the General Conditions, Special Conditions and Division 1 General Requirements. The requirements of these sections apply to this section.

1.03 REFERENCE STANDARDS

- A. ASME A13.1 - Scheme for the Identification of Piping Systems; 2023.
- B. ASTM D709 - Standard Specification for Laminated Thermosetting Materials; 2017.

1.04 SUBMITTALS

- A. See Division 1 specifications for submittal procedures.
- B. List: Submit list of wording, symbols, letter size, and color coding for mechanical identification.
- C. Product Data: Provide manufacturers catalog literature for each product required.
- D. Manufacturer's Installation Instructions: Indicate special procedures, and installation.

PART 2 PRODUCTS

2.01 IDENTIFICATION APPLICATIONS

- A. Air Handling Units: Nameplates.
- B. Air Terminal Units: Nameplates.
- C. Control Panels: Nameplates.
- D. Heat Transfer Equipment: Nameplates.
- E. Major Control Components: Nameplates.
- F. Thermostats: Nameplates.

2.02 MANUFACTURERS

- A. Brady Corporation: www.bradycorp.com.
- B. Seton Identification Products: www.seton.com/aec.

2.03 NAMEPLATES

- A. Description: Laminated three-layer plastic with engraved letters.
 - 1. Letter Color: White.
 - 2. Letter Height: Air Handling Units, Control panels: 1 inch.

3. Letter Height: All others: 1/4 inch.
4. Background Color: Black.
5. Plastic: Comply with ASTM D709.

PART 3 EXECUTION

3.01 PREPARATION

- A. Degrease and clean surfaces to receive adhesive for identification materials.

3.02 INSTALLATION

- A. Install nameplates with corrosive-resistant mechanical fasteners, or adhesive. Apply with sufficient adhesive to ensure permanent adhesion and seal with clear lacquer.
- B. Identify fans and filter boxes with plastic nameplates. Small devices, such as in-line pumps, may be identified with tags.
- C. Identify air conditioning units, air handling units, heating and ventilating units, exhaust fans, pumps, heat transfer equipment, tanks, fire/smoke damper access doors, and water treatment devices with nameplates. Small devices, such as terminal units, in-line pumps, may be identified with tags.
- D. Identify control panels and major control components outside panels with plastic nameplates.
- E. Identify thermostats/sensors relating to fan unit and/or zone unit with nameplates.

END OF SECTION

SECTION 23 05 93

TESTING, ADJUSTING, AND BALANCING FOR HVAC

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Testing, adjustment, and balancing of air systems.

1.02 RELATED REQUIREMENTS

- A. Refer to the General Conditions, Special Conditions and Division 1 General Requirements. The requirements of these sections apply to this section.

1.03 REFERENCE STANDARDS

- A. AABC (NSTSB) - AABC National Standards for Total System Balance, 7th Edition; 2016.
- B. ASHRAE Std 111 - Measurement, Testing, Adjusting, and Balancing of Building HVAC Systems; 2008, with Errata (2019).
- C. NEBB (TAB) - Procedural Standards for Testing Adjusting and Balancing of Environmental Systems; 2015, with Errata (2017).
- D. SMACNA (TAB) - HVAC Systems Testing, Adjusting and Balancing; 2002.

1.04 SUBMITTALS

- A. See Division 1 specifications for submittal procedures.
- B. TAB Plan: Submit a written plan indicating the testing, adjusting, and balancing standard to be followed and the specific approach for each system and component and include controls contractor to assist in testing, adjusting, and balancing procedures. Submit plan for each phase.
 - 1. Submit to LP Consulting Engineers, Inc..
 - 2. Submit to the Commissioning Authority.
 - 3. Submit four weeks prior to starting the testing, adjusting, and balancing work.
 - 4. Include certification that the plan developer has reviewed Contract Documents, the equipment and systems, and the control system with the LP Consulting Engineers, Inc. and other installers to sufficiently understand the design intent for each system.
 - 5. Include at least the following in the plan:
 - a. List of all air flow, water flow, sound level, system capacity and efficiency measurements to be performed and a description of specific test procedures, parameters, formulas to be used.
 - b. List of all air flow measurements to be performed and a description of specific test procedures, parameters, formulas to be used.
 - c. Completed planned test sheets listing each piece of equipment to be tested, adjusted and balanced with the data cells to be gathered for each.
 - d. Single-line drawings with system test locations.

- e. Identification and types of measurement instruments to be used and their most recent calibration date.
 - f. Detailed step-by-step procedures for TAB work for each system and issue, including:
 - 1) SA, RA, EA, OA, for each AHU.
 - 2) Economizer proportioning and vfd speed adjustments.
 - 3) Rechecking.
 - g. Confirmation of understanding of the outside air ventilation criteria under all conditions.
 - h. Method of verifying and setting minimum outside air flow rate will be verified and set and for what level (total building, zone, etc.).
 - i. Method of checking building static and exhaust fan and/or relief damper capacity.
 - j. Procedures for field technician logs of discrepancies, deficient or uncompleted work by others, contract interpretation requests and lists of completed tests (scope and frequency).
- C. Final Report: Indicate deficiencies in systems that would prevent proper testing, adjusting, and balancing of systems and equipment to achieve specified performance.
- 1. Submit to LP Consulting Engineers, Inc. within 2 days after completion of testing, adjusting, and balancing.
 - 2. Include actual instrument list, with manufacturer name, serial number, and date of calibration.
 - 3. Form of Test Reports: Where the TAB standard being followed recommends a report format use that; otherwise, follow ASHRAE Std 111.
 - 4. Units of Measure: Report data in I-P (inch-pound) units only.
 - 5. Test Reports: Indicate data on AABC MN-1 forms, forms prepared following ASHRAE Std 111, or NEBB forms.
 - 6. Include the following on the title page of each report:
 - a. Name of Testing, Adjusting, and Balancing Agency.
 - b. Address of Testing, Adjusting, and Balancing Agency.
 - c. Telephone number of Testing, Adjusting, and Balancing Agency.
 - d. Project name.
 - e. Project location.
 - f. Project Engineer.
 - g. Project altitude.
 - h. Report date.
- D. Test and balance shall be performed by an independent test and balance agency.
- E. Perform total system balance in accordance with AABC MN-1, ASHRAE Std 111, or NEBB Procedural Standards for Testing, Balancing and Adjusting of Environmental Systems.
- F. TAB Agency Qualifications: Company specializing in the testing, adjusting, and balancing of systems specified in this Section with minimum three years documented experience certified by AABC or NEBB.

- G. Perform Work under supervision of AABC Certified Test and Balance Engineer or NEBB Certified Testing, Balancing and Adjusting Supervisor experienced in performance of this Work and licensed at the .

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION

3.01 GENERAL REQUIREMENTS

- A. Perform total system balance in accordance with one of the following:
 - 1. AABC (NSTSB), AABC National Standards for Total System Balance.
 - 2. ASHRAE Std 111, Practices for Measurement, Testing, Adjusting and Balancing of Building Heating, Ventilation, Air-Conditioning, and Refrigeration Systems.
 - 3. SMACNA (TAB).
- B. Where HVAC systems and/or components interface with life safety systems, including fire and smoke detection, alarm, and control, coordinate scheduling and testing and inspection procedures with the authorities having jurisdiction.
- C. TAB Agency Qualifications:
 - 1. Company specializing in the testing, adjusting, and balancing of systems specified in this section.
 - 2. Having minimum of three years documented experience.
 - 3. Certified by one of the following:
 - a. AABC, Associated Air Balance Council: www.aabc.com/#sle; upon completion submit AABC National Performance Guaranty.
 - b. TABB, The Testing, Adjusting, and Balancing Bureau of National Energy Management Institute: www.tabbcertified.org/#sle.
- D. TAB Supervisor and Technician Qualifications: Certified by same organization as TAB agency.

3.02 TESTING, ADJUSTING, AND BALANCING AGENCIES

- A. RS Analysis Inc.; www.rsanalysis.com; (888-330-1935).
- B. Mesa 3; www.mesa3.com; (408-928-3000).
- C. Raglen System Balance; www.raglensystembalance.com; (775-747-0100).
- D. National Air Balance Company Inc.; www.nabco.biz; (510-623-7000).

3.03 EXAMINATION

- A. Verify that systems are complete and operable before commencing work. Ensure the following conditions:
 - 1. Systems are started and operating in a safe and normal condition.
 - 2. Temperature control systems are installed complete and operable.
 - 3. Final filters are clean and in place. If required, install temporary media in addition to final filters.
 - 4. Duct systems are clean of debris.

5. Fans are rotating correctly.
 6. Fire and volume dampers are in place and open.
 7. Air coil fins are cleaned and combed.
 8. Access doors are closed and duct end caps are in place.
 9. Air outlets are installed and connected.
 10. Hydronic systems are flushed, filled, and vented.
 11. Pumps are rotating correctly.
 12. Proper strainer baskets are clean and in place.
 13. Service and balance valves are open.
- B. Contractor to inspect ductwork and piping systems at 60% and 90% completion to verify systems are ready for testing and balancing.
- C. Submit field reports. Report defects and deficiencies that will or could prevent proper system balance.
- D. Beginning of work means acceptance of existing conditions.

3.04 PREPARATION

- A. Provide instruments required for testing, adjusting, and balancing operations. Make instruments available to LP Consulting Engineers, Inc. to facilitate spot checks during testing.
- B. Provide additional balancing devices as required.

3.05 ADJUSTMENT TOLERANCES

- A. Air Handling Systems: Adjust total airflow(s) to within plus 10 percent and minus 5 percent of design.
- B. Air Outlets and Inlets: Adjust outlets and inlets in space to within plus 10 percent and minus 5 percent of design.
- C. Hydronic Systems: Adjust to within plus 10 percent and minus 5 percent of design.

3.06 RECORDING AND ADJUSTING

- A. Field Logs: Maintain written logs including:
1. Running log of events and issues.
 2. Discrepancies, deficient or uncompleted work by others.
 3. Contract interpretation requests.
 4. Lists of completed tests.
- B. Ensure recorded data represents actual measured or observed conditions.
- C. Permanently mark settings of valves, dampers, and other adjustment devices allowing settings to be restored. Set and lock memory stops.
- D. After adjustment, take measurements to verify balance has not been disrupted or that such disruption has been rectified.
- E. Leave systems in proper working order, replacing belt guards, closing access doors, closing doors to electrical switch boxes, and restoring thermostats to specified settings.

- F. At final inspection, recheck ~~random selections of data recorded in report.~~ Recheck points or areas as selected and witnessed by Owner.

3.07 AIR SYSTEM PROCEDURE

- A. Adjust air handling and distribution systems to provide required or design supply, return, and exhaust air quantities at site altitude.
- B. Make air quantity measurements in ducts by Pitot tube traverse of entire cross sectional area of duct.
- C. Measure air quantities at air inlets and outlets.
- D. Vary total system air quantities by adjustment of fan speeds. Provide drive changes required. Vary branch air quantities by damper regulation.
- E. Provide system schematic with required and actual air quantities recorded at each outlet or inlet.
- F. Adjust outside air automatic dampers, outside air, return air, and exhaust dampers for design conditions.
- G. Where modulating dampers are provided, take measurements and balance at extreme conditions. Balance variable volume systems at maximum air flow rate, full cooling, and at minimum air flow rate, full heating.

3.08 TITLE 24 TESTING

- A. Complete applicable Title 24 Acceptance Testing as delineated in contract drawings.

3.09 SCOPE

- A. Test, adjust, and balance the following:
 - 1. Air Handling Units.
 - 2. Fans.
 - 3. Air Filters.
 - 4. Air Inlets and Outlets.

3.10 MINIMUM DATA TO BE REPORTED

- A. Electric Motors:
 - 1. Manufacturer.
 - 2. Model/Frame.
 - 3. HP/BHP.
 - 4. Phase, voltage, amperage; nameplate, actual, no load.
 - 5. RPM.
 - 6. Service factor.
 - 7. Starter size, rating, heater elements.
 - 8. Sheave Make/Size/Bore.
- B. Cooling Coils:
 - 1. Location.
 - 2. Service.
 - 3. Manufacturer.

4. Air flow, design and actual.
 5. Entering air DB temperature, design and actual.
 6. Entering air WB temperature, design and actual.
 7. Leaving air DB temperature, design and actual.
 8. Leaving air WB temperature, design and actual.
 9. Saturated suction temperature, design and actual.
 10. Air pressure drop, design and actual.
- C. Air Moving Equipment:
1. Location.
 2. Manufacturer.
 3. Model number.
 4. Serial number.
 5. Arrangement/Class/Discharge.
 6. Air flow, specified and actual.
 7. Return air flow, specified and actual.
 8. Outside air flow, specified and actual.
 9. Total static pressure (total external), specified and actual.
 10. Inlet pressure.
 11. Discharge pressure.
 12. Sheave Make/Size/Bore.
 13. Number of Belts/Make/Size.
 14. Fan RPM.
- D. Return Air/Outside Air/Exhaust Air:
1. Identification/location.
 2. Design air flow (determined by initial test)
 3. Actual air flow.
 4. Design return air flow (determined by initial test)
 5. Actual return air flow.
 6. Design outside air flow (determined by initial test)
 7. Actual outside air flow.
 8. Return air temperature.
 9. Outside air temperature.
 10. Actual mixed air temperature.
- E. Duct Traverses:
1. System zone/branch.
 2. Duct size.
 3. Area.
 4. Design velocity.
 5. Design air flow.
 6. Test velocity.
 7. Test air flow.
 8. Duct static pressure.
 9. Air temperature.

10. Air correction factor.

END OF SECTION

SECTION 23 07 13 DUCT INSULATION

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Duct insulation.
- B. Duct liner.
- C. Jacketing and accessories.

1.02 RELATED REQUIREMENTS

- A. Refer to the General Conditions, Special Conditions and Division 1 General Requirements. The requirements of these sections apply to this section.
- B. Section 23 31 00 - HVAC Ducts and Casings: Ductwork.

1.03 REFERENCE STANDARDS

- A. ASTM B209/B209M - Standard Specification for Aluminum and Aluminum-Alloy Sheet and Plate; 2021a.
- B. ASTM B209 - Standard Specification for Aluminum and Aluminum-Alloy Sheet and Plate; 2014.
- C. ASTM B209M - Standard Specification for Aluminum and Aluminum-Alloy Sheet and Plate (Metric); 2014.
- D. ASTM C518 - Standard Test Method for Steady-State Thermal Transmission Properties by Means of the Heat Flow Meter Apparatus; 2021.
- E. ASTM C553 - Standard Specification for Mineral Fiber Blanket Thermal Insulation for Commercial and Industrial Applications; 2013 (Reapproved 2019).
- F. ASTM C612 - Standard Specification for Mineral Fiber Block and Board Thermal Insulation; 2014 (Reapproved 2019).
- G. ASTM C916 - Standard Specification for Adhesives for Duct Thermal Insulation; 2020.
- H. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2023d.
- I. ASTM E96/E96M - Standard Test Methods for Gravimetric Determination of Water Vapor Transmission Rate of Materials; 2022a, with Editorial Revision (2023).
- J. SMACNA (DCS) - HVAC Duct Construction Standards Metal and Flexible; 2021.
- K. UL 723 - Standard for Test for Surface Burning Characteristics of Building Materials; Current Edition, Including All Revisions.

1.04 RELATED SECTIONS

- A. The Drawings and General Provisions of the Contract, including the General Conditions, Special Conditions and Division 1 General Requirements apply to this section.

- B. The Contract Agreement, Bidding Documents and all Addenda issued prior to Contract Agreement execution form a part of these specifications and apply to all Contracts or Subcontracts relating to the mechanical systems.
- C. The requirements of this Section apply to all Work of Division 23.

1.05 SUBMITTALS

- A. See Division 1 specifications for submittal procedures.
- B. Product Data: Provide product description, thermal characteristics, list of materials and thickness for each service, and locations.
- C. Manufacturer's Instructions: Indicate installation procedures necessary to ensure acceptable workmanship and that installation standards will be achieved.

1.06 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing products of the type specified in this section with not less than three years of documented experience.
- B. Applicator Qualifications: Company specializing in performing the type of work specified in this section, with minimum three years of experience and approved by manufacturer.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Accept materials on site in original factory packaging, labelled with manufacturer's identification, including product density and thickness.
- B. Protect insulation from weather and construction traffic, dirt, water, chemical, and mechanical damage, by storing in original wrapping.

1.08 FIELD CONDITIONS

- A. Maintain ambient temperatures and conditions required by manufacturers of adhesives, mastics, and insulation cements.
- B. Maintain temperature during and after installation for minimum period of 24 hours.

PART 2 PRODUCTS

2.01 REGULATORY REQUIREMENTS

- A. Surface Burning Characteristics: Flame spread index/Smoke developed index of 25/50, maximum, when tested in accordance with ASTM E84, UL 723, ASTM E84, or UL 723.

2.02 GLASS FIBER, FLEXIBLE

- A. Manufacturer:
 - 1. Owens-Corning Fiberglas; Model [All Service Faced Duct Wrap].
 - 2. Knauf Insulation: www.knaufinsulation.com.
 - 3. Johns Manville: www.jm.com/#sle.

- B. Insulation: ASTM C553; flexible, noncombustible blanket.
 - 1. K value: 0.36 at 75 degrees F, when tested in accordance with ASTM C518.
 - 2. Duct Application: 2" thick, 3/4 pound density.
 - 3. Maximum Water Vapor Absorption: 5.0 percent by weight.
- C. Vapor Barrier Jacket:
 - 1. Kraft paper with glass fiber yarn and bonded to aluminized film.
 - 2. Moisture Vapor Permeability: 0.02 perm inch, when tested in accordance with ASTM E96/E96M.
 - 3. Secure with pressure-sensitive tape.
- D. Vapor Barrier Tape:
 - 1. Kraft paper reinforced with glass fiber yarn and bonded to aluminized film, with pressure-sensitive rubber-based adhesive.

2.03 GLASS FIBER, RIGID

- A. Manufacturer:
 - 1. CertainTeed Corporation: www.certainteed.com/#sle.
 - 2. Knauf Insulation: www.knaufinsulation.com.
 - 3. Johns Manville: www.jm.com/#sle.
 - 4. Owens Corning Corporation: www.ocbuildingspec.com/#sle.
- B. Insulation: ASTM C612; rigid, noncombustible blanket.
 - 1. K Value: 0.24 at 75 degrees F, when tested in accordance with ASTM C518.
 - 2. Maximum Service Temperature: 450 degrees F.
 - 3. Maximum Water Vapor Absorption: 5.0 percent.
 - 4. Density: 3.0 lb/cu ft.
- C. Vapor Barrier Jacket:
 - 1. Kraft paper with glass fiber yarn and bonded to aluminized film.
 - 2. Secure with pressure-sensitive tape.
- D. Vapor Barrier Tape:
 - 1. Kraft paper reinforced with glass fiber yarn and bonded to aluminized film, with pressure-sensitive rubber-based adhesive.

2.04 JACKETING AND ACCESSORIES

- A. Aluminum Jacket:
 - 1. Comply with ASTM B209/B209M, Temper H14, minimum thickness of 0.016 inch with factory-applied polyethylene and kraft paper moisture barrier on the inside surface.
 - 2. Thickness: 0.020 inch sheet.
 - 3. Finish: Embossed.
 - 4. Joining: Longitudinal slip joints and 2 inch laps.
 - 5. Fittings: 0.016 inch thick die-shaped fitting covers with factory-attached protective liner.
 - 6. Metal Jacket Bands: 3/8 inch wide; 0.015 inch thick aluminum.

2.05 DUCT LINER

- A. Manufacturers:
 - 1. CertainTeed Corporation: www.certainteed.com/#sle.
 - 2. Knauf Insulation: www.knaufinsulation.com.
 - 3. Johns Manville: www.jm.com/#sle.
 - 4. Owens Corning Corp: www.owenscorning.com.
- B. Insulation: Incombustible glass fiber complying with ASTM C 1071; flexible blanket; impregnated surface and edges coated with acrylic polymer shown to be fungus and bacteria resistant by testing to ASTM G 21.
 - 1. Apparent Thermal Conductivity: Maximum of 0.31 at 75 degrees F.
 - 2. Duct Application (Indoors): 1" thick, 1-1/2 pound density.
 - 3. Duct Application (Outdoors): 2" thick, 1-1/2 pound density.
 - 4. Service Temperature: Up to 250 degrees F.
 - 5. Acoustical Requirements
 - a. Sound absorption coefficients of the material (with and/or without erosion resistive coating) shall be greater than or equal to the coefficients listed in the specifications when tested under the specified conditions.
 - b. All acoustical measurements shall be performed in accordance with ANSI/ASTM C423 and shall be performed in the ASTM E795 mounting configuration as indicated.
 - c. An independent acoustical laboratory shall perform the tests.
 - d. The sound absorption coefficient provided by the material shall meet or exceed the following values in each octave band listed:
 - 6. Thickness, 1 inch Hz/Coefficient: 125/.05, 250/.20, 500/.65, 1k/.90, 2k/.95, 4k/.95.
- C. Liner Fasteners: Galvanized steel, welded with integral head.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Test ductwork for design pressure prior to applying insulation materials.
- B. Verify that surfaces are clean, foreign material removed, and dry.

3.02 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Insulated Ducts Conveying Air Below Ambient Temperature:
 - 1. Provide insulation with vapor barrier jackets.
 - 2. Finish with tape and vapor barrier jacket.
 - 3. Continue insulation through walls, sleeves, hangers, and other duct penetrations.
 - 4. Insulate entire system, including fittings, joints, flanges, fire dampers, flexible connections, and expansion joints.
- C. Insulated Ducts Conveying Air Above Ambient Temperature:
 - 1. Provide with or with standard vapor barrier jacket.

2. Finish with tape and vapor barrier jacket.
 3. Continue insulation through walls, sleeves, hangers, and other duct penetrations.
 4. Insulate entire system including fittings, joints, flanges, fire dampers, flexible connections, and expansion joints.
- D. Duct and Plenum Liner Application:
1. Adhere insulation with adhesive for 100 percent coverage.
 2. Secure insulation with mechanical liner fasteners. Liner shall start within 3 inches of the upstream transverse edges of the liner and 3 inches from the longitudinal joints, and shall be spaced at a maximum of 12 inches on center around the perimeter of the duct (except that they shall be a maximum of 12 inches from a corner break). Elsewhere, they shall be a maximum of 18 inches on center, except that they shall not be placed more than 6 inches from a longitudinal joint of the liner or 12 inches from a corner break. Refer to SMACNA HVAC Duct Construction Standards - Metal and Flexible for spacing.
 3. Seal and smooth joints. Seal and coat transverse and longitudinal joints.
 4. Seal liner surface penetrations with adhesive.
 5. Duct dimensions indicated are inside dimensions and do not include consideration for liner thickness.

3.03 SCHEDULES

- A. Supply and Return Ducts: Insulate all unlined supply ducts, except ducts exposed in conditioned spaces.
- B. Exterior Applications:
1. Supply and Return Ducts exposed to outdoors to be internally lined except ductwork conveying direct evaporatively cooled air.
 2. Supply and Return ductwork exposed to outdoors for direct evaporatively cooling systems to be externally insulated. Cover insulation with with calked aluminum jacket with seams located on bottom side of horizontal duct section.
- C. Supply and Return Ducts: Install lining on ductwork and plenums where shown or noted on drawings.

END OF SECTION

SECTION 23 31 00 HVAC DUCTS AND CASINGS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Metal ducts.
- B. Flexible ducts.
- C. Air plenums and casings.
- D. Ducts for kitchen exhaust applications.

1.02 RELATED REQUIREMENTS

- A. Refer to the General Conditions, Special Conditions and Division 1 General Requirements. The requirements of these sections apply to this section.
- B. Section 230713 - Duct Insulation.
- C. Section 23 33 00 - Air Duct Accessories.

1.03 REFERENCE STANDARDS

- A. ASHRAE Std 126 - Method of Testing HVAC Air Ducts; 2020.
- B. ASTM A653/A653M - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process; 2022.
- C. ASTM A666 - Standard Specification for Annealed or Cold-Worked Austenitic Stainless Steel Sheet, Strip, Plate, and Flat Bar; 2023.
- D. ASTM B209/B209M - Standard Specification for Aluminum and Aluminum-Alloy Sheet and Plate; 2021a.
- E. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2023d.
- F. ASTM E814 - Standard Test Method for Fire Tests of Penetration Firestop Systems; 2023a.
- G. ASTM E2336 - Standard Test Methods for Fire Resistive Grease Duct Enclosure Systems; 2020.
- H. NFPA 90A - Standard for the Installation of Air-Conditioning and Ventilating Systems; 2021.
- I. NFPA 90B - Standard for the Installation of Warm Air Heating and Air-Conditioning Systems; 2021.
- J. NFPA 91 - Standard for Exhaust Systems for Air Conveying of Vapors, Gases, Mists, and Particulate Solids; 2020.
- K. NFPA 96 - Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations; 2021.
- L. SMACNA (DCS) - HVAC Duct Construction Standards Metal and Flexible; 2021.

- M. SMACNA (KVS) - Kitchen Ventilation Systems and Food Service Equipment Fabrication and Installation Guidelines; 2001.
- N. UL 181 - Standard for Factory-Made Air Ducts and Air Connectors; Current Edition, Including All Revisions.
- O. UL 723 - Standard for Test for Surface Burning Characteristics of Building Materials; Current Edition, Including All Revisions.
- P. UL 1978 - Grease Ducts; Current Edition, Including All Revisions.
- Q. UL 2221 - Tests of Fire Resistive Grease Duct Enclosure Assemblies; Current Edition, Including All Revisions.

1.04 RELATED SECTIONS

- A. The Drawings and General Provisions of the Contract, including the General Conditions, Special Conditions and Division 1 General Requirements apply to this section.
- B. The Contract Agreement, Bidding Documents and all Addenda issued prior to Contract Agreement execution form a part of these specifications and apply to all Contracts or Subcontracts relating to the mechanical systems.
- C. The requirements of this Section apply to all Work of Division 23.

1.05 SUBMITTALS

- A. See Division 1 specifications for submittal procedures.
- B. Product Data: Provide data for duct materials.
- C. Shop Drawings: Indicate duct fittings, particulars such as gages, sizes, welds, and configuration prior to start of work for all ductwork systems. Provide 1/4"=1'-0" ductwork layout plans showing duct routing, offsets, fittings, duct accessories, fire/smoke dampers, hydronic piping, seismic bracing, etc. Shop drawings shall be fully coordinated with all other trades, including the building structure, finishes, fire sprinkler piping, plumbing piping, hydronic piping and electrical systems.
- D. Project Record Documents: Record actual locations of ducts and duct fittings. Record changes in fitting location and type. Show additional fittings used.

1.06 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing the type of products specified in this section, with minimum three years of documented experience, and approved by manufacturer.
- B. Installer Qualifications: Company specializing in performing the type of work specified in this section, with minimum three years of documented experience.

1.07 FIELD CONDITIONS

- A. Do not install duct sealants when temperatures are less than those recommended by sealant manufacturers.

- B. Maintain temperatures within acceptable range during and after installation of duct sealants.

PART 2 PRODUCTS

2.01 GENERAL REQUIREMENTS

- A. Provide UL Class 1 ductwork, fittings, hangers, supports, and appurtenances in accordance with NFPA 90A, NFPA 90B, and SMACNA (DCS) guidelines unless stated otherwise.
- B. Ductwork to be galvanized steel unless otherwise indicated.
- C. Duct Sealing and Leakage in accordance with Static Pressure Class:
 - 1. Duct Pressure Class and Material for Common Mechanical Ventilation Applications:
 - a. Supply Air: 2 in-wc pressure class, galvanized steel.
 - b. Outside Air Intake: 1/2 in-wc pressure class, galvanized steel.
 - c. Return and Relief Air: 1 in-wc 2 in-wc pressure class, galvanized steel.
 - d. General Exhaust Air: 1/2 in-wc pressure class, galvanized steel.
 - 2. Low Pressure Service: Up to 2 in-wc:
 - a. Seal: Class C, apply to seal off transverse joints.
 - 3. Low Pressure Service: From 2 in-wc to 3 in-wc:
 - a. Seal: Class B, apply sealing of transverse joints and longitudinal seams.
 - 4. Medium and High Pressure Service: Above 3 in-wc:
 - a. Seal: Class A, apply sealing of transverse joints, longitudinal seams, and duct wall penetrations.
- D. Duct Fabrication Requirements:
 - 1. Duct and Fitting Fabrication and Support: SMACNA (DCS) including specifics for continuously welded round and oval duct fittings.
 - 2. Use reinforced and sealed sheet-metal materials at recommended gauges for indicated operating pressures or pressure class.
 - 3. Construct tees, bends, and elbows with radius of not less than 1-1/2 times width of duct on centerline. Where not possible and where rectangular elbows must be used, provide airfoil turning vanes of perforated metal with glass fiber insulation.
 - 4. Provide turning vanes of perforated metal with glass fiber insulation when acoustical lining is indicated.
 - 5. Increase duct sizes gradually, not exceeding 15 degrees divergence wherever possible; maximum 30 degrees divergence upstream of equipment and 45 degrees convergence downstream.
 - 6. Where ducts are connected to exterior wall louvers and duct outlet is smaller than louver frame, provide blank-out panels sealing louver area around duct. Use same material as duct, painted black on exterior side; seal to louver frame and duct.
 - 7. Exposed ductwork within occupied spaces shall be 20 gauge minimum.

2.02 METAL DUCTS

- A. Material Requirements:
 - 1. Galvanized Steel: Hot-dipped galvanized steel sheet, ASTM A653/A653M FS Type B, with G90/Z275 coating.
 - 2. Stainless Steel: ASTM A666, Type 304.
 - a. Application: Kitchen exhaust.
- B. Round Spiral Duct:
 - 1. Round spiral lock seam duct with galvanized steel outer wall.
 - 2. Manufacturers:
 - a. EHG, a DMI Company: www.ehgduct.com/#sle.
 - b. Elgen Manufacturing Company, Inc: www.elgenmfg.com/#sle.
 - c. Linx Industries, Inc, a DMI Company: www.li-hvac.com/#sle.
 - d. MKT Metal Manufacturing: www.mktduct.com/#sle.
- C. Connectors, Fittings, Sealants, and Miscellaneous:
 - 1. Fittings: Manufacture with solid inner wall of perforated galvanized steel.
 - 2. Transverse Duct Connection System: SMACNA "E" rated rigid class connection, interlocking angle and duct edge connection system with sealant, gasket, cleats, and corner clips in accordance with SMACNA (DCS).
 - a. Manufacturers:
 - 1) Carlisle HVAC Products: www.carlislehvac.com/#sle.
 - 2) Ductmate Industries, Inc, a DMI Company: www.ductmate.com/#sle.
 - 3) Elgen Manufacturing Company, Inc: www.elgenmfg.com/#sle.
 - 3. Joint Sealers and Sealants: Non-hardening, water resistant, mildew and mold resistant.
 - a. Type: Heavy mastic or liquid used alone or with tape, suitable for joint configuration and compatible with substrates, and recommended by manufacturer for pressure class of ducts.
 - b. VOC Content: Not more than 250 g/L, excluding water.
 - c. Sealants intended for use outdoors to include UV inhibitors.
 - d. Surface Burning Characteristics: Flame spread index of zero and smoke developed index of zero, when tested in accordance with ASTM E84.
 - e. Manufacturers:
 - 1) Carlisle HVAC Products; Hardcast Duct-Seal 321 Indoor/Outdoor Water Based Duct Sealant: www.carlislehvac.com/#sle.
 - 2) Design Polymeric; DP 1010 Water Based Smooth Duct Sealant, Premium Quality: www.designpoly.com/#sle.
 - 3) Ductmate Industries, Inc, a DMI Company: www.ductmate.com/#sle.
 - 4. Gasket Tape:
 - a. Provide butyl rubber gasket tape for a flexible seal between transfer duct connector (TDC), transverse duct flange (TDF), applied flange connections, and angle ring connections.
 - b. Manufacturers:
 - 1) Design Polymeric; DP 1040 100 Percent Solids, High Pressure/High-Velocity Butyl Gasket Tape: www.designpoly.com/#sle.

- 2) Elgen Manufacturing Company, Inc; 440 Butyl Gasket Tape: www.elgenmfg.com/#sle.

2.03 FLEXIBLE DUCTS

- A. Flexible Air Ducts:
1. UL 181, Class 1, multiple layers of aluminum laminate supported by helically wound spring steel wire.
 2. Insulation: Fiberglass insulation with polyethylene vapor barrier film.
 3. Pressure Rating: From 4 in-wc positive to 0.5 in-wc negative.
 4. Maximum Velocity: 4,000 fpm.
 5. Temperature Range: Minus 20 to 210 degrees F.
 6. Manufacturers:
 - a. JP Lamborn Co: www.jpflex.com/#sle.
 - b. Atco Rubber Products, Inc..

2.04 AIR PLENUMS AND CASINGS

- A. Fabricate in accordance with SMACNA (DCS) for indicated operating pressures indicated.
- B. Minimum Fabrication Requirements:
1. Fabricate acoustic plenum or casing with reinforcing turned inward.
 2. Provide 16-gauge, 0.059-inch sheet steel back facing and 22-gauge, 0.029-inch perforated sheet steel front facing with 3/32 inch diameter holes on 5/32 inch centers.
 3. Construct panels 1 inches thick, packed with 4.5 pcf minimum glass fiber insulation media, on inverted channel of 16-gauge, 0.059-inch sheet steel.
- C. Access Doors:
1. Install hinged access doors where indicated or required for access to equipment for cleaning and inspection.
 2. Reinforce door frames with steel angles tied to horizontal and vertical plenum supporting angles.

2.05 DUCTS FOR KITCHEN EXHAUST APPLICATIONS

- A. Provide ductwork, fittings, and appurtenances per NFPA 96, SMACNA (KVS), UL 1978, and UL 2221 requirements and guidelines.
- B. Class 1 duct for air with gas and grease particle exhaust at an air velocity of 1,500 to 2,500 fpm.
- C. Where ducts are not self-draining back to equipment, provide low-point drain pocket with the copper drain pipe to a sanitary sewer.
- D. Design, fabricate, and install liquidtight preventing exhaust leakage into building.
- E. Dishwasher Exhaust Duct:
1. Duct Size: 1 in-wc pressure class stainless steel.
 2. Fabricate using single wall, 16-gauge, 0.059-inch sheet steel with continuous external welded joints to form rectangular sections.

- F. Kitchen Hood and Grease Exhaust Duct:
 - 1. Fabricate in accordance with ductwork manufacturer's instructions, SMACNA (DCS), SMACNA (KVS), and NFPA 96.
 - 2. Round, Single-Wall, Premanufactured Grease Exhaust Duct:
 - a. UL Listed and labeled to UL 1978.
 - b. Construct of 20-gauge, 0.035-inch Type 304 stainless steel.
 - 3. Rectangular, Single-Wall, Premanufactured Grease Exhaust Duct:
 - a. UL Listed and labeled to UL 1978.
 - b. Construct of 16-gauge, 0.059-inch sheet steel using continuous external welded joints in rectangular sections.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install, support, and seal ducts in accordance with SMACNA (DCS).
- B. Install products following the manufacturer's instructions.
- C. Comply with safety standards NFPA 90A and NFPA 90B.
- D. During construction, provide temporary closures of metal or taped polyethylene on open ductwork to prevent construction dust from entering the ductwork system.
- E. Increase duct sizes gradually, not exceeding 15 degrees divergence wherever possible; maximum 30 degrees divergence upstream of equipment and 45 degrees convergence downstream.
- F. Ductwork exposed to view outdoors shall be primed and painted, color by architect.
- G. Flexible Ducts: Connect to metal ducts with adhesive plus sheet metal screws.
- H. Flexible Ducts: Maximum length of single runout to air inlet or outlet to be 5 feet per CMC.
- I. Duct sizes indicated are outside dimensions. For lined ducts, duct sizes must be increased to account for lining.
- J. Seal all standing seams and transverse joints in all sheetmetal ductwork with Hardcast DT tape, 4 inches wide, and Hardcast FTA-20 adhesive.
- K. Locate ducts with sufficient space around equipment to allow normal operating and maintenance activities.
- L. Use double nuts and lock washers on threaded rod supports.
- M. Connect diffusers boots to low pressure ducts directly or with 5 feet maximum length of flexible duct held in place with strap or clamp.
- N. Use stainless steel for ductwork exposed to view in Kitchen areas.
- O. Kitchen hood exhaust ductwork shall so be constructed and installed that grease cannot be pocketed in any portion thereof, and the system shall slope not less than 1/4 unit vertical in 12 units horizontal (2% slope) toward the hood or toward an approved grease reservoir.

FOR REFERENCE ONLY

- P. Kitchen hood exhaust ductwork shall be wrapped with a 2 hour fire resistive duct wrap designed for use specifically with kitchen grease ducts, installed in accordance with manufacturer's installation instructions.
- Q. Grease ductwork systems shall be leakage tested per CMC 510.5.3.1 and CMC 510.5.6. Perform light test: A light of no less than 100 watts is passed through the entire duct system, including the hood-to-duct connection. If any light shines through any portion of the ductwork in a darkened room, the hole must be found and welded so that the light is no longer visible.

END OF SECTION

SECTION 23 33 00 AIR DUCT ACCESSORIES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Air turning devices.
- B. Duct access doors.
- C. Duct test holes.
- D. Flexible duct connectors.
- E. Volume control dampers.
- F. Miscellaneous Products:
 - 1. Damper operators.

1.02 RELATED REQUIREMENTS

- A. Refer to the General Conditions, Special Conditions and Division 1 General Requirements. The requirements of these sections apply to this section.
- B. Section 23 31 00 - HVAC Ducts and Casings.

1.03 REFERENCE STANDARDS

- A. AMCA 500-D - Laboratory Methods of Testing Dampers for Rating; 2018.
- B. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2023d.
- C. NFPA 90A - Standard for the Installation of Air-Conditioning and Ventilating Systems; 2021.
- D. NFPA 96 - Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations; 2021.
- E. SMACNA (DCS) - HVAC Duct Construction Standards Metal and Flexible; 2021.
- F. UL 555S - Standard for Smoke Dampers; Current Edition, Including All Revisions.
- G. UL 1978 - Grease Ducts; Current Edition, Including All Revisions.

1.04 RELATED SECTIONS

- A. The Contract Agreement, Bidding Documents and all Addenda issued prior to Contract Agreement execution form a part of these specifications and apply to all Contracts or Subcontracts relating to the mechanical systems.
- B. The requirements of this Section apply to all Work of Division 23.
- C. Section 013300 - Submittals.

1.05 SUBMITTALS

- A. See Division 1 specifications for submittal procedures.

- B. Product Data: Provide for shop fabricated assemblies including volume control dampers, duct access doors, duct test holes, and hardware used. Include electrical characteristics and connection requirements.

1.06 PROJECT RECORD DOCUMENTS

- A. Record actual locations of access doors and test holes.

1.07 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing the type of products specified in this section, with minimum three years of documented experience.
- B. Products Requiring Electrical Connection: Listed and classified by Underwriters Laboratories Inc. as suitable for the purpose specified and indicated.

1.08 DELIVERY, STORAGE, AND HANDLING

- A. Protect dampers from damage to operating linkages and blades.

PART 2 PRODUCTS

2.01 AIR TURNING DEVICES

- A. Manufacturers:
 - 1. ProRail, Ductmate Industries, Inc.
 - 2. Duro Dyne Corp.
- B. Manufactured turning vanes with 2" single thickness curved blades set at 1-1/2" on-center mounted in 2" vane rails, self-aligning, hot dipped galvanized steel.
- C. Turning vanes, vane rails and mounting shall be constructed and installed in accordance with the SMACNA "HVAC Duct Construction Standards".

2.02 DUCT ACCESS DOORS

- A. Manufacturers:
 - 1. Ductmate Industries, Inc, a DMI Company: www.ductmate.com/#sle.
 - 2. Ruskin Company: www.ruskin.com/#sle.
 - 3. or equal.
- B. Fabrication: Rigid and close fitting of galvanized steel with sealing gaskets and quick-fastening locking devices. For insulated ducts, install minimum 1-inch thick insulation with sheet metal cover.
 - 1. High Temperature Duct Access Doors:
 - a. Comply with NFPA 96.
 - b. Comply with UL 1978.
- C. Access doors with sheet metal screw fasteners are not acceptable.

2.03 DUCT TEST HOLES

- A. Temporary Test Holes: Cut or drill in ducts as required. Cap with neat patches, neoprene plugs, threaded plugs, or threaded or twist-on metal caps.

2.04 FLEXIBLE DUCT CONNECTORS

- A. Manufacturers:
 - 1. Carlisle HVAC Products: www.carlislehvac.com/#sle.
 - 2. Ductmate Industries, Inc, a DMI Company: www.ductmate.com/#sle.
- B. Fabricate in accordance with SMACNA (DCS) and as indicated.
- C. Flexible Duct Connections (Indoors): Fabric crimped into metal edging strip.
 - 1. Fabric: UL listed fire-retardant neoprene coated woven glass fiber fabric to NFPA 90A, minimum density 30 oz/sq yd.
 - a. Net Fabric Width: Approximately 2 inches wide.
 - 2. Metal: 3 inches wide, 24 gage, 0.0239 inch thick galvanized steel.
- D. Flexible Duct Connections (Outdoors): Fabric crimped into metal edging strip.
 - 1. Fabric: Ventfabrics Ventlon UL listed fire-retardant duPont's Hypalon coated woven glass fiber fabric to NFPA 90A, minimum density 26 oz per sq yd, sunlight, ozone and weather resistant.
 - a. Net Fabric Width: Approximately 3 inches wide.
 - 2. Metal: 3 inches wide, 24 gage thick galvanized steel.

2.05 VOLUME CONTROL DAMPERS

- A. Manufacturers:
 - 1. Nailor Industries, Inc: www.nailor.com/#sle.
 - 2. Ruskin Company: www.ruskin.com/#sle.
 - 3. United Enertech: www.unitedenertech.com/#sle.
- B. Fabricate in accordance with SMACNA (DCS) and as indicated.
- C. Single Blade Dampers for Round Ductwork and Rectangular Ductwork up to 10 inches in Height: 18 gauge steel minimum.
- D. Multi-Blade Damper for Rectangular Ductwork: Fabricate of opposed blade pattern with maximum blade sizes 8 x 72 inch. Assemble center and edge crimped blades in prime coated or galvanized channel frame with suitable hardware; Model CD35 Manufactured by Ruskin. Provide Ruskin Model CD50 for installation in medium pressure ductwork and/or ducts with velocities exceeding 1500 FPM.
- E. End Bearings: Except in round ducts 12 inches and smaller, provide end bearings, Ventlok Model 607. On multiple blade dampers, provide oil impregnated nylon or sintered bronze bearings.
- F. Quadrants:
 - 1. Provide locking, indicating quadrant regulators on single and multi-blade dampers.
 - 2. On insulated ducts mount quadrant regulators on stand-off mounting brackets, bases, or adapters.
 - 3. Where rod lengths exceed 30 inches provide regulator at both ends.

2.06 MISCELLANEOUS PRODUCTS

- A. Remote Balancing Damper Operator: Cable operated remote damper controller.
 - 1. Manufacturers:
 - a. Young Regulator Co.; www.youngregulator.com
 - 2. "Bowden" damper regulator with mounting bracket, hub and cable coupling.
 - 3. "Bowden" stainless steel operating cable and control wrench. Cable to be 50 foot length standard.
 - 4. Recessed control box with control shaft, cable coupling and cover plate.
 - 5. Provide options and accessories as needed for balancing damper.

PART 3 EXECUTION

3.01 PREPARATION

- A. Verify that electric power is available and of the correct characteristics.

3.02 INSTALLATION

- A. Install accessories in accordance with manufacturer's instructions, NFPA 90A, and follow SMACNA (DCS). See Section 23 31 00 for duct construction and pressure class.
- B. Provide duct access doors for inspection and cleaning before and after filters, coils, fans, automatic dampers, at fire dampers, combination fire and smoke dampers, and elsewhere as indicated. Provide for cleaning kitchen exhaust ducts in accordance with NFPA 96 Provide minimum 14 by 14 inch size access door for hand and shoulder access, or as indicated on drawings.
- C. For concealed balancing dampers only where damper is inaccessible, provide Young Regulator "Bowden" cable operated damper controller.
- D. Provide duct test holes where indicated and required for testing and balancing purposes.
- E. Provide balancing dampers at points on supply, return, outside air and exhaust systems where branches are taken from larger ducts as required for air balancing. Install minimum 2 duct widths from duct take-off.
- F. Provide balancing dampers on duct take-off to diffusers, grilles, and registers, regardless of whether dampers are specified as part of the diffuser, grille, or register assembly.

END OF SECTION

SECTION 23 34 23 HVAC POWER VENTILATORS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Roof exhausters.
- B. Utility vent blowers.

1.02 RELATED REQUIREMENTS

- A. Section 23 33 00 - Air Duct Accessories: Backdraft dampers.

1.03 REFERENCE STANDARDS

- A. AMCA (DIR) - (Directory of) Products Licensed Under AMCA International Certified Ratings Program; 2015.
- B. AMCA 99 - Standards Handbook; 2016.
- C. AMCA 204 - Balance Quality and Vibration Levels for Fans; 2020.
- D. AMCA 210 - Laboratory Methods of Testing Fans for Certified Aerodynamic Performance Rating; 2016.
- E. AMCA 211 - Certified Ratings Program Product Rating Manual for Fan Air Performance; 2022.
- F. AMCA 260 - Laboratory Methods of Testing Induced Flow Fans for Rating; 2020.
- G. AMCA 300 - Reverberant Room Method for Sound Testing of Fans; 2014.
- H. AMCA 301 - Methods for Calculating Fan Sound Ratings from Laboratory Test Data; 2022.
- I. AMCA 311 - Certified Ratings Program Product Rating Manual for Fan Sound Performance; 2016.
- J. ANSI Z9.5 - Laboratory Ventilation; 2022.
- K. NFPA 91 - Standard for Exhaust Systems for Air Conveying of Vapors, Gases, Mists, and Particulate Solids; 2020.
- L. NFPA 96 - Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations; 2021.
- M. UL 705 - Power Ventilators; Current Edition, Including All Revisions.
- N. UL 762 - Outline of Investigation for Power Roof Ventilators for Restaurant Exhaust Appliances; Current Edition, Including All Revisions.

1.04 RELATED SECTIONS

- A. The Contract Agreement, Bidding Documents and all Addenda issued prior to Contract Agreement execution form a part of these specifications and apply to all Contracts or Subcontracts relating to the mechanical systems.

- B. The requirements of this Section apply to all Work of Division 23.
- C. Section 013300 - Submittals.

1.05 SUBMITTALS

- A. See Division 1 specifications for submittal procedures.
- B. Product Data: Provide data on fans and accessories, including fan curves with specified operating point plotted, power, rpm, sound power levels at rated capacity, and electrical characteristics and connection requirements.
- C. Manufacturer's Instructions: Indicate installation instructions.
- D. Maintenance Data: Include instructions for lubrication, motor and drive replacement, spare parts list, and wiring diagrams.

1.06 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing the type of products specified in this section, with minimum three years of documented experience.
- B. Products Requiring Electrical Connection: Listed and classified by Underwriters Laboratories Inc. as suitable for the purpose specified and indicated.

1.07 DELIVERY, STORAGE, AND PROTECTION

- A. Protect units from physical damage by storing indoors or off site until roof mounting curbs or other mountings are in place, ready for immediate installation of units.

1.08 WARRANTY

- A. See Section 01700 - Contract Closeout, for additional warranty requirements.
- B. Provide a full parts warranty for one year from start-up or 18 months from shipment, whichever occurs first.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Greenheck Fan Corporation: www.greenheck.com/#sle.
- B. Loren Cook Company: www.lorencook.com/#sle.

2.02 POWER VENTILATORS - GENERAL

- A. Static and Dynamically Balanced: Comply with AMCA 204.
- B. Performance Ratings: Comply with AMCA 210, bearing certified rating seal.
- C. Sound Ratings: Comply with AMCA 301, tested to AMCA 300, bearing certified sound ratings seal.
- D. Fabrication: Comply with AMCA 99.
- E. UL Compliance: UL 705, listed, labeled, designed, manufactured, and tested.

- F. Electrical Components: Listed and classified by Underwriters Laboratories Inc. as suitable for the purpose specified and indicated.
- G. Kitchen Hood Exhaust Fans: Comply with requirements of NFPA 96 and UL 762.

2.03 ROOF EXHAUSTERS

- A. Product Requirements:
 - 1. Performance Ratings: Conform to AMCA 210 and bearing the AMCA Certified Rating Seal.
 - 2. Sound Ratings: AMCA 301, tested to AMCA 300, and bearing AMCA Certified Sound Rating Seal.
 - 3. Fabrication: Conform to AMCA 99.
 - 4. UL Compliance: UL listed and labeled, designed, manufactured, and tested in accordance with UL 705.
- B. Fan Unit: V-belt or direct driven as indicated, with spun aluminum housing; resilient mounted motor; 1/2 inch mesh, 0.62 inch thick aluminum wire birdscreen; square base to suit roof curb with continuous curb gaskets.
- C. Roof exhaust fans fan wheel shall be centrifugal backward inclined, constructed of aluminum and shall include a wheel cone carefully matched to the inlet cone for precise running tolerances. Wheels shall be statically and dynamically balanced. The fan housing shall be constructed of heavy gauge aluminum with a rigid internal support structure. The fan shroud shall have a rolled bead for added strength.
- D. Motors shall be heavy duty ball bearing type, carefully matched to the fan load, and furnished at the specified voltage, phase and enclosure. Motors and drives shall be mounted on vibration isolators, out of the airstream. Fresh air for motor cooling shall be drawn into the motor compartment from an area free of discharge contaminants. Motors shall be readily accessible for maintenance.
- E. A disconnect switch shall be factory installed and wired from the fan motor to a junction box installed within the motor compartment.
- F. A fan conduit chase shall be provided through the curb cap to the motor compartment for ease of installation.
- G. All fans shall bear the AMCA Certified Ratings Seal for sound and air performance.
- H. Each fan shall bear a permanently affixed manufacturer's nameplate containing the model number and individual serial number for future identification.
- I. Roof Curb: 12 inch high self-flashing of galvanized steel with continuously welded seams, built-in cant strips, and insulation.
- J. Backdraft Damper: Gravity actuated, aluminum multiple blade construction, felt edged with offset hinge pin, nylon bearings, blades linked.
- K. Sheaves: Cast iron or steel, dynamically balanced, bored to fit shafts and keyed; variable and adjustable pitch motor sheave selected so required rpm gets attained with sheaves set at mid-position; fan shaft with self-aligning pre-lubricated ball bearings.
- L. See drawing schedule for additional optional equipment requirements.

2.04 UTILITY VENT BLOWERS

- A. Direct Drive Fan:
 - 1. Fan Wheel:
 - a. Type: Non-overloading, backward inclined centrifugal.
 - b. Material: Aluminum, statically and dynamically balanced.
 - 2. Motors:
 - 3. Housing:
 - a. Construct of heavy gauge aluminum including curb cap, windband, and motor compartment.
 - b. Rigid internal support structure.
 - c. One-piece fabricated or fully welded curb-cap base to windband for leak proof construction.
 - d. Construct drive frame assembly of heavy gauge steel, mounted on vibration isolators.
 - e. Provide breather tube for fresh air motor cooling and wiring.
- B. Shafts and Bearings:
 - 1. Fan Shaft:
 - a. Ground and polished steel with anti-corrosive coating.
 - b. First critical speed at least 25 percent over maximum cataloged operating speed.
 - 2. Bearings:
 - a. Permanently sealed or pillow block type.
 - b. Minimum L10 life in excess of 100,000 hours (equivalent to L50 average life of 500,000 hours), at maximum cataloged operating speed.
 - c. 100 percent factory tested.
- C. Drive Assembly:
 - 1. Belts, pulleys, and keys oversized for a minimum of 150 percent of driven horsepower.
 - 2. Belts: Static free and oil resistant.
 - 3. Fully machined cast iron type, keyed and securely attached to the wheel and motor shafts.
 - 4. Motor pulley adjustable for final system balancing.
 - 5. Readily accessible for maintenance.
- D. Options/Accessories:
 - 1. Clean Out Port: Removable grease repellent compression rubber plug allows access for cleaning wheel through windband.
 - 2. Drain Connection:
 - 3. Grease Trap:
 - a. Built-in drain connection.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Secure roof exhausters with stainless steel lag screws to roof curb. See drawings for additional mounting requirements.
- C. Extend ducts to roof exhausters into roof curb. Counterflash duct to roof opening.
- D. Provide sheaves required for final air balance.
- E. Provide speed control on direct drive fans required for final air balance.
- F. Install backdraft dampers on inlet to roof exhausters.
- G. Provide backdraft dampers on outlet from cabinet and ceiling exhaust fans and as indicated.

END OF SECTION

SECTION 23 37 00 AIR OUTLETS AND INLETS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Diffusers
- B. Registers/grilles

1.02 RELATED REQUIREMENTS

- A. Refer to the General Conditions, Special Conditions and Division 1 General Requirements. The requirements of these sections apply to this section.
- B. Section 09 91 23 - Interior Painting: Painting of ducts visible behind outlets and inlets.

1.03 REFERENCE STANDARDS

- A. ADC 1062: GRD - Test Code for Grilles, Registers & Diffusers; Air Diffusion Council; 1984.
- B. AMCA 500-L - Laboratory Methods of Testing Louvers for Rating; 2012 (Reapproved 2015).
- C. AMCA 511 - Certified Ratings Program Product Rating Manual for Air Control Devices; 2021.
- D. AMCA 550 - Test Method for High Velocity Wind Driven Rain Resistant Louvers; 2022.
- E. ASHRAE Std 70 - Method of Testing the Performance of Air Outlets and Air Inlets; 2006 (Reaffirmed 2021).
- F. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2023d.
- G. NFPA 90A - Standard for the Installation of Air-Conditioning and Ventilating Systems; 2021.
- H. NFPA 90B - Standard for the Installation of Warm Air Heating and Air-Conditioning Systems; 2021.
- I. SMACNA (ASMM) - Architectural Sheet Metal Manual; 2012.
- J. SMACNA (DCS) - HVAC Duct Construction Standards Metal and Flexible; 2021.

1.04 RELATED SECTIONS

- A. The Drawings and General Provisions of the Contract, including the General Conditions, Special Conditions and Division 1 General Requirements apply to this section.
- B. The Contract Agreement, Bidding Documents and all Addenda issued prior to Contract Agreement execution form a part of these specifications and apply to all Contracts or Subcontracts relating to the mechanical systems.
- C. The requirements of this Section apply to all Work of Division 23.

1.05 SUBMITTALS

- A. See Division 1 specifications for submittal procedures.
- B. Product Data: Provide data for equipment required for this project. Review outlets and inlets as to size, finish, and type of mounting prior to submission. Submit schedule of outlets and inlets showing type, size, location, application, and noise level.
- C. Project Record Documents: Record actual locations of air outlets and inlets.

1.06 QUALITY ASSURANCE

- A. Test and rate air outlet and inlet performance in accordance with ASHRAE Std 70.
- B. Test and rate louver performance in accordance with AMCA 500-L.
- C. Manufacturer Qualifications: Company specializing in manufacturing the type of products specified in this section, with minimum three years of documented experience.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Krueger-HVAC: www.krueger-hvac.com/#sle.
- B. Price Industries: www.price-hvac.com/#sle.
- C. Ruskin Company: www.ruskin.com/#sle.
- D. Titus, a brand of Air Distribution Technologies: www.titus-hvac.com/#sle.
- E. Tuttle and Bailey: www.tuttleandbailey.com/#sle.

2.02 DIFFUSERS

- A. Frame: Provide surface mount, snap-in, inverted T-bar, and spline type. In plaster ceilings, provide plaster frame and ceiling frame.
- B. Fabrication: Steel or aluminum with baked enamel finish.
- C. Color by Architect.
- D. Accessories: Provide radial opposed blade, butterfly, combination splitter, and volume control damper; removable core, sectorizing baffle, safety chain, wire guard, equalizing grid, operating rod extension, and gaskets for surface mounted diffusers with damper adjustable from diffuser face.
- E. SEE DRAWINGS FOR DIFFUSER SPECIFICATIONS.

2.03 REGISTERS/GRILLES

- A. Frame: Provide surface mount, snap-in, inverted T-bar, and spline type. In plaster ceilings, provide plaster frame and ceiling frame.
- B. Fabrication: Steel or aluminum with baked enamel finish.
- C. Color by Architect.

- D. Accessories: Provide radial opposed blade, butterfly, combination splitter, and volume control damper; removable core, sectorizing baffle, safety chain, wire guard, equalizing grid, operating rod extension, and gaskets for surface mounted diffusers with damper adjustable from diffuser face.
- E. SEE DRAWINGS FOR REGISTER/GRILLE SPECIFICATIONS.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Comply with SMACNA (ASMM) for flashing/counter-flashing of roof penetrations and supports for roof curbs and roof mounted equipment.
- C. Check location of outlets and inlets and make necessary adjustments in position to comply with architectural features, symmetry, and lighting arrangement.
- D. Install diffusers to ductwork with air tight connection.
- E. Provide balancing dampers on duct take-off to diffusers and grilles and registers, despite whether dampers are specified as part of diffuser, or grille and register assembly.
- F. Paint ductwork visible behind air outlets and inlets matte black, see Section 09 91 23.

END OF SECTION

SECTION 23 74 13

PACKAGED OUTDOOR CENTRAL-STATION AIR-HANDLING UNITS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Packaged Air Conditioning Unit.
- B. Makeup Air Unit.

1.02 RELATED REQUIREMENTS

- A. Division 26 - Equipment Wiring: Electrical characteristics and wiring connections.

1.03 REFERENCE STANDARDS

- A. AHRI 210/240 - Performance Rating of Unitary Air-Conditioning and Air-Source Heat Pump Equipment; 2023.
- B. AHRI 270 - Sound Performance Rating of Outdoor Unitary Equipment; 2015, with Addendum (2016).
- C. NFPA 90A - Standard for the Installation of Air-Conditioning and Ventilating Systems; 2021.
- D. Unit shall be designed to conform to ASHRAE 15, latest revision, and in accordance with UL 1995.
- E. Units shall be UL tested and certified in accordance with ANSI Z21.47 Standard. Units may be ETL listed.
- F. New roof curbs shall be designed to conform to NRCA Standards.
- G. Insulation and adhesive shall meet NFPA 90A requirements for flame spread and smoke generation.

1.04 SUBMITTALS

- A. See Division 1 specifications for submittal procedures.
- B. Product Data: Provide capacity and dimensions of manufactured products and assemblies required for this project. Indicate electrical service with electrical characteristics and connection requirements, and duct connections.
- C. Manufacturer's Instructions: Indicate assembly, support details, connection requirements, and include start-up instructions.
- D. Operation and Maintenance Data: Include manufacturer's descriptive literature, operating instructions, installation instructions, maintenance and repair data, and parts listing.
- E. Warranty: Submit manufacturer's warranty and ensure forms have been filled out in Owner's name and registered with manufacturer.

1.05 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing the type of products specified in this section, with minimum three years of documented experience.
- B. Products Requiring Electrical Connection: Listed and classified by Underwriters Laboratories Inc. as suitable for the purpose specified and indicated.

1.06 DELIVERY, STORAGE, AND HANDLING

- A. Protect units from physical damage by storing off site until roof mounting curbs are in place, ready for immediate installation of units.

1.07 WARRANTY

- A. See Section 01700 - Contract Closeout, for additional warranty requirements.
- B. See Section 01 78 00 - Closeout Submittals, for additional warranty requirements.
- C. Provide a one year warranty to include coverage for refrigeration compressors.
- D. Provide a full parts warranty for one year from start-up or 18 months from shipment, whichever occurs first.
- E. Provide five year limited warranty for heat exchanger including materials only.
- F. Furnish one complete set of fan motor drive belts.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Packaged Air Conditioning Units
 - 1. The Carrier Corporation.
 - 2. York International, Inc..
 - 3. or equal.

2.02 PACKAGED AIR CONDITIONING UNITS

- A. General
 - 1. Outdoor, rooftop mounted, electrically controlled, heating and cooling unit utilizing hermetic scroll compressor(s) for cooling duty and gas combustion for heating duty.
 - 2. Factory assembled, single piece heating and cooling rooftop unit. Contained within the unit enclosure shall be all factory wiring, piping, controls, and special features required prior to field start-up.
 - 3. Unit shall use R-410a refrigerant.
 - 4. Unit shall be installed in accordance with the manufacturer's instructions.
 - 5. Unit must be selected and installed in compliance with local, state, and federal codes.
 - 6. Unit shall meet ASHRAE 90.1 and IECC minimum efficiency requirements.
 - 7. Unit shall be rated in accordance with AHRI Standards 210/240 and 340/360.
 - 8. Unit shall be designed to conform to ASHRAE 15.

9. Unit shall be UL-tested and certified in accordance with ANSI Z21.47 Standards and UL or ETL-listed and certified under Canadian standards as a total package for safety requirements.
 10. Insulation and adhesive shall meet NFPA 90A requirements for flame spread and smoke generation.
 11. Unit internal insulation linings shall be resistant to mold growth in accordance with “mold growth and humidity” test in ASTM C1338, G21, and UL 181 or comparable test method. Air stream surfaces shall be evaluated in accordance with the “Erosion Test” in UL 181, as part of ASTM C1071.
 12. Unit casing shall be capable of withstanding 500-hour salt spray exposure per ASTM B117 (scribed specimen).
 13. Roof curb shall be designed to conform to NRCA Standards.
 14. Unit shall be subjected to a completely automated run test on the assembly line. The data for each unit will be stored at the factory, and must be available upon request.
 15. Unit shall be designed in accordance with UL Standard 1995, including tested to withstand rain.
 16. Unit shall be constructed to prevent intrusion of snow and tested to prevent snow intrusion into the control box up to 40 mph.
- B. Delivery, Storage, and Handling:
1. Unit shall be stored and handled per manufacturer’s recommendations.
 2. Unit shall only be stored or positioned in the upright position.
- C. Operating Characteristics:
1. Unit shall be capable of starting and running at 125°F (52°C) ambient outdoor temperature, meeting maximum load criteria of AHRI Standard 340/360 at ± 10% voltage.
 2. Compressor with standard controls shall be capable of operation from 35°F (2°C), ambient outdoor temperatures. Accessory kits are necessary if mechanically cooling at ambient temperatures below 35°F (2°C).
- D. Unit Cabinet:
1. Unit cabinet shall be constructed of galvanized steel, and shall be bonderized and coated with a pre-painted baked enamel finish on all externally exposed surfaces.
 2. Evaporator fan compartment interior cabinet insulation shall conform to AHRI Standards 340/360 minimum exterior sweat criteria. Interior surfaces shall be insulated with a minimum 1/2-in. thick, 1 lb density, flexible fiberglass insulation, neoprene coated on the air side. Aluminum foil-faced fiberglass insulation shall be used in the heat compartment.
 3. Unit internal insulation linings shall be resistant to mold growth in accordance with “mold growth and humidity” test in ASTM C1338, G21, and UL 181 or comparable test method. Air stream surfaces shall be evaluated in accordance with the “Erosion Test” in UL 181, as part of ASTM C1071.
 4. Condensate Pan and Connections:
 - a. Shall be a sloped condensate drain pan made of a non-corrosive material.
 - b. Shall comply with ASHRAE Standard 62.

5. Gas Connections:
 - a. All gas piping connecting to unit gas valve shall enter the unit cabinet at a single location.
6. Electrical Connections:
 - a. All unit power wiring shall enter unit cabinet at a single, factory-prepared, knockout location.
7. Component Access Panels (standard):
 - a. Cabinet panels shall be easily removable for servicing.
- E. Gas Heat:
 1. Heat exchanger shall be an induced draft design. Positive pressure heat exchanger designs shall not be allowed.
 2. Shall incorporate a direct-spark ignition system and redundant main gas valve.
 3. Gas supply pressure at the inlet to the rooftop unit gas valve must match that required by the manufacturer.
 4. The heat exchanger shall be controlled by an integrated gas controller (IGC) microprocessor.
 5. Unit shall be equipped with anti-cycle protection with one short cycle on unit flame roll-out switch or 4 continuous short cycles on the high temperature limit switch.
 6. Standard Heat Exchanger Construction:
 - a. Heat exchanger shall be of the tubular-section type constructed of a minimum of 20-gauge steel coated with a nominal 1.2 mil aluminum-silicone alloy for corrosion resistance.
 7. Optional Stainless Steel Heat Exchanger Construction:
 - a. The optional stainless steel heat exchanger shall be of the tubular-section type, constructed of a minimum of 20-gauge type 409 stainless steel.
 8. Optional Low NOx Heat Exchanger Construction:
 - a. Low NOx reduction shall be provided to reduce nitrous oxide emissions to meet California's Air Quality Management District (SCAQMD) low-NOx emissions requirement of 40 nanograms per joule or less.
- F. Coils:
 1. Standard Aluminum Fin/Copper Tube Coils:
 - a. Standard evaporator and condenser coils shall have aluminum lanced plate fins mechanically bonded to seamless internally grooved copper tubes with all joints brazed.
 2. Optional Pre-Coated Aluminum-Fin Condenser Coils:
 - a. Shall have a durable epoxy-phenolic coating to provide protection in mildly corrosive coastal environments.
 - b. Corrosion durability of fin stock shall be confirmed through testing to be no less than 1000 hours salt spray per ASTM B117-90.
- G. Refrigerant Components:
 1. Refrigerant circuit shall include the following control, safety, and maintenance features:

- a. Thermostatic Expansion Valve (TXV) shall help provide optimum performance across the entire operating range. Shall contain removable power element to allow change out of power element and bulb without removing the valve body.
- b. Refrigerant filter drier.
- c. Service gauge connections on suction and discharge lines.
2. Compressors:
 - a. Unit shall use fully hermetic, scroll compressors.
 - b. Compressor motors shall be cooled by refrigerant gas passing through motor windings.
 - c. Compressors shall be internally protected from high discharge temperature conditions.
 - d. Compressors shall be protected from an over-temperature and over-ampereage conditions by an internal, motor overload device.
 - e. Compressor shall be factory mounted on rubber grommets.
 - f. Compressor motors shall have internal line break thermal, current overload and high pressure differential protection.
 - g. Crankcase heaters shall be utilized on all models to protect compressor with specific refrigerant charge.
- H. Filter Section:
 1. Shall consist of factory-installed, low velocity, throw-away 2-in. thick fiberglass filters.
 2. Filters shall be standard, commercially available sizes.
- I. Evaporator Fan and Motor:
 1. Evaporator fan motor:
 - a. Shall have permanently lubricated bearings.
 - b. Shall have inherent automatic-reset thermal overload protection or circuit breaker.
 - c. Shall have a maximum continuous bhp rating for continuous duty operation; no safety factors above that rating shall be required.
 2. Evaporator fan:
 - a. Blower fan shall be double-inlet type with forward-curved blades.
 - b. Shall be constructed from steel with a corrosion resistant finish and dynamically balanced.
- J. Condenser Fans and Motors:
 1. Condenser fan motors:
 - a. Shall be a totally enclosed motor.
 - b. Shall use permanently lubricated bearings.
 - c. Shall have inherent thermal overload protection with an automatic reset feature.
 2. Condenser fans:
 - a. Shall be a direct driven propeller type fan and shall be dynamically balanced.
- K. Special Features Options and Accessories:
 1. Low Ambient Controller:

- a. Controller shall control coil head pressure by condenser-fan speed modulation or condenser-fan cycling and wind baffles.
- b. Shall consist of solid-state control and condenser-coil temperature sensor to maintain condensing temperature at outdoor ambient temperatures down to 0°-F (-18°-C). (Not available on 11 size models as standard unit cooling operation down to 0°-F /-18°-C).
2. Condenser Coil Hail Guard Assembly:
 - a. Shall protect against damage from hail.
 - b. Shall be of louvered style.
3. Flue Discharge Deflector:
 - a. Flue discharge deflector shall direct unit exhaust vertically instead of horizontally.
 - b. Deflector shall be defined as a “natural draft” device by the National Fuel and Gas (NFG) code.
4. Economizer:
 - a. Independent modules for vertical or horizontal return configuration shall be available. Vertical return modules shall be available as a factory-installed option.
 - b. Ultra low leak design meets California Title 24 and, ASHRAE 90.1 and IECC requirements.
 - c. Shall be capable of introducing up to 100% outdoor air.
 - d. The economizer controller shall also provide control of an accessory power exhaust unit function. Factory set at 100%, with a range of 0% to 100%.
 - e. Shall include all hardware and controls to provide free cooling with outdoor air when temperature and/or humidity are below setpoints.
 - f. Shall be equipped with gear driven dampers for both the outdoor ventilation air and the return air for positive air stream control.
 - g. Shall be equipped with a barometric relief damper capable of relieving up to 100% return air and contain seals that meet ASHRAE 90.1-2016 and IECC-2015 requirements.
 - h. Shall be designed to close damper(s) during loss-of-power situations with spring return built into motor.
 - i. Dampers shall be completely closed when the unit is in the unoccupied mode.
 - j. Integrated, gear driven opposing modulating blade design type capable of simultaneous economizer and compressor operation.
 - k. Combined minimum and DCV maximum damper position potentiometers with compressor staging relay.
 - l. On-board Fault Detection and Diagnostics (FDD) that senses and alerts when the economiz-er is not operating properly, per California Title 24.
 - m. Dry bulb outdoor air temperature sensor shall be provided as standard. Enthalpy sensor is also avail-able on factory-installed only. Outdoor air sensor setpoint shall be adjustable and shall range from 40 to 100°F (4 to 38°C). Additional sensor options shall be available as accessories.
5. Power Exhaust:

- a. Power exhaust shall be used in conjunction with an integrated economizer.
 - b. Independent modules for vertical or horizontal return configurations shall be available.
 - c. Horizontal power exhaust shall be mounted in return ductwork.
 - d. Power exhaust shall be controlled by economizer controller operation. Exhaust fans shall be energized when dampers open past the 0 to 100% adjustable setpoint on the economizer control.
6. Roof Curbs (Vertical):
- a. Formed galvanized steel with wood nailer strip and shall be capable of supporting entire unit weight.
 - b. Permits installation and securing of ductwork to curb prior to mounting unit on the curb.
7. Winter Start Kit:
- a. Shall contain a bypass device around the low pressure switch.
 - b. Shall be required when mechanical cooling is required down to 25°F (−4°C).
 - c. Shall not be required to operate on an economizer when below an outdoor ambient of 40°F (4°C).
8. Anti-short Cycle Timer:
- a. Shall prevent compressor short cycling by providing a 5-minute delay (±2 minutes) before restarting a compressor after shutdown for any reason.
 - b. One device shall be required per compressor.
9. Hinged Access Panels:
- a. Shall provide easy access through integrated quarter turn latches.
 - b. Shall be on major panels of — filter, control box, fan motor and compressor

2.03 MAKEUP AIR UNITS

- A. Acceptable Manufacturers.
 1. Greenheck.
 2. Captive Aire.
- B. General
 1. Make-Up Air unit shall be as manufactured by Greenheck or approved equal provided all specifications are met. Greenheck Model IGX equipment is used as the basis of design. Performance to be as scheduled on plans.
- C. Furnace and Controls
 1. Indirect-gas fired furnace shall be 80% efficient, ETL list and have a blow through fan design. Furnace shall be capable of operation with Natural or LP gas and have a power venting system. The heat exchanger shall be constructed of stainless steel. Standard furnace features shall include main gas pressure regulator, main gas valve, electronic staged or electronic modulating controls, direct spark ignition system, high limit and a 24 volt control transformer. Furnace shall be insulated and have double wall construction.
- D. Temperature Control
 1. Furnace heat output shall be controlled based on a field adjustable discharge temperature set point. Discharge temperature sensor shall be factory mounted

and wired to the unit control center. Furnace(s) shall have electronic modulation or at least two stages of control.

E. Unit Casing and Frame

1. Unit shall be of internal frame type construction of galvanized steel. All frames and panels shall be G90 galvanized steel. Where top panels are joined there shall be a standing seam to insure positive weather protection. All metal-to-metal surfaces exposed to the weather shall be sealed, requiring no caulking at job site. All components shall be easily accessible through removable doors.

F. Insulation

1. Models provided with a mixing box shall be insulated from the return section through to the supply discharge. Insulation shall be in accordance with NFPA 90A and tested to meet UL 181 erosion requirements. Double wall shall be provided if specified.

G. Fan Section

1. Centrifugal fans shall be double width, double inlet. Fan and motor shall be mounted on a common base and shall be internally spring isolated. All blower wheels shall be statically and dynamically balanced. Ground and polished steel fan shafts shall be mounted in permanently lubricated ball bearings (up to size 118) or ball bearing pillow blocks (size 120 and larger). Bearings shall be selected for a minimum (L10) life in excess of 100,000 hours at maximum cataloged speeds.

H. Motors and Drives

1. Motors shall be energy efficient, single or two speed as indicated with ODP enclosures. Motors shall be permanently lubricated, heavy duty type, matched to the fan load and furnished at the specified voltage, phase and enclosure. Drives shall be sized for a minimum of 150% of driven horsepower. Pulleys shall be cast and have machined surfaces, 10 horsepower and less shall be supplied with an adjustable drive pulley.

I. Electrical

1. All internal electrical components shall be prewired for single point power connection. All electrical components shall be UL listed, recognized or classified where applicable and wired in compliance with the National Electrical Code. Control center shall include motor starter, control circuit fusing, control transformer for 120 VAC circuit, integral door interlocking disconnect switch with separate motor fusing and terminal strip. Contactors, Class 20 adjustable overload protection and single phase protection shall be standard.

J. Filter Section

1. Filters shall be mounted in a V-bank arrangement such that velocities across the filters do not exceed 550 feet per minute. Filters shall be easily accessible through a removable access panel.

K. Evaporative Cooler Section

1. Evaporative cooling section shall include a galvanized steel housing with louvered intake, two inch aluminum mesh filters and a stainless steel evaporative cooling module all provided by the make-up air unit manufacturer. Evaporative

cooling media shall be Munters CELdek with a depth of 12 inches for a cooling effectiveness of 90%. Drain and overflow connections shall be piped through the side of the evaporative cooling section. Provide with "Water Wizard" evaporative cooling system control.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that roof is ready to receive work and opening dimensions are as indicated on shop drawings.
- B. Verify that proper power supply is available.

3.02 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Install in accordance with NFPA 90A.
- C. Mount units on factory built roof mounting curb providing watertight enclosure to protect ductwork and utility services. Install roof mounting curb level.

3.03 SYSTEM STARTUP

- A. Provide factory start-up and supervise installation by Contractor.

END OF SECTION

SECTION 26 05 00

COMMON WORK RESULTS FOR ELECTRICAL

PART 1 - GENERAL

1.01 CONTRACT PROVISIONS

- A. The requirements of this Section are in addition to the requirements of Division 1, General Conditions and Supplementary Conditions.

1.02 SUMMARY

- A. This section describes the requirements for the electrical work includes, among others, the furnishing and installation of the following:
 - 1. Electrical service from the Main Switchboard to the building Distribution Panel(s) including transformer(s), conduit and trenching, conductors.
 - 2. Power distribution system.
 - 3. Grounding system.
 - 4. Lighting and lighting control systems.
 - 5. Wiring systems including power wiring to plumbing and HVAC and other misc. appliances and equipment.
 - 6. Electrical services (power) for Communications management system. (voice/video/media/clock) as described in Division 27 and as indicated on the drawings.
 - 7. Electrical services (power) for Computer data systems, as described in Division 28 and as indicated on the drawings to include outlets, raceways, and cabling.
 - 8. Electrical services (power) for Intrusion alarm and security systems as described in Division 28 and as indicated on the drawings.
 - 9. Emergency egress lighting.
 - 10. Testing and commissioning for all electrical work installed under this contract and as described in these specifications and indicated on the drawings.
- B. Furnish and install all electrical equipment and systems as shown on the Drawings and as described in this Division of the Specifications to provide a complete and functional electrical installation. This work includes but is not limited to all material and labor required for installation of electrical and special systems complete as described herein this specification and drawings; and connections (and installation where not otherwise provided for) of electrical equipment furnished by others. Provide and install all items of equipment, devices, supports, etc., which are incidental to the major components shown on the Drawings or described in these Specifications.

1.03 DEFINITIONS

- A. The meaning of words shall be as defined in the CEC Article 100, Definitions, unless defined otherwise in an individual specification section.
- B. The following specification development organizations are referenced throughout the various specification sections of Division 26:
 - 1. ADAAG – Americans with Disabilities Act Accessibility Guidelines.

2. ANSI – American National Standards Institute.
3. AQMD – Air Quality Management District.
4. ASME – American Society of Mechanical Engineers.
5. ASTM – American Society for Testing and Materials.
6. FCC – Federal Communications Commission.
7. ICC - International Code Council
8. 21. IEEE – Institute of Electrical and Electronic Engineers.
9. ISO – International Organization for Standardization.
10. 27. NECA – National Electrical Contractors Association.
11. 28. NEMA – National Electrical Manufacturing Association.
12. 29. NETA – National Electrical Testing Association.
13. 30. NFPA – National Fire Protection Association.
14. 32. OSHA – Occupational Safety and Health Administration.
15. 34. UL – Underwriters Laboratories.

1.04 RELATED WORK INCLUDED IN OTHER DIVISIONS

- A. Finish painting except factory applied finishes and repair of factory finishes shall be provided in accordance with appropriate sections of this Specification. Coordinate "painting" requirements of this Division with other trades as required to assure timely and satisfactory completion of required work. In finished areas, all exposed raceway, boxes, galvanized steel box covers (where allowed), and other electrical "structure" shall be finished to match adjacent structures. Verify that all raceway openings are closed and box covers are in place prior to finishing work done by others.
- B. Examine the drawings and specification for mechanical and plumbing equipment and provide electrical installation for heating, ventilation and air conditioning equipment, motors, pumps and associated motor starters and controls as described in Division 22 and Division 23.
- C. Examine the Architectural drawings and specification for electrical appliances and equipment which may not be shown on the plans to include and provide electrical installations as described in the architectural division of work.
- D. Examine the Architectural drawings and provide all construction necessary to maintain the integrity of the fire rated barriers.
- E. Examine the Architectural drawings and coordinate with the Architect to provide access doors, whether shown on drawings or not, where floors, walls, or ceiling must be penetrated for access to electrical equipment, outlet boxes, devices, etc., and as specified in this specification.
- F. Provide and install, as part of the work described in this Division, all power and control wiring fed from a source of 30 Volts or more (i.e. all wiring except temperature control wiring) for mechanical equipment described in Division 23.
- G. Examine the fire sprinkler system drawings and specifications for electrical work which may not be shown on the electrical and/or fire detection and alarm plans to be included in the electrical work as necessary as described in the Division 21 fire sprinkler system.

1.05 APPLICATION OF OTHER DIVISIONS

- A. Where carpentry, masonry, concrete work, painting, etc., is required in the installation of equipment specified under this Division, the work shall be done in accordance with the applicable Division of these Specifications. This work could include for example: work associated with panelboard installation, equipment pads or bases, support structures, etc.

1.06 DRAWINGS AND SPECIFICATIONS

- A. The information presented in these Specifications, and on the drawings, is intended to describe the utilitarian and physical aspects of the systems shown as well as the quality of the entire installation. All information is as complete and thorough as possible, but every condition or situation cannot be anticipated. Exact locations, dimensions, elevations, etc. must be determined "on the job" with careful attention to the "intent" of the Drawings and Specifications.
- B. The above paragraph shall not be construed as to allow significant deviation from either the Drawings or Specifications without prior approval of the Architect, but minor changes in conduit routing or equipment locations may be required or desired due to specific conditions encountered. This work shall be accomplished in accordance with these Specifications and no "extra charges" are to be created for any unanticipated labor or material.
- C. Any error or omissions of detail in either the drawings or the specifications shall not relieve the Contractor from correctly installing all materials necessary for complete and operating electrical systems.
- D. Contractor shall inspect the site and verify all measurements and conditions. No extra compensation will be allowed because of differences between work shown on the drawings and measurements at the site.
 - 1. The Drawings are diagrammatic in nature, but the locations of devices, equipment, outlets, and lighting fixtures are shown approximately where installations are intended. Architectural, structural, mechanical, audio/video, theatrical lighting and other drawings shall be examined, noting all conditions that may affect this work. Report conflicting conditions to the Architect/Engineer for adjustment before proceeding with the work. Should the Contractor proceed with work without reporting the matter, he does so on his own responsibility and shall alter work if directed by the Architect/Engineer at his own expense.
- E. Examine the architectural, structural, mechanical, fire sprinkler and manufacturer's drawings for various equipment in order to determine exact routing and final terminations for all conduits and cables. Conduits shall be stubbed up as near as possible to equipment enclosure.
- F. All equipment shall be located and installed so that it will be readily accessible for operation and maintenance. The Owner reserves the right to require minor changes in location of outlets or equipment, prior to rough in without incurring any additional cost or changes.

- G. If significant departures from the Drawings or Specifications are considered necessary by the Contractor, details of the changes and the reasons therefore shall be submitted to the Architect as within thirty days after award of contract. Prior written acceptance of the Architect is required for these departures.
- H. Clarification of plans and specifications for the purpose of facilitating construction, but not involving additional labor and materials, may be prepared during construction by the Architect/Engineer. Said revised plans and specifications shall become a part of the contract. The Contractor shall conform to the revised plans and specifications at no additional cost to the Owner.

1.07 CODES, STANDARDS, RULES AND REGULATIONS

- A. All work and materials shall be in full accordance with the latest rules, codes, and/or regulations and not limited to the following:
 - B. California Building Standards Code (California Code of Regulations - Title 24)
 - C. NFPA 70 - National Electrical Code; National Fire Protection Association, 2020 with 2022 California Electrical Code amendments
 - D. NFPA 72 - Fire Alarm Code
 - E. NFPA 101 - Life Safety Code
 - F. City and County Electrical Codes as applicable.
 - G. Utility rules and regulations.
 - H. Any applicable additional codes and regulatory documents effective at the project site.
 - I. Nothing on the Drawings or in the Specifications shall be construed to allow work not in conformance with these rules, codes, and regulations.
 - 1. The Drawings and/or Specifications shall take precedence where work and material described therein exceeds that required by rules, codes, or regulations.

1.08 MANUFACTURER'S INSTRUCTIONS

- A. Follow the manufacturer's instructions when specific installation or connection details are not indicated or specified on the contract documents.
- B. Notify the Architect/Engineer of conflicts between the manufacturer's instructions and installation or connection details prior to the installation of materials.

1.09 WORKMANSHIP

- A. High quality workmanship shall be evidenced in the installation of all electrical equipment and materials. Use the National Electrical Contractors Association's "Standard of Installation" as a guide to the workmanship required. Be prepared to replace or repair any material or equipment damaged by or installed in a manner exhibiting evidence of poor workmanship.

1.10 COORDINATION WITH OTHER TRADES

- A. Examine the Electrical Drawings and refer to the Drawings and Specifications describing other work to be accomplished. Verify and coordinate prior to bid. Continue to coordinate work planning and all work in the field to avoid conflicts, errors, and/or delays. No compensation will be allowed for extra work necessitated by lack of coordination.

1.11 AUTHORITY OF THE ARCHITECT

- A. As used in this paragraph only, the word "Architect" shall mean the Architect of record or his designated representative.
- B. The authority of the Architect shall be absolute with respect to all performance under this Specification. In case of dispute, the decision of the Architect shall be final.
- C. Where optional materials, methods, or installation techniques are allowed under the provisions of this Specification, they may be used at the discretion of the Architect. The Architect may require specific materials, methods, or techniques to be used in specific situations where use of other materials, methods, or techniques might in his judgment result in loss of aesthetics, accidental damage, life safety hazard, or loss of utility over the system design lifetime.
- D. No additional charges will be allowed for work or material require to be supplied under the conditions of this paragraph unless the need for such material or work could not have been anticipated by thorough study of the site, Drawings, and Specifications and knowledge of all applicable codes, laws, and ordinances.

1.12 EXAMINATION OF THE SITE

- A. The contractor is required to visit the site of construction prior to bid to determine existing conditions and their effect upon the work he will be required to perform. No additional compensation will be allowed for any extra expenses incurred by failure to detect and evaluate all existing conditions that will affect his work to be included in the bid to accomplish this contract document's goal.

1.13 STRUCTURAL REQUIREMENTS

- A. Secure all anchors for electrical equipment in a manner, which will not decrease the structural value of any structure to an unsafe level. Install all equipment, fixtures, etc. to resist seismic movements. Inform the Architect in advance and provide drawings of any proposed modifications to the structure that involves cutting or patching of concrete, masonry, steel, or wood in this project.

1.14 PERMITS, FEES, AND, INSPECTIONS

- A. Obtain all permits and licenses as required and pay all fees incidental to construction.
- B. Inspections required by prevailing Local Authorities, and/or ordinances, shall be coordinated and arranged by the contractor. Provide the Architect with a schedule of inspections, where applicable, and submit all certificates of inspection to the Architect.

- C. The Contractor shall cooperate with the Architect and shall provide assistance at all times for the inspection of the electrical work. Remove covers, operate equipment, or perform any reasonable work, which, in the opinion of the Architect, will be necessary to determine the quality or adequacy of the work. Work shall not be closed in or covered before inspection and approval by the Architect. Cost of uncovering and making repairs where un-inspected work has been closed in shall be borne by the Contractor. If any material does not conform with these specifications the Contractor shall, within three days after being notified by the Architect, remove the materials from the premises.

1.15 PRODUCT DELIVERY, STORAGE, AND HANDLING

- A. Deliver materials and equipment to project site in manufacturer's original packaging with labeling showing product name, brand, model, project name, address, and Contractor's name. Store in a location as agreeable to the Owner. Secure material from weather or accidental damage.

1.16 SEQUENCING AND SCHEDULING

- A. Sequence work under provisions of Division 1.
- B. Coordinate the incoming electrical, telephone and cable television services with the local serving utility companies. Install utility service trench and duct systems in accordance with the respective serving utility company requirements.
- C. Coordinate hand hole locations with the existing site conditions. Hand holes are to be located approximately five feet from building or as indicated on drawings.

1.17 SHORT CIRCUIT AND PROTECTIVE DEVICE COORDINATION STUDY

- A. The contractor shall provide short circuit, protective device and arc flash studies for the complete electrical distribution system. Submit to the Electrical Engineer of Record for review. Provide all short circuit device and equipment characteristic information for all electrical components. Provide Time-Current curves for all overcurrent protective devices in the submittal. Set and adjust all devices in accordance with the results of this study prior to energizing equipment. Refer to Section 26 05 73, Power Systems Studies for additional requirements.
- B. The Contractor shall be responsible for obtaining all pertinent information necessary in order to perform the required short circuit, protective device coordination and arc flash studies to include but not limited to the following:
 1. Contacting the serving power utility to obtain the available short circuit current at the project point of connection and/or secondary of the serving utility company service transformer(s).
 2. Field investigation to determine the short circuit current rating for any existing electrical service and distribution equipment.
 3. Electrical characteristics for all proposed new electrical service and distribution equipment.
 4. The Contractor shall provide approved permanent labels for all electrical service and distribution equipment to clearly identify the available short circuit current and arc flash energy levels and required PPE (Personnel Protective Equipment).

1.18 OPERATING INSTRUCTIONS

- A. Instruct the Owner as to function, operation, maintenance, and adjustment of each system and piece of equipment provided.

1.19 RECORD DRAWING

- A. The Contractor shall keep a separate set of Electrical Drawings at the job site to be used as RECORD Drawings. These Drawings are to be kept current and in a neat and clean condition at all times. They are to be available for inspection by the Architect or Engineer at any time during site visitations. These Drawings shall be "red lined" to indicate all changes in equipment, device, and outlet locations; and to indicate the true locations of all concealed or underground work where different from that shown on the Drawings. Each sheet of this set shall be clearly and permanently marked "RECORD DRAWINGS".
- B. Upon completion of the project and prior to final payment, transfer all RECORD DRAWINGS information to the provided original drawings. All information shall be clearly drawn with "RED" ink. The drawings shall be scanned, 100% edited, and converted into an AutoCAD ".dwg" version 2011 (or higher) electronic file. Deliver the original, final sets, and electronic files (CD) to the Architect for review and delivery to the Owner.

1.20 SPARE PARTS

- A. Spare parts shall be provided and maintained by the Contractor to support the maintenance response requirements defined in this document.
- B. At a minimum, the following spare parts shall be stored onsite at a location identified by the Owner's representative. The spare parts shall be the property of the Owner. The spare parts shall be of the same type submitted and installed in the facility to include the following:
 - C. Lighting fixture LED driver, one for each fixture type.
 - D. Branch circuit panelboard circuit breaker, one for each circuit breaker type.
 - E. Fuses, one set of three for each fuse type and size.
 - F. Lighting occupancy sensors and switches, one for each sensor and switch type.

1.21 GUARANTEE

- A. All electrical work, material, and equipment shall be guaranteed to be free from defects in workmanship or material for a period of two (2) year from the date of final acceptance. Repair or replace all such defects in a timely manner and any damage to the owner's property resulting from such defect or repair thereof. All equipment and material provided and all work accomplished under the requirements of this section shall be at no expense to the Owner.

PART 2 - PRODUCTS

2.01 MATERIALS

- A. Unless specifically indicated otherwise, all material shall be new and free from defects; it shall be listed by Underwriters' Laboratories where applicable. Like items shall be of the same manufacturer (except lighting fixtures - which shall be as specified).
- B. Except as noted otherwise, where material of a particular manufacturer is specified, the intent is to describe the quality and function of the item. The term "...or acceptable equal" is implied. A substitution of any of these items will require that the item be presented in a submittal whether specifically listed in the "Submittals" paragraph below or not.

2.02 SUBMITTALS

- A. Material submittals shall be complete and submitted all at the same time. The individual groups of submittal types (e.g.: lighting fixtures, wiring devices, distribution equipment, etc.) MUST be prefaced with a list of contents identifying each item by its project name or symbol, manufacturer, and complete catalog number. Each copy of each submittal group shall have the list of contents attached. These lists will be used to report submittal comments. The Contractor is responsible for submitting this information in a timely manner so that material may be ordered early enough to meet the construction schedule. If material is not ordered in time for whatever reason, pay such premium prices and special handling charges as are required to meet the construction schedule. No substitution of an "accepted" item will be allowed due to failure to plan for adequate material procurement lead time.
- B. Shop drawings shall be drawn to scale or completely dimensioned and shall give all information required to completely describe the item. The Contractor shall carefully check all the shop drawings for compliance with these specifications and the Plans.
- C. If the shop drawings show variations from the Contract requirements because of standard shop practice or other reasons, the Contractor shall make specific mention of such variations in order that if (acceptable) suitable action may be taken for proper adjustment of the Contract. The Contractor will not be relieved of the responsibility for executing the work in accordance with the Contract, even though the shop drawings have been reviewed.
- D. Work requiring shop drawings shall not be started before receipt of the Architect's review and acceptance.
- E. The Architect's/Engineer's review of the submitted materials, items and shop drawings are for general compliance with the plans and specifications and general design and arrangement only. Therefore, it shall not relieve the Contractor from responsibility for errors of any sort in the materials, items, shop drawings or schedules. The Contractor shall verify all dimensions and job site conditions affecting the work, and shall be responsible for furnishing and installing the proper materials required by the Contract, whether or not indicated on the drawings and specifications.

- F. As a minimum, submittals are required for the following items:
1. RACEWAY COMPONENTS
 2. WIRE AND CABLE
 3. WIRING DEVICES
 4. MAIN SWITCHBOARD AND DISTRIBUTION PANELS
 5. PANELBOARDS
 6. PHOTOVOLTAIC SYSTEM
 7. PULL BOXES
 8. SAFETY SWITCHES, DISCONNECTS AND CIRCUIT BREAKERS
 9. TRANSFORMERS
 10. LIGHTING FIXTURES, CONTROL SYSTEMS, PEDESTALS AND POLES
 11. EMERGENCY GENERATOR AND TRANSFER SWITCH(ES)

2.03 SUBSTITUTIONS

- A. Specific brand names and catalog numbers are used to describe materials in order to establish of performance and quality.
- B. Only one substitution will be considered for any item. Substitute materials must be equal in quality and function to that specified. Allowance of a substitution does not permit any reduction of system performance or utility, and the Contractor is responsible for additional costs incurred due to use of a substituted item. If the proposed substitute item is "rejected", the specified item shall be provided (re-submittal required) without further discussions or delay.
- C. Any Contractor's proposed substitution of material, article, or method in the opinion of the Architect/Engineer are equal to that specified will be accepted, provided the Contractor submits a single written request, in triplicate, to the Architect, with the following information for each item:
- D. Name of Manufacturer or supplier.
- E. Trade or brand names.
- F. Type, model, style, and/or catalog number.
- G. Size or capacity rating.
- H. After receipt of a written request from the contractor, the engineer of record will review product substitutions fourteen (14) days prior to the bid date. If system substitutions are submitted after the award of the project contract, the analysis for the whole system substitution will be charged to the contractor at senior engineer hourly rates.
- I. The decision of the Architect/Engineer shall govern as to what is equal to the item specified in the plans and specifications. Equality will be judge on the basis of the following:
1. Conformance with description or performance required.
 2. Equal in quality.
 3. Comparable in appearance and artistic effect where these are in considerations.
 4. Comparable operation, maintenance and performance.
 5. Equal in longevity and service under conditions of climate and usage.

6. Conformance with space allocations and requirements for operations from in details and construction of related work.
 7. Conformance with all applicable codes and regulations.
- J. If the Architect/Engineer considers it necessary, tests to determine the quality of the proposed materials shall be made, at the expense of the Contractor, by an unbiased laboratory, satisfactory to the Architect.

2.04 ENCLOSURES

- A. Provide enclosures suitable for the specific type of location in which they are installed.
1. Provide NEMA 1 or NEMA 12 boxes and enclosures for dry locations. Dry locations are all indoor areas that do not fall within the definitions below for wet or damp locations.
 2. Provide NEMA 3R boxes and enclosures for wet locations. Wet locations are all locations exposed to weather, whether under a roof or not.
 3. Provide NEMA 4 boxes and enclosures for damp locations. Damp locations are all indoor spaces wholly or partially underground or any area subject to water spray.
 4. Provide NEMA 4X, stainless steel enclosures in all kitchen and wash down areas.

PART 3 - EXECUTION

3.01 INSTALLATION

- A. All equipment shall be set square and plumb, securely mounted, adequately supported, and permanent. Provide workspace around items of electrical equipment as required by California Electrical Code (CEC). In general, equipment is to be installed in accordance with manufacturer's instructions; but the requirements of these specifications shall take precedence where conflicts exist.
- B. WIRING METHODS: The cables and conductors of all systems specified in the Specification are required to be installed in raceway.
- C. Coordinate electrical work with the Owner's representative and work of other trades to avoid conflicts, errors, delays, and unnecessary interference with operation of the facility during construction.
- D. Check and coordinate the approximate locations of electrical stub-ups, light fixtures, electrical outlets, equipment, and other electrical system components shown on the Drawings for conflicts with openings, structural members, and components of other systems and equipment having fixed locations. In the event of conflicts, notify the architect in writing. The architect's decision shall govern. Make modifications and changes required to correct conflicts as required.

3.02 ELECTRICAL WORK FOR EQUIPMENT PROVIDED UNDER OTHER SECTIONS

- A. Install power conductors and terminate on equipment provided under other specification sections. Verify specific requirements.
- B. Install and terminate electrical controls as described on the Electrical Drawings (For mechanical equipment specified in Division 23).

- C. Line voltage control wiring of exhaust fans is to be accomplished under this Division. The controlling device may be specified elsewhere.
- D. Provide and install all disconnect/safety switches and motor starters except those devices specified to be furnished with equipment specified elsewhere.
- E. Unless provided for in another Division, install all items of electrical equipment provided by others.
- F. Assist others in equipment testing to verify that wiring and connections made under this Division are correct.

3.03 EQUIPMENT IDENTIFICATION

- A. Nameplates shall be installed on all items of electrical equipment as follows: switchboard(s) and switchboard circuit breakers, panelboards, terminal cabinets, time switches, contactors, motor control switches, wall switches (where noted on the Drawings), motor starters provided under this Division where the function is not immediately obvious, and safety switches.
- B. The nameplate shall identify the item by Drawing name where applicable and describe its use or function in this installation.
- C. Permanently mark all utility outlets to show source of power panel and circuit breaker number.
- D. Provide nameplates per Section 26 05 53.

3.04 EXCAVATION AND BACKFILL

- A. Excavation and backfill shall be accomplished as required for installation of electrical equipment as shown on the Drawings. Restore all surfaces, roadways, walks, etc., and any existing underground structures which might be disturbed during this work to their original condition in a manner acceptable to the Architect.
- B. Trenches shall be straight except where otherwise indicated. Depth shall be as noted on the Drawings and at least as required to provide the minimum cover specified by applicable codes and regulations for the equipment installed. Bottom of trench shall be smooth and free of any rock points. Place a 4" sand bed in trench if these conditions cannot be met with native material.
- C. Backfill shall be clean and free of rocks and debris. Backfill is to be tamped in 6" layers to nominal 95% compaction using a mechanical tamper manufactured specifically for this purpose. In an area of engineered fill or other area of specified compaction, backfill shall be compacted to match that specified for that area.
- D. At a depth of 12" below finished grade and at least 6" above installed equipment, lay a 6" wide red warning tape on the compacted backfill for the full length of the trench. Do not stretch the tape. Use Brady "Identoline" stating: "CAUTION BURIED ELECTRICAL LINE". Installation under building slabs is not required unless noted otherwise.
- E. If at any time during a period of one-year dating from the date of final acceptance of the project, there shall be any settlement of conduit trenches, the Architect may notify the Contractor to immediately provide additional fill and to make such repairs or replacements in paving, planting, or structures, as may be deemed necessary at the

Contractor's expense.

- F. Cooperate and coordinate with others in planning for and execution of all trench work.
 - 1. The Contractor is expected to exercise due care when excavating in an area of existing utilities to avoid damage to these facilities. Where it can be determined that underground facilities are likely to exist (either from the Drawings or inspection of the site), the Contractor is required to determine the exact locations of these existing installations. Damage to existing facilities, due to failure to properly accomplish the above, shall be repaired at the Contractor's expense to the approval by the Architect and satisfaction of the Owner.
 - 2. CALL AN UNDERGROUND SERVICE FIRM BEFORE TRENCHING, CALL U.S.A. (800) 624-2444.

3.05 SEALING PENETRATIONS

- A. Flash and counter flash roof and wall penetrations with equipment manufactured for the purpose and as described in other Divisions of these Specifications or as Directed by the Architect. Apply mastic as required to seal absolutely watertight.
- B. Conduits penetrating floor slabs or block or concrete walls shall be grouted and sealed watertight.

3.06 CUTTING AND PATCHING

- A. Obtain the Architect's acceptance prior to cutting existing surfaces or surfaces under construction. All such surfaces must be repaired or patched to the satisfaction of the Architect.

3.07 EQUIPMENT ANCHORING

- A. Seismic Withstand Requirements: Freestanding or wall-hung equipment shall be anchored in place by methods, which will meet the requirements of the applicable codes for seismic loads. The contractor shall submit calculations in accordance with "Contractor Submittals", for the design of the anchoring systems for all equipment, including panels, transformers, etc. in excess of 250 pounds. Calculations shall be performed, signed and stamped by a Structural Engineer or a Civil Engineer experienced in structural design and licensed in the State of California. The calculation shall provide an analysis of lateral and overturning forces and shall include a factor of safety against overturning equal to 1.5. The calculation shall also provide an analysis of both the anchoring system and the foundation or wall system to receive the anchor loads and shall show that the foundation is capable of resisting all anchor loads. Submittal shall include data on attachment hardware and methods that will satisfy withstand criteria.
- B. Seismic bracing for light fixtures cable or pendant suspended from ceiling or roof structure shall be seismically braced to prevent fixture from swaying 45 degree in either direction of suspension point. Contractor shall use same cable used to suspend light fixture. Where pendants are used the contractor shall use air craft light fixture suspension cable. Submittal shall include data on attachment hardware and methods that will satisfy withstand criteria referred to in above paragraph.

3.08 HOUSEKEEPING PADS AND FOUNDATIONS

- A. Concrete work required for housekeeping pads and foundations shall be provided by General Construction Work.
- B. Furnish required dimensional drawings and specify locations for all equipment pads and foundations. Minimum height of housekeeping pads shall be four inches and shall extend out six inches from the footprint of the equipment. Extend pad dimensions where required to maintain accessibility and meet all code requirements.
- C. Furnish anchor bolts and sleeves, verify accuracy of installation.
- D. Provide housekeeping pads for the following:
 - 1. Outdoor switchboards.
 - 2. Emergency and/or Stand-by generator.
 - 3. Outdoor distribution panels.
 - 4. Outdoor floor mounted transformers.
 - 5. Other equipment as required or as noted on the drawings.

3.09 PROTECTION CLEANING AND REPAIRS

- A. All electrical equipment shall be protected from damage or degradation during construction. Electrical equipment stored or installed shall be protected from dust, water, or damage from other sources.
- B. After all other work has been accomplished, such as plastering, painting, etc., and prior to final review by the Architect; all electrical equipment, especially equipment enclosures, panelboards, switchboards, and lighting fixtures shall be thoroughly cleaned (inside and out) of all dirt, water, grease, plaster, paint, or other construction debris. All surfaces shall be clean and in "new" condition. All scratches, dents, marks, cracks, etc., shall be repaired to the satisfaction of the Architect or the equipment shall be replaced at no additional cost.

3.10 ELECTRICAL EQUIPMENT DELIVERABLES

- A. Retain and safeguard all detachable and spare devices, equipment, and literature (O&M manuals, instruction books, wiring diagrams, test reports, keys, fixtures, etc.) until completion of work. At this time, all items will be delivered to the Owner as directed by the Architect.

3.11 TESTS

- A. Prior to energization of equipment, check the insulation resistance of listed circuits, with a 500 volt "Megger".
- B. Take precaution during the testing period to insure the safety of personnel and equipment.
- C. Test all wiring for continuity and grounds before any fixtures or equipment are connected. Where such tests indicate faulty installation or other defects, the fault(s) shall be located and repaired at the Contractor's expense. The repaired installation shall then be retested.

- D. Verify rotation of all three phase motors and reconnect if necessary.
- E. Verify the resistance of the grounding electrode system(s).
- F. Balance all loads on each panelboard and all other types of distribution equipment as applicable.
- G. Provide all site testing under provisions of Section 26 08 13.

3.12 ADJUSTING

- A. Inspect all equipment and put into good working order.

3.13 CLEANING

- A. Clean work under provisions of Division 1.
- B. Clean all electrical items. Fixtures and equipment shall be free of dirt, dust and other construction debris.

3.14 START UP

- A. Operate all electrical systems in good working order for a period of five consecutive days at a time period agreed to by the Owner's representative.

END OF SECTION 26 05 00

SECTION 26 05 05 SELECTIVE DEMOLITION FOR ELECTRICAL

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Electrical demolition.
- B. The requirements of this Section are in addition to the requirements of Division 1 – General Conditions and Supplementary Conditions.

1.02 RELATED REQUIREMENTS

- A. Section 01 70 00 - Execution and Closeout Requirements: Additional requirements for alterations work.
- B. Section 02 84 00-Polychlorinate Biphenyl (PCB) Remediation: Removal of equipment and materials containing substances regulated under the Federal Toxic Substances Control Act (TSCA), including but not limited to those containing PCBs and mercury.
- C. Section 26 05 00-Common Work Results for Electrical.

1.03 SUBMITTALS

- A. See Section 01 30 00-Administrative Requirements, for submittal procedures.
- B. Sustainable Design Documentation: Submit certification of removal and appropriate disposal of abandoned cables containing lead stabilizers.

1.04 REQUIREMENTS INCLUDED

- A. The Contractor shall furnish materials, equipment, and labor necessary to perform and complete demolition work.
- B. The work includes demolition of the existing electrical system and equipment.
- C. The work shall include, but not limited to. Removal of existing electrical equipment and devices, conduits, and wiring.
- D. Manufactured articles, materials, equipment, and accessories shall be demolished in accordance with the manufacturer's specifications and recommendations, and industry standards.
- E. Notify the Owner's Representative at least 72 hours prior to any electrical systems shutdown and receive approval prior to proceeding.

1.05 PROTECTION

- A. It is essential that there be minimal interruption of existing systems such as power, fire protection, and other systems, in addition to the normal operations of the Owner's facilities.
- B. Take care to ensure that there will be no damage to structural elements or portions there-of-which are not to be removed. Erect and maintain temporary shoring, bracing and other means to safeguard the structural integrity of the existing building(s) and

structures.

- C. Erect and maintain temporary bracing, shoring, lights, barricades, signs, and other means to protect the public, workers, and other persons; finishes, and improvements to remain; and adjoining property from damage from demolition work; all in accordance with applicable regulatory requirements.
- D. Protect existing structures, facilities, and plant life from damage. Items damaged as a result of demolition operations shall be repaired or replaced, at no cost to the Owner.
- E. Perform demolition to provide the least interference and most protection to existing facilities and improvements to remain.
- F. Demolish concrete in small sections.
- G. Perform demolition as much as possible with small tools.
- H. Jackhammering:
 - 1. Jackhammering will be permitted only to a limited degree, and only with the prior written approval of the Owner.
 - 2. Do not jackhammer within 2-inches of reinforcing or structural steel to remain; remove final 2-inches of material with chipping gun.

1.06 CUTTING AND PATCHING

- A. Make new openings neat, as close as possible to profiles indicated, and only to extent necessary for new work.
- B. Do not cut or alter structural members unless specifically indicated or approved, and do not damage reinforcing or structural steel to remain.
- C. At concrete, masonry, paving, and other materials where edges of cuts and holes will remain exposed in the completed work, make cuts using power-sawing and coring equipment. Do not over cut at corners of cut openings – saw overruns will not be permitted. Core hole at corner of proposed openings to insert blade and chip square.
- D. Upon completion of cutting and coring, clean remaining surfaces of loose particles and dust.
- E. Repair and patch all holes and openings from the removed electrical equipment, outlet boxes, etc.: Coordinate with the General Contractor and Architect to include and provide finishes to match adjacent surfaces.

1.07 PIPES, DUCTS AND CONDUITS

- A. Remove deactivated electrical conduits, including fasteners, connections, and other related appurtenances and accessories which would otherwise be exposed in the completed work or interfere with construction operations.
- B. Unless noted otherwise, remove existing exposed conduits and abandon existing concealed conduits in walls, ceilings and underground whether shown on drawings or not.
- C. Cap deactivated piping systems at point of cutoff.

1.08 DEMOLITION DEBRIS

- A. All demolished equipment and associated materials must be disposed of in an approved manner and in accordance with all applicable federal, state and local laws.
- B. Regularly remove debris from the site so that it's presence will not delay the progress of the work.
- C. Nothing removed from the site shall be stored, sold, or burned on site without the Owner's prior written acceptance.

1.09 RECONDITIONING EXISTING SUBSTRATES

- A. Clean surfaces on which new materials will be applied, removing adhesives, bitumen, and other adhering materials, as necessary to furnish acceptable substrates for new materials.
- B. Perform sandblasting, chipping, grinding, acid washing, etching, and other work as required by conditions encountered and new materials involved.
- C. Use of acids or other cleaning agents shall include neutralizing, washing, rinsing, and drying, as applicable.
- D. Determine substrate requirements for reconditioned surfaces in cooperation with the manufacturer's representative and installer of each new installer involved.

1.10 DISPOSAL OF FLUORESCENT LAMPS AND BALLASTS

- A. All existing fluorescent lamps and ballasts shall be properly disposed or recycled according to the Environmental Protection Agency (EPA) and Resource Conservation and Recovery Act (RCTA) standards. Include all costs for disposal or recycling in the bid proposal.
 - 1. Lamps: Dispose or recycle through "Allied Technology Group", 47375 Fremont Blvd., Fremont, CA, 94538, (510) 490-3008 or equal.
 - 2. Ballasts: Dispose or recycle through "Fulcircle Ballast Recyclers", 550 Montori Court, Pleasanton, CA, 94556, (510) 417-5967 or equal.

1.11 ASBESTOS

- A. In the event asbestos is found to be present in areas conflicting with electrical work, before continuation of work in these areas, notify the General Contractor and/or Owner's Representative and if applicable, for the removal of such hazardous material by a certified asbestos contractor.

PART 2 PRODUCTS

2.01 MATERIALS AND EQUIPMENT

- A. Materials and equipment for patching and extending work: As specified in individual sections.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify field measurements and circuiting arrangements are as indicated.
- B. Verify that abandoned wiring and equipment serve only abandoned facilities.
- C. Demolition drawings are based on field observation and existing record documents.
- D. Report discrepancies to Architect and Owner before disturbing existing installation.
- E. Beginning of demolition means installer accepts existing conditions.

3.02 PREPARATION

- A. Disconnect electrical systems in walls, floors, and ceilings to be removed.
- B. Coordinate utility service outages with utility company.
- C. Provide temporary wiring and connections to maintain existing systems in service during construction. When work must be performed on energized equipment or circuits, use personnel experienced in such operations.
- D. Existing Electrical Service: Maintain existing system in service until new system is complete and ready for service. Disable system only to make switchovers and connections. Minimize outage duration.
 - 1. Obtain permission from Owner Representative at least 24 hours and receive approval before partially or completely disabling system.
 - 2. Make temporary connections to maintain service in areas adjacent to work area.

3.03 DEMOLITION AND EXTENSION OF EXISTING ELECTRICAL WORK

- A. Perform work for removal and disposal of equipment and materials containing toxic substances regulated under the Federal Toxic Substances Control Act (TSCA) in accordance with applicable federal, state, and local regulations. Applicable equipment and materials include, but are not limited to:
 - 1. PCB-containing electrical equipment, including transformers, capacitors, and switches.
 - 2. PCB- and DEHP-containing lighting ballasts.
 - 3. Mercury-containing lamps and tubes, including fluorescent lamps, high intensity discharge (HID), arc lamps, ultra-violet, high pressure sodium, mercury vapor, ignitron tubes, neon, and incandescent.
- B. Remove, relocate, and extend existing installations to accommodate new construction.
- C. Remove abandoned wiring to source of supply.
- D. Remove exposed abandoned conduit, including abandoned conduit above accessible ceiling finishes. Cut conduit flush with walls and floors, and patch surfaces.
- E. Disconnect abandoned outlets and remove devices. Remove abandoned outlets if conduit servicing them is abandoned and removed. Provide blank cover for abandoned outlets that are not removed.

- F. Disconnect and remove abandoned panelboards and distribution equipment.
- G. Disconnect and remove electrical devices and equipment serving utilization equipment that has been removed.
- H. Disconnect and remove abandoned luminaires. Remove brackets, stems, hangers, and other accessories.
- I. Repair adjacent construction and finishes damaged during demolition and extension work.
- J. Maintain access to existing electrical installations that remain active. Modify installation or provide access panel as appropriate.
- K. Extend existing installations using materials and methods compatible with existing electrical installations, or as specified.

3.04 CLEANING AND REPAIR

- A. See Section 01 74 19 - Construction Waste Management and Disposal for additional requirements.
- B. Clean and repair existing materials and equipment that remain or that are to be reused.
- C. Panelboards: Clean exposed surfaces and check tightness of electrical connections. Replace damaged circuit breakers and provide closure plates for vacant positions. Provide typed circuit directory showing revised circuiting arrangement.
- D. Luminaires: Remove existing luminaires for cleaning. Use mild detergent to clean all exterior and interior surfaces; rinse with clean water and wipe dry. Replace lamps, ballasts and broken electrical parts.

END OF SECTION 26 05 05

SECTION 26 05 19

LOW-VOLTAGE ELECTRICAL POWER CONDUCTORS AND CABLES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Scope: furnish all labor, materials, equipment, and incidentals required to install wire and cable for a complete operable electrical system as shown on the drawings and as described in the specifications.
- B. Section Includes:
 - 1. Single conductor building wire
 - 2. Metal-clad cable.
 - 3. Wire and cable for 600 volts and less.
 - 4. Wiring connectors.
 - 5. Electrical tape.
 - 6. Heat shrink tubing.
 - 7. Oxide inhibiting compound.
 - 8. Wire pulling lubricant.
 - 9. Cable ties.
 - 10. Firestop sleeves.

1.02 RELATED REQUIREMENTS

- A. Section 07 84 00 - Firestopping.
- B. Section 26 05 00-Common Work Results for Electrical.
- C. Section 26 05 05 - Selective Demolition for Electrical: Disconnection, removal, and/or extension of existing electrical conductors and cables.
- D. Section 26 05 26 - Grounding and Bonding for Electrical Systems: Additional requirements for grounding conductors and grounding connectors.
- E. Section 26 05 53 - Identification for Electrical Systems: Identification products and requirements.
- F. Section 28 46 00 - Fire Detection and Alarm: Fire alarm system conductors and cables.
- G. Section 31 23 16 - Excavation.
- H. Section 31 23 23 - Fill: Bedding and backfilling.

1.03 REFERENCE STANDARDS

- A. ASTM B3 - Standard Specification for Soft or Annealed Copper Wire; 2013 (Reapproved 2018).
- B. ASTM B8 - Standard Specification for Concentric-Lay-Stranded Copper Conductors, Hard, Medium-Hard, or Soft; 2011 (Reapproved 2017).
- C. ASTM B33 - Standard Specification for Tin-Coated Soft or Annealed Copper Wire for Electrical Purposes; 2010, with Editorial Revision (2020).

- D. ASTM B787/B787M - Standard Specification for 19 Wire Combination Unilay-Stranded Copper Conductors for Subsequent Insulation; 2004 (Reapproved 2020).
- E. ASTM B800 - Standard Specification for 8000 Series Aluminum Alloy Wire for Electrical Purposes - Annealed and Intermediate Tempers; 2005 (Reapproved 2021).
- F. ASTM B801 - Standard Specification for Concentric-Lay-Stranded Conductors of 8000 Series Aluminum Alloy for Subsequent Covering or Insulation; 2018.
- G. ASTM D3005 - Standard Specification for Low-Temperature Resistant Vinyl Chloride Plastic Pressure-Sensitive Electrical Insulating Tape; 2017.
- H. ASTM D4388 - Standard Specification for Nonmetallic Semi-Conducting and Electrically Insulating Rubber Tapes; 2020.
- I. FS A-A-59544 - Cable and Wire, Electrical (Power, Fixed Installation); 2008a (Validated 2019).
- J. NECA 1 - Standard for Good Workmanship in Electrical Construction; 2015.
- K. NEMA WC 70 - Power Cables Rated 2000 Volts or Less for the Distribution of Electrical Energy; 2021.
- L. NETA ATS - Standard For Acceptance Testing Specifications For Electrical Power Equipment And Systems; 2021.
- M. NFPA 70 - National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- N. UL 44 - Thermoset-Insulated Wires and Cables; Current Edition, Including All Revisions.
- O. UL 83 - Thermoplastic-Insulated Wires and Cables; Current Edition, Including All Revisions.
- P. UL 267 - Outline of Investigation for Wire-Pulling Compounds; Current Edition, Including All Revisions.
- Q. UL 486A-486B - Wire Connectors; Current Edition, Including All Revisions.
- R. UL 486C - Splicing Wire Connectors; Current Edition, Including All Revisions.
- S. UL 486D - Sealed Wire Connector Systems; Current Edition, Including All Revisions.
- T. UL 510 - Polyvinyl Chloride, Polyethylene, and Rubber Insulating Tape; Current Edition, Including All Revisions.
- U. UL 1569 - Metal-Clad Cables; Current Edition, Including All Revisions.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Coordinate sizes of raceways, boxes, and equipment enclosures installed under other sections with the actual conductors to be installed, including adjustments for conductor sizes increased for voltage drop.
 - 2. Coordinate with electrical equipment installed under other sections to provide terminations suitable for use with the conductors to be installed.
 - 3. Notify Electrical Engineer of Record of any conflicts with or deviations from Contract Documents. Obtain direction before proceeding with work.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide manufacturer's standard catalog pages and data sheets for conductors and cables, including detailed information on materials, construction, ratings, listings, and available sizes, configurations, and stranding.
- C. Sustainable Design Documentation: Submit manufacturer's product data on conductor and cable showing compliance with specified lead content requirements.
- D. Product Data: Provide for each cable assembly type.
- E. Test Reports: Indicate procedures and values obtained.
- F. Design Data: Indicate voltage drop and ampacity calculations for aluminum conductors substituted for copper conductors. Include proposed modifications to raceways, boxes, wiring gutters, enclosures, etc. to accommodate substituted conductors.
- G. Field Quality Control Test Reports.
- H. Manufacturer's Installation Instructions: Indicate application conditions and limitations of use stipulated by product testing agency. Include instructions for storage, handling, protection, examination, preparation, and installation of product.
- I. Project Record Documents: Record actual installed circuiting arrangements. Record actual routing for underground circuits.
- J. Maintenance Materials: Furnish the following for Owner's use in maintenance of project.
 - 1. See Section 01 60 00 - Product Requirements, for additional provisions.
- K. Project Record Documents: Record actual locations of components and circuits.

1.06 QUALITY ASSURANCE

- A. Comply with requirements of NFPA 70.
- B. All wire and cable shall comply with applicable standards of the Underwriters Laboratories Inc.
- C. Maintain at the project site a copy of each referenced document that prescribes execution requirements.
- D. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum three years documented experience.
- E. Product Listing Organization Qualifications: An organization recognized by OSHA as a Nationally Recognized Testing Laboratory (NRTL) and acceptable to authorities having jurisdiction.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Receive, inspect, handle, and store conductors and cables in accordance with manufacturer's instructions.

1.08 FIELD CONDITIONS

- A. Do not install or otherwise handle thermoplastic-insulated conductors at temperatures lower than 14 degrees F, unless otherwise permitted by manufacturer's instructions. When installation below this temperature is unavoidable, notify the Electrical Engineer or Record and obtain direction before proceeding with work.

1.09 PROJECT CONDITIONS

- A. Existing Conditions
 - 1. Wire and cable routing shown on the Drawings is approximate unless dimensioned. Route wire and cable as required to meet project conditions.
 - 2. Where wire and cable routing is not shown, and destination only is indicated, determine exact routing and lengths required.
- B. Verify that field measurements are as shown or indicated on the Drawings.

PART 2 PRODUCTS

2.01 CONDUCTOR AND CABLE APPLICATIONS

- A. Do not use conductors and cables for applications other than as permitted by NFPA 70 and product listing.
- B. Provide single conductor building wire installed in suitable raceway unless otherwise indicated, permitted, or required.
- C. Metal-clad cable is not permitted.
- D. Manufactured wiring systems are not permitted.
- E. Concealed Dry Interior Locations: Use only building wire in raceway.
- F. Exposed Dry Interior Locations: Use only building wire in raceway.
- G. Above Accessible Ceilings: Use only building wire in raceway.
- H. Wet or Damp Interior Locations: Use only building wire in raceway.
- I. Exterior Locations: Use only building wire with Type THWN/THW insulation in raceway.
- J. Underground Installations: Use only building wire with Type THWN/THW insulation in raceway.
- K. Use solid conductor for feeders and branch circuits 10 AWG and smaller.
- L. Use stranded conductors for control circuits.
- M. Use conductor not smaller than 12 AWG for power and lighting circuits.
- N. Use conductor not smaller than 14 AWG for control circuits.
- O. Use 10 AWG conductors for 20 ampere, 120 volt branch circuits longer than 75 feet.
- P. Use 10 AWG conductors for 20 ampere, 277 volt branch circuits longer than 150 feet.
- Q. Conductor sizes are based on copper unless indicated as aluminum or "AL".

2.02 WIRE MANUFACTURERS (LISTED IN ALPHABETICALLY ORDER ONLY AND NOT NECESSARY BY PREFERENCE)

~~~~~ **PROJECT NOTE** ~~~~~

Web Address: {HL#6428174}

~~~~~ **END OF PROJECT NOTE** ~~~~~

- A. Cerro Wire LLC: www.cerrowire.com.
- B. Industrial Wire & Cable, Inc: www.iewc.com.

~~~~~ **PROJECT NOTE** ~~~~~

Web Address: {HL#6428071}

~~~~~ **END OF PROJECT NOTE** ~~~~~

- C. Southwire Company: www.southwire.com.
- D. Or approved equal.
- E. Substitutions: See Section 01 6000 - Product Requirements.

2.03 CONDUCTOR AND CABLE GENERAL REQUIREMENTS

- A. Provide products that comply with requirements of NFPA 70.
- B. Provide products listed, classified, and labeled as suitable for the purpose intended.
- C. Provide conductors and cables with lead content less than 300 parts per million.
- D. Provide new conductors and cables manufactured not more than one year prior to installation.
- E. Unless specifically indicated to be excluded, provide all required conduit, boxes, wiring, connectors, etc. as required for a complete operating system.
- F. Comply with NEMA WC 70.
- G. Comply with FS A-A-59544 where applicable.
- H. Thermoplastic-Insulated Conductors and Cables: Listed and labeled as complying with UL 83.
- I. Thermoset-Insulated Conductors and Cables: Listed and labeled as complying with UL 44.
- J. Conductors for Grounding and Bonding: Also comply with Section 26 05 26.
- K. Conductors and Cables Installed in Cable Tray: Listed and labeled as suitable for cable tray use.
- L. Conductors and Cables Installed Where Exposed to Direct Rays of Sun: Listed and labeled as sunlight resistant.
- M. Conductors and Cables Installed Exposed in Spaces Used for Environmental Air (only where specifically permitted): Plenum rated, listed and labeled as suitable for use in

return air plenums.

- N. Conductor Material:
 - 1. Provide copper conductors only. Aluminum conductors are not acceptable for this project. Conductor sizes indicated are based on copper.
 - 2. Copper Conductors: Soft drawn annealed, 98 percent conductivity, uncoated copper conductors complying with ASTM B3, ASTM B8, or ASTM B787/B787M unless otherwise indicated.
 - 3. Tinned Copper Conductors: Comply with ASTM B33.
- O. Minimum Conductor Size:
 - 1. Branch Circuits: 12 AWG.
 - a. Exceptions:
 - 1) 20 A, 120 V circuits longer than 75 feet: 10 AWG, for voltage drop.
 - 2) 20 A, 120 V circuits longer than 150 feet: 8 AWG, for voltage drop.
 - 3) 20 A, 277 V circuits longer than 150 feet: 10 AWG, for voltage drop.
 - 2. Control Circuits: 14 AWG.
- P. Where conductor size is not indicated, size to comply with NFPA 70 but not less than applicable minimum size requirements specified.
- Q. Conductor Color Coding:
 - 1. Color code conductors as indicated unless otherwise required by the authority having jurisdiction. Maintain consistent color coding throughout project.
 - 2. Color Coding Method: Integrally colored insulation.
 - a. Conductors size 4 AWG and larger may have black insulation color coded using vinyl color coding electrical tape.
 - 3. Color Code:
 - a. 480Y/277 V, 3 Phase, 4 Wire System:
 - 1) Phase A: Brown.
 - 2) Phase B: Orange.
 - 3) Phase C: Yellow.
 - 4) Neutral/Grounded: Gray.
 - b. 208Y/120 V, 3 Phase, 4 Wire System:
 - 1) Phase A: Black.
 - 2) Phase B: Red.
 - 3) Phase C: Blue.
 - 4) Neutral/Grounded: White.
 - c. Equipment Ground, All Systems: Green.
 - d. Isolated Ground, All Systems: Green with yellow stripe.
 - e. Travelers for 3-Way and 4-Way Switching: Pink.
 - f. For modifications or additions to existing wiring systems, comply with existing color code when existing code complies with NFPA 70 and is approved by the authority having jurisdiction.
 - g. For control circuits, comply with manufacturer's recommended color code.

2.04 SINGLE CONDUCTOR BUILDING WIRE

A. Manufacturers:

Twin Rivers Unified School District

Low-Voltage Electrical Power Conductors and Cables

Kitchen Upgrades at Madison ES

26 05 19 - 6

RCA Project No. 1-104-02

1. Copper Building Wire:
 - a. Cerro Wire LLC: www.cerrowire.com/#sle.
 - b. Encore Wire Corporation: www.encorewire.com/#sle.
 - c. General Cable Technologies Corporation: www.generalcable.com/#sle.
 - d. Service Wire Co: www.servicewire.com/#sle.
 - e. Southwire Company: www.southwire.com/#sle.
 - f. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Description: Single conductor insulated wire.
- C. Conductor Stranding:
 1. Feeders and Branch Circuits:
 - a. Size 10 AWG and Smaller: Solid.
 - b. Size 8 AWG and Larger: Stranded.
 2. Control Circuits: Stranded.
- D. Insulation Voltage Rating: 600 V.
- E. Insulation:
 1. Copper Building Wire: Type THHN/THWN or THHN/THWN-2.
 - a. Size 4 AWG and Larger: Type XHHW-2 or THHN/THWN.
 - b. Installed Underground: Type XHHW-2 or THHN/THWN.
 - c. Fixture Wiring Within Luminaires: Type TFFN/TFN for luminaires with labeled maximum temperature of 90 degrees C; Approved suitable type for luminaires with labeled maximum temperature greater than 90 degrees C.
- F. Conductor: Copper.
 1. For Sizes Smaller Than 4 AWG: Copper.
 2. For Sizes 4 AWG and Larger: Copper.
- G. Insulation Voltage Rating: 600 volts.
- H. Insulation: NFPA 70, Type THHN/THWN.

2.05 METAL-CLAD CABLE

- A. Manufacturers:
 1. AFC Cable Systems Inc: www.afcweb.com/#sle.
 2. Encore Wire Corporation: www.encorewire.com/#sle.
 3. Service Wire Co: www.servicewire.com/#sle.
 4. Southwire Company: www.southwire.com/#sle.
 5. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Description: NFPA 70, Type MC cable listed and labeled as complying with UL 1569, and listed for use in classified firestop systems to be used.
- C. Conductor Stranding:
 1. Size 10 AWG and Smaller: Solid.
 2. Size 8 AWG and Larger: Stranded.
- D. Insulation Voltage Rating: 600 V.
- E. Insulation: Type THHN, THHN/THWN, or THHN/THWN-2.

- F. Provide oversized neutral conductors.
- G. Provide dedicated neutral conductor for each phase conductor.
- H. Grounding: Full-size integral equipment grounding conductor.
 - 1. Provide additional isolated/insulated grounding conductor.
- I. Armor: Steel, interlocked tape.
- J. Provide PVC jacket applied over cable armor.

2.06 WIRING CONNECTORS

- A. Description: Wiring connectors appropriate for the application, suitable for use with the conductors to be connected, and listed as complying with UL 486A-486B or UL 486C as applicable.
- B. Connectors for Grounding and Bonding: Comply with Section 26 05 26.
- C. Wiring Connectors for Splices and Taps:
 - 1. Copper Conductors Size 8 AWG and Smaller: Use twist-on insulated spring connectors.
 - 2. Copper Conductors Size 6 AWG and Larger: Use mechanical connectors or compression connectors.
- D. Wiring Connectors for Terminations:
 - 1. Provide terminal lugs for connecting conductors to equipment furnished with terminations designed for terminal lugs.
 - 2. Provide compression adapters for connecting conductors to equipment furnished with mechanical lugs when only compression connectors are specified.
 - 3. Where over-sized conductors are larger than the equipment terminations can accommodate, provide connectors suitable for reducing to appropriate size, but not less than required for the rating of the overcurrent protective device.
 - 4. Provide motor pigtail connectors for connecting motor leads in order to facilitate disconnection.
 - 5. Copper Conductors Size 8 AWG and Larger: Use mechanical connectors or compression connectors where connectors are required.
 - 6. Stranded Conductors Size 10 AWG and Smaller: Use crimped terminals for connections to terminal screws.
 - 7. Conductors for Control Circuits: Use crimped terminals for all connections.
- E. Do not use insulation-piercing or insulation-displacement connectors designed for use with conductors without stripping insulation.
- F. Do not use push-in wire connectors as a substitute for twist-on insulated spring connectors.
- G. Twist-on Insulated Spring Connectors: Rated 600 V, 221 degrees F for standard applications and 302 degrees F for high temperature applications; pre-filled with sealant and listed as complying with UL 486D for damp and wet locations.
 - 1. Manufacturers:
 - a. 3M: www.3m.com/#sle.
 - b. Ideal Industries, Inc: www.idealindustries.com/#sle.

- c. NSI Industries LLC: www.nsiindustries.com/#sle.
 - d. Or approved equal.
 - e. Substitutions: See Section 01 60 00 - Product Requirements.
- H. Mechanical Connectors: Provide bolted type or set-screw type.
- 1. Manufacturers:
 - a. Burndy LLC: www.burndy.com/#sle.
 - b. IlSCO: www.ilSCO.com/#sle.
 - c. Thomas & Betts Corporation: www.tnb.com/#sle.
 - d. Or approved equal.
 - e. Substitutions: See Section 01 60 00 - Product Requirements.
- I. Compression Connectors: Provide circumferential type or hex type crimp configuration with prestressed insulation to equal the insulation of wire being installed. .
- 1. Manufacturers:
 - a. Burndy LLC: www.burndy.com/#sle.
 - b. IlSCO: www.ilSCO.com/#sle.
 - c. Thomas & Betts Corporation: www.tnb.com/#sle.
 - d. Or approved equal.
 - e. Substitutions: See Section 01 60 00 - Product Requirements.
- J. Crimped Terminals: Nylon-insulated, with insulation grip and terminal configuration suitable for connection to be made.
- 1. Manufacturers:
 - a. Burndy LLC: www.burndy.com/#sle.
 - b. IlSCO: www.ilSCO.com/#sle.
 - c. Thomas & Betts Corporation: www.tnb.com/#sle.
 - d. Or approved equal.
 - e. Substitutions: See Section 01 60 00 - Product Requirements.
- K. Power Conductor Splicers
- 1. Blackburn.
 - 2. Burndy "Hylug".
 - 3. IlSCO.
 - 4. O.Z. Gedney.

2.07 ACCESSORIES

- A. Electrical Tape:
- 1. Manufacturers:
 - a. 3M: www.3m.com/#sle.
 - b. Plymouth Rubber Europa: www.plymouthrubber.com/#sle.
 - c. Or approved equal.
 - d. Substitutions: See Section 01 60 00 - Product Requirements.
 - 2. Vinyl Color Coding Electrical Tape: Integrally colored to match color code indicated; listed as complying with UL 510; minimum thickness of 7 mil; resistant to abrasion, corrosion, and sunlight; suitable for continuous temperature

- environment up to 221 degrees F.
3. Vinyl Insulating Electrical Tape: Complying with ASTM D3005 and listed as complying with UL 510; minimum thickness of 7 mil; resistant to abrasion, corrosion, and sunlight; conformable for application down to 0 degrees F and suitable for continuous temperature environment up to 221 degrees F.
 4. Rubber Splicing Electrical Tape: Ethylene Propylene Rubber (EPR) tape, complying with ASTM D4388; minimum thickness of 30 mil; suitable for continuous temperature environment up to 194 degrees F and short-term 266 degrees F overload service.
 5. Electrical Filler Tape: Rubber-based insulating moldable putty, minimum thickness of 125 mil; suitable for continuous temperature environment up to 176 degrees F.
 6. Varnished Cambric Electrical Tape: Cotton cambric fabric tape, with or without adhesive, oil-primed and coated with high-grade insulating varnish; minimum thickness of 7 mil; suitable for continuous temperature environment up to 221 degrees F.
 7. Moisture Sealing Electrical Tape: Insulating mastic compound laminated to flexible, all-weather vinyl backing; minimum thickness of 90 mil.
- B. Heat Shrink Tubing: Heavy-wall, split-resistant, with factory-applied adhesive; rated 600 V; suitable for direct burial applications; listed as complying with UL 486D.
1. Manufacturers:
 - a. 3M: www.3m.com/#sle.
 - b. Burndy LLC: www.burndy.com/#sle.
 - c. Thomas & Betts Corporation: www.tnb.com/#sle.
 - d. Or approved equal.
 - e. Substitutions: See Section 01 60 00 - Product Requirements.
- C. Oxide Inhibiting Compound: Listed; suitable for use with the conductors or cables to be installed.
1. Manufacturers:
 - a. Burndy LLC: www.burndy.com/#sle.
 - b. Ideal Industries, Inc: www.idealindustries.com/#sle.
 - c. IlSCO: www.ilsco.com/#sle.
 - d. Or approved equal.
 - e. Substitutions: See Section 01 60 00 - Product Requirements.
- D. Wire Pulling Lubricant:
1. Manufacturers:
 - a. 3M: www.3m.com/#sle.
 - b. American Polywater Corporation: www.polywater.com/#sle.
 - c. Ideal Industries, Inc: www.idealindustries.com/#sle.
 - d. Or approved equal.
 - e. Substitutions: See Section 01 60 00 - Product Requirements.
 2. Listed and labeled as complying with UL 267.
 3. Suitable for use with conductors/cables and associated insulation/jackets to be installed.

4. Suitable for use at installation temperature.
- E. Cable Ties: Material and tensile strength rating suitable for application.
 1. Manufacturers:
 - a. Burndy LLC: www.burndy.com/#sle.
 - b. Scotchflex.
 - c. Thomas & Betts.
 - d. Or approved equal.
 - e. Substitutions: See Section 01 60 00 - Product Requirements.
- F. Sealing Systems for Roof Penetrations: Premanufactured components and accessories as required to preserve integrity of roofing system and maintain roof warranty; suitable for cables and roofing system to be installed; designed to accommodate existing penetrations where applicable.
 1. Products:
 - a. Menzies Metal Products; Electrical Roof Stack and Cap: www.menzies-metal.com/#sle.
 - b. Menzies Metal Products; Electrical Retro Box: www.menzies-metal.com/#sle.
 - c. Substitutions: See Section 01 60 00 - Product Requirements.
- G. Firestop Sleeves: Listed; provide as required to preserve fire resistance rating of building elements.
 1. Products:
 - a. HoldRite, a brand of Reliance Worldwide Corporation; HydroFlame Pro Series/HydroFlame Custom Built: www.holdrite.com/#sle.
 - b. Substitutions: See Section 01 60 00 - Product Requirements.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that interior of building has been protected from weather.
- B. Verify that work likely to damage wire and cable has been completed.
- C. Verify that raceways, boxes, and equipment enclosures are installed and are properly sized to accommodate conductors and cables in accordance with NFPA 70.
- D. Verify that raceway installation is complete and supported.
- E. Verify that field measurements are as indicated.
- F. Verify that conditions are satisfactory for installation prior to starting work.

3.02 PREPARATION

- A. Clean raceways thoroughly to remove foreign materials before installing conductors and cables.

3.03 INSTALLATION

- A. Circuiting Requirements:

1. Unless dimensioned, circuit routing indicated is diagrammatic.
 2. When circuit destination is indicated without specific routing, determine exact routing required.
 3. Arrange circuiting to minimize splices.
 4. Include circuit lengths required to install connected devices within 10 ft of location indicated.
 5. Maintain separation of Class 1, Class 2, and Class 3 remote-control, signaling, and power-limited circuits in accordance with NFPA 70.
 6. Maintain separation of wiring for emergency systems in accordance with NFPA 70.
 7. Circuiting Adjustments: Unless otherwise indicated, when branch circuits are indicated as separate, combining them together in a single raceway is permitted, under the following conditions:
 - a. Provide no more than six current-carrying conductors in a single raceway. Dedicated neutral conductors are considered current-carrying conductors.
 - b. Increase size of conductors as required to account for ampacity derating.
 - c. Size raceways, boxes, etc. to accommodate conductors.
 - d. Record any circuit changes on record drawings.
 8. Common Neutrals: Sharing of neutral/grounded conductors among branch circuits is not permitted.
 9. Provide oversized neutral/grounded conductors where indicated and as specified below.
 - a. Provide 200 percent rated neutral for feeders fed from K-rated transformers.
 - b. Provide 200 percent rated neutral for feeders serving panelboards with 200 percent rated neutral bus.
- B. Install products in accordance with manufacturer's instructions.
- C. Perform work in accordance with NECA 1 (general workmanship).
- D. Install metal-clad cable (Type MC) in accordance with NECA 120.
- E. Installation in Raceway:
 1. Tape ends of conductors and cables to prevent infiltration of moisture and other contaminants.
 2. Pull all conductors and cables together into raceway at same time.
 3. Do not damage conductors and cables or exceed manufacturer's recommended maximum pulling tension and sidewall pressure.
 4. Use suitable wire pulling lubricant where necessary, except when lubricant is not recommended by the manufacturer.
- F. Paralleled Conductors: Install conductors of the same length and terminate in the same manner.
- G. Secure and support conductors and cables in accordance with NFPA 70 using suitable supports and methods approved by the authority having jurisdiction. Provide independent support from building structure. Do not provide support from raceways, piping, ductwork, or other systems.

1. Installation Above Suspended Ceilings: Do not provide support from ceiling support system. Do not provide support from ceiling grid or allow conductors and cables to lay on ceiling tiles.
 2. Installation in Vertical Raceways: Provide supports where vertical rise exceeds permissible limits.
- H. Terminate cables using suitable fittings.
1. Metal-Clad Cable (Type MC):
 - a. Use listed fittings.
 - b. Cut cable armor only using specialized tools to prevent damaging conductors or insulation. Do not use hacksaw or wire cutters to cut armor.
 - c. Do not use direct-bearing set-screw type fittings for cables with aluminum armor.
- I. Install conductors with a minimum of 12 inches of slack at each outlet.
- J. Where conductors are installed in enclosures for future termination by others, provide a minimum of 5 feet of slack.
- K. Neatly train and bundle conductors inside boxes, wireways, panelboards and other equipment enclosures.
- L. Group or otherwise identify neutral/grounded conductors with associated ungrounded conductors inside enclosures in accordance with NFPA 70.
- M. Make wiring connections using specified wiring connectors.
1. Make splices and taps only in accessible boxes. Do not pull splices into raceways or make splices in conduit bodies or wiring gutters.
 2. Remove appropriate amount of conductor insulation for making connections without cutting, nicking or damaging conductors.
 3. Do not remove conductor strands to facilitate insertion into connector.
 4. Clean contact surfaces on conductors and connectors to suitable remove corrosion, oxides, and other contaminates. Do not use wire brush on plated connector surfaces.
 5. Connections for Aluminum Conductors: Fill connectors with oxide inhibiting compound where not pre-filled by manufacturer.
 6. Mechanical Connectors: Secure connections according to manufacturer's recommended torque settings.
 7. Compression Connectors: Secure connections using manufacturer's recommended tools and dies.
- N. Insulate splices and taps that are made with uninsulated connectors using methods suitable for the application, with insulation and mechanical strength at least equivalent to unspliced conductors.
1. Dry Locations: Use insulating covers specifically designed for the connectors, electrical tape, or heat shrink tubing.
 - a. For taped connections, first apply adequate amount of rubber splicing electrical tape or electrical filler tape, followed by outer covering of vinyl insulating electrical tape.

- b. For taped connections likely to require re-entering, including motor leads, first apply varnished cambric electrical tape, followed by adequate amount of rubber splicing electrical tape, followed by outer covering of vinyl insulating electrical tape.
- 2. Damp Locations: Use insulating covers specifically designed for the connectors, electrical tape, or heat shrink tubing.
 - a. For connections with insulating covers, apply outer covering of moisture sealing electrical tape.
 - b. For taped connections, follow same procedure as for dry locations but apply outer covering of moisture sealing electrical tape.
- 3. Wet Locations: Use heat shrink tubing.
- O. Insulate ends of spare conductors using vinyl insulating electrical tape.
- P. Field-Applied Color Coding: Where vinyl color coding electrical tape is used in lieu of integrally colored insulation as permitted in Part 2 under "Color Coding", apply half overlapping turns of tape at each termination and at each location conductors are accessible.
- Q. Identify conductors and cables in accordance with Section 26 05 53.
- R. Color Code Legend: Provide identification label identifying color code for ungrounded conductors at each piece of feeder or branch-circuit distribution equipment when premises has feeders or branch circuits served by more than one nominal voltage system.
- S. Install firestopping to preserve fire resistance rating of partitions and other elements, using materials and methods specified in Section 07 84 00.
- T. Unless specifically indicated to be excluded, provide final connections to all equipment and devices, including those furnished by others, as required for a complete operating system.
- U. Install wire and cable securely, in a neat and workmanlike manner, as specified in NECA 1.
- V. Route wire and cable as required to meet project conditions.
 - 1. Wire and cable routing indicated is approximate unless dimensioned.
 - 2. Where wire and cable destination is indicated and routing is not shown, determine exact routing and lengths required.
 - 3. Include wire and cable of lengths required to install connected devices within 10 ft of location shown.
- W. Use wiring methods indicated.
- X. Pull all conductors into raceway at same time.
- Y. Use suitable wire pulling lubricant for building wire 4 AWG and larger.
- Z. Protect exposed cable from damage.
- AA. Support cables above accessible ceiling, using spring metal clips or metal cable ties to support cables from structure or ceiling suspension system. Do not rest cable on ceiling panels.
- BB. Use suitable cable fittings and connectors.

- CC. Neatly train and lace wiring inside boxes, equipment, and panelboards.
- DD. Clean conductor surfaces before installing lugs and connectors.
- EE. Make splices, taps, and terminations to carry full ampacity of conductors with no perceptible temperature rise.
- FF. Use split bolt connectors for copper conductor splices and taps, 6 AWG and larger. Tape uninsulated conductors and connector with electrical tape to 150 percent of insulation rating of conductor.
- GG. Use solderless pressure connectors with insulating covers for copper conductor splices and taps, 8 AWG and smaller.
- HH. Use insulated spring wire connectors with plastic caps for copper conductor splices and taps, 10 AWG and smaller.
- II. Identify and color code wire and cable under provisions of Section 26 05 53. Identify each conductor with its circuit number or other designation indicated.

3.04 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements, for additional requirements.
- B. Inspect wire for physical damage and proper connections.
- C. Measure tightness of bolted connections and compare torque measurements with manufacturer's values.
- D. Inspect and test in accordance with NETA ATS, except Section 4.
- E. Perform inspections and tests listed in NETA ATS, Section 7.3.2. The insulation resistance test is required for all conductors. The resistance test for parallel conductors listed as optional is not required.
 - 1. Disconnect surge protective devices (SPDs) prior to performing any high potential testing. Replace SPDs damaged by performing high potential testing with SPDs connected.
- F. Correct deficiencies and replace damaged or defective conductors and cables.
- G. Perform field inspection
- H. Megger test and record all feeder conductors.
 - 1. Replace conductors failing test.
 - 2. Test replaced conductors in same manner.

END OF SECTION 26 05 19

SECTION 26 05 26

GROUNDING AND BONDING FOR ELECTRICAL SYSTEMS

PART 1 GENERAL

1.01 SUMMARY

- A. Scope: provide a complete grounding and bonding system as shown on the electrical drawings and as described in the specifications such that the entire raceway system including all equipment enclosures, data racks, telephone backboards and cabinets, fixtures, and outlets, etc. are effectively connected to ground.
- B. Grounding and bonding requirements.
- C. Section includes:
 - 1. Materials and methods for grounding systems and equipment.
 - 2. Grounding electrodes and conductors.
 - 3. Equipment ground conductors.
 - 4. Bonding
 - 5. Grounding well.
 - 6. Ground bars.
 - 7. Chemically enhanced ground electrodes.
 - 8. Ground plate electrodes.
- D. Connectors for grounding and bonding.
- E. Ground bars.
- F. Ground rod electrodes.
- G. Chemically-enhanced ground electrodes.
- H. Ground plate electrodes.
- I. Ground enhancement material.
- J. Ground access wells.
- K. Pre-fabricated signal reference grids.
- L. Provide all components necessary to complete the grounding system(s) consisting of:
 - 1. Metal underground water pipe.
 - 2. Metal frame of the building.
 - 3. Concrete-encased electrode.
 - 4. Existing metal underground gas piping system.
 - 5. Metal underground gas piping system.

1.02 RELATED REQUIREMENTS

- A. Section 26 05 00-Common Work Results for Electrical.
- B. Section 26 05 19 - Low-Voltage Electrical Power Conductors and Cables: Additional requirements for conductors for grounding and bonding, including conductor color coding.
 - 1. Includes oxide inhibiting compound.

- C. Section 26 05 53 - Identification for Electrical Systems: Identification products and requirements.
- D. Section 26 56 00 - Exterior Lighting: Additional grounding and bonding requirements for pole-mounted luminaires.

1.03 REFERENCE STANDARDS

- A. IEEE 81 - IEEE Guide for Measuring Earth Resistivity, Ground Impedance, and Earth Surface Potentials of a Grounding System; 2012.
- B. NECA 1 - Standard for Good Workmanship in Electrical Construction; 2015.
- C. NEMA GR 1 - Grounding Rod Electrodes and Grounding Rod Electrode Couplings; 2022.
- D. NETA ATS - Standard For Acceptance Testing Specifications For Electrical Power Equipment And Systems; 2021.
- E. NFPA 70 - National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- F. NFPA 99 - Health Care Facilities Code; 2021, with Amendment.
- G. NFPA 780 - Standard for the Installation of Lightning Protection Systems; 2023.
- H. UL 467 - Grounding and Bonding Equipment; Current Edition, Including All Revisions.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Verify exact locations of underground metal water service pipe entrances to building.
 - 2. Coordinate the work with other trades to provide steel reinforcement complying with specified requirements for concrete-encased electrode.
 - 3. Notify Electrical Engineer of Record of any conflicts with or deviations from Contract Documents. Obtain direction before proceeding with work.
- B. Sequencing:
 - 1. Do not install ground rod electrodes until final backfill and compaction is complete.

1.05 PERFORMANCE REQUIREMENTS

- A. Grounding System Resistance:
 - 1. Building grounding electrode: 10 ohms.
 - 2. Separately Derived Sources Grounding Electrode: 10 ohms
 - 3. Non-current carrying metal parts: 25 ohms
 - 4. Grounds not covered above: 25 ohms

1.06 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittals procedures.
- B. Product Data: Provide manufacturer's standard catalog pages and data sheets for grounding and bonding system components.

- C. Shop Drawings:
 - 1. Indicate proposed arrangement for signal reference grids. Include locations of items to be bonded and methods of connection.
- D. Product Data: Provide for grounding electrodes and connections.
- E. Test Reports: Indicate overall resistance to ground and resistance of each electrode.
- F. Manufacturer's Instructions: Indicate application conditions and limitations of use stipulated by product testing agency. Include instructions for storage, handling, protection, examination, preparation, and installation of product.
- G. Field quality control test reports.
- H. Project Record Documents: Record actual locations of grounding electrode system components and connections.
- I. Project Record Documents: Record actual locations of components and grounding electrodes.
- J. Certificate of Compliance: Indicate approval of installation by authority having jurisdiction.

1.07 QUALITY ASSURANCE

- A. Comply with requirements of NFPA 70.
- B. Maintain at the project site a copy of each referenced document that prescribes execution requirements.
- C. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum three years documented experience.
- D. Installer Qualifications for Signal Reference Grids: Company with minimum five years documented experience with high frequency grounding systems.
- E. Product Listing Organization Qualifications: An organization recognized by OSHA as a Nationally Recognized Testing Laboratory (NRTL) and acceptable to authorities having jurisdiction.

1.08 DELIVERY, STORAGE, AND HANDLING

- A. Receive, inspect, handle, and store products in accordance with manufacturer's instructions.

PART 2 PRODUCTS

2.01 GROUNDING AND BONDING REQUIREMENTS

- A. Existing Work: Where existing grounding and bonding system components are indicated to be reused, they may be reused only where they are free from corrosion, integrity and continuity are verified, and where acceptable to the authority having jurisdiction.
- B. Do not use products for applications other than as permitted by NFPA 70 and product listing.

- C. Unless specifically indicated to be excluded, provide all required components, conductors, connectors, conduit, boxes, fittings, supports, accessories, etc. as necessary for a complete grounding and bonding system.
- D. Where conductor size is not indicated, size to comply with NFPA 70 but not less than applicable minimum size requirements specified.
- E. Grounding System Resistance:
 - 1. Achieve specified grounding system resistance under normally dry conditions unless otherwise approved by Electrical Engineer of Record. Precipitation within the previous 48 hours does not constitute normally dry conditions.
 - 2. Grounding Electrode System: Not greater than 5 ohms to ground, when tested according to IEEE 81 using "fall-of-potential" method.
 - 3. Between Grounding Electrode System and Major Electrical Equipment Frames, System Neutral, and Derived Neutral Points: Not greater than 0.5 ohms, when tested using "point-to-point" methods.
- F. Grounding Electrode System:
 - 1. Provide connection to required and supplemental grounding electrodes indicated to form grounding electrode system.
 - a. Provide continuous grounding electrode conductors without splice or joint.
 - b. Install grounding electrode conductors in raceway where exposed to physical damage. Bond grounding electrode conductor to metallic raceways at each end with bonding jumper.
 - 2. Metal Underground Water Pipe(s):
 - a. Provide connection to underground metal domestic and fire protection (where present) water service pipe(s) that are in direct contact with earth for at least 10 feet at an accessible location not more than 5 feet from the point of entrance to the building.
 - b. Provide bonding jumper(s) around insulating joints/pipes as required to make pipe electrically continuous.
 - c. Provide bonding jumper around water meter of sufficient length to permit removal of meter without disconnecting jumper.
 - 3. Metal In-Ground Support Structure:
 - a. Provide connection to metal in-ground support structure that is in direct contact with earth in accordance with NFPA 70.
 - 4. Concrete-Encased Electrode:
 - a. Provide connection to concrete-encased electrode consisting of not less than 20 feet of bare copper conductor not smaller than 4 AWG embedded within concrete foundation or footing that is in direct contact with earth in accordance with NFPA 70.
 - 5. Ground Ring:
 - a. Where indicated on drawings, provide a ground ring encircling the building or structure consisting of bare copper conductor not less than 2 AWG in direct contact with earth, installed at a depth of not less than 30 inches.
 - b. Where location is not indicated, locate ground ring conductor at least 24 inches outside building perimeter foundation.

- c. Provide ground enhancement material around conductor where indicated.
- d. Provide connection from ground ring conductor to:
 - 1) Perimeter columns of metal building frame.
 - 2) Ground rod electrodes located as indicated.
 - 3) Building structural steel.
6. Ground Rod Electrode(s):
 - a. Provide three electrodes in an equilateral triangle configuration unless otherwise indicated or required.
 - b. Space electrodes not less than 10 feet from each other and any other ground electrode.
 - c. Where location is not indicated, locate electrode(s) at least 5 feet outside building perimeter foundation as near as possible to electrical service entrance; where possible, locate in softscape (uncovered) area.
 - d. Provide ground enhancement material around electrode where indicated.
 - e. Provide ground access well for each electrode.
7. Provide additional ground electrode(s) as required to achieve specified grounding electrode system resistance.
8. Ground Bar: Provide ground bar, separate from service equipment enclosure, for common connection point of grounding electrode system bonding jumpers as permitted in NFPA 70. Connect grounding electrode conductor provided for service-supplied system grounding to this ground bar.
 - a. Ground Bar Size: 1/4 by 4 by 12 inches unless otherwise indicated or required.
 - b. Where ground bar location is not indicated, locate in accessible location as near as possible to service disconnect enclosure.
 - c. Ground Bar Mounting Height: 18 inches above finished floor unless otherwise indicated.
9. Ground Riser: Provide common grounding electrode conductor not less than 3/0 AWG for tap connections to multiple separately derived systems as permitted in NFPA 70.
- G. Service-Supplied System Grounding:
 1. For each service disconnect, provide grounding electrode conductor to connect neutral (grounded) service conductor to grounding electrode system. Unless otherwise indicated, make connection at neutral (grounded) bus in service disconnect enclosure.
 2. For each service disconnect, provide main bonding jumper to connect neutral (grounded) bus to equipment ground bus where not factory-installed. Do not make any other connections between neutral (grounded) conductors and ground on load side of service disconnect.
- H. Grounding for Separate Building or Structure Supplied by Feeder(s) or Branch Circuits:
 1. Provide grounding electrode system for each separate building or structure.
 2. Provide equipment grounding conductor routed with supply conductors.
 3. For each disconnecting means, provide grounding electrode conductor to connect equipment ground bus to grounding electrode system.

4. Do not make any connections and remove any factory-installed jumpers between neutral (grounded) conductors and ground.
- I. Separately Derived System Grounding:
1. Separately derived systems include, but are not limited to:
 - a. Transformers (except autotransformers such as buck-boost transformers).
 - b. Uninterruptible power supplies (UPS), when configured as separately derived systems.
 - c. Generators, when neutral is switched in the transfer switch.
 2. Provide grounding electrode conductor to connect derived system grounded conductor to common grounding electrode conductor ground riser. Unless otherwise indicated, make connection at neutral (grounded) bus in source enclosure.
 3. Provide bonding jumper to connect derived system grounded conductor to nearest metal building frame and nearest metal water piping in the area served by the derived system, where not already used as a grounding electrode for the derived system. Make connection at same location as grounding electrode conductor connection.
 4. Where common grounding electrode conductor ground riser is used for tap connections to multiple separately derived systems, provide bonding jumper to connect the metal building frame and metal water piping in the area served by the derived system to the common grounding electrode conductor.
 5. Outdoor Source: Where the source of the separately derived system is located outside the building or structure supplied, provide connection to grounding electrode at source in accordance with NFPA 70.
 6. Provide system bonding jumper to connect system grounded conductor to equipment ground bus. Make connection at same location as grounding electrode conductor connection. Do not make any other connections between neutral (grounded) conductors and ground on load side of separately derived system disconnect.
 7. Where the source and first disconnecting means are in separate enclosures, provide supply-side bonding jumper between source and first disconnecting means.
- J. Bonding and Equipment Grounding:
1. Provide bonding for equipment grounding conductors, equipment ground busses, metallic equipment enclosures, metallic raceways and boxes, device grounding terminals, and other normally non-current-carrying conductive materials enclosing electrical conductors/equipment or likely to become energized as indicated and in accordance with NFPA 70.
 2. Provide insulated equipment grounding conductor in each feeder and branch circuit raceway. Do not use raceways as sole equipment grounding conductor.
 3. Where circuit conductor sizes are increased for voltage drop, increase size of equipment grounding conductor proportionally in accordance with NFPA 70.
 4. Unless otherwise indicated, connect wiring device grounding terminal to branch circuit equipment grounding conductor and to outlet box with bonding jumper.

5. Terminate branch circuit equipment grounding conductors on solidly bonded equipment ground bus only. Do not terminate on neutral (grounded) or isolated/insulated ground bus.
 6. Provide bonding jumper across expansion or expansion/deflection fittings provided to accommodate conduit movement.
 7. Provide bonding for interior metal piping systems in accordance with NFPA 70. This includes, but is not limited to:
 - a. Metal water piping where not already effectively bonded to metal underground water pipe used as grounding electrode.
 - b. Metal gas piping.
 - c. Metal process piping.
 8. Provide bonding for interior metal air ducts.
 9. Provide bonding for metal building frame.
 10. Provide bonding for metal siding not effectively bonded through attachment to metal building frame.
 11. Provide bonding and equipment grounding for pools and fountains and associated equipment in accordance with NFPA 70.
 12. Provide redundant grounding and bonding for patient care areas of health care facilities in accordance with NFPA 70 and NFPA 99.
- K. Communications Systems Grounding and Bonding:
1. Provide intersystem bonding termination at service equipment or metering equipment enclosure and at disconnecting means for any additional buildings or structures in accordance with NFPA 70.
 2. Provide bonding jumper in raceway from intersystem bonding termination to each communications room or backboard and provide ground bar for termination.
 - a. Bonding Jumper Size: 6 AWG, unless otherwise indicated or required.
 - b. Raceway Size: 3/4 inch trade size unless otherwise indicated or required.
 - c. Ground Bar Size: 1/4 by 2 by 12 inches unless otherwise indicated or required.
 - d. Ground Bar Mounting Height: 18 inches above finished floor unless otherwise indicated.
- L. Pole-Mounted Luminaires: Also comply with Section 26 56 00.

2.02 GROUNDING AND BONDING COMPONENTS

- A. General Requirements:
1. Provide products listed, classified, and labeled as suitable for the purpose intended.
 2. Provide products listed and labeled as complying with UL 467 where applicable.
- B. Conductors for Grounding and Bonding, in Addition to Requirements of Section 26 05 26:
1. Use insulated copper conductors unless otherwise indicated.
 - a. Exceptions:

- 1) Use bare copper conductors where installed underground in direct contact with earth.
- 2) Use bare copper conductors where directly encased in concrete (not in raceway).
2. Factory Pre-fabricated Bonding Jumpers: Furnished with factory-installed ferrules; size braided cables to provide equivalent gauge of specified conductors.
- C. Connectors for Grounding and Bonding:
 1. Description: Connectors appropriate for the application and suitable for the conductors and items to be connected; listed and labeled as complying with UL 467.
 2. Unless otherwise indicated, use exothermic welded connections for underground, concealed and other inaccessible connections.
 - a. Exceptions:
 - 1) Use mechanical connectors for connections to electrodes at ground access wells.
 3. Unless otherwise indicated, use mechanical connectors for accessible connections.
 - a. Exceptions:
 - 1) Use exothermic welded connections for connections to metal building frame.
 4. Manufacturers - Mechanical and Compression Connectors:
 - a. Advanced Lightning Technology (ALT): www.altfab.com/#sle.
 - b. Burndy LLC: www.burndy.com/#sle.
 - c. Harger Lightning & Grounding: www.harger.com/#sle.
 - d. Thomas & Betts Corporation: www.tnb.com/#sle.
 - e. Or approved equal.
 - f. Substitutions: See Section 01 60 00 - Product Requirements.
 5. Manufacturers - Exothermic Welded Connections:
 - a. Burndy LLC: www.burndy.com/#sle.
 - b. ThermOweld, subsidiary of Continental Industries; division of Burndy LLC: www.thermoweld.com/#sle.
 - c. Or approved equal.
 - d. Substitutions: See Section 01 60 00 - Product Requirements.
- D. Ground Bars:
 1. Description: Copper rectangular ground bars with mounting brackets and insulators.
 2. Size: As indicated.
 3. Holes for Connections: As indicated or as required for connections to be made.
 4. Manufacturers:
 - a. Advanced Lightning Technology (ALT): www.altfab.com/#sle.
 - b. Harger Lightning & Grounding: www.harger.com/#sle.
 - c. ThermOweld, subsidiary of Continental Industries; division of Burndy LLC: www.thermoweld.com/#sle.
 - d. Or approved equal.

- e. Substitutions: See Section 01 60 00 - Product Requirements.
- E. Ground Rod Electrodes:
 - 1. Comply with NEMA GR 1.
 - 2. Material: Copper-bonded (copper-clad) steel.
 - 3. Size: 3/4 inch diameter by 10 feet length, unless otherwise indicated.
 - 4. Where rod lengths of greater than 10 feet are indicated or otherwise required, sectionalized ground rods may be used.
 - 5. Manufacturers:
 - a. Advanced Lightning Technology (ALT): www.altfab.com/#sle.
 - b. Galvan Industries, Inc: www.galvanelectrical.com/#sle.
 - c. Harger Lightning & Grounding: www.harger.com/#sle.
 - d. Or approved equal.
 - e. Substitutions: See Section 01 60 00 - Product Requirements.
- F. Chemically-Enhanced Ground Electrodes:
 - 1. Description: Copper tube factory-filled with electrolytic salts designed to provide a low-impedance ground in locations with high soil resistivity; straight (for vertical installations) or L-shaped (for horizontal installations) as indicated or as required.
 - 2. Length: 10 feet.
 - 3. Integral Pigtail: Factory-attached, sized not less than grounding electrode conductor to be attached.
 - 4. Backfill Material: Grounding enhancement material recommended by electrode manufacturer.
 - 5. Manufacturers:
 - a. Advanced Lightning Technology (ALT): www.altfab.com/#sle.
 - b. Harger Lightning & Grounding: www.harger.com/#sle.
 - c. ThermOweld, subsidiary of Continental Industries; division of Burndy LLC: www.thermoweld.com/#sle.
 - d. Or approved equal.
 - e. Substitutions: See Section 01 60 00 - Product Requirements.
- G. Ground Plate Electrodes:
 - 1. Material: Copper.
 - 2. Size: 24 by 24 by 1/4 inches, unless otherwise indicated.
 - 3. Manufacturers:
 - a. Advanced Lightning Technology (ALT): www.altfab.com/#sle.
 - b. Harger Lightning & Grounding: www.harger.com/#sle.
 - c. ThermOweld, subsidiary of Continental Industries; division of Burndy LLC: www.thermoweld.com/#sle.
 - d. Or approved equal.
 - e. Substitutions: See Section 01 60 00 - Product Requirements.
- H. Ground Enhancement Material:
 - 1. Description: Factory-mixed conductive material designed for permanent and maintenance-free improvement of grounding effectiveness by lowering resistivity.

2. Resistivity: Not more than 20 ohm-cm in final installed form.
3. Manufacturers:
 - a. Harger Lightning & Grounding: www.harger.com/#sle.
 - b. ThermOweld, subsidiary of Continental Industries; division of Burndy LLC: www.thermoweld.com/#sle.
 - c. Or approved equal.
 - d. Substitutions: See Section 01 60 00 - Product Requirements.
- I. Ground Access Wells:
 1. Description: Open bottom round or rectangular well with access cover for testing and inspection; suitable for the expected load at the installed location.
 - a. Areas Exposed to Vehicular Traffic: Rated for not less than 2000 pounds vertical design load.
 2. Size: As required to provide adequate access for testing and inspection, but not less than minimum size requirements specified.
 - a. Round Wells: Not less than 8 inches in diameter.
 - b. Rectangular Wells: Not less than 12 by 12 inches.
 3. Depth: As required to extend below frost line to prevent frost upheaval, but not less than 10 inches.
 4. Cover: Factory-identified by permanent means with word "GROUND".
 5. Manufacturers:
 - a. Advanced Lightning Technology (ALT): www.altfab.com/#sle.
 - b. Harger Lightning & Grounding: www.harger.com/#sle.
 - c. ThermOweld, subsidiary of Continental Industries; division of Burndy LLC: www.thermoweld.com/#sle.
 - d. Or approved equal.
 - e. Substitutions: See Section 01 60 00 - Product Requirements.
- J. Oxide Inhibiting Compound: Comply with Section 26 05 19.

2.03 MANUFACTURERS

- A. Cooper Power Systems: www.cooperpower.com.
- B. Framatome Connectors International: www.fciconnect.com.
- C. Or approved equal.
- D. Substitutions: See Section 01 6000 - Product Requirements.

2.04 ELECTRODES

- A. Manufacturers:
 1. Cooper Power Systems: www.cooperpower.com.
 2. Framatome Connectors International: www.fciconnect.com.
 3. Or approved equal.
 4. Substitutions: See Section 01 6000 - Product Requirements.
- B. Rod Electrodes: Copper.
 1. Diameter: 3/4 inch.
 2. Length: 10 feet.

- C. Foundation Electrodes: 3/0 AWG, unless noted on plan.

2.05 CONNECTORS AND ACCESSORIES

- A. Mechanical Connectors: Bronze.
- B. Exothermic Connections: Weld
- C. Wire: Stranded copper.
- D. Grounding Electrode Conductor: Size to meet NFPA 70 requirements.
- E. Grounding Well:
 - 1. Well Pipe: 8 inch by 24 inch long clay tile pipe with belled end.
 - 2. Well Cover: Cast iron with legend "GROUND" embossed on cover.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that work likely to damage grounding and bonding system components has been completed.
- B. Verify that field measurements are as indicated.
- C. Verify that conditions are satisfactory for installation prior to starting work.
- D. Verify existing conditions prior to beginning work.
- E. Verify that final backfill and compaction has been completed before driving rod electrodes.

3.02 INSTALLATION

- A. Install products in accordance with manufacturer's instructions.
- B. Perform work in accordance with NECA 1 (general workmanship).
- C. Ground Electrodes: Provide a grounding electrode system in the main electrical room/space of each building as follows:
 - 1. Provide a 2-inch x 1/4-inch copper ground bar. Length shall be a minimum of 12 inches but longer as required for the number of connections made to the bar. This bar shall serve as the connection point for all grounding electrodes in the building. Install the copper ground bar in a NEMA 1 screw cover cabinet, minimum size 18 inches x 12 inches x 6 inches.
 - 2. Connect the copper ground bar to the underground metal pipe (other than gas).
 - a. Connect to metal pipe with approved pipe clamp near the pressure reducing valve.
 - b. Connect to ground bar with exothermic weld.
 - c. Connect to metal pipe with copper clamp where copper water pipe occurs and with a malleable iron clamp where cast iron pipe occurs.
 - d. Install grounding conductor, sized as indicated on plans, in a 3/4-inch metal conduit from the ground cabinet to the water pipe. Provide grounding bushings at each end of the conduit.
 - 3. Connect the copper ground bar to the metal frame of the building.

- a. At all steel framed buildings, provide a connection to the closest column.
 - b. Connect to column with exothermic weld.
 - c. Connect to the ground bar with exothermic weld or bolted-type connector.
 - d. Install grounding conductor, sized as indicated on the plans, in a 3/4-inch metal conduit from the ground cabinet to the column. Provide grounding bushing at each end of the conduit.
4. Connect the copper ground bar to a concrete-encased electrode/Ufer.
- a. Install a minimum of 20 feet of #3/0 AWG conductor (minimum unless noted otherwise) encased in a minimum of 3 inches of concrete. Provide a non-metallic protective sleeve, minimum 6 inches long (3 inches in the concrete and 3 inches out of the concrete), located where the conductor exits the concrete.
 - b. Install a #3/0 conductor from the ground bar to the concrete-encased electrode in a 3/4-inch metal conduit with grounding bushings. Make connections to the concrete-encased electrode with a bolted-type connector and transition from the metal conduit and non-metallic sleeve.
 - c. Connect to the ground bar with exothermic weld or bolted-type connector.
5. Provide additional ground rod or concrete-encased electrodes as required to meet the performance requirements listed in these specifications at the ground bar.
- a. Install additional ground rods a minimum of 5 feet from any other rod.
 - b. Notify the Owner's Representative if performance requirements have not been met after installing 2 additional ground rods or concrete-encased electrodes.
6. Install other grounding electrodes as indicated on the single line diagram and other Contract Documents.
- D. Grounding Electrode Conductor
1. Install grounding electrode conductor from the main normal and emergency power panels and each separately derived system in the building to the ground bar (grounding electrode system). Install grounding electrode conductor in steel conduit and bond grounding conductor to conduit at entrance and exit. Connect to the ground bar (grounding electrode system) with exothermic weld.
 - a. Unless otherwise indicated, install main ground unspliced.
 - b. Make connections easily accessible for inspection in ground bar cabinet.
 2. Grounding electrode conductor shall be of the same type and quality as other conductors in the building.
 3. The main neutral to ground bonding jumper will be located at the site utilities switchboard. Locate additional neutral to ground bonding jumper at separately derived systems only, or at the main service panel when the building is served from a dedicated transformer. Neutral bar with all interior secondary neutrals shall be isolated from the common equipment grounding bus at all other locations.
- E. Bonding
1. Provide bonding to meet requirements of CEC.
 2. Bond together metal siding not attached to grounded structure, bond to ground.

3. Bond prefabricated metal building to grounding electrode system at a minimum of one location.
 4. Bond together all metallic conduit, boxes, cabinets, and enclosures.
- F. Grounding Conductors
1. Provide grounding conductor for each branch circuit indicated.
 2. Equipment Grounding Conductor: Provide separate, insulated conductor within each feeder circuit raceway and within each motor feeder raceway. Terminate each end on suitable lug, bus, or bushing.
 3. Provide separate, isolated grounding conductor for each circuit which is installed (all or in part) in non-metallic conduit.
 4. Provide separate grounding conductor for circuits installed in flexible steel conduit. Terminate each end on a suitable lug, bus or bushing.
 5. Ground all conduit systems, cabinets, equipment, motor frames, etc., in accordance with CEC and applicable codes.
- G. Grounding Connections
1. Ground shields of shielded power cable and signal cable at each splice or termination in accordance with recommendations of the splice or termination manufacturer.
 2. Ground metal sheathing and exposed metal vertical structural elements of buildings. Ground metal fences enclosing electrical equipment. Bond any metal equipment platforms which support electrical equipment to that equipment. Provide good electrical contact between metal frames and railings supporting pushbutton stations, receptacles, instrument cabinets, etc., and raceways carrying circuits to these devices.
 3. Ground all fencing as shown on the grounding details on the Drawings.
 4. Bond neutrals of transformers within buildings to the system ground network, and to additional indicated grounding electrodes.
 5. Unless shown otherwise, make connections of grounding conductors to ground rods at the upper end of the rod with the end of the rod and the connection point below finished grade.
 6. Make connections of sections of outdoor ground mats (counterpoise) for substations or other equipment underground. Make connections of other grounding conductors generally accessible.
 7. In manhole pull boxes, install ground rods with ends 4 to 6 inches above the floor with connections of grounding conductors fully visible and accessible.
 8. When making thermite welds, wire brush or file the point of contact to a bare metal surface. Use thermite welding cartridges and molds in accordance with the manufacturer's recommendations. After welds have been made and cooled, brush slag from the weld area and thoroughly clean the joint. Re-galvanize area if required. For compression connectors, use homogeneous copper, anti-corrosion, surface treatment compound at connectors in accordance with connector manufacturer's recommendations. Use connectors of proper size for conductors and ground rods specified. Use connector manufacturer's compression tool. Notify the Owner's Representative prior to backfilling any ground connections.

9. Grounding pad plates shall be cast into the slab with the surface flush with the finished floor.
- H. Ground Rod Electrodes: Unless otherwise indicated, install ground rod electrodes vertically. Where encountered rock prohibits vertical installation, install at 45 degree angle or bury horizontally in trench at least 30 inches (750 mm) deep in accordance with NFPA 70 or provide ground plates.
 1. Outdoor Installations: Unless otherwise indicated, install with top of rod 6 inches below finished grade.
 2. Indoor Installations: Unless otherwise indicated, install with 4 inches of top of rod exposed.
 3. Provide ground well for future access to rod electrodes.
- I. Ground Plate Electrodes: Unless otherwise indicated, install ground plate electrodes at a depth of not less than 30 inches.
- J. Make grounding and bonding connections using specified connectors.
 1. Remove appropriate amount of conductor insulation for making connections without cutting, nicking or damaging conductors. Do not remove conductor strands to facilitate insertion into connector.
 2. Remove nonconductive paint, enamel, or similar coating at threads, contact points, and contact surfaces.
 3. Exothermic Welds: Make connections using molds and weld material suitable for the items to be connected in accordance with manufacturer's recommendations.
 4. Mechanical Connectors: Secure connections according to manufacturer's recommended torque settings.
 5. Compression Connectors: Secure connections using manufacturer's recommended tools and dies.
- K. Identify grounding and bonding system components in accordance with Section 26 05 53.
- L. Install ground electrodes at locations indicated. Install additional rod electrodes as required to achieve specified resistance to ground.
- M. Provide grounding well pipe with cover at each rod location. Install well pipe top flush with finished grade.
- N. Provide grounding electrode conductor and connect to reinforcing steel in foundation footing . Bond steel together.
- O. Provide bonding to meet requirements described in Quality Assurance.
- P. Provide isolated grounding conductor for circuits supplying electronic cash registers and other similar electronic equipment loads. .
- Q. Equipment Grounding Conductor: Provide separate, insulated conductor within each feeder and branch circuit raceway. Terminate each end on suitable lug, bus, or bushing.

3.03 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements, for additional requirements.

- B. Inspect and test in accordance with NETA ATS except Section 4.
- C. Perform inspections and tests listed in NETA ATS, Section 7.13.
- D. Site Tests:
 - 1. Test under provisions of Section 26 08 13.
 - 2. Notify the Owner's Representative five days before inspection and testing.
 - 3. Use suitable test instruments to measure resistance to ground of systems. Perform testing in accordance with test instrument manufacturer's recommendations using the fall-of-potential method.
 - 4. Remove main bonding jumper at main service switchboard and at each separately derived system and test for infinite resistance between neutral and ground systems. Reconnect bonding jumper(s) after completion of testing.
 - 5. Record test results in accordance with Section 26 05 00 and submit.
- E. Perform ground electrode resistance tests under normally dry conditions. Precipitation within the previous 48 hours does not constitute normally dry conditions.
- F. Investigate and correct deficiencies where measured ground resistances do not comply with specified requirements.
- G. Submit detailed reports indicating inspection and testing results and corrective actions taken.

END OF SECTION 26 05 26

SECTION 26 05 29

HANGERS AND SUPPORTS FOR ELECTRICAL SYSTEMS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Support and attachment requirements and components for equipment, conduit, cable, boxes, and other electrical work.

1.02 RELATED REQUIREMENTS

- A. Section 03 30 00 - Cast-in-Place Concrete: Concrete equipment pads.
- B. Section 05 50 00 - Metal Fabrications: Materials and requirements for fabricated metal supports.
- C. Section 26 05 00 – Common Work Results for Electrical.
- D. Section 26 05 33.13 - Conduit for Electrical Systems: Additional support and attachment requirements for conduits.
- E. Section 26 05 33.16 - Boxes for Electrical Systems: Additional support and attachment requirements for boxes.
- F. Section 26 05 48 - Vibration and Seismic Controls for Electrical Systems.
- G. Section 26 51 00 - Interior Lighting: Additional support and attachment requirements for interior luminaires.
- H. Section 26 56 00 - Exterior Lighting: Additional support and attachment requirements for exterior luminaires.

1.03 REFERENCE STANDARDS

- A. ASTM A123/A123M - Standard Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products; 2017.
- B. ASTM A153/A153M - Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware; 2023.
- C. ASTM B633 - Standard Specification for Electrodeposited Coatings of Zinc on Iron and Steel; 2023.
- D. ASTM D635 - Standard Test Method for Rate of Burning and/or Extent and Time of Burning of Plastics in a Horizontal Position; 2022.
- E. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2023d.
- F. MFMA-4 - Metal Framing Standards Publication; 2004.
- G. ICC-ES AC01 - Acceptance Criteria for Expansion Anchors in Masonry Elements; 2009.
- H. ICC-ES AC106 - Acceptance Criteria for Predrilled Fasteners (Screw Anchors) in Masonry Elements; 2006

- I. ICC-ES AC193 - Acceptance Criteria for Mechanical Anchors in Concrete Elements; 2010
- J. ICC-ES AC308 - Acceptance Criteria for Post-Installed Adhesive Anchors in Concrete Elements; 2009.
- K. NECA 1 - Standard for Good Workmanship in Electrical Construction; 2015.
- L. NFPA 70 - National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- M. NFPA 101 - Life Safety Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- N. UL 5B - Strut-Type Channel Raceways and Fittings; Current Edition, Including All Revisions.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Coordinate sizes and arrangement of supports and bases with actual equipment and components to be installed.
 - 2. Coordinate work to provide additional framing and materials required for installation.
 - 3. Coordinate compatibility of support and attachment components with mounting surfaces at installed locations.
 - 4. Coordinate arrangement of supports with ductwork, piping, equipment and other potential conflicts.
 - 5. Notify LP Consulting Engineers, Inc. of any conflicts with or deviations from Contract Documents. Obtain direction before proceeding with work.
- B. Sequencing:
 - 1. Do not install products on or provide attachment to concrete surfaces until concrete has cured; see Section 03 30 00.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide manufacturer's standard catalog pages and data sheets for channel/strut framing systems, nonpenetrating rooftop supports, and post-installed concrete/masonry anchors.
 - 1. Fiberglass Channel/Strut Framing Systems: Include requirements for strength derating according to ambient temperature.
- C. Shop Drawings: Include details for fabricated hangers and supports where materials or methods other than those indicated are proposed for substitution.
- D. Design Data
 - 1. Indicate hanger and support framing and attachment methods.
 - 2. Submit seismic and structural calculations for proposed methods of support and attachment.

- E. Derating Calculations for Fiberglass Channel/Strut Framing Systems: Indicate load ratings adjusted for applicable service conditions.
- F. Evaluation Reports: For products specified as requiring evaluation and recognition by ICC Evaluation Service, LLC (ICC-ES), provide current ICC-ES evaluation reports upon request.
- G. Installer's qualification statement.
- H. Product Data: Provide manufacturer's catalog data for fastening systems.
- I. Manufacturer's Instructions: Indicate application conditions and limitations of use stipulated by product testing agency. Include instructions for storage, handling, protection, examination, preparation, and installation of product.

1.06 QUALITY ASSURANCE

- A. Conform to requirements of NFPA 70.
- B. Maintain at project site one copy of each referenced document that prescribes execution requirements.
- C. Installer Qualifications for Field Welding: See Section 05 50 00.
- D. Product Listing Organization Qualifications: Organization recognized by OSHA as Nationally Recognized Testing Laboratory (NRTL) and acceptable to authorities having jurisdiction.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Receive, inspect, handle, and store products in accordance with manufacturer's instructions.

PART 2 PRODUCTS

2.01 SUPPORT AND ATTACHMENT COMPONENTS

- A. General Requirements:
 - 1. Comply with the following. Where requirements differ, comply with most stringent.
 - a. NFPA 70.
 - b. Applicable building code.
 - c. Requirements of authorities having jurisdiction.
 - 2. Provide required hangers, supports, anchors, fasteners, fittings, accessories, and hardware as necessary for complete installation of electrical work.
 - 3. Provide products listed, classified, and labeled as suitable for purpose intended, where applicable.
 - 4. Where support and attachment component types and sizes are not indicated, select in accordance with manufacturer's application criteria as required for the load to be supported with a minimum safety factor of 25%. Include consideration for vibration, equipment operation, and shock loads where applicable.
 - 5. Do not use products for applications other than as permitted by NFPA 70 and product listing.

6. Do not use wire, chain, perforated pipe strap, or wood for permanent supports unless specifically indicated or permitted.
7. Steel Components: Use corrosion-resistant materials suitable for environment where installed.
 - a. Indoor Dry Locations: Use zinc-plated steel or approved equivalent unless otherwise indicated.
 - b. Outdoor and Damp or Wet Indoor Locations: Use galvanized steel, stainless steel, or approved equivalent unless otherwise indicated.
 - c. Zinc-Plated Steel: Electroplated in accordance with ASTM B633.
 - d. Galvanized Steel: Hot-dip galvanized after fabrication in accordance with ASTM A123/A123M or ASTM A153/A153M.
- B. Components for Vibration Isolation and/or Seismic Controls: See Section 26 05 48.
- C. Materials for Metal Fabricated Supports: See Section 05 50 00.
- D. Conduit and Cable Supports: Straps and clamps suitable for conduit or cable to be supported.
 1. Manufacturers:
 - a. ABB: www.electrification.us.abb.com/#sle.
 - b. Eaton Corporation: www.eaton.com/#sle.
 - c. Emerson Electric Co; O-Z/Gedney: www.emerson.com/#sle.
 - d. HoldRite, a brand of Reliance Worldwide Corporation: www.holdrite.com/#sle.
 - e. nVent; Caddy: www.nvent.com/#sle.
 - f. Substitutions: See Section 01 60 00 - Product Requirements.
 2. Conduit Straps: One-hole or two-hole type; steel or malleable iron.
 3. Conduit Clamps: Bolted type unless otherwise indicated.
- E. Outlet Box Supports: Hangers and brackets suitable for boxes to be supported.
- F. Metal Channel/Strut Framing Systems:
 1. Description: Factory-fabricated, continuous-slot, metal channel/strut and associated fittings, accessories, and hardware required for field assembly of supports.
 2. Comply with MFMA-4.
 3. Channel/Strut Used as Raceway, Where Indicated: Listed and labeled as complying with UL 5B.
 4. Channel Material:
 - a. Indoor Dry Locations: Use painted steel, zinc-plated steel, or galvanized steel.
 - b. Outdoor and Damp or Wet Indoor Locations: Use galvanized steel.
 5. Minimum Channel Thickness: Steel sheet, 12 gauge, 0.1046 inch.
 6. Minimum Channel Dimensions: 1-5/8 inch width by 1-5/8 inch height.
- G. Fiberglass Channel/Strut Framing Systems:
 1. Description: Factory-fabricated, continuous-slot, fiberglass channel/strut and associated fittings, accessories, and hardware required for field assembly of supports.

2. Channel Material: Use polyester resin or vinyl ester resin.
 3. Minimum Channel Dimensions: 1-5/8 inch wide by 1 inch high.
 4. Flammability: Fire retardant with NFPA 101, Class A flame spread index, maximum of 25, when tested in accordance with ASTM E84; self extinguishing in accordance with ASTM D635.
- H. Hanger Rods: Threaded, zinc-plated steel unless otherwise indicated.
1. Minimum Size, Unless Otherwise Indicated or Required:
 - a. Equipment Supports: 1/2-inch diameter.
 - b. Busway Supports: 1/2-inch diameter.
 - c. Single Conduit up to 1-inch (27 mm) Trade Size: 1/4-inch diameter.
 - d. Single Conduit Larger than 1-inch (27 mm) Trade Size: 3/8-inch diameter.
 - e. Trapeze Support for Multiple Conduits: 3/8-inch diameter.
 - f. Outlet Boxes: 1/4-inch diameter.
 - g. Luminaires: 1/4-inch diameter.
- I. Nonpenetrating Rooftop Supports for Low-Slope Roofs:
1. Description: Steel pedestals with thermoplastic or rubber bases that rest on top of roofing membrane, not requiring attachment to roof structure and not penetrating roofing assembly, with support fixtures as specified.
 2. Base Sizes: As required to distribute load sufficiently to prevent indentation of roofing assembly.
 3. Attachment/Support Fixtures: As recommended by manufacturer, same type as indicated for equivalent indoor hangers and supports.
 4. Mounting Height: Provide minimum clearance of 6 inches under supported component to top of roofing.
- J. Anchors and Fasteners:
1. Unless otherwise indicated and where not otherwise restricted, use anchor and fastener types indicated for specified applications.
 2. Concrete: Use preset concrete inserts, expansion anchors, or screw anchors.
 3. Solid or Grout-Filled Masonry: Use expansion anchors or screw anchors.
 4. Hollow Masonry: Use toggle bolts.
 5. Hollow Stud Walls: Use toggle bolts.
 6. Steel: Use beam clamps, machine bolts, or welded threaded studs.
 7. Sheet Metal: Use sheet metal screws.
 8. Wood: Use wood screws.
 9. Hammer-driven anchors and fasteners are not permitted.
 - a. Nails are permitted for attachment of nonmetallic boxes to wood frame construction.
 - b. Staples are permitted for attachment of nonmetallic-sheathed cable to wood frame construction.
 10. Preset Concrete Inserts: Continuous metal channel/strut and spot inserts specifically designed to be cast in concrete ceilings, walls, and floors.
 - a. Manufacturer: Same as manufacturer of metal channel/strut framing system.
 - b. Comply with MFMA-4.

- c. Channel Material: Use galvanized steel.
 - d. Minimum Channel Thickness: Steel sheet, 12 gauge, 0.1046 inch minimum base metal thickness.
11. Post-Installed Concrete and Masonry Anchors: Evaluated and recognized by ICC Evaluation Service, LLC (ICC-ES) for compliance with applicable building code.

2.02 MANUFACTURERS (LISTED IN ALPHABETICALLY ORDER ONLY AND NOT NECESSARY BY PREFERENCE)

- A. Thomas & Betts Corporation: www.tnb.com.
- B. Threaded Rod Company: www.threadedrod.com.
- C. Or Approved Equal.
- D. Substitutions: See Section 01 6000 - Product Requirements.

2.03 SUPPORTS

- A. Pipe hangers for individual conduits shall be factory made, consisting of a pipe ring and threaded suspension rod. The pipe ring shall be malleable iron, split and hinged, or shall be springable wrought steel. Rings shall be bolted to or interlocked with the suspension rod socket.
- B. Pipe racks for groups of parallel conduits shall be constructed of galvanized structural steel preformed channels of length as required, suspended on threaded rods and secured thereto with nuts above and below the cross bar.
- C. Factory made pipe straps shall be one hole malleable iron or two hole galvanized clamps.
- D. Supporting rods shall be at least 3/8" diameter and channel shall be at least 3/4" deep. Supporting hardware shall be galvanized steel.

2.04 MATERIALS

- A. Hangers, Supports, Anchors, and Fasteners - General: Corrosion-resistant materials of size and type adequate to carry the loads of equipment and conduit, including weight of wire in conduit.
- B. Supports: Fabricated of structural steel or formed steel members; galvanized.
- C. Anchors and Fasteners:
 - 1. Sheet Metal Screws: Steel
 - 2. Machine Screws Bolts, Nuts and Washers: Steel
 - 3. Precast Inserts: Suitable for the purpose.
 - 4. Anchor Bolts, expansion type (stainless steel).
 - a. Phillips Red-Head
 - b. Hilti Kwik-Bolt.
 - c. WEJ-IT.
 - 5. Cast-in-Place Anchors: Suitable for the purpose (hot-dip galvanized except cadmium plated in dry locations)
 - 6. Beam Clamps: Steel.

- D. Concrete Structural Elements: Use precast inserts, expansion anchors, or preset inserts.
- E. Steel Structural Elements: Use beam clamps or welded fasteners.
- F. Concrete Surfaces: Use self-drilling anchors or expansion anchors.
- G. Hollow Masonry, Plaster, and Gypsum Board Partitions: Use toggle bolts or hollow wall fasteners.
- H. Solid Masonry Walls: Use expansion anchors or preset inserts.
- I. Sheet Metal: Use sheet metal screws.
- J. Wood Elements: Use wood screws.
- K. Fastener Types:
 - 1. Concrete Wedge Expansion Anchors: Complying with ICC-ES AC193.
 - 2. Masonry Wedge Expansion Anchors: Complying with ICC-ES AC01.
 - 3. Concrete Screw Type Anchors: Complying with ICC-ES AC193.
 - 4. Masonry Screw Type Anchors: Complying with ICC-ES AC106.
 - 5. Other Types: As required.
 - 6. Manufacturers:
 - a. Powers Fasteners, Inc: www.powers.com.
 - b. Or approved equal.
- L. Formed Steel Channel as indicated on drawings.
- M. Steel Spring Clips: As indicated on drawings

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that field measurements are as indicated.
- B. Verify that mounting surfaces are ready to receive support and attachment components.
- C. Verify that conditions are satisfactory for installation prior to starting work.

3.02 INSTALLATION

- A. General
 - 1. Install products in accordance with manufacturer's instructions.
 - 2. Provide independent support from building structure. Do not provide support from piping, ductwork, or other systems.
 - 3. Do not penetrate or otherwise notch or cut structural members without approval of Structural Engineer.
- B. Install hangers and supports in accordance with NECA 1.
- C. Install anchors and fasteners in accordance with ICC Evaluation Services, LLC (ICC-ES) evaluation report conditions of use where applicable.
 - 1. Concrete – Precast inserts, cast-place anchors, or expansion type anchor bolts.

- a. When installing drilled-in anchors in non-prestressed reinforced concrete, avoid the reinforcing bars.
- b. When installing drilled-in anchors into prestressed concrete (Pre- or Post-tensioned) locate tendons by using a non-destructive method prior to installation. Maintain a minimum clearance of one-inch between the reinforcement and the drilled-in anchor.
2. Sheet Metal – Sheet metal screws or machine bolts, nuts, and washers.
3. Structural Steel Members – Beam clamps, machine screws, bolts, nuts, and washers.
- D. Provide independent support from building structure. Do not provide support from piping, ductwork, or other systems.
- E. Unless specifically indicated or approved by LP Consulting Engineers, Inc., do not provide support from suspended ceiling support system or ceiling grid.
- F. Unless specifically indicated or approved by LP Consulting Engineers, Inc., do not provide support from roof deck.
- G. Do not penetrate or otherwise notch or cut structural members without approval of Structural Engineer.
- H. Provide required vibration isolation and/or seismic controls; see Section 26 05 48.
- I. Field Welding, Where Approved by LP Consulting Engineers, Inc.: See Section 05 50 00.
- J. Equipment Support and Attachment:
 1. Use metal, fabricated supports or supports assembled from metal channel/strut to support equipment as required.
 2. Use metal channel/strut secured to studs to support equipment surface mounted on hollow stud walls when wall strength is not sufficient to resist pull-out.
 3. Use metal channel/strut to support surface-mounted equipment in wet or damp locations to provide space between equipment and mounting surface.
 4. Unless otherwise indicated, mount floor-mounted equipment on properly sized concrete pad 3 inches in height; see Section 03 30 00.
 5. Securely fasten floor-mounted equipment. Do not install equipment such that it relies on its own weight for support.
 6. Install surface mounted cabinets and panelboards with minimum of four anchors.
 7. In wet and damp locations, use steel channel supports to stand cabinets and panelboards 13/16-inch minimum off wall.
 8. Use sheet metal channels to bridge studs above and below cabinets and panelboards recessed in hollow partitions.
 9. Support equipment in accordance with manufacturer's instructions.
 10. Verify that equipment will fit support layouts indicated.
 - a. Where suitable equipment is used, revise indicated supports to fit at no additional cost.
 11. Arrange for necessary openings to allow entry of equipment.

- a. Where equipment cannot be installed as structure is being erected, provide and arrange for building-in of boxes, sleeves, or other devices to allow for later installation.
- K. Conduit Support and Attachment
 - 1. In damp or wet locations, space conduit support directly from concrete or metal structure out at least ¼ inch using straps with spacers or, if three (3) or more conduits are located in a parallel run, they shall be spaced out from the wall approximately 5/8 inch to 1 inch by means of a channel.
 - 2. Runs of individual conduit suspended from the floor or ceiling shall be supported with pipe hangers. Where three (3) or more conduits are suspended from the floor or ceiling, suitable racks shall be constructed from channel material with suitable fittings.
 - 3. Space supporting points no greater than required by CEC.
- L. Sleeves
 - 1. Set sleeves in position in formwork. Provide reinforcing around sleeves.
 - 2. Extend sleeves through floors 1 inch above finished floor levels. Caulk sleeves full depth and provide floor plate.
 - 3. Where raceway penetrated floor, ceiling, or wall. Close off space between pipe or duct and adjacent work with fire stopping insulation and caulk seal.
- M. Conduit Support and Attachment: See Section 26 05 33.13 for additional requirements.
- N. Box Support and Attachment: See Section 26 05 33.16 for additional requirements.
- O. Busway Support and Attachment: See Section 26 25 13 for additional requirements.
- P. Interior Luminaire Support and Attachment: See Section 26 51 00 for additional requirements.
- Q. Exterior Luminaire Support and Attachment: See Section 26 56 00 for additional requirements.
- R. Preset Concrete Inserts: Use manufacturer provided closure strips to inhibit concrete seepage during concrete pour.
- S. Secure fasteners in accordance with manufacturer's recommended torque settings.
- T. Remove temporary supports.
- U. Identify independent electrical component support wires above accessible ceilings, where permitted, with color distinguishable from ceiling support wires in accordance with NFPA 70.

3.03 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements for additional requirements.
- B. Inspect support and attachment components for damage and defects.
- C. Repair cuts and abrasions in galvanized finishes using zinc-rich paint recommended by manufacturer. Replace components that exhibit signs of corrosion.

- D. Correct deficiencies and replace damaged or defective support and attachment components.
 - 1. Obtain permission from the Architect and the Structural Engineer before drilling or cutting structural members.
- E. All expansion anchors shall have 50 percent of the bolts (alternate bolts in any group arrangement) proof tested in tension and certified by a recognized testing agency at the values indicated in the following table, except where shown otherwise in the Contract Documents. If there are any failures, the immediately adjacent bolts must then also be tested. Anchor capacities shall not exceed 80 percent of the values in the published ICBO report.

| ANCHOR CAPACITY
(3,000 PSI MINIMUM STONE AGGREGATE CONCRETE) | | | | | | | |
|---|-------------|-------------|-------------|-------------|--------|-----------------|--------|
| | 1/2
inch | 5/8
inch | 3/4
inch | 7/8
inch | 1 inch | 1-1/4
inches | UNITS |
| IN TENSION | 680 | 960 | 1,360 | 1,900 | 2,700 | 3,600 | LBS |
| IN SHEAR | 1,170 | 1,680 | 2,420 | 3,500 | 5,020 | 6,700 | LBS |
| TYPE OF TEST: | | | | | | | |
| DIRECT PULL-TENSION, LBS. | 1,360 | 1,920 | 2,720 | 3,800 | 5,400 | 7,200 | LBS |
| MINIMUM EMBEDMENT | 3 | 3-3/4 | 4-1/2 | 5-1/4 | 6 | 7-1/2 | INCHES |

END OF SECTION 26 05 29

SECTION 26 05 33.13 CONDUIT FOR ELECTRICAL SYSTEMS

PART 1 GENERAL

1.01 SUMMARY

- A. Scope: Provide rigid metallic conduit, rigid non-metallic conduit, intermediate metal conduit, flexible metal conduit, electrical metallic tubing, surface metal and/or non-metallic raceways, cable tray and wireways as shown on the drawings and as described in the specifications.

1.02 SECTION INCLUDES

- A. Galvanized steel rigid metal conduit (RMC).
- B. Galvanized steel intermediate metal conduit (IMC).
- C. PVC-coated galvanized steel rigid metal conduit (RMC).
- D. Flexible metal conduit (FMC).
- E. Liquidtight flexible metal conduit (LFMC).
- F. Galvanized steel electrical metallic tubing (EMT).
- G. Rigid polyvinyl chloride (PVC) conduit.
- H. Conduit, fittings and conduit bodies.

1.03 RELATED REQUIREMENTS

- A. Section 03 30 00 - Cast-in-Place Concrete: Concrete encasement of conduits.
- B. Section 07 84 00 - Firestopping.
- C. Section 26 05 00 – Common Work Results for Electrical.
- D. Section 26 05 19 - Low-Voltage Electrical Power Conductors and Cables: Cable assemblies consisting of conductors protected by integral metal armor.
- E. Section 26 05 26 - Grounding and Bonding for Electrical Systems.
 - 1. Includes additional requirements for fittings for grounding and bonding.
- F. Section 26 05 29 - Hangers and Supports for Electrical Systems.
- G. Section 26 05 33.16 - Boxes for Electrical Systems.
- H. Section 26 05 33.23 - Surface Raceways for Electrical Systems.
- I. Section 26 05 39 - Underfloor Raceways for Electrical Systems.
- J. Section 26 05 48 - Vibration and Seismic Controls for Electrical Systems.
- K. Section 26 05 53 - Identification for Electrical Systems: Identification products and requirements.
- L. Section 26 21 00 - Low-Voltage Electrical Service Entrance: Additional requirements for electrical service conduits.
- M. Section 26 27 23 - Indoor Service Poles.

- N. Section 27 05 33.13 - Conduit for Communications Systems.
- O. Section 31 23 16 - Excavation.
- P. Section 31 23 16.13 - Trenching: Excavating, bedding, and backfilling.
- Q. Section 31 23 23 - Fill: Bedding and backfilling.
- R. Section 33 71 19 - Electrical Underground Ducts, Ductbanks, and Manholes.
- S. The requirements of the kitchen equipment consultant plans and specifications.

1.04 REFERENCE STANDARDS

- A. ANSI C80.1 - American National Standard for Electrical Rigid Steel Conduit (ERSC); 2020.
- B. ANSI C80.3 - American National Standard for Electrical Metallic Tubing -- Steel (EMT-S); 2020.
- C. ANSI C80.5 - American National Standard for Electrical Rigid Metal Conduit -- Aluminum (ERMC-A); 2020.
- D. ANSI C80.6 - American National Standard for Electrical Intermediate Metal Conduit; 2018.
- E. NECA 1 - Standard for Good Workmanship in Electrical Construction; 2015.
- F. NECA 101 - Standard for Installing Steel Conduits (Rigid, IMC, EMT); 2020.
- G. NECA 102 - Standard for Installing Aluminum Rigid Metal Conduit; 2004.
- H. NECA 111 - Standard for Installing Nonmetallic Raceways (RNC, ENT, LFNC); 2017.
- I. NEMA FB 1 - Fittings, Cast Metal Boxes, and Conduit Bodies for Conduit, Electrical Metallic Tubing, and Cable; 2014.
- J. NEMA RN 1 - Polyvinyl-Chloride (PVC) Externally Coated Galvanized Rigid Steel Metal Conduit and Intermediate Metal Conduit; 2018.
- K. NEMA TC 2 - Electrical Polyvinyl Chloride (PVC) Conduit; 2020.
- L. NEMA TC 3 - Polyvinyl Chloride (PVC) Fittings for Use with Rigid PVC Conduit and Tubing; 2021.
- M. NEMA TC 14 (SERIES) - Reinforced Thermosetting Resin Conduit and Fittings Series; 2015.
- N. NFPA 70 - National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- O. UL 1 - Flexible Metal Conduit; Current Edition, Including All Revisions.
- P. UL 6 - Electrical Rigid Metal Conduit-Steel; Current Edition, Including All Revisions.
- Q. UL 6A - Electrical Rigid Metal Conduit-Aluminum, Red Brass, and Stainless Steel; Current Edition, Including All Revisions.
- R. UL 360 - Liquid-Tight Flexible Metal Conduit; Current Edition, Including All Revisions.
- S. UL 514B - Conduit, Tubing, and Cable Fittings; Current Edition, Including All Revisions.

- T. UL 651 - Schedule 40, 80, Type EB and A Rigid PVC Conduit and Fittings; Current Edition, Including All Revisions.
- U. UL 797 - Electrical Metallic Tubing-Steel; Current Edition, Including All Revisions.
- V. UL 1203 - Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations; Current Edition, Including All Revisions.
- W. UL 1242 - Electrical Intermediate Metal Conduit-Steel; Current Edition, Including All Revisions.
- X. UL 1660 - Liquid-Tight Flexible Nonmetallic Conduit; Current Edition, Including All Revisions.
- Y. UL 2419 - Outline of Investigation for Electrically Conductive Corrosion Resistant Compounds; Current Edition, Including All Revisions.

1.05 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Coordinate minimum sizes of conduits with actual type and quantity of conductors to be installed, including adjustments for conductor sizes increased for voltage drop.
 - 2. Coordinate arrangement of conduits with structural members, ductwork, piping, equipment, and other potential conflicts.
 - 3. Verify exact conduit termination locations required for boxes, enclosures, and equipment.
 - 4. Coordinate work to provide roof penetrations that preserve integrity of roofing system and do not void roof warranty.
 - 5. Notify Electrical Engineer of Record of any conflicts with or deviations from Contract Documents. Obtain direction before proceeding with work.
- B. Sequencing:
 - 1. Do not begin installation of conductors and cables until installation of conduit between termination points is complete.

1.06 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittals procedures.
- B. Product Data: Provide manufacturer's standard catalog pages and data sheets for conduits and fittings.
- C. Shop Drawings:
 - 1. Indicate proposed arrangement for conduits to be installed within structural concrete slabs, where permitted.
 - 2. Include proposed locations of roof penetrations and proposed methods for sealing.
- D. Project Record Documents: Record actual routing for conduits installed underground, conduits embedded within concrete slabs, and conduits 2-inch (53 mm) trade size and larger.

- E. Product Data: Provide for metallic conduit, flexible metal conduit, liquidtight flexible metal conduit, metallic tubing, nonmetallic conduit, fittings, and conduit bodies.
- F. Project Record Documents: Accurately record actual routing of conduits larger than 1 1/4 inches.

1.07 QUALITY ASSURANCE

- A. Documents at Project Site: Maintain at project site one copy of manufacturer's instructions and shop drawings.
- B. Product Listing Organization Qualifications: Organization recognized by OSHA as Nationally Recognized Testing Laboratory (NRTL) and acceptable to authorities having jurisdiction.
- C. Products: Listed and classified by Underwriters Laboratories Inc. as suitable for purpose specified and shown.

1.08 DELIVERY, STORAGE, AND HANDLING

- A. Receive, inspect, handle, and store conduit and fittings in accordance with manufacturer's instructions.
- B. Accept conduit on site. Inspect for damage.
- C. Protect conduit from corrosion and entrance of debris by storing above grade. Provide appropriate covering.
- D. Protect PVC conduit from sunlight.

1.09 PROJECT CONDITIONS

- A. Verify that field measurements are as shown on drawings.
- B. Verify conduit routing and termination locations of conduits prior to rough in.
- C. Conduit routing is shown on drawings in approximate locations unless dimensioned. Route as required to complete wiring systems.

1.10 RATED WALLS AND CEILINGS

- A. Inspect architectural plans for locations and fire ratings for all walls, ceilings, and floors. Install materials as required to maintain the fire integrity of the rated assemblies.

PART 2 PRODUCTS

2.01 CONDUIT APPLICATIONS

- A. Do not use conduit and associated fittings for applications other than as permitted by NFPA 70, manufacturer's instructions, and product listing.
- B. Unless otherwise indicated and where not otherwise restricted, use conduit types indicated for specified applications. Where more than one listed application applies, comply with most restrictive requirements. Where conduit type for particular application is not specified, use galvanized steel rigid metal conduit.

- C. Underground:
1. Under Slab on Grade: Use rigid PVC conduit.
 2. Exterior, Direct-Buried: Use rigid PVC conduit.
 3. Exterior, Embedded Within Concrete: Use PVC-coated galvanized steel rigid metal conduit or rigid PVC conduit.
 4. Where rigid polyvinyl (PVC) conduit is provided, transition to galvanized steel rigid metal conduit or PVC-coated galvanized steel rigid metal conduit where emerging from underground.
 5. Where rigid polyvinyl (PVC) conduit larger than 2 inch (53 mm) trade size is provided, use PVC-coated galvanized steel rigid metal conduit elbows for bends.
 6. Where galvanized rigid metal conduit (RMC), galvanized steel intermediate metal conduit (IMC), or galvanized steel electrical metallic tubing (EMT) emerges from concrete into soil, use corrosion protection tape, factory-applied corrosion protection coating, or field-applied corrosion protection compound acceptable to authorities having jurisdiction to provide supplementary corrosion protection for minimum of 4 inches on either side of where conduit emerges.
- D. Embedded Within Concrete:
1. Within Slab on Grade: Use PVC-coated galvanized steel rigid metal conduit (RMC) or rigid PVC conduit. Embed within structural slabs only where approved by Structural Engineer.
 2. Within Slab Above Ground: Use PVC-coated galvanized steel rigid metal conduit (RMC) or rigid PVC conduit. Embed within structural slabs only where approved by Structural Engineer.
 3. Within Concrete Walls Above Ground: Use galvanized steel rigid metal conduit or rigid PVC conduit.
 4. Where rigid polyvinyl (PVC) conduit is provided, transition to galvanized steel rigid metal conduit or PVC-coated galvanized steel rigid metal conduit where emerging from concrete.
 5. Where galvanized steel electrical metallic tubing (EMT) emerges from concrete into salt air, use corrosion protection tape, factory-applied corrosion protection coating, or field-applied corrosion protection compound acceptable to authorities having jurisdiction to provide supplementary corrosion protection for minimum of 4 inches on either side of where conduit emerges.
- E. Concealed Within Masonry Walls: Use galvanized steel rigid metal conduit (RMC), stainless steel rigid metal conduit (RMC), galvanized steel intermediate metal conduit (IMC), stainless steel intermediate metal conduit (IMC), galvanized steel electrical metallic tubing (EMT), or stainless steel electrical metallic tubing (EMT).
- F. Concealed Within Hollow Stud Walls: Use galvanized steel rigid metal conduit (RMC), stainless steel rigid metal conduit (RMC), galvanized steel intermediate metal conduit (IMC), stainless steel intermediate metal conduit (IMC), galvanized steel electrical metallic tubing (EMT), or stainless steel electrical metallic tubing (EMT).
- G. Concealed Above Accessible Ceilings: Use galvanized steel rigid metal conduit (RMC), stainless steel rigid metal conduit (RMC), galvanized steel intermediate metal conduit (IMC), stainless steel intermediate metal conduit (IMC), galvanized steel electrical

- metallic tubing (EMT), or stainless steel electrical metallic tubing (EMT).
- H. Interior, Damp or Wet Locations: Use galvanized steel rigid metal conduit (RMC), stainless steel rigid metal conduit (RMC), galvanized steel intermediate metal conduit (IMC), stainless steel intermediate metal conduit (IMC), galvanized steel electrical metallic tubing (EMT), or stainless steel electrical metallic tubing (EMT).
 - I. Exposed, Interior, Not Subject to Physical Damage: Use galvanized steel rigid metal conduit (RMC), stainless steel rigid metal conduit (RMC), galvanized steel intermediate metal conduit (IMC), stainless steel intermediate metal conduit (IMC), galvanized steel electrical metallic tubing (EMT), or stainless steel electrical metallic tubing (EMT).
 - J. Exposed, Interior, Subject to Physical Damage: Use galvanized steel rigid metal conduit (RMC), stainless steel rigid metal conduit (RMC), galvanized steel intermediate metal conduit (IMC), stainless steel intermediate metal conduit (IMC), galvanized steel electrical metallic tubing (EMT), or stainless steel electrical metallic tubing (EMT).
 - 1. Locations subject to physical damage include, but are not limited to:
 - a. Where exposed below 8 feet, except within electrical and communication rooms or closets.
 - b. Where exposed below 20 feet in warehouse areas.
 - c. In Correctional Facilities, Galvanized rigid steel only for inmate accessible areas. Locations shall be verified with the architect.
 - K. Exposed, Exterior, Not Subject to Severe Physical Damage: Use galvanized steel rigid metal conduit (RMC), stainless steel rigid metal conduit (RMC), galvanized steel intermediate metal conduit (IMC), stainless steel intermediate metal conduit (IMC), galvanized steel electrical metallic tubing (EMT), or stainless steel electrical metallic tubing (EMT).
 - L. Concealed, Exterior, Not Embedded in Concrete or in Contact With Earth: Use galvanized steel rigid metal conduit (RMC), stainless steel rigid metal conduit (RMC), galvanized steel intermediate metal conduit (IMC), stainless steel intermediate metal conduit (IMC), galvanized steel electrical metallic tubing (EMT), or stainless steel electrical metallic tubing (EMT).
 - M. Corrosive Locations Above Ground: Use PVC-coated galvanized steel rigid metal conduit.
 - N. Hazardous/Classified Locations: Use galvanized steel rigid metal conduit (RMC), stainless steel rigid metal conduit (RMC), galvanized steel intermediate metal conduit (IMC), stainless steel intermediate metal conduit (IMC), or PVC-coated galvanized steel rigid metal conduit (RMC).
 - O. Flexible Connections to Luminaires Above Accessible Ceilings: Use flexible metal conduit (FMC).
 - 1. Maximum Length: 6 feet.
 - P. Flexible Connections to Vibrating Equipment:
 - 1. Dry Locations: Use flexible metal conduit (FMC).
 - 2. Damp, Wet, or Corrosive Locations: Use liquidtight flexible metal conduit (LFMC).
 - 3. Maximum Length: 6 feet unless otherwise indicated.

4. Vibrating equipment includes, but is not limited to:
 - a. Transformers.
 - b. Motors.
 - c. Engine generators.
- Q. Fished in Existing Walls, Where Necessary: Use flexible metal conduit.
- R. Freezer and Refrigeration Rooms
 1. Galvanized rigid steel conduit.
 2. Use sealing fittings on refrigeration and freezer room conduit runs in accordance with CEC 300-7(a).

2.02 CONDUIT - GENERAL REQUIREMENTS

- A. Comply with NFPA 70.
- B. Existing Work: Where existing conduits are indicated to be reused, they may be reused only where they comply with specified requirements, are free from corrosion, and integrity is verified by pulling mandrel through them.
- C. Electrical Service Conduits: See Section 26 21 00 for additional requirements.
- D. Fittings for Grounding and Bonding: See Section 26 05 26 for additional requirements.
- E. Provide conduit, fittings, supports, and accessories required for complete raceway system.
- F. Provide products listed, classified, and labeled as suitable for purpose intended.
- G. Minimum Conduit Size, Unless Otherwise Indicated:
 1. Branch Circuits: 1/2-inch trade size.
 2. Branch Circuit Homeruns: 3/4-inch trade size.
 3. Control Circuits: 1/2-inch trade size.
 4. Flexible Connections to Luminaires: 1/2 inch (16 mm) trade size.
 5. Underground, Interior: 1 inch (27 mm) trade size.
 6. Underground, Exterior: 1-inch trade size.
- H. Where conduit size is not indicated, size to comply with NFPA 70 but not less than applicable minimum size requirements specified.

2.03 GALVANIZED STEEL RIGID METAL CONDUIT (RMC)

- A. Manufacturers:
 1. Allied Tube & Conduit, a division of Atkore International: www.alliedeg.com/#sle.
 2. Nucor Tubular Products: www.nucortubular.com/#sle.
 3. Rymco USA: www.rymcousa.com/#sle.
 4. Western Tube, a division of Zekelman Industries: www.westerntube.com/#sle.
 5. Wheatland Tube, a division of Zekelman Industries: www.wheatland.com/#sle.
 6. Or approved equal.
 7. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Description: NFPA 70, Type RMC galvanized steel rigid metal conduit complying with ANSI C80.1 and listed and labeled as complying with UL 6.

- C. Fittings:
 - 1. Manufacturers:
 - a. Bridgeport Fittings Inc: www.bptfittings.com/#sle.
 - b. Appleton.
 - c. Crouse-Hinds.
 - d. Emerson Electric Co; O-Z/Gedney: www.emerson.com/#sle.
 - e. Or approved equal.
 - f. Substitutions: See Section 01 60 00 - Product Requirements.
 - 2. Nonhazardous Locations: Use fittings complying with NEMA FB 1 and listed and labeled as complying with UL 514B or UL 6.
 - 3. Hazardous/Classified Locations: Use fittings listed and labeled as complying with UL 1203 for classification of installed location.
 - 4. Material: Use steel or malleable iron.
 - a. Do not use die cast zinc fittings.
 - 5. Connectors and Couplings: Where an expansion type fitting is not required, use a coupling or "Erickson" type coupling as appropriate. Threadless set screw and compression (gland) type fittings are not permitted.
 - 6. At building expansion joints, use expansion type fittings.
 - 7. Make connections to NEMA 12 boxes with a threaded hub.
- D. Locknuts
 - 1. Hardened Steel or malleable iron construction, electro zinc plated, capable of insuring positive bond to enclosure.
 - a. Non-bonding: T & B Series 142 or approved equal.
 - b. Bonding: T & B Series 107 or approved equal.
- E. Bushings
 - 1. Insulated: T & B Series 223 or approved equal.
 - 2. Insulated Metallic Bushing: T & B Series 1223 or approved equal.
 - 3. Insulated Grounding and Bonding Bushing: T & B Series 3871 or approved equal.
- F. Couplings
 - 1. Non-metallic Conduit Coupling: By non-metallic conduit manufacturer for the application.
 - 2. Threaded Rigid Metal Conduit Couplings: By conduit manufacturer for the application.
 - 3. Threadless Coupling: "Erickson" Type Y & B Series 676 or approved equal.
 - 4. Expansion Type: Permit $\frac{3}{4}$ inch movement any direction.
 - a. Exposed: Weatherproof with external bonding jumper.
 - b. Embedded: Watertight with internal bonding jumper.
- G. Connectors
 - 1. Non-Metallic Conduit Connector: By conduit manufacturer for the application.
 - 2. Threaded Hubs: Electro zinc coated with nylon insulated throat and ail/moisture resistant recessed sealing ring, raintight.
 - a. Non-bonding: T & B Series 371 or approved equal.

- b. Bonding: T & B Series 371 with 107 series bonding locknut or approved equals.
- H. Nipple: "Chase" Type, insulated: T & B Series 5263 or approved equal.
- I. Sealing Gaskets: Oil and moisture resistant rubber bonded to metallic retainer.
 - 1. With rigid conduit – T & B Series 5303 or approved equal.
 - 2. Fittings not specifically listed but required shall be of similar style and quality.

2.04 GALVANIZED STEEL INTERMEDIATE METAL CONDUIT (IMC)

- A. Manufacturers:
 - 1. Allied Tube & Conduit, a division of Atkore International: www.alliedeg.com/#sle.
 - 2. Nucor Tubular Products: www.nucortubular.com/#sle.
 - 3. Western Tube, a division of Zekelman Industries: www.westerntube.com/#sle.
 - 4. Wheatland Tube, a division of Zekelman Industries: www.wheatland.com/#sle.
 - 5. Or approved equal.
 - 6. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Description: NFPA 70, Type IMC galvanized steel intermediate metal conduit complying with ANSI C80.6 and listed and labeled as complying with UL 1242.
- C. Fittings:
 - 1. Manufacturers:
 - a. Bridgeport Fittings, LLC: www.bptfittings.com/#sle.
 - b. Emerson Electric Co; O-Z/Gedney: www.emerson.com/#sle.
 - c. Or approved equal.
 - d. Substitutions: See Section 01 60 00 - Product Requirements.
 - 2. Nonhazardous Locations: Use fittings complying with NEMA FB 1 and listed and labeled as complying with UL 514B or UL 1242.
 - 3. Hazardous/Classified Locations: Use fittings listed and labeled as complying with UL 1203 for classification of installed location.
 - 4. Material: Use steel or malleable iron.
 - a. Do not use die cast zinc fittings.
 - 5. Connectors and Couplings: Use threaded type fittings only. Threadless fittings, including set screw and compression/gland types, are not permitted.
- D. Conduit Size: Comply with NFPA 70.
 - 1. Exposed: Use rigid steel conduit or intermediate metal conduit for installation up to 8 feet.

2.05 FLEXIBLE METAL CONDUIT (FMC)

- A. Manufacturers:
 - 1. AFC Cable Systems, Inc: www.afcweb.com/#sle.
 - 2. Electri-Flex Company: www.electriflex.com/#sle.
 - 3. International Metal Hose: www.metalhose.com/#sle.
 - 4. Or approved equal.
 - 5. Substitutions: See Section 01 60 00 - Product Requirements.

- B. Description: NFPA 70, Type FMC standard-wall steel flexible metal conduit listed and labeled as complying with UL 1, and listed for use in classified firestop systems.
- C. Fittings:
 - 1. Manufacturers:
 - a. ABB; T&B: www.electrification.us.abb.com/#sle.
 - b. Bridgeport Fittings, LLC: www.bptfittings.com/#sle.
 - c. Emerson Electric Co; O-Z/Gedney: www.emerson.com/#sle.
 - d. Or approved equal.
 - e. Substitutions: See Section 01 60 00 - Product Requirements.
 - 2. Description: Fittings complying with NEMA FB 1 and listed and labeled as complying with UL 514B.
 - 3. Material: Use steel or malleable iron.
 - a. Do not use die cast zinc fittings.
- D. Description: Interlocked steel construction.
- E. Connectors and Fittings: NEMA FB 1.
 - 1. Flexible metal conduit connector – Insulated throat, suitable as grounding means: T & B Series 3115.

2.06 LIQUIDTIGHT FLEXIBLE METAL CONDUIT (LFMC)

- A. Manufacturers:
 - 1. AFC Cable Systems, Inc: www.afcweb.com/#sle.
 - 2. Electri-Flex Company: www.electriflex.com/#sle.
 - 3. International Metal Hose: www.metalhose.com/#sle.
 - 4. Or approved equal.
 - 5. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Description: NFPA 70, Type LFMC polyvinyl chloride (PVC) jacketed steel flexible metal conduit listed and labeled as complying with UL 360.
- C. Fittings:
 - 1. Manufacturers:
 - a. ABB; T&B: www.electrification.us.abb.com/#sle.
 - b. Bridgeport Fittings, LLC: www.bptfittings.com/#sle.
 - c. Emerson Electric Co; O-Z/Gedney: www.emerson.com/#sle.
 - d. Or approved equal.
 - e. Substitutions: See Section 01 60 00 - Product Requirements.
 - 2. Description: Fittings complying with NEMA FB 1 and listed and labeled as complying with UL 514B.
 - 3. Material: Use steel or malleable iron.
 - a. Do not use die cast zinc fittings.
- D. Description: Interlocked steel construction with PVC jacket.
- E. Fittings: NEMA FB 1.

2.07 GALVANIZED STEEL ELECTRICAL METALLIC TUBING (EMT)

- A. Manufacturers:
 - 1. Allied Tube & Conduit: www.alliedeg.com/#sle.
 - 2. Nucor Tubular Products: www.nucortubular/#sle.
 - 3. Rymco USA: www.rymcousa.com/#sle.
 - 4. Western Tube, a division of Zekelman Industries: www.westerntube.com/#sle.
 - 5. Beck Manufacturing, Inc: www.beckmfg.com.
 - 6. Wheatland Tube Company: www.wheatland.com/#sle.
 - 7. Or Equal.
 - 8. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Description: NFPA 70, Type EMT galvanized steel electrical metallic tubing complying with ANSI C80.3 and listed and labeled as complying with UL 797.
- C. Fittings:
 - 1. Manufacturers:
 - a. Bridgeport Fittings, LLC: www.bptfittings.com/#sle.
 - b. Emerson Electric Co; O-Z/Gedney: www.emerson.com/#sle.
 - c. Or approved equal.
 - d. Substitutions: See Section 01 60 00 - Product Requirements.
 - 2. Description: Fittings complying with NEMA FB 1 and listed and labeled as complying with UL 514B.
 - 3. Material: Use steel or malleable iron.
 - a. Do not use die cast zinc fittings.
 - 4. Connectors and Couplings: Use compression/gland type.
 - a. Do not use indenter type connectors and couplings.
 - b. Do not use set-screw type connectors and couplings.
 - c. EMT Coupling: Raintight T & B Series 5220 or approved equal.
 - d. EMT to Rigid Metal Conduit Connector, Raintight: T & B Series 531 or approved equal.
 - 5. Damp or Wet Locations, Where Permitted: Use fittings listed for use in wet locations.
 - 6. Embedded Within Concrete, Where Permitted: Use fittings listed as concrete-tight. Fittings that require taping to be concrete-tight are acceptable.
- D. Description: ANSI C80.3; galvanized tubing.
- E. Fittings and Conduit Bodies: NEMA FB 1; steel or malleable iron compression type.

2.08 RIGID POLYVINYL CHLORIDE (PVC) CONDUIT

- A. Manufacturers:
 - 1. Cantex Inc: www.cantexinc.com/#sle.
 - 2. JM Eagle: www.jmeagle.com/#sle.
 - 3. Or approved equal.
 - 4. Substitutions: See Section 01 60 00 - Product Requirements.

- B. Description: NFPA 70, Type PVC rigid polyvinyl chloride conduit complying with NEMA TC 2 and listed and labeled as complying with UL 651; Schedule 40 unless otherwise indicated, Schedule 80 where subject to physical damage; rated for use with conductors rated 90 degrees C.
- C. Fittings:
 - 1. Manufacturer: Same as manufacturer of conduit to be connected.
 - 2. Description: Fittings complying with NEMA TC 3 and listed and labeled as complying with UL 651; material to match conduit.

2.09 ACCESSORIES

- A. Corrosion Protection Tape: PVC-based, minimum thickness of 20 mil, 0.020 inch.
- B. Conduit Joint Compound: Corrosion-resistant, electrically conductive compound listed as complying with UL 2419; suitable for use with conduit to be installed.
- C. Solvent Cement for PVC Conduit and Fittings: As recommended by manufacturer of conduit and fittings to be installed.
- D. Pull Strings: Use nylon or polyester tape with average breaking strength of not less than 1,250 lbf.
- E. Sealing Compound for Sealing Fittings: Listed for use with the particular fittings to be installed.
 - 1. Internal to fittings
 - a. Approved by manufacturer for application.
 - 2. Manufacturer
 - a. Crouse-Hinds Chico A-P and Chico X fiber.
 - b. O.Z. Gedney.
 - c. Or approved equal.
- F. Sealing Systems for Concrete Penetrations:
 - 1. Sleeves: Provide water stop ring or cement coating that bonds to concrete to prevent water infiltration.
 - 2. Rate for minimum of 40 psig; suitable for sealing around conduits to be installed.
- G. Sealing Systems for Roof Penetrations: Premanufactured components and accessories as required to preserve integrity of roofing system and maintain roof warranty; suitable for conduits and roofing system to be installed; designed to accommodate existing penetrations where applicable.
 - 1. Products:
 - a. Menzies Metal Products; Electrical Roof Stack and Cap: www.menzies-metal.com/#sle.
 - b. Menzies Metal Products; Electrical Retro Box: www.menzies-metal.com/#sle.
 - c. Or approved equal.
 - d. Substitutions: See Section 01 60 00 - Product Requirements.
- H. Flashing Panels for Exterior Wall Penetrations: Premanufactured components and accessories as required to preserve integrity of building envelope; suitable for conduits and facade materials to be installed.

1. Products:
 - a. Quickflash Weatherproofing Products, Inc:
www.quickflashproducts.com/#sle.
 - b. Or approved equal.
 - c. Substitutions: See Section 01 60 00 - Product Requirements.
- I. Firestop Sleeves: Listed; provide as required to preserve fire resistance rating of building elements.
 1. Products:
 - a. HoldRite, a brand of Reliance Worldwide Corporation; HydroFlame Pro Series/HydroFlame Custom Built: www.holdrite.com/#sle.
 - b. Or approved equal.
 - c. Substitutions: See Section 01 60 00 - Product Requirements.
- J. Duct Bank Spacers: Nonmetallic; designed for maintaining conduit/duct spacing for concrete encasement in open trench installation; suitable for conduit/duct arrangement to be installed.
 1. Products:
 - a. Advance Products & Systems, LLC; Duct Bank Spacers:
www.apsonline.com/#sle.
 - b. Or approved equal.
 - c. Substitutions: See Section 01 60 00 - Product Requirements.
- K. Bore Spacers: Nonmetallic; designed for maintaining conduit/duct spacing for installation within casing; furnished with roller wheels to facilitate installation, openings to facilitate grout flow, and holes for stabilization cable; suitable for casing and conduit/duct arrangement to be installed.
 1. Products:
 - a. Advance Products & Systems, LLC; Bore Spacers: www.apsonline.com/#sle.
 - b. Or approved equal.
 - c. Substitutions: See Section 01 60 00 - Product Requirements.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that field measurements are as indicated.
- B. Verify that mounting surfaces are ready to receive conduits.
- C. Verify that conditions are satisfactory for installation prior to starting work.
- D. Verify routing and termination locations of conduit prior to rough-in.
- E. Conduit routing is shown on drawings in approximate locations unless dimensioned.
Route as required to complete wiring system.

3.02 INSTALLATION

- A. Install products in accordance with manufacturer's instructions.
- B. Install conduit in accordance with NECA 1.

- C. Install galvanized steel rigid metal conduit (RMC) in accordance with NECA 101.
- D. Install aluminum rigid metal conduit (RMC) in accordance with NECA 102.
- E. Install intermediate metal conduit (IMC) in accordance with NECA 101.
- F. Install PVC-coated galvanized steel rigid metal conduit (RMC) using only tools approved by manufacturer.
- G. Install rigid polyvinyl chloride (PVC) conduit in accordance with NECA 111.
- H. Install liquidtight flexible nonmetallic conduit (LFNC) in accordance with NECA 111.
- I. Conduit Routing:
 - 1. Unless dimensioned, conduit routing indicated is diagrammatic.
 - 2. When conduit destination is indicated without specific routing, determine exact routing required.
 - 3. Conceal conduits unless specifically indicated to be exposed.
 - 4. Conduits in the following areas may be exposed, unless otherwise indicated:
 - a. Electrical rooms.
 - b. Mechanical equipment rooms.
 - c. Within joists in areas with no ceiling.
 - 5. Unless otherwise approved, do not route exposed conduits:
 - a. Across floors.
 - b. Across roofs.
 - c. Across top of parapet walls.
 - d. Across building exterior surfaces.
 - 6. Conduits installed underground or embedded in concrete may be routed in shortest possible manner unless otherwise indicated. Route other conduits parallel or perpendicular to building structure and surfaces, following surface contours where practical.
 - 7. Arrange conduit to maintain adequate headroom, clearances, and access.
 - 8. Arrange conduit to provide no more than equivalent of four 90-degree bends between pull points.
 - 9. Arrange conduit to provide no more than 150 feet between pull points.
 - 10. Route conduits above water and drain piping where possible.
 - 11. Arrange conduit to prevent moisture traps. Provide drain fittings at low points and at sealing fittings where moisture may collect.
 - 12. Maintain minimum clearance of 6 inches between conduits and piping for other systems.
 - 13. Maintain minimum clearance of 12 inches between conduits and hot surfaces. This includes, but is not limited to:
 - a. Heaters.
 - b. Hot water piping.
 - c. Flues.
 - 14. Group parallel conduits in same area on common rack.
- J. Conduit Support:
 - 1. Secure and support conduits in accordance with NFPA 70 using suitable supports and methods approved by authorities having jurisdiction; see Section 26 05 29.

2. Provide required vibration isolation and/or seismic controls; see Section 26 05 48.
 3. Provide independent support from building structure. Do not provide support from piping, ductwork, or other systems.
 4. Installation Above Suspended Ceilings: Do not provide support from ceiling support system. Do not provide support from ceiling grid or allow conduits to lay on ceiling tiles.
 5. Use conduit strap to support single surface-mounted conduit.
 - a. Use clamp back spacer with conduit strap for damp and wet locations to provide space between conduit and mounting surface.
 6. Use metal channel/strut with accessory conduit clamps to support multiple parallel surface-mounted conduits.
 7. Use conduit clamp to support single conduit from beam clamp or threaded rod.
 8. Use trapeze hangers assembled from threaded rods and metal channel/strut with accessory conduit clamps to support multiple parallel suspended conduits.
 9. Use nonpenetrating rooftop supports to support conduits routed across rooftops, where approved.
 10. Use of spring steel conduit clips for support of conduits is not permitted.
 11. Use of wire for support of conduits is not permitted.
 12. Where conduit support intervals specified in NFPA 70 and NECA standards differ, comply with most stringent requirements.
- K. Connections and Terminations:
1. Use approved zinc-rich paint or conduit joint compound on field-cut threads of galvanized steel conduits prior to making connections.
 2. Where two threaded conduits must be joined and neither can be rotated, use three-piece couplings or split couplings. Do not use running threads.
 3. Use suitable adapters where required to transition from one type of conduit to another.
 4. Provide drip loops for liquidtight flexible conduit connections to prevent drainage of liquid into connectors.
 5. Terminate threaded conduits in boxes and enclosures using threaded hubs or double lock nuts for dry locations and raintight hubs for wet locations.
 6. Where spare conduits stub up through concrete floors and are not terminated in box or enclosure, provide threaded couplings equipped with threaded plugs set flush with finished floor.
 7. Provide insulating bushings, insulated throats, or listed metal fittings with smooth, rounded edges at conduit terminations to protect conductors.
 8. Secure joints and connections to provide mechanical strength and electrical continuity.
- L. Penetrations:
1. Do not penetrate or otherwise notch or cut structural members, including footings and grade beams, without approval of Structural Engineer.
 2. Make penetrations perpendicular to surfaces unless otherwise indicated.
 3. Provide sleeves for penetrations as indicated or as required to facilitate installation. Set sleeves flush with exposed surfaces unless otherwise indicated

- or required.
4. Conceal bends for conduit risers emerging above ground.
 5. Provide suitable sealing system where conduits penetrate exterior wall below grade.
 6. Where conduits penetrate waterproof membrane, seal as required to maintain integrity of membrane.
 7. Make penetrations for roof-mounted equipment within associated equipment openings and curbs where possible to minimize roofing system penetrations. Where penetrations are necessary, seal as indicated or as required to preserve integrity of roofing system and maintain roof warranty.
 8. Provide metal escutcheon plates for conduit penetrations exposed to public view.
 9. Install firestopping to preserve fire resistance rating of partitions and other elements; see Section 07 84 00.
- M. Underground Installation:
1. Provide trenching and backfilling; see Section 31 23 16 and Section 31 23 23.
 2. Minimum Cover, Unless Otherwise Indicated or Required:
 - a. Underground, Exterior: 18 inches.
 - b. Under Slab on Grade: 12 inches to bottom of slab.
 3. Provide underground warning tape along entire conduit length for service entrance where not concrete-encased; see Section 26 05 53.
- N. Embedment Within Structural Concrete Slabs (only where approved by Structural Engineer):
1. Maximum Conduit Size: 1-inch trade size unless otherwise approved.
 2. Minimum Conduit Spacing: As indicated on drawings.
 3. Install conduits within middle one third of slab thickness.
 4. Secure conduits to prevent floating or movement during pouring of concrete.
- O. Concrete Encasement: Where conduits not otherwise embedded within concrete are indicated to be concrete-encased, provide minimum concrete cover of 3 inches on all sides unless otherwise indicated; see Section 03 30 00.
- P. Conduit Movement Provisions: Where conduits are subject to movement, provide expansion and expansion/deflection fittings to prevent damage to enclosed conductors or connected equipment. This includes, but is not limited to:
1. Where conduits cross structural joints intended for expansion, contraction, or deflection.
 2. Where calculated in accordance with NFPA 70 for rigid polyvinyl chloride (PVC) conduit installed above ground to compensate for thermal expansion and contraction.
 3. Where calculated in accordance with NFPA 70 for reinforced thermosetting resin conduit (RTRC) conduit installed above ground to compensate for thermal expansion and contraction.
 4. Where conduits are subject to earth movement by settlement or frost.
- Q. Conduit Sealing:

1. Use foam conduit sealant to prevent entry of moisture and gases. This includes, but is not limited to:
 - a. Where conduits enter building from outside.
 - b. Where service conduits enter building from underground distribution system.
 - c. Where conduits enter building from underground.
 - d. Where conduits may transport moisture to contact live parts.
2. Where conduits cross barriers between areas of potential substantial temperature differential, use foam conduit sealant at accessible point near penetration to prevent condensation. This includes, but is not limited to:
 - a. Where conduits pass from outdoors into conditioned interior spaces.
 - b. Where conduits pass from unconditioned interior spaces into conditioned interior spaces.
- R. Provide pull string in each empty conduit and in conduits where conductors and cables are to be installed by others. Leave minimum slack of 12 inches at each end.
- S. Provide grounding and bonding; see Section 26 05 26.
- T. Identify conduits; see Section 26 05 53.

3.03 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements for additional requirements.
- B. Repair cuts and abrasions in galvanized finishes using zinc-rich paint recommended by manufacturer. Replace components that exhibit signs of corrosion.
- C. Where coating of PVC-coated galvanized steel rigid metal conduit (RMC) contains cuts or abrasions, repair in accordance with manufacturer's instructions.
- D. Correct deficiencies and replace damaged or defective conduits.

3.04 EMPTY CONDUITS

- A. Certain conduits will have no conductors pulled in as a part of this contract. Identify with tags at each end of the origin and destination of each such empty conduits. Provide a permanent cap over each end of each empty conduit. Provide a nylon pull wire in each empty conduit, tie off at both ends.

3.05 TESTING AND INSPECTION

- A. So not cover up conduit work until inspected. Notify the Owner's Representative at least 3 days before desired inspection date.

3.06 CLEANING

- A. Clean interior of conduits to remove moisture and foreign matter.

3.07 PROTECTION

- A. Immediately after installation of conduit, use suitable manufactured plugs to provide protection from entry of moisture and foreign material and do not remove until ready for installation of conductors.

- B. All conduits shall be run concealed in walls and/or ceiling. Where conduits can not be run concealed in wall and/or ceiling space, the Contractor shall coordinate with the architectural and structural plans and the Architect for installing and routing of exposed conduits.

3.08 INTERFACE WITH OTHER PRODUCTS

- A. Install conduit to preserve fire resistance rating of partitions and other elements, using materials and methods specified in Section 07 84 00.

END OF SECTION 26 05 33.13

SECTION 26 05 33.16 BOXES FOR ELECTRICAL SYSTEMS

PART 1 GENERAL

1.01 SUMMARY

- A. Scope: Provide boxes, pull boxes, racks, and enclosures as shown on drawings or as required by code(s).
- B. Section Includes:
 - 1. Boxes and enclosures for integrated power, data, and audio/video.
 - 2. Boxes for hazardous (classified) locations.
 - 3. Floor boxes.
 - 4. Underground boxes/enclosures.
 - 5. Accessories.
 - 6. Wall and ceiling outlet boxes.
 - 7. Floor boxes.
 - 8. Pull and junction boxes.

1.02 RELATED REQUIREMENTS

- A. Section 03 30 00 - Cast-in-Place Concrete.
- B. Section 07 84 00 - Firestopping.
- C. Section 08 31 00 - Access Doors and Panels: Panels for maintaining access to concealed boxes.
- D. Section 26 05 26 - Grounding and Bonding for Electrical Systems.
- E. Section 26 05 29 - Hangers and Supports for Electrical Systems.
- F. Section 26 05 33.13 - Conduit for Electrical Systems:
 - 1. Conduit bodies and other fittings.
 - 2. Additional requirements for locating boxes to limit conduit length and/or number of bends between pulling points.
- G. Section 26 05 33.23 - Surface Raceways for Electrical Systems:
 - 1. Accessory boxes designed specifically for surface raceway systems.
 - 2. Lay-in wireways and wiring troughs with removable covers.
- H. Section 26 05 48 - Vibration and Seismic Controls for Electrical Systems.
- I. Section 26 05 53 - Identification for Electrical Systems: Identification products and requirements.
- J. Section 26 27 26 - Wiring Devices:
 - 1. Wall plates.
 - 2. Floor box service fittings.
 - 3. Poke-through assemblies.
 - 4. Access floor boxes.
 - 5. Additional requirements for locating boxes for wiring devices.

- K. Section 26 28 13 - Fuses: Spare fuse cabinets.
- L. Section 27 10 00 - Structured Cabling: Additional requirements for communications systems outlet boxes.
- M. Section 33 71 19 - Electrical Underground Ducts, Ductbanks, and Manholes: Concrete manholes for electrical systems.
- N. The requirements of the kitchen equipment consultant plans and specifications.

1.03 REFERENCE STANDARDS

- A. NECA 1 - Standard for Good Workmanship in Electrical Construction; 2015.
- B. NECA 130 - Standard for Installing and Maintaining Wiring Devices; 2016.
- C. NEMA 250 - Enclosures for Electrical Equipment (1000 Volts Maximum); 2020.
- D. NEMA FB 1 - Fittings, Cast Metal Boxes, and Conduit Bodies for Conduit, Electrical Metallic Tubing, and Cable; 2014.
- E. NEMA OS 1 - Sheet-Steel Outlet Boxes, Device Boxes, Covers, and Box Supports; 2013 (Reaffirmed 2020).
- F. NEMA OS 2 - Nonmetallic Outlet Boxes, Device Boxes, Covers and Box Supports; 2013 (Reaffirmed 2020).
- G. NEMA 250 - Enclosures for Electrical Equipment (1000 Volts Maximum); 2020.
- H. NFPA 70 - National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- I. SCTE 77 - Specifications for Underground Enclosure Integrity; 2017.
- J. UL 50 - Enclosures for Electrical Equipment, Non-Environmental Considerations; Current Edition, Including All Revisions.
- K. UL 50E - Enclosures for Electrical Equipment, Environmental Considerations; Current Edition, Including All Revisions.
- L. UL 508A - Industrial Control Panels; Current Edition, Including All Revisions.
- M. UL 514A - Metallic Outlet Boxes; Current Edition, Including All Revisions.
- N. UL 514C - Nonmetallic Outlet Boxes, Flush-Device Boxes, and Covers; Current Edition, Including All Revisions.
- O. UL 1203 - Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations; Current Edition, Including All Revisions.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Coordinate the work with other trades to avoid placement of ductwork, piping, equipment, or other potential obstructions within the dedicated equipment spaces and working clearances for electrical equipment required by NFPA 70.
 - 2. Coordinate arrangement of electrical equipment with the dimensions and clearance requirements of the actual equipment to be installed.

3. Coordinate minimum sizes of boxes with the actual installed arrangement of conductors, clamps, support fittings, and devices, calculated according to NFPA 70.
4. Coordinate minimum sizes of pull boxes with the actual installed arrangement of connected conduits, calculated according to NFPA 70.
5. Coordinate the placement of boxes with millwork, furniture, devices, equipment, etc. installed under other sections or by others.
6. Coordinate the work with other trades to preserve insulation integrity.
7. Coordinate the work with other trades to provide walls suitable for installation of flush-mounted boxes where indicated.
8. Notify LP Consulting Engineers, Inc. of any conflicts with or deviations from Contract Documents. Obtain direction before proceeding with work.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide manufacturer's standard catalog pages and data sheets for cabinets and enclosures, boxes for hazardous (classified) locations, floor boxes, and underground boxes/enclosures.
 1. Underground Boxes/Enclosures: Include reports for load testing in accordance with SCTE 77 certified by a professional engineer or an independent testing agency upon request.
- C. Samples:
 1. Floor Boxes: Provide one sample(s) of each floor box proposed for substitution upon request.
- D. Manufacturer's Installation Instructions: Indicate application conditions and limitations of use stipulated by product testing agency. Include instructions for storage, handling, protection, examination, preparation, and installation of product.
- E. Project Record Documents: Record actual locations for outlet and device boxes, pull boxes, cabinets and enclosures, floor boxes, and underground boxes/enclosures.
- F. Maintenance Materials: Furnish the following for Owner's use in maintenance of project.
 1. See Section 01 60 00 - Product Requirements, for additional provisions.
 2. Keys for Lockable Enclosures: Two of each different key.

1.06 QUALITY ASSURANCE

- A. Comply with requirements of NFPA 70.
- B. Maintain at the project site a copy of each referenced document that prescribes execution requirements.
- C. Product Listing Organization Qualifications: An organization recognized by OSHA as a Nationally Recognized Testing Laboratory (NRTL) and acceptable to authorities having jurisdiction.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Receive, inspect, handle, and store products in accordance with manufacturer's instructions.

PART 2 PRODUCTS

2.01 BOXES

- A. General Requirements:
 1. Do not use boxes and associated accessories for applications other than as permitted by NFPA 70 and product listing.
 2. Provide all boxes, fittings, supports, and accessories required for a complete raceway system and to accommodate devices and equipment to be installed.
 3. Provide products listed, classified, and labeled as suitable for the purpose intended.
 4. Where box size is not indicated, size to comply with NFPA 70 but not less than applicable minimum size requirements specified.
 5. Provide grounding terminals within boxes where equipment grounding conductors terminate.
- B. Outlet and Device Boxes Up to 100 cubic inches, Including Those Used as Junction and Pull Boxes:
 1. Use sheet-steel boxes for dry locations unless otherwise indicated or required.
 2. Use cast iron boxes or cast aluminum boxes for damp or wet locations unless otherwise indicated or required; furnish with compatible weatherproof gasketed covers.
 3. Use cast iron boxes or cast aluminum boxes where exposed galvanized steel rigid metal conduit or exposed intermediate metal conduit (IMC) is used.
 4. Use cast aluminum boxes where aluminum rigid metal conduit is used.
 5. Use nonmetallic boxes where exposed rigid PVC conduit is used.
 6. Use suitable concrete type boxes where flush-mounted in concrete.
 7. Use suitable masonry type boxes where flush-mounted in masonry walls.
 8. Use raised covers suitable for the type of wall construction and device configuration where required.
 9. Use shallow boxes where required by the type of wall construction.
 10. Do not use "through-wall" boxes designed for access from both sides of wall.
 11. Sheet-Steel Boxes: Comply with NEMA OS 1, and list and label as complying with UL 514A.
 12. Cast Metal Boxes: Comply with NEMA FB 1, and list and label as complying with UL 514A; furnish with threaded hubs.
 13. Nonmetallic Boxes: Comply with NEMA OS 2, and list and label as complying with UL 514C.
 14. Boxes for Supporting Luminaires and Ceiling Fans: Listed as suitable for the type and weight of load to be supported; furnished with fixture stud to accommodate mounting of luminaire where required.

15. Boxes for Ganged Devices: Use multigang boxes of single-piece construction. Do not use field-connected gangable boxes unless specifically indicated or permitted.
16. Minimum Box Size, Unless Otherwise Indicated:
 - a. Wiring Devices (Other Than Communications Systems Outlets): 4 inch square by 1-1/2 inch deep (100 by 38 mm) trade size.
 - b. Communications Systems Outlets: 4 inch square by 2-1/8 inch (100 by 54 mm) trade size.
 - c. Ceiling Outlets: 4 inch octagonal or square by 1-1/2 inch deep (100 by 38 mm) trade size.
17. Wall Plates: Comply with Section 26 27 26.
18. Manufacturers:
 - a. Cooper Crouse-Hinds, a division of Eaton Corporation: www.cooperindustries.com/#sle.
 - b. Hubbell Incorporated; Bell Products: www.hubbell-rtb.com/#sle.
 - c. Hubbell Incorporated; RACO Products: www.hubbell-rtb.com/#sle.
 - d. O-Z/Gedney, a brand of Emerson Electric Co: www.emerson.com/#sle.
 - e. Thomas & Betts Corporation: www.tnb.com/#sle.
 - f. Or equal.
 - g. Substitutions: See Section 01 60 00 - Product Requirements.
- C. Cabinets and Enclosures, Including Junction and Pull Boxes Larger Than 100 cubic inches:
 1. Comply with NEMA 250, and list and label as complying with UL 50 and UL 50E, or UL 508A.
 2. NEMA 250 Environment Type, Unless Otherwise Indicated:
 - a. Indoor Clean, Dry Locations: Type 1, painted steel.
 - b. Outdoor Locations: Type 3R, painted steel.
 - c. Kitchens and food prep. Locations: Type 4X, stainless steel, unpainted.
 3. Junction and Pull Boxes Larger Than 100 cubic inches:
 - a. Provide screw-cover or hinged-cover enclosures unless otherwise indicated.
 - b. Boxes 6 square feet and Larger: Provide sectionalized screw-cover or hinged-cover enclosures.
 4. Cabinets and Hinged-Cover Enclosures, Other Than Junction and Pull Boxes:
 - a. Provide lockable hinged covers, all locks keyed alike unless otherwise indicated.
 - b. Back Panels: Painted steel, removable.
 - c. Terminal Blocks: Provide voltage/current ratings and terminal quantity suitable for purpose indicated, with 25 percent spare terminal capacity.
 5. Finish for Painted Steel Enclosures: Manufacturer's standard grey unless otherwise indicated.
 6. Manufacturers:
 - a. Cooper B-Line, a division of Eaton Corporation: www.cooperindustries.com/#sle.
 - b. Hoffman, a brand of Pentair Technical Products: www.hoffmanonline.com/#sle.

- c. Hubbell Incorporated; Wiegmann Products: www.hubbell-wiegmann.com/#sle.
 - d. Or equal.
 - e. Substitutions: See Section 01 60 00 - Product Requirements.
- D. Boxes and Enclosures for Integrated Power, Data, and Audio/Video: Size and configuration as indicated or as required with partitions to separate services; field-connected gangable boxes may be used.
- 1. Manufacturers:
 - a. Hubbell Incorporated: www.hubbell.com/#sle.
 - b. Or approved equal.
 - c. Substitutions: See Section 01 60 00 - Product Requirements.
- E. Boxes for Hazardous (Classified) Locations: Listed and labeled as complying with UL 1203 for the classification of the installed location.
- 1. Manufacturers:
 - a. Appleton, a brand of Emerson Electric Co: www.emerson.com/#sle.
 - b. Cooper Crouse-Hinds, a division of Eaton Corporation: www.cooperindustries.com/#sle.
 - c. Hubbell Incorporated; Killark Products: www.hubbell-killark.com/#sle.
 - d. Or approved equal.
 - e. Substitutions: See Section 01 60 00 - Product Requirements.
- F. Floor Boxes:
- 1. Description: Floor boxes compatible with floor box service fittings provided in accordance with Section 26 27 26; with partitions to separate multiple services; furnished with all components, adapters, and trims required for complete installation.
 - 2. Use cast iron floor boxes within slab on grade.
 - 3. Use sheet-steel or cast iron floor boxes within slab above grade.
 - 4. Metallic Floor Boxes: Fully adjustable (with integral means for leveling adjustment prior to and after concrete pour).
 - 5. Manufacturer: Same as manufacturer of floor box service fittings.
- G. Underground Boxes/Enclosures:
- 1. Description: In-ground, open bottom boxes furnished with flush, non-skid covers with legend indicating type of service and stainless steel tamper resistant cover bolts.
 - 2. Size: As indicated on drawings.
 - 3. Depth: As required to extend below frost line to prevent frost upheaval, but not less than 12 inches.
 - 4. Provide logo on cover to indicate type of service.
 - 5. Applications:
 - a. Sidewalks and Landscaped Areas Subject Only to Occasional Nondeliberate Vehicular Traffic: Use polymer concrete enclosures, with minimum SCTE 77 Tier 8 load rating.
 - b. Parking Lots, in Areas Subject Only To Occasional Nondeliberate Vehicular Traffic: Use polymer concrete enclosures, with minimum SCTE 77 Tier 15

- load rating.
- c. Do not use polymer concrete enclosures in areas subject to deliberate vehicular traffic.
- 6. Polymer Concrete Underground Boxes/Enclosures: Comply with SCTE 77.
 - a. Manufacturers:
 - 1) Hubbell Incorporated; Quazite Products: www.hubbellpowersystems.com/#sle.
 - 2) MacLean Highline: www.macleanhighline.com/#sle.
 - 3) Oldcastle Precast, Inc: www.oldcastleprecast.com/#sle.
 - 4) Or equal.
 - 5) Substitutions: See Section 01 60 00 - Product Requirements.
 - b. Combination fiberglass/polymer concrete boxes/enclosures are acceptable.
 - c. Product(s):
 - 1) MacLean Highline PHA Series: Straight wall, all-polymer concrete splice box/pull box; available Tier 8, Tier 15, and Tier 22 load ratings.
 - (a) 11 by 18 by 12 inches nominal; Model PHA111812 (stackable).
 - 2) MacLean Highline CHA Series: Fiberglass/polymer concrete splice box/pull box; available Tier 8 and Tier 15 load ratings.
 - (a) 11 by 18 by 12 inches nominal; Model CHA111812.
 - 3) MacLean Highline CVA Series: Fiberglass/polymer concrete splice vault; available Tier 8, Tier 15, and Tier 22 load ratings.
 - (a) 30 by 48 by 18 inches nominal; Model CVA304818.
 - 4) Or approved equal.

2.02 ACCESSORIES

- A. Flashing Panels for Exterior Wall Penetrations: Premanufactured components and accessories as required to preserve integrity of building envelope; suitable for boxes and facade materials to be installed.
 - 1. Manufacturers:
 - a. Quickflash Weatherproofing Products, Inc: www.quickflashproducts.com/#sle.
 - b. Or approved equal.
 - c. Substitutions: See Section 01 60 00 - Product Requirements.

2.03 MANUFACTURERS

- A. Appleton Electric: www.appletonelec.com.
- B. Arc-Co./Division of Arcade Technology: www.arc-co.com.
- C. Unity Manufacturing: www.unitymfg.com.
- D. Or approved equal.
- E. Substitutions: See Section 01 6000 - Product Requirements.

2.04 OUTLET BOXES

- A. Sheet Metal Outlet Boxes: NEMA OS 1, galvanized steel.

1. Luminaire and Equipment Supporting Boxes: Rated for weight of equipment supported; include 1/2 inch male fixture studs where required.
 2. Concrete Ceiling Boxes: Concrete type.
- B. Cast Boxes: NEMA FB 1, Type FD, aluminum. Provide gasketed cover by box manufacturer. Provide threaded hubs.
- C. Wall Plates for Finished Areas: As specified in Section 26 27 26.

2.05 FLOOR BOXES

- A. Floor Boxes: NEMA OS 1, fully adjustable, 1-1/2 inches deep.
- B. Material: Cast metal.
- C. Shape: Round.
- D. Service Fittings: As specified in Section 26 27 26.

2.06 PULL AND JUNCTION BOXES

- A. Sheet Metal Boxes: NEMA OS 1, galvanized steel.
- B. Hinged Enclosures: As specified in Section 26 27 16.
- C. Surface Mounted Cast Metal Box: NEMA 250, Type 4; flat-flanged, surface mounted junction box:
 1. Material: Galvanized cast iron.
 2. Cover: Furnish with ground flange, neoprene gasket, and stainless steel cover screws.
- D. In-Ground Cast Metal Box: NEMA 250, Type 6, outside flanged, recessed cover box for flush mounting:
 1. Material: Galvanized cast iron.
 2. Cover: Smooth cover with neoprene gasket and stainless steel cover screws.
 3. Cover Legend: "ELECTRIC".

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that field measurements are as indicated.
- B. Boxes are indicated in approximate locations only on the drawings unless specifically dimensioned. Verify all box locations prior to rough-in.
- C. Verify that mounting surfaces are ready to receive boxes.
- D. Verify that conditions are satisfactory for installation prior to starting work.
- E. Verify locations of floor boxes and outlets prior to rough-in.
- F. Verify locations of all boxes required for kitchen equipment with kitchen consultant plans and specifications.

3.02 INSTALLATION

- A. Install products in accordance with manufacturer's instructions.

- B. Install boxes in accordance with NECA 1 (general workmanship) and, where applicable, NECA 130, including mounting heights specified in those standards where mounting heights are not indicated.
- C. Arrange equipment to provide minimum clearances in accordance with manufacturer's instructions and NFPA 70.
- D. Provide separate boxes for emergency power and normal power systems.
- E. Unless otherwise indicated, provide separate boxes for line voltage and low voltage systems.
- F. Flush-mount boxes in finished areas unless specifically indicated to be surface-mounted.
- G. Unless otherwise indicated, boxes may be surface-mounted where exposed conduits are indicated or permitted.
- H. Box Locations:
 - 1. Locate boxes to be accessible. Provide access panels in accordance with Section 08 31 00 as required where approved by the Architect.
 - 2. Unless dimensioned, box locations indicated are approximate.
 - 3. Locate boxes as required for devices installed under other sections or by others.
 - a. Switches, Receptacles, and Other Wiring Devices: Comply with Section 26 27 26.
 - b. Communications Systems Outlets: Comply with Section 27 10 00.
 - 4. Locate boxes so that wall plates do not span different building finishes.
 - 5. Locate boxes so that wall plates do not cross masonry joints.
 - 6. Unless otherwise indicated, where multiple outlet boxes are installed at the same location at different mounting heights, install along a common vertical center line.
 - 7. Do not install flush-mounted boxes on opposite sides of walls back-to-back. Provide minimum 6 inches horizontal separation unless otherwise indicated.
 - 8. Acoustic-Rated Walls: Do not install flush-mounted boxes on opposite sides of walls back-to-back; provide minimum 24 inches horizontal separation.
 - 9. Fire Resistance Rated Walls: Install flush-mounted boxes such that the required fire resistance will not be reduced.
 - a. Do not install flush-mounted boxes on opposite sides of walls back-to-back; provide minimum 24 inches separation where wall is constructed with individual noncommunicating stud cavities or protect both boxes with listed putty pads.
 - b. Do not install flush-mounted boxes with area larger than 16 square inches or such that the total aggregate area of openings exceeds 100 square inches for any 100 square feet of wall area.
 - 10. Locate junction and pull boxes as indicated, as required to facilitate installation of conductors, and to limit conduit length and/or number of bends between pulling points in accordance with Section 26 05 33.13.
 - 11. Locate junction and pull boxes in the following areas, unless otherwise indicated or approved by the Architect:

- a. Concealed above accessible suspended ceilings.
 - b. Within joists in areas with no ceiling.
 - c. Electrical rooms.
 - d. Mechanical equipment rooms.
- I. Box Supports:
1. Secure and support boxes in accordance with NFPA 70 and Section 26 05 29 using suitable supports and methods approved by the authority having jurisdiction.
 2. Provide required seismic controls in accordance with Section 26 05 48.
 3. Provide independent support from building structure except for cast metal boxes (other than boxes used for fixture support) supported by threaded conduit connections in accordance with NFPA 70. Do not provide support from piping, ductwork, or other systems.
 4. Installation Above Suspended Ceilings: Do not provide support from ceiling grid or ceiling support system.
 5. Use far-side support to secure flush-mounted boxes supported from single stud in hollow stud walls. Repair or replace supports for boxes that permit excessive movement.
- J. Install boxes plumb and level.
- K. Flush-Mounted Boxes:
1. Install boxes in noncombustible materials such as concrete, tile, gypsum, plaster, etc. so that front edge of box or associated raised cover is not set back from finished surface more than 1/4 inch or does not project beyond finished surface.
 2. Install boxes in combustible materials such as wood so that front edge of box or associated raised cover is flush with finished surface.
 3. Repair rough openings around boxes in noncombustible materials such as concrete, tile, gypsum, plaster, etc. so that there are no gaps or open spaces greater than 1/8 inch at the edge of the box.
- L. Floor-Mounted Cabinets: Mount on properly sized 3 inch high concrete pad constructed in accordance with Section 03 30 00.
- M. Install boxes as required to preserve insulation integrity.
- N. Metallic Floor Boxes: Install box level at the proper elevation to be flush with finished floor.
- O. Nonmetallic Floor Boxes: Cut box flush with finished floor after concrete pour.
- P. Underground Boxes/Enclosures:
1. Install enclosure on gravel base, minimum 6 inches deep.
 2. Flush-mount enclosures located in concrete or paved areas.
 3. Mount enclosures located in landscaped areas with top at 1 inch above finished grade.
 4. Provide cast-in-place concrete collar constructed in accordance with Section 03 30 00, minimum 10 inches wide by 12 inches deep, around enclosures that are not located in concrete areas.

5. Install additional bracing inside enclosures in accordance with manufacturer's instructions to minimize box sidewall deflections during backfilling. Backfill with cover bolted in place.
- Q. Install permanent barrier between ganged wiring devices when voltage between adjacent devices exceeds 300 V.
- R. Install firestopping to preserve fire resistance rating of partitions and other elements, using materials and methods specified in Section 07 84 00.
- S. Close unused box openings.
- T. Install blank wall plates on junction boxes and on outlet boxes with no devices or equipment installed or designated for future use.
- U. Provide grounding and bonding in accordance with Section 26 05 26.
- V. Identify boxes in accordance with Section 26 05 53.
- W. Install boxes securely, in a neat and workmanlike manner, as specified in NECA 1.
- X. Install in locations as shown on Drawings, and as required for splices, taps, wire pulling, equipment connections, and as required by NFPA 72.
- Y. Coordinate installation of outlet boxes for equipment connected under Section 26 27 17.
- Z. Set wall mounted boxes at elevations to accommodate mounting heights indicated.
- AA. Electrical boxes are shown on Drawings in approximate locations unless dimensioned.
 1. Adjust box locations up to 10 feet if required to accommodate intended purpose.
- BB. Orient boxes to accommodate wiring devices oriented as specified in Section 26 27 26.
- CC. Maintain headroom and present neat mechanical appearance.
- DD. Install pull boxes and junction boxes above accessible ceilings and in unfinished areas only.
- EE. Inaccessible Ceiling Areas: Install outlet and junction boxes no more than 6 inches from ceiling access panel or from removable recessed luminaire.
- FF. Install boxes to preserve fire resistance rating of partitions and other elements, using materials and methods specified in Section 07 84 00.
- GG. Coordinate mounting heights and locations of outlets mounted above counters, benches, and backsplashes.
- HH. Locate outlet boxes to allow luminaires positioned as shown on reflected ceiling plan.
- II. Align adjacent wall mounted outlet boxes for switches, thermostats, and similar devices.
- JJ. Use flush mounting outlet box in finished areas.
- KK. Locate flush mounting box in masonry wall to require cutting of masonry unit corner only. Coordinate masonry cutting to achieve neat opening.
- LL. Do not install flush mounting box back-to-back in walls; provide minimum 6 inches separation. Provide minimum 24 inches separation in fire-rated and acoustic rated walls.

- MM. Secure flush mounting box to interior wall and partition studs. Accurately position to allow for surface finish thickness.
- NN. Use stamped steel bridges to fasten flush mounting outlet box between studs.
- OO. Install flush mounting box without damaging wall insulation or reducing its effectiveness.
- PP. Use adjustable steel channel fasteners for hung ceiling outlet box.
- QQ. Do not fasten boxes to ceiling support wires.
- RR. Support boxes independently of conduit, except cast box that is connected to two rigid metal conduits both supported within 12 inches of box.
- SS. Use gang box where more than one device is mounted together. Do not use sectional box.
- TT. Use gang box with plaster ring for single device outlets.
- UU. Use cast outlet box in exterior locations exposed to the weather and wet locations.
- VV. Use cast floor boxes for installations in slab on grade; formed steel boxes are acceptable for other installations.
- WW. Set floor boxes level.
- XX. Large Pull Boxes: Use hinged enclosure in interior dry locations, surface-mounted cast metal box in other locations.

3.03 ADJUSTING

- A. Adjust floor boxes flush with finish flooring material.
- B. Adjust flush-mounting outlets to make front flush with finished wall material.
- C. Install knockout closures in unused box openings.

3.04 CLEANING

- A. Clean interior of boxes to remove dirt, debris, plaster and other foreign material.

3.05 PROTECTION

- A. Immediately after installation, protect boxes from entry of moisture and foreign material until ready for installation of conductors.

END OF SECTION 26 05 33.16

SECTION 26 05 48

VIBRATION AND SEISMIC CONTROLS FOR ELECTRICAL SYSTEMS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Vibration isolation requirements.
- B. Seismic control requirements.
 - 1. Includes requirements for seismic qualification of equipment not specified in this section.
- C. Vibration-isolated equipment support bases.
- D. Vibration isolators.
- E. External seismic snubber assemblies.
- F. Anchoring and seismic restraint systems.

1.02 RELATED REQUIREMENTS

- A. Section 01 45 33 - Code-Required Special Inspections and Procedures.
- B. Section 03 30 00 - Cast-in-Place Concrete.
- C. Section 26 05 00 - Common Work Results for Electrical.
- D. Section 05 50 00 - Metal Fabrications: Materials and requirements for fabricated metal supports.
- E. Section 26 05 29 - Hangers and Supports for Electrical Systems.

1.03 SYSTEM DESCRIPTION

- A. Design Requirements
 - 1. Provide the work in compliance with CCR Title 24, Part 2, State Chapters, Drawings, and calculations to be stamped and signed by a California licensed structural engineer.
 - 2. Provide seismic restraints for the listed materials and equipment. The attachments shall resist forces to the center of gravity of the component. Criteria shall be the operating weight of the item times 0.5g for horizontal force to be applied in any direction. Wall-mounted or suspended components shall in addition, resist a downward force of 200 pounds minimum added to the operating weight of the component.

1.04 DEFINITIONS

- A. Electrical Component: Where referenced in this section in regards to seismic controls, applies to any portion of the electrical system subject to seismic evaluation in accordance with applicable codes, including distributed systems (e.g., conduit, cable tray).
- B. Seismic Restraint: Structural members or assemblies of members or manufactured elements specifically designed and applied for transmitting seismic forces between

components and the seismic force-resisting system of the structure.

1.05 REFERENCE STANDARDS

- A. ASTM E2265-2003 – Standard Terminology for Anchors and Fasteners in Concrete and Masonry.
- B. ASCE 7 - Minimum Design Loads and Associated Criteria for Buildings and Other Structures; Most Recent Edition Cited by Referring Code or Reference Standard.
- C. ASCE 19 - Structural Applications of Steel Cables for Buildings; 2016.
- D. ASHRAE (HVACA) - ASHRAE Handbook - HVAC Applications; Most Recent Edition Cited by Referring Code or Reference Standard.
- E. ASTM E580/E580M - Standard Practice for Installation of Ceiling Suspension Systems for Acoustical Tile and Lay-in Panels in Areas Subject to Earthquake Ground Motions; 2022.
- F. FEMA 413 - Installing Seismic Restraints for Electrical Equipment; 2004.
- G. FEMA E-74 - Reducing the Risks of Nonstructural Earthquake Damage; 2012.
- H. ICC (IBC) - International Building Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- I. ICC-ES AC156 - Acceptance Criteria for Seismic Certification by Shake-Table Testing of Nonstructural Components; 2010, with Editorial Revision (2020).
- J. MFMA-4 - Metal Framing Standards Publication; 2004.
- K. NECA 1 - Standard for Good Workmanship in Electrical Construction; 2015.
- L. NFPA 70 - National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- M. SMACNA (SRM) - Seismic Restraint Manual Guidelines for Mechanical Systems; 2008.

1.06 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Coordinate selection and arrangement of vibration isolation and/or seismic control components with the actual equipment to be installed.
 - 2. Coordinate the work with other trades to provide additional framing and materials required for installation.
 - 3. Coordinate compatibility of support and attachment components with mounting surfaces at the installed locations.
 - 4. Coordinate compatibility of support and attachment components with mounting surfaces at the installed locations.
 - 5. Seismic Controls:
 - a. Coordinate the arrangement of seismic restraints with ductwork, piping, equipment and other potential conflicts installed under other sections or by others.
 - b. Coordinate the work with other trades to accommodate relative positioning of essential and nonessential components in consideration of seismic interaction.

6. Notify LP Consulting Engineers, Inc. of any conflicts with or deviations from Contract Documents. Obtain direction before proceeding with work.
- B. Sequencing:
 1. Do not install products on or provide attachment to concrete surfaces until concrete has fully cured in accordance with Section 03 30 00.

1.07 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Design Documents: Prepare and submit all information required for plan review and permitting by authorities having jurisdiction, including but not limited to floor plans, details, and calculations.
- C. Product Data: Provide manufacturer's standard catalog pages and data sheets for products, including materials, fabrication details, dimensions, and finishes.
 1. Vibration Isolators: Include rated load capacities and deflections; include information on color coding or other identification methods for spring element load capacities.
 2. Seismic Controls: Include seismic load capacities.
- D. Shop Drawings - Vibration Isolation Systems:
 1. Include dimensioned plan views and sections indicating proposed arrangement of vibration isolators; indicate equipment weights and static deflections.
 2. Vibration-Isolated Equipment Support Bases: Include base weights, including concrete fill where applicable; indicate equipment mounting provisions.
- E. Shop Drawings - Seismic Controls:
 1. Include dimensioned plan views and sections indicating proposed electrical component locations and distributed system routing, with locations and details of gravity supports and seismic restraints and associated attachments.
 2. Identify mounting conditions required for equipment seismic qualification.
 3. Identify anchor manufacturer, type, minimum embedment, minimum spacing, minimum member thickness, and minimum edge distance requirements.
 4. Indicate proposed arrangement of distributed system trapeze support groupings.
 5. Indicate proposed locations for distributed system flexible fittings and/or connections.
 6. Indicate locations of seismic separations where applicable.
 7. Include point load drawings indicating design loads transmitted to structure at each attachment location.
- F. Seismic Design Data:
 1. Compile information on project-specific characteristics of actual installed electrical components necessary for determining seismic design forces required to design appropriate seismic controls, including but not limited to the following.
 - a. Component operating weight and center of gravity.
 - b. Component elevation in the building in relation to the roof elevation (z/h).
 - c. Component importance factor (I_p).
 - d. For distributed systems, component materials and connection methods.

- e. Component amplification factor (a_p) and component response modification factor (R_p), determined in accordance with ASCE 7 tables.
- f. Applicability of overstrength factor (for certain anchorage in concrete and masonry).
- 2. Include structural calculations, stamped or sealed by seismic controls designer, demonstrating suitability of seismic controls for seismic design forces.
- G. Certification for seismically qualified equipment; identify basis for certification.
- H. Evaluation Reports: For products specified as requiring evaluation and recognition by a qualified evaluation service, provide current evaluation reports.
- I. Manufacturer's Instructions: Indicate application conditions and limitations of use stipulated by product testing agency. Include instructions for storage, handling, protection, examination, preparation, and installation of product.
- J. Evidence of qualifications for seismic controls designer.
- K. Evidence of qualifications for manufacturer.
- L. Manufacturer's detailed field testing and inspection procedures.
- M. Field quality control test reports.

1.08 QUALITY ASSURANCE

- A. Comply with NFPA 70.
- B. Comply with applicable building code.
- C. Maintain at the project site a copy of each referenced document that prescribes execution requirements.
- D. Seismic Controls Designer Qualifications: Registered professional engineer licensed in California and with minimum five years experience designing seismic restraints for nonstructural components.
 - 1. Designer may be employed by the manufacturer of the seismic restraint products.
- E. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum three years documented experience.

1.09 DELIVERY, STORAGE, AND HANDLING

- A. Receive, inspect, handle, and store products in accordance with manufacturer's instructions.

PART 2 PRODUCTS

2.01 VIBRATION ISOLATION REQUIREMENTS

- A. Design and provide vibration isolation systems to reduce vibration transmission to supporting structure from vibration-producing electrical equipment and/or electrical connections to vibration-isolated equipment.
- B. Comply with applicable general recommendations of ASHRAE (HVACA), where not in conflict with other specified requirements:

C. General Requirements:

1. Select vibration isolators to provide required static deflection.
2. Select vibration isolators for uniform deflection based on distributed operating weight of actual installed equipment.
3. Select seismic type vibration isolators to comply with seismic design requirements, including conditions of equipment seismic certification where applicable.
4. Select vibration isolators for outdoor equipment to comply with wind design requirements.
5. Select vibration-isolated equipment support bases and associated vibration isolators to provide minimum 2-inch operating clearance beneath base unless otherwise indicated.

D. Equipment Isolation:

1. Transformers:
 - a. Specified vibration isolators are in addition to any factory-installed internal core and coil assembly vibration isolators unless otherwise indicated.
 - b. Floor-Mounted Transformers, Nonseismic Applications: Use resilient material isolator pads, resilient material isolator mounts, or open (unhoused) spring isolators.
 - c. Floor-Mounted Transformers, Seismic Applications: Use seismic type resilient material isolator mounts or seismic type restrained spring isolators.
 - d. Suspended Transformers, Nonseismic Applications: Use resilient material isolator hangers, spring isolator hangers, or combination resilient material/spring isolator hangers.
 - e. Suspended Transformers, Seismic Applications: Use seismic type resilient material isolator hangers, seismic type spring isolator hangers, or seismic type combination resilient material/spring isolator hangers.
 - f. Wall-Mounted Transformers, Nonseismic Applications: Use resilient material isolator mounts.
 - g. Wall-Mounted Transformers, Seismic Applications: Use seismic type resilient material isolator mounts.
 - h. Minimum Static Deflection:
 - 1) Transformers Mounted on Grade-Level Slabs: 0.25 inch deflection unless otherwise indicated.
 - 2) Transformers Mounted at Above-Grade Levels: 0.5 inch deflection unless otherwise indicated.
2. Engine Generators:
 - a. Specified vibration isolators are in addition to any factory-installed internal vibration isolators between generator set and integral base unless otherwise indicated; obtain generator set manufacturer approval of applied vibration isolation.
 - b. Nonseismic Applications, Isolators Not Located Below Sub-Base Fuel Tank: Use housed spring isolators or restrained spring isolators.
 - c. Nonseismic Applications, Isolators Located Below Sub-Base Fuel Tank: Use restrained spring isolators.

- d. Seismic Applications: Use seismic type restrained spring isolators.
 - e. Provide vibration-isolated concrete inertia bases where indicated.
 - f. Minimum Static Deflection:
 - 1) Generators Mounted on Grade-Level Slabs: 1 inch deflection unless otherwise indicated.
 - 2) Generators Mounted at Above-Grade Levels: 2 inch deflection unless otherwise indicated.
- E. Conduit Isolation:
- 1. Use flexible conduit or cable for electrical connections to vibration-isolated equipment, including equipment installed under other sections or by others.
 - a. Minimum Length: 3 feet unless otherwise indicated.
 - 2. Vibration Isolators:
 - a. Provide vibration isolators for conduit supports:
 - 1) Located within 50 feet of connected vibration-isolated equipment where flexible connection to equipment is not possible.
 - 2) For conduits over 2 inch trade size located below or within 50 feet of noise-sensitive areas indicated.
 - b. Minimum Static Deflection:
 - 1) First Three Supports Closest to Isolated Equipment: Same as static deflection of equipment; maximum of 2 inch deflection required.
 - 2) Remainder of Supports: 0.75 inch deflection unless otherwise indicated.
 - c. Suspended Conduits, Nonseismic Applications: Use resilient material isolator hangers, spring isolator hangers, or combination resilient material/spring isolator hangers.
 - d. Suspended Conduits, Seismic Applications: Use seismic type resilient material isolator hangers, seismic type spring isolator hangers, or seismic type combination resilient material/spring isolator hangers.
 - e. Use modular seal or approved resilient material where vibration-isolated conduits penetrate building elements (e.g., walls, floors) arranged to prevent vibration transmission to structure.

2.02 SEISMIC CONTROL REQUIREMENTS

- A. Design and provide electrical component restraints, supports, and attachments suitable for seismic loads determined in accordance with applicable codes, as well as gravity and operating loads and other structural design considerations of the installed location. Consider wind loads for outdoor electrical components.
- B. Seismic Design Criteria: ICC (IBC)/ASCE 7.
- C. Component Importance Factor (I_p): Electrical components to be assigned a component importance factor (I_p) of 1.5 unless otherwise indicated.
- D. Seismic Qualification of Equipment:
 - 1. Provide special certification for electrical equipment furnished under other sections and assigned a component importance factor (I_p) of 1.5, certifying that equipment will remain operable following a design level earthquake.

2. Seismic qualification to be by shake table testing in accordance with recognized testing standard procedure, such as ICC-ES AC156, acceptable to authorities having jurisdiction.
 3. Notify LP Consulting Engineers, Inc. and obtain direction where mounting restrictions required by conditions of seismic certification conflict with specified requirements.
 4. Seismically qualified equipment to be furnished with factory-installed labels referencing certificate of compliance and associated mounting restrictions.
- E. Seismic Restraints:
1. Provide seismic restraints for electrical components except where exempt according to applicable codes and specified seismic design criteria, as approved by authorities having jurisdiction.
 2. Comply with applicable general recommendations of the following, where not in conflict with applicable codes, seismic design criteria, or other specified requirements:
 - a. ASHRAE (HVACA).
 - b. FEMA 413.
 - c. FEMA E-74.
 - d. SMACNA (SRM).
 3. Seismic restraint capacities to be verified by a Nationally Recognized Testing Laboratory (NRTL) or certified by an independent third-party registered professional engineer acceptable to authorities having jurisdiction.
 4. Seismic Type Vibration Isolators:
 - a. Comply with seismic design requirements, including conditions of equipment seismic certification where applicable.
 5. External Seismic Snubber Assemblies:
 - a. Provide quantity and arrangement of external seismic snubber assemblies as required to restrain equipment in all directions (both lateral and vertical).
 - b. Do not use external seismic snubber assemblies that restrain equipment only in one or more lateral directions (but not vertical) except where uplift forces are zero or are addressed by other restraints.
 6. Seismic Restraint Systems:
 - a. Except where otherwise restricted, use of either cable or rigid restraints is permitted.
 - b. Use only cable restraints to restrain vibration-isolated electrical components, including distributed systems.
 - c. Use only one restraint system type for a given electrical component or distributed system (e.g., conduit, cable tray) run; mixing of cable and rigid restraints on a given component/run is not permitted.
 - d. Size restraint elements, including anchorage, to resist seismic loads as necessary to restrain electrical component in all lateral directions; consider bracket geometry in anchor load calculations.
 - e. Use rod stiffener clips to attach bracing to hanger rods as required to prevent rod buckling from vertical (upward) compressive load introduced by cable or rigid restraints loaded in tension, in excess of downward tensile

load due to supported electrical component weight.

- f. Select hanger rods and associated anchorage as required to accommodate vertical (downward) tensile load introduced by rigid restraints loaded in compression, in addition to downward tensile load due to supported electrical component weight.
 - g. Clevis hangers may only be used for attachment of transverse restraints; do not use for attachment of longitudinal restraints.
 - h. Where seismic restraints are attached to clevis hangers, provide clevis bolt reinforcement accessory to prevent clevis hanger deformation.
 - i. Do not introduce lateral loads on open bar joist chords or the weak axis of beams, or loads in any direction at other than panel points unless approved by project Structural Engineer of Record.
 - j. Manufacturer's certified seismic restraint design may be submitted as an alternative to project-specific design and documentation, subject to approval of authorities having jurisdiction.
- F. Seismic Attachments:
- 1. Attachments to be bolted, welded, or otherwise positively fastened without consideration of frictional resistance produced by the effects of gravity.
 - 2. Post-Installed Concrete and Masonry Anchors: Evaluated and recognized by ICC Evaluation Service, LLC (ICC-ES) or qualified evaluation service acceptable to authorities having jurisdiction for compliance with applicable building code, and qualified for seismic applications; concrete anchors to be qualified for installation in both cracked and uncracked concrete.
 - 3. Do not use power-actuated fasteners.
 - 4. Do not use friction clips (devices that rely on mechanically applied friction to resist loads). Beam clamps may be used for supporting sustained loads where provided with restraining straps.
 - 5. Comply with anchor minimum embedment, minimum spacing, minimum member thickness, and minimum edge distance requirements.
 - 6. Concrete Housekeeping Pads:
 - a. Increase size of pad as required to comply with anchor requirements.
 - b. Provide pad reinforcement and doweling to ensure integrity of pad and connection and to provide adequate load path from pad to supporting structure.
- G. Seismic Interactions:
- 1. Include provisions to prevent seismic impact between electrical components and other structural or nonstructural components.
 - 2. Include provisions such that failure of a component, either essential or nonessential, does not cause the failure of an essential component.
 - 3. Comply with minimum clearance requirements between electrical equipment, distribution systems, and associated supports and fire protection sprinkler system drops and sprigs.
- H. Seismic Relative Displacement Provisions:
- 1. Use suitable fittings or flexible connections to accommodate:

- a. Relative displacements at connections between components, including distributed systems (e.g., conduit, cable tray); do not exceed load limits for equipment utility connections.
 - b. Relative displacements between component supports attached to dissimilar parts of structure that may move differently during an earthquake.
 - c. Design displacements at seismic separations.
 - d. Anticipated drifts between floors.
2. Include provisions to prevent interruption of utility service due to seismic displacements.

2.03 VIBRATION-ISOLATED EQUIPMENT SUPPORT BASES

- A. Manufacturers:
 1. Vibration-Isolated Equipment Support Bases:
 - a. Kinetics Noise Control, Inc: www.kineticsnoise.com/#sle.
 - b. Mason Industries: www.mason-ind.com/#sle.
 - c. Vibration Eliminator Company, Inc: www.vec0-nyc.com/#sle.
 - d. Korfund Dynamics Corp.
 - e. Amber-Booth Co.
 - f. Consolidated Kinetics.
 2. Substitutions: See Section 01 60 00 - Product Requirements.
 3. Source Limitations: Furnish vibration-isolated equipment support bases and associated components and accessories produced by the same manufacturer as the vibration isolators and obtained from a single supplier.
- B. Vibration-Isolated Structural Steel Bases:
 1. Description: Engineered structural steel frames with integral mounting provisions for vibration isolators, sized and configured for mounting of equipment.
- C. Vibration-Isolated Concrete Inertia Bases:
 1. Description: Concrete-filled engineered steel forms with integral mounting provisions for vibration isolators, sized and configured for mounting of equipment.
 2. Minimum Base Depth: 6 inches.
 3. Minimum Base Mass (Including Concrete): 1.5 times weight of supported equipment.
 4. Concrete Reinforcement: Welded or tied reinforcing bars running both ways in a single layer.
 5. Concrete: Filled on site with minimum 3000 psi concrete in accordance with Section 03 30 00.

2.04 VIBRATION ISOLATORS

- A. Manufacturers:
 1. Vibration Isolators:
 - a. Kinetics Noise Control, Inc: www.kineticsnoise.com/#sle.
 - b. Mason Industries: www.mason-ind.com/#sle.

- c. Vibration Eliminator Company, Inc: www.veco-nyc.com/#sle.
 - d. Korfund Dynamics Corp.
 - e. Amber-Booth Co.
 - f. Consolidated Kinetics.
 - g. Or approved equal.
2. Substitutions: See Section 01 60 00 - Product Requirements.
 3. Source Limitations: Furnish vibration-isolators and associated accessories produced by a single manufacturer and obtained from a single supplier.
- B. General Requirements:
1. Resilient Materials for Vibration Isolators: Oil, ozone, and oxidant resistant.
 2. Spring Elements for Spring Isolators:
 - a. Color code or otherwise identify springs to indicate load capacity.
 - b. Lateral Stability: Minimum lateral stiffness to vertical stiffness ratio of 0.8.
 - c. Designed to operate in the linear portion of their load versus deflection curve over deflection range of not less than 50 percent above specified deflection.
 - d. Designed to provide additional travel to solid of not less than 50 percent of rated deflection at rated load.
 - e. Selected to provide designed deflection of not less than 75 percent of specified deflection.
 - f. Selected to function without undue stress or overloading.
 3. Seismic Snubbing Elements for Seismic Isolators:
 - a. Air Gap: Between 0.125 inches and 0.25 inches unless otherwise indicated.
 - b. Points of Contact: Cushioned with resilient material, minimum 0.25 inch thick; capable of being visually inspected for damage and replaced.
- C. Vibration Isolators for Nonseismic Applications:
1. Resilient Material Isolator Pads:
 - a. Description: Single or multiple layer pads utilizing elastomeric (e.g., neoprene, rubber) or fiberglass isolator material.
 - b. Pad Thickness: As required for specified minimum static deflection; minimum 0.25 inch thickness.
 - c. Multiple Layer Pads: Provide bonded, galvanized sheet metal separation plate between each layer.
 2. Resilient Material Isolator Mounts, Nonseismic:
 - a. Description: Mounting assemblies for bolting equipment to supporting structure utilizing elastomeric (e.g., neoprene, rubber) or fiberglass isolator material; fail-safe type.
 3. Open (Unhoused) Spring Isolators:
 - a. Description: Isolator assembly consisting of single or multiple free-standing, laterally stable steel spring(s) without a housing.
 - b. Bottom Load Plate: Nonskid, molded, elastomeric isolator material or steel with nonskid elastomeric isolator pad with provisions for bolting to supporting structure as required.

- c. Furnished with integral leveling device for positioning and securing supported equipment.
4. Housed Spring Isolators:
 - a. Description: Isolator assembly consisting of single or multiple free-standing, laterally stable steel spring(s) within a metal housing.
 - b. Furnished with integral elastomeric snubbing elements, nonadjustable type, for limiting equipment movement and preventing metal-to-metal contact between housing elements.
 - c. Bottom Load Plate: Steel with nonskid, elastomeric isolator pad with provisions for bolting to supporting structure as required.
 - d. Furnished with integral leveling device for positioning and securing supported equipment.
5. Restrained Spring Isolators, Nonseismic:
 - a. Description: Isolator assembly consisting of single or multiple free-standing, laterally stable steel spring(s) within a metal housing designed to prevent movement of supported equipment above an adjustable vertical limit stop.
 - b. Bottom Load Plate: Steel with nonskid, elastomeric isolator pad with provisions for bolting to supporting structure as required.
 - c. Furnished with integral leveling device for positioning and securing supported equipment.
 - d. Provides constant free and operating height.
6. Resilient Material Isolator Hangers, Nonseismic:
 - a. Description: Isolator assembly designed for installation in hanger rod suspension system utilizing elastomeric (e.g., neoprene, rubber) or fiberglass isolator material for the lower hanger rod connection.
7. Spring Isolator Hangers, Nonseismic:
 - a. Description: Isolator assembly designed for installation in hanger rod suspension system utilizing single or multiple free-standing, laterally stable steel spring(s) in series with an elastomeric element for the lower hanger rod connection.
 - b. Designed to accommodate misalignment of bottom hanger rod up to 30 degrees (plus/minus 15 degrees) without short-circuiting of isolation.
8. Combination Resilient Material/Spring Isolator Hangers, Nonseismic:
 - a. Description: Isolator assembly designed for installation in hanger rod suspension system utilizing single or multiple free-standing, laterally stable steel spring(s) for the lower hanger rod connection and elastomeric (e.g., neoprene, rubber) or fiberglass isolator material for the upper hanger rod connection.
 - b. Designed to accommodate misalignment of bottom hanger rod up to 30 degrees (plus/minus 15 degrees) without short-circuiting of isolation.
- D. Vibration Isolators for Seismic Applications:
 1. Resilient Material Isolator Mounts, Seismic:
 - a. Description: Mounting assemblies for bolting equipment to supporting structure utilizing elastomeric (e.g., neoprene, rubber) isolator material; specifically designed and rated for seismic applications with integral

- snubbing in all directions.
2. Restrained Spring Isolators, Seismic:
 - a. Description: Isolator assembly consisting of single or multiple free-standing, laterally stable steel spring(s) in series with elastomeric (e.g., neoprene, rubber) isolator material within a metal housing designed to prevent movement of supported equipment above an adjustable vertical limit stop; specifically designed and rated for seismic applications with integral snubbing in all directions.
 - b. Bottom Load Plate: Steel with provisions for bolting to supporting structure as required.
 - c. Furnished with integral leveling device for positioning and securing supported equipment.
 - d. Provides constant free and operating height.
 3. Resilient Material Isolator Hangers, Seismic:
 - a. Description: Isolator assembly designed for installation in hanger rod suspension system utilizing elastomeric (e.g., neoprene, rubber) isolator material for the lower hanger rod connection; specifically designed and rated for seismic applications with vertical limit stop to prevent upward travel of hanger rod and cushion impact.
 4. Spring Isolator Hangers, Seismic:
 - a. Description: Isolator assembly designed for installation in hanger rod suspension system utilizing single or multiple free-standing, laterally stable steel spring(s) in series with an elastomeric element for the lower hanger rod connection; specifically designed and rated for seismic applications with vertical limit stop to prevent upward travel of hanger rod and cushion impact.
 - b. Designed to accommodate misalignment of bottom hanger rod up to 30 degrees (plus/minus 15 degrees) without short-circuiting of isolation.
 5. Combination Resilient Material/Spring Isolator Hangers, Seismic:
 - a. Description: Isolator assembly designed for installation in hanger rod suspension system utilizing single or multiple free-standing, laterally stable steel spring(s) for the lower hanger rod connection and elastomeric (e.g., neoprene, rubber) isolator material for the upper hanger rod connection; specifically designed and rated for seismic applications with vertical limit stop to prevent upward travel of hanger rod and cushion impact.
 - b. Designed to accommodate misalignment of bottom hanger rod up to 30 degrees (plus/minus 15 degrees) without short-circuiting of isolation.

2.05 EXTERNAL SEISMIC SNUBBER ASSEMBLIES

- A. Manufacturers:
 1. External Seismic Snubber Assemblies:
 - a. Kinetics Noise Control, Inc: www.kineticsnoise.com/#sle.
 - b. Mason Industries: www.mason-ind.com/#sle.
 - c. Vibration Eliminator Company, Inc: www.veco-nyc.com/#sle.
 - d. Korfund Dynamics Corp.

- e. Amber-Booth Co.
- f. Consolidated Kinetics.
- g. Or approved equal.
- 2. Substitutions: See Section 01 60 00 - Product Requirements.
- 3. Source Limitations: Furnish external seismic snubber assemblies and associated accessories produced by the same manufacturer as the vibration isolators and obtained from a single supplier.
- B. Description: Steel snubbing assemblies designed for external attachment to both equipment and supporting structure that, as part of a complete system, restrain equipment motion in all directions during a seismic event while maintaining vibration isolation during normal operation.
- C. Seismic Snubbing Elements:
 - 1. Air Gap: Between 0.125 inches and 0.25 inches unless otherwise indicated.
 - 2. Points of Contact: Cushioned with resilient material, minimum 0.25 inch thick; capable of being visually inspected for damage and replaced.

2.06 SEISMIC RESTRAINT SYSTEMS

- A. Manufacturers:
 - 1. Seismic Restraint Systems:
 - a. AFCON, a brand of Anvil International: www.anvilintl.com/#sle.
 - b. Eaton Corporation: www.eaton.com/#sle.
 - c. Kinetics Noise Control, Inc: www.kineticsnoise.com/#sle.
 - d. Mason Industries: www.mason-ind.com/#sle.
 - e. Or approved equal.
 - 2. Substitutions: See Section 01 60 00 - Product Requirements.
 - 3. Source Limitations: Furnish seismic restraint system components and accessories produced by a single manufacturer and obtained from a single supplier.
- B. Description: System components and accessories specifically designed for field assembly and attachment of seismic restraints.
- C. Cable Restraints:
 - 1. Comply with ASCE 19.
 - 2. Cables: Pre-stretched, galvanized steel wire rope with certified break strength.
 - 3. Cable Connections: Use only swaged end fittings. Cable clips and wedge type end fittings are not permitted in accordance with ASCE 19.
 - 4. Use protective thimbles for cable loops where potential for cable damage exists.
- D. Rigid Restraints: Use MFMA-4 steel channel (strut), steel angle, or steel pipe for structural element; suitable for both compressive and tensile design loads.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that field measurements are as shown on the drawings.

- B. Verify that mounting surfaces are ready to receive vibration isolation and/or seismic control components and associated attachments.
- C. Verify that conditions are satisfactory for installation prior to starting work.

3.02 CODE-REQUIRED SPECIAL INSPECTIONS

- A. Arrange work to accommodate tests and/or inspections performed by Special Inspection Agency employed by Owner or LP Consulting Engineers, Inc. in accordance with Section 01 45 33 and statement of special inspections as required by applicable building code.
- B. Frequency of Special Inspections: Where special inspections are designated as continuous or periodic, arrange work accordingly.
 - 1. Continuous Special Inspections: Special Inspection Agency to be present in the area where the work is being performed and observe the work at all times the work is in progress.
 - 2. Periodic Special Inspections: Special Inspection Agency to be present in the area where work is being performed and observe the work part-time or intermittently and at the completion of the work.
- C. Seismic special inspections include, but are not limited to:
 - 1. Seismically Qualified Equipment: Verification that label, anchorage, and mounting comply with certificate of compliance.
 - 2. Anchorage of electric equipment for emergency and standby power systems for Seismic Design Categories C, D, E, and F; periodic inspection.
 - 3. Anchorage of electrical equipment other than for emergency and standby power systems for Seismic Design Categories E and F; periodic inspection.
 - 4. Installation and anchorage of vibration isolation systems for Seismic Design Categories C, D, E, and F where Contract Documents require a nominal clearance of 1/4 inch or less between equipment support frame and seismic restraint; periodic inspection.
 - 5. Verification of required clearances between electrical equipment, distribution systems, and associated supports and fire protection sprinkler system drops and sprigs for Seismic Design Categories C, D, E, and F; periodic inspection.
- D. Seismic special inspections include, but are not limited to:
 - 1. Seismically Qualified Equipment: Verification that label, anchorage, and mounting comply with certificate of compliance.
 - 2. Anchorage of electric equipment for emergency and standby power systems for Seismic Design Categories C, D, E, and F; periodic inspection.
 - 3. Anchorage of electrical equipment other than for emergency and standby power systems for Seismic Design Categories E and F; periodic inspection.
 - 4. Installation and anchorage of vibration isolation systems for Seismic Design Categories C, D, E, and F where Contract Documents require a nominal clearance of 1/4 inch or less between equipment support frame and seismic restraint; periodic inspection.
- E. Prior to starting work, to submit written statement of responsibility to authorities having jurisdiction and to Owner acknowledging awareness of special requirements

contained in the statement of special inspections.

- F. Special Inspection Agency services do not relieve from performing inspections and testing specified elsewhere.

3.03 INSTALLATION

- A. Install products in accordance with manufacturer's instructions.
- B. Install products in accordance with applicable requirements of NECA 1 (general workmanship).
- C. Install anchors and fasteners in accordance with ICC Evaluation Services, LLC (ICC-ES) evaluation report conditions of use where applicable.
- D. Secure fasteners according to manufacturer's recommended torque settings.
- E. Field-Welding (where approved by LP Consulting Engineers, Inc.): Comply with Section 05 50 00.
- F. Install flexible conduit and cable connections to provide sufficient slack for vibration isolation and/or seismic relative displacements as indicated or as required.
- G. Vibration Isolation Systems:
 - 1. Vibration-Isolated Equipment Support Bases:
 - a. Provide specified minimum clearance beneath base.
 - 2. Spring Isolators:
 - a. Position equipment at operating height; provide temporary blocking as required.
 - b. Lift equipment free of isolators prior to lateral repositioning to avoid damage to isolators.
 - c. Level equipment by adjusting isolators gradually in sequence to raise equipment uniformly such that excessive weight or stress is not placed on any single isolator.
 - 3. Isolator Hangers:
 - a. Use precompressed isolator hangers where required to facilitate installation and prevent damage to equipment utility connection provisions.
 - b. Locate isolator hangers at top of hanger rods in accordance with manufacturer's instructions.
 - 4. Clean debris from beneath vibration-isolated equipment that could cause short-circuiting of isolation.
 - 5. Use elastomeric grommets for attachments where required to prevent short-circuiting of isolation.
 - 6. Adjust isolators to be free of isolation short circuits during normal operation.
 - 7. Do not overtighten fasteners such that resilient material isolator pads are compressed beyond manufacturer's maximum recommended deflection.
- H. Seismic Controls:
 - 1. Provide specified snubbing element air gap; remove any factory-installed spacers, debris or other obstructions.
 - 2. Use only specified components, anchorage, and hardware evaluated by seismic design. Comply with conditions of seismic certification where applicable.

3. Where mounting hole diameter exceeds bolt diameter by more than 0.125 inch, use epoxy grout, elastomeric grommet, or welded washer to reduce clearance to 0.125 inch or less.
4. Equipment with Sheet Metal Housings:
 - a. Use Belleville washers to distribute stress over a larger surface area of the sheet metal connection interface as approved by manufacturer.
 - b. Attach additional steel as approved by manufacturer where required to transfer loads to structure.
 - c. Where mounting surface is irregular, do not shim housing; reinforce housing with additional steel as approved by manufacturer.
5. Concrete Housekeeping Pads:
 - a. Size in accordance with seismic design to meet anchor requirements.
 - b. Install pad reinforcement and doweling in accordance with seismic design to ensure integrity of pad and associated connection to slab.
6. Seismic Restraint Systems:
 - a. Do not attach seismic restraints and gravity supports to dissimilar parts of structure that may move differently during an earthquake.
 - b. Install restraints within permissible angles in accordance with seismic design.
 - c. Install cable restraints straight between component/run and structural attachment; do not bend around other nonstructural components or structural elements.
 - d. Install cable restraints for vibration-isolated components slightly slack to prevent short-circuiting of isolation.
 - e. Install hanger rod stiffeners where indicated using only specified clamps; do not weld stiffeners to hanger rod.

3.04 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements, for additional requirements.
- B. Inspect vibration isolation and/or seismic control components for damage and defects.
- C. Provide services of a manufacturer's authorized representative for vibration isolation systems and seismic controls to observe installation and assist in inspection and testing. Include manufacturer's detailed testing and inspection procedures and field reports with submittals.
- D. Vibration Isolation Systems:
 1. Verify isolator static deflections.
 2. Verify required clearance beneath vibration-isolated equipment support bases.
 3. Verify vibration isolation performance during normal operation; investigate sources of isolation short circuits.
- E. Seismic Controls:
 1. Verify snubbing element air gaps.
- F. Correct deficiencies and replace damaged or defective vibration isolation and/or seismic control components.

- G. Submit detailed reports indicating inspection and testing results and corrective actions taken.

3.05 ATTACHMENTS

- A. Statement of special inspections.

END OF SECTION 26 05 48

SECTION 26 05 53

IDENTIFICATION FOR ELECTRICAL SYSTEMS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Electrical identification requirements.
- B. Identification nameplates and labels.
- C. Wire and cable markers.
- D. Voltage markers.
- E. Underground warning tape.
- F. Floor marking tape.
- G. Warning signs and labels.
- H. Field-painted identification of conduit.

1.02 RELATED REQUIREMENTS

- A. Section 09 91 13 - Exterior Painting.
- B. Section 09 91 23 - Interior Painting.
- C. Section 26 05 00 – Common Work Results for Electrical.
- D. Section 26 05 19 - Low-Voltage Electrical Power Conductors and Cables: Color coding for power conductors and cables 600 V and less; vinyl color coding electrical tape.
- E. Section 26 05 73 - Power System Studies: Arc flash hazard warning labels.
- F. Section 26 27 26 - Wiring Devices: Device and wallplate finishes; factory pre-marked wallplates.
- G. Section 27 10 00 - Structured Cabling: Identification for communications cabling and devices.

1.03 REFERENCE STANDARDS

- A. ANSI Z535.2 - American National Standard for Environmental and Facility Safety Signs; 2011 (Reaffirmed 2017).
- B. ANSI Z535.4 - American National Standard for Product Safety Signs and Labels; 2011 (Reaffirmed 2017).
- C. NFPA 70 - National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- D. NFPA 70E - Standard for Electrical Safety in the Workplace; 2024.
- E. UL 969 - Marking and Labeling Systems; Current Edition, Including All Revisions.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:

1. Verify final designations for equipment, systems, and components to be identified prior to fabrication of identification products.
- B. Sequencing:
 1. Do not conceal items to be identified, in locations such as above suspended ceilings, until identification products have been installed.
 2. Do not install identification products until final surface finishes and painting are complete.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittals procedures.
- B. Product Data: Provide manufacturer's standard catalog pages and data sheets for each product.
- C. Shop Drawings: Provide schedule of items to be identified indicating proposed designations, materials, legends, and formats.
- D. Samples:
 1. Identification Nameplates: One of each type and color specified.
 2. Warning Signs and Labels: One of each type and legend specified.
- E. Manufacturer's Instructions: Indicate application conditions and limitations of use stipulated by product testing agency. Include instructions for storage, handling, protection, examination, preparation and installation of product.

1.06 QUALITY ASSURANCE

- A. Conform to requirements of CEC.
- B. Conform to requirements of NFPA 70.
- C. Furnish products listed and classified by UL as suitable for the purpose specified and shown.

1.07 FIELD CONDITIONS

- A. Do not install adhesive products when ambient temperature is lower than recommended by manufacturer.

PART 2 PRODUCTS

2.01 IDENTIFICATION REQUIREMENTS

- A. Existing Work: Unless specifically excluded, identify existing elements to remain that are not already identified in accordance with specified requirements.
- B. Identification for Equipment:
 1. Use identification nameplate to identify each piece of electrical distribution and control equipment and associated sections, compartments, and components.
 - a. Switchboards:
 - 1) Identify ampere rating.
 - 2) Identify voltage and phase.

- 3) Identify power source and circuit number. Include location when not within sight of equipment.
 - 4) Use identification nameplate to identify main overcurrent protective device.
 - 5) Use identification nameplate to identify load(s) served for each branch device. Do not identify spares and spaces.
- b. Panelboards:
- 1) Identify ampere rating.
 - 2) Identify voltage and phase.
 - 3) Identify power source and circuit number. Include location when not within sight of equipment.
 - 4) Identify main overcurrent protective device. Use identification label for panelboards with a door. For power distribution panelboards without a door, use identification nameplate.
 - 5) Use typewritten circuit directory to identify load(s) served for panelboards with a door. Identify spares and spaces using pencil.
 - 6) For power panelboards without a door, use identification nameplate to identify load(s) served for each branch device. Do not identify spares and spaces.
- c. Transformers:
- 1) Identify kVA rating.
 - 2) Identify voltage and phase for primary and secondary.
 - 3) Identify power source and circuit number. Include location when not within sight of equipment.
 - 4) Identify load(s) served. Include location when not within sight of equipment.
- d. Enclosed switches, circuit breakers, and motor controllers:
- 1) Identify voltage and phase.
 - 2) Identify power source and circuit number. Include location when not within sight of equipment.
 - 3) Identify load(s) served. Include location when not within sight of equipment.
- e. Time Switches:
- 1) Identify load(s) served and associated circuits controlled. Include location.
- f. Enclosed Contactors:
- 1) Identify ampere rating.
 - 2) Identify voltage and phase.
 - 3) Identify configuration, e.g., E.O.E.H. (electrically operated, electrically held) or E.O.M.H. (electrically operated, mechanically held).
 - 4) Identify coil voltage.
 - 5) Identify load(s) and associated circuits controlled. Include location.
- g. Centralized Emergency Lighting Inverters:
- 1) Identify input and output voltage and phase.

- 2) Identify power source and circuit number for normal power source. Include location when not within sight of equipment.
- 3) Identify load(s) served. Include location.
- h. Transfer Switches:
 - 1) Identify voltage and phase.
 - 2) Identify power source and circuit number for both normal power source and standby power source. Include location when not within sight of equipment.
 - 3) Identify load(s) served. Include location when not within sight of equipment.
 - 4) Identify short circuit current rating based on the specific overcurrent protective device type and settings protecting the transfer switch.
- i. Electricity Meters:
 - 1) Identify load(s) metered.
2. Service Equipment:
 - a. Use identification nameplate to identify each service disconnecting means.
 - b. For buildings or structures supplied by more than one service, or any combination of branch circuits, feeders, and services, use identification nameplate or means of identification acceptable to authority having jurisdiction at each service disconnecting means to identify all other services, feeders, and branch circuits supplying that building or structure. Verify format and descriptions with authority having jurisdiction.
3. Emergency System Equipment:
 - a. Use identification nameplate or voltage marker to identify emergency system equipment in accordance with NFPA 70.
 - b. Use identification nameplate at each piece of service equipment to identify type and location of on-site emergency power sources.
 - c. Use identification nameplate to identify emergency operating instructions for emergency system equipment.
4. Use voltage marker to identify highest voltage present for each piece of electrical equipment.
5. Use identification nameplate to identify equipment utilizing series ratings, where permitted, in accordance with NFPA 70.
6. Use identification nameplate to identify switchboards and panelboards utilizing a high leg delta system in accordance with NFPA 70.
7. Use identification nameplate to identify disconnect location for equipment with remote disconnecting means.
8. Use identification label or handwritten text using indelible marker on inside of door at each fused switch to identify required NEMA fuse class and size.
9. Use identification label or handwritten text using indelible marker on inside of door at each motor controller to identify nameplate horsepower, full load amperes, code letter, service factor, voltage, and phase of motor(s) controlled.
10. Use identification label to identify overcurrent protective devices for branch circuits serving fire alarm circuits. Identify with text "FIRE ALARM CIRCUIT".

11. Use field-painted floor markings, floor marking tape, or warning labels to identify required equipment working clearances where indicated or where required by the authority having jurisdiction.
 - a. Field-Painted Floor Markings: Alternating black and white stripes, 3 inches wide, painted in accordance with Section 09 91 23 and 09 91 13.
 12. Available Fault Current Documentation: Comply with Section 26 05 73. Use identification label to identify the available fault current and date calculations were performed at locations requiring documentation by NFPA 70 including but not limited to the following.
 - a. Service equipment.
 - b. Industrial control panels.
 - c. Motor control centers.
 - d. Elevator control panels.
 - e. Industrial machinery.
 13. Arc Flash Hazard Warning Labels: Comply with Section 26 05 73.
 14. Use warning signs to identify electrical hazards for entrances to all rooms and other guarded locations that contain exposed live parts operating at 600 V nominal or less with the word message "DANGER; Electrical hazard; Authorized personnel only" or approved equivalent.
 15. Use warning signs to identify electrical hazards for entrances to all buildings, vaults, rooms, or enclosures containing exposed live parts or exposed conductors operating at over 600 V nominal with the word message "DANGER; HIGH VOLTAGE; KEEP OUT".
 16. Use warning labels to identify electrical hazards for equipment, compartments, and enclosures containing exposed live parts or exposed conductors operating at over 600 V nominal with the word message "DANGER; HIGH VOLTAGE; KEEP OUT".
 17. Use warning labels, identification nameplates, or identification labels to identify electrical hazards for equipment where multiple power sources are present with the word message "DANGER; Hazardous voltage; Multiple power sources may be present; Disconnect all electric power including remote disconnects before servicing" or approved equivalent.
- C. Identification for Conductors and Cables:
1. Color Coding for Power Conductors 600 V and Less: Comply with Section 26 05 19.
 2. Identification for Communications Conductors and Cables: Comply with Section 27 10 00.
 3. Use identification nameplate or identification label to identify color code for ungrounded and grounded power conductors inside door or enclosure at each piece of feeder or branch-circuit distribution equipment when premises has feeders or branch circuits served by more than one nominal voltage system.
 4. Use wire and cable markers to identify circuit number or other designation indicated for power, control, and instrumentation conductors and cables at the following locations:
 - a. At each source and load connection.

- b. Within boxes when more than one circuit is present.
 - c. Within equipment enclosures when conductors and cables enter or leave the enclosure.
 5. Use wire and cable markers to identify connected grounding electrode system components for grounding electrode conductors.
 6. Use underground warning tape to identify direct buried cables.
- D. Identification for Raceways:
1. Use voltage markers to identify highest voltage present for accessible conduits at maximum intervals of 20 feet.
 - a. Maximum Intervals: 20 feet.
 2. Use voltage markers, color-coded bands, or factory-painted conduits to identify systems other than normal power system for accessible conduits.
 - a. Color-Coded Bands: Use field-painting or vinyl color coding electrical tape to mark bands 3 inches wide.
 - 1) Field-Painting: Comply with Section 09 91 23 and 09 91 13.
 - 2) Vinyl Color Coding Electrical Tape: Comply with Section 26 05 19.
 - 3) Other Owner required color coding systems.
 3. Use identification labels, handwritten text using indelible marker, or plastic marker tags to identify circuits enclosed for accessible conduits at wall penetrations, at floor penetrations, at roof penetrations, and at equipment terminations when source is not within sight.
 4. Use identification labels, handwritten text using indelible marker, or plastic marker tags to identify spare conduits at each end. Identify purpose and termination location.
 5. Use underground warning tape to identify underground raceways.
 6. Use voltage markers to identify highest voltage present for wireways at maximum intervals of 20 feet.
- E. Identification for Boxes:
1. Use voltage markers to identify highest voltage present.
 2. Use voltage markers or color coded boxes to identify systems other than normal power system.
 3. Use identification labels or handwritten text using indelible marker to identify circuits enclosed.. Install on back side of box cover.
 - a. For exposed boxes in public areas, use only identification labels.
 4. Use warning labels to identify electrical hazards for boxes containing exposed live parts or exposed conductors operating at over 600 V nominal with the word message "DANGER; HIGH VOLTAGE; KEEP OUT".
- F. Identification for Devices:
1. Wiring Device and Wallplate Finishes: Comply with Section 26 27 26.
 2. Factory Pre-Marked Wallplates: Comply with Section 26 27 26.
 3. Use identification label to identify fire alarm system devices.
 - a. For devices concealed above suspended ceilings, provide additional identification on ceiling tile below device location.

4. Use identification label or engraved wallplate to identify serving branch circuit for all receptacles.
 - a. For receptacles in public areas or in areas as directed by Architect, provide identification on inside surface of wallplate.
 5. Use identification label or engraved wallplate to identify load controlled for wall-mounted control devices controlling loads that are not visible from the control location and for multiple wall-mounted control devices installed at one location.
 6. Use identification label to identify receptacles protected by upstream GFI protection, where permitted.
- G. Identification for Luminaires:
1. Use permanent red dot on luminaire frame to identify luminaires connected to emergency power system.
- H. Buried Electrical Lines: Underground warning tapes.
- I. Communication Cabinets: Nameplates.
- J. Conduit: Conduit markers.
- K. Control Device Station: Labels.
- L. Electrical Distribution and Control Equipment Enclosures: Nameplates.

2.02 MANUFACTURERS

- A. Brady Corporation: www.bradycorp.com.
- B. Seton Identification Products: www.seton.com/aec.
- C. HellermannTyton: www.hellermanntyton.com.
- D. E-Z Code by T&B.
- E. Pan-Code by Panduit.
- F. Or approved equal.
- G. Substitutions: See Section 01 6000 - Product Requirements.

2.03 IDENTIFICATION NAMEPLATES AND LABELS

- A. Identification Nameplates:
1. Manufacturers:
 - a. Brimar Industries, Inc: www.brimar.com/#sle.
 - b. Kolbi Pipe Marker Co: www.kolbipipemarkers.com/#sle.
 - c. Seton Identification Products: www.seton.com/#sle.
 - d. Or approved equal.
 - e. Substitutions: See Section 01 60 00 - Product Requirements.
 2. Materials:
 - a. Indoor Clean, Dry Locations: Use plastic nameplates.
 - b. Outdoor Locations: Use plastic, stainless steel, or aluminum nameplates suitable for exterior use.
 3. Plastic Nameplates: Two-layer or three-layer laminated acrylic or electrically non-conductive phenolic with beveled edges; minimum thickness of 1/16 inch; engraved text.

- a. Exception: Provide minimum thickness of 1/8 inch when any dimension is greater than 4 inches.
 4. Stainless Steel Nameplates: Minimum thickness of 1/32 inch; engraved or laser-etched text.
 5. Aluminum Nameplates: Anodized; minimum thickness of 1/32 inch; engraved or laser-etched text.
 6. Mounting Holes for Mechanical Fasteners: Two, centered on sides for sizes up to 1 inch high; Four, located at corners for larger sizes.
- B. Identification Labels:
1. Manufacturers:
 - a. Brady Corporation: www.bradyid.com/#sle.
 - b. Brother International Corporation: www.brother-usa.com/#sle.
 - c. Panduit Corp: www.panduit.com/#sle.
 - d. Or approved equal.
 - e. Substitutions: See Section 01 60 00 - Product Requirements.
 2. Materials: Use self-adhesive laminated plastic labels; UV, chemical, water, heat, and abrasion resistant.
 - a. Use only for indoor locations.
 3. Text: Use factory pre-printed or machine-printed text. Do not use handwritten text unless otherwise indicated.
- C. Format for Equipment Identification:
1. Minimum Size: 1 inch by 2.5 inches.
 2. Legend:
 - a. System designation where applicable:
 - 1) Emergency Power System: Identify with text "EMERGENCY".
 - b. Equipment designation or other approved description.
 - c. Other information as indicated.
 3. Text: All capitalized unless otherwise indicated.
 4. Minimum Text Height:
 - a. System Designation: 1/2 inch.
 - b. Equipment Designation: 1/4 inch.
 - c. Other Information: 1/8 inch.
 - d. Exception: Provide minimum text height of 1 inch for equipment located more than 10 feet above floor or working platform.
 5. Color:
 - a. Normal Power System: White text on black background.
 - 1) 480Y/277 V, 3 Phase Equipment: White text on orange background.
 - 2) 208Y/120 V, 3 Phase Equipment: White text on black background.
 - b. Emergency Power System: White text on red background.
- D. Format for General Information and Operating Instructions:
1. Minimum Size: 1 inch by 2.5 inches.
 2. Legend: Include information or instructions indicated or as required for proper and safe operation and maintenance.
 3. Text: All capitalized unless otherwise indicated.

4. Minimum Text Height: 1/4 inch.
5. Color: Black text on white background unless otherwise indicated.
 - a. Exceptions:
 - 1) Provide white text on red background for general information or operational instructions for emergency systems.
 - 2) Provide white text on red background for general information or operational instructions for fire alarm systems.
 - 3) Provide white text on black background for all other systems, unless noted otherwise.
- E. Format for Caution and Warning Messages:
 1. Minimum Size: 2 inches by 4 inches.
 2. Legend: Include information or instructions indicated or as required for proper and safe operation and maintenance.
 3. Text: All capitalized unless otherwise indicated.
 4. Minimum Text Height: 1/2 inch.
 5. Color: Black text on yellow background unless otherwise indicated.
- F. Format for Receptacle Identification:
 1. Minimum Size: 3/8 inch by 1.5 inches.
 2. Legend: Power source and circuit number or other designation indicated.
 - a. Include voltage and phase for other than 120 V, single phase circuits.
 3. Text: All capitalized unless otherwise indicated.
 4. Minimum Text Height: 3/16 inch.
 5. Color: Black text on clear background.
- G. Format for Control Device Identification:
 1. Minimum Size: 3/8 inch by 1.5 inches.
 2. Legend: Load controlled or other designation indicated.
 3. Text: All capitalized unless otherwise indicated.
 4. Minimum Text Height: 3/16 inch.
 5. Color: Black text on clear background.
- H. Manufacturers:
 1. Kolbi Pipe Marker Co.; Model: www.kolbipipemarkers.com.
 2. Seton Identification Product; Model:: www.seton.com.
 3. Or approved equal.
- I. Nameplates: Engraved three-layer laminated plastic, white letters on black background, unless noted otherwise on drawings or specifications.
- J. Locations:
 1. Each electrical distribution and control equipment enclosure.
 2. Communication cabinets.
- K. Letter Size:
 1. Use 1/8 inch letters for identifying individual equipment and loads.
 2. Use 1/4 inch letters for identifying grouped equipment and loads.

- L. Labels: Embossed adhesive tape, with 3/16 inch white letters on black background. Use only for identification of individual wall switches and receptacles, control device stations.

2.04 WIRE AND CABLE MARKERS

- A. Manufacturers:
 - 1. Brady Corporation: www.bradyid.com/#sle.
 - 2. Seton Identification Products: www.seton.com.
 - 3. HellermannTyton: www.hellermanntyton.com/#sle.
 - 4. Panduit Corp: www.panduit.com/#sle.
 - 5. Or approved equal.
 - 6. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Markers for Conductors and Cables: Use wrap-around self-adhesive vinyl cloth, wrap-around self-adhesive vinyl self-laminating, heat-shrink sleeve, or plastic sleeve type markers suitable for the conductor or cable to be identified.
- C. Markers for Conductor and Cable Bundles: Use plastic marker tags secured by nylon cable ties.
- D. Legend: Power source and circuit number or other designation indicated.
- E. Text: Use factory pre-printed or machine-printed text, all capitalized unless otherwise indicated.
 - 1. Do not use handwritten text.
- F. Minimum Text Height: 1/8 inch.
- G. Color: Black text on white background unless otherwise indicated.
- H. Description: Vinyl cloth type self-adhesive wire markers.
- I. Description: Cloth type wire markers.
- J. Locations: Each conductor at panelboard gutters, pull boxes, outlet boxes, and junction boxes each load connection.
- K. Legend:
 - 1. Power and Lighting Circuits: Branch circuit or feeder number indicated on drawings.
 - 2. Control Circuits: Control wire number indicated on schematic and interconnection diagrams on drawings.

2.05 VOLTAGE MARKERS

- A. Manufacturers:
 - 1. Brady Corporation: www.bradyid.com/#sle.
 - 2. Brimar Industries, Inc: www.brimar.com/#sle.
 - 3. Seton Identification Products: www.seton.com/#sle.
 - 4. HellermannTyton: www.hellermanntyton.com.
 - 5. Or approved equal.
 - 6. Substitutions: See Section 01 60 00 - Product Requirements.

- B. Markers for Conduits: Use factory pre-printed self-adhesive vinyl, self-adhesive vinyl cloth, or vinyl snap-around type markers.
- C. Markers for Boxes and Equipment Enclosures: Use factory pre-printed self-adhesive vinyl or self-adhesive vinyl cloth type markers.
- D. Minimum Size:
 - 1. Markers for Equipment: 1 1/8 by 4 1/2 inches.
 - 2. Markers for Conduits: As recommended by manufacturer for conduit size to be identified.
 - 3. Markers for Pull Boxes: 1 1/8 by 4 1/2 inches.
 - 4. Markers for Junction Boxes: 1/2 by 2 1/4 inches.
- E. Legend:
 - 1. Markers for Voltage Identification: Highest voltage present.
 - 2. Markers for System Identification:
 - a. Emergency Power System: Text "EMERGENCY".
 - b. Other Systems: Type of service.
- F. Color: Black text on orange background unless otherwise indicated.
- G. Location: Furnish markers for each conduit longer than 6 feet.
- H. Spacing: 20 feet on center.
- I. Color:
 - 1. Fire Alarm System: Red.

2.06 UNDERGROUND WARNING TAPE

- A. Manufacturers:
 - 1. Brady Corporation: www.bradyid.com/#sle.
 - 2. Brimar Industries, Inc: www.brimar.com/#sle.
 - 3. Seton Identification Products: www.seton.com/#sle.
 - 4. HellermannTyton: www.hellermannntyton.com.
 - 5. Or approve equal.
 - 6. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Materials: Use foil-backed detectable type polyethylene tape suitable for direct burial, unless otherwise indicated.
- C. Non-detectable Type Tape: 6 inches wide, with minimum thickness of 4 mil.
- D. Foil-backed Detectable Type Tape: 3 inches wide, with minimum thickness of 5 mil, unless otherwise required for proper detection.
- E. Legend: Type of service, continuously repeated over full length of tape.
- F. Color:
 - 1. Tape for Buried Power Lines: Black text on red background.
 - 2. Tape for Buried Communication, Alarm, and Signal Lines: Black text on orange background.

2.07 FLOOR MARKING TAPE

- A. Manufacturers:
 - 1. Brady Corporation: www.bradyid.com/#sle.
 - 2. Brimar Industries, Inc: www.brimar.com/#sle.
 - 3. Insite Solutions, LLC: www.stop-painting.com/#sle.
 - 4. Seton Identification Products: www.seton.com/#sle.
 - 5. Or approved equal..
 - 6. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Floor Marking Tape for Equipment Working Clearance Identification: Self-adhesive vinyl or polyester tape with overlamine, 3 inches wide, with alternating black and white stripes.

2.08 WARNING SIGNS AND LABELS

- A. Manufacturers:
 - 1. Brimar Industries, Inc: www.brimar.com/#sle.
 - 2. Clarion Safety Systems, LLC: www.clarionsafety.com/#sle.
 - 3. Insite Solutions, LLC: www.stop-painting.com/#sle.
 - 4. Seton Identification Products: www.seton.com/#sle.
 - 5. Or approved equal.
 - 6. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Comply with ANSI Z535.2 or ANSI Z535.4 as applicable.
- C. Warning Signs:
 - 1. Materials:
 - a. Indoor Dry, Clean Locations: Use factory pre-printed rigid plastic or self-adhesive vinyl signs.
 - b. Outdoor Locations: Use factory pre-printed rigid aluminum signs.
 - 2. Rigid Signs: Provide four mounting holes at corners for mechanical fasteners.
 - 3. Minimum Size: 7 by 10 inches unless otherwise indicated.
- D. Warning Labels:
 - 1. Materials: Use factory pre-printed or machine-printed self-adhesive polyester or self-adhesive vinyl labels; UV, chemical, water, heat, and abrasion resistant; produced using materials recognized to UL 969.
 - a. Do not use labels designed to be completed using handwritten text.
 - 2. Machine-Printed Labels: Use thermal transfer process printing machines and accessories recommended by label manufacturer.
 - 3. Minimum Size: 2 by 4 inches unless otherwise indicated.
- E. Floor Signs:
 - 1. Materials: Use factory preprinted, self-adhesive vinyl, polyester, or rubber labels with protective overlamine; removable.
 - 2. Minimum Size: 17-inch diameter unless otherwise indicated.
- F. Description: 3 inch wide polyethylene tape, detectable type colored red with suitable warning legend describing buried electrical lines.

- G. Description: 4 inch wide plastic tape, detectable type colored red with suitable warning legend describing buried electrical lines.

PART 3 EXECUTION

3.01 PREPARATION

- A. Clean surfaces to receive adhesive products according to manufacturer's instructions.
- B. Degrease and clean surfaces to receive nameplates and labels.

3.02 INSTALLATION

- A. Install products in accordance with manufacturer's instructions.
- B. Install identification products to be plainly visible for examination, adjustment, servicing, and maintenance. Unless otherwise indicated, locate products as follows:
 - 1. Surface-Mounted Equipment: Enclosure front.
 - 2. Flush-Mounted Equipment: Enclosure front.
 - 3. Free-Standing Equipment: Enclosure front; also enclosure rear for equipment with rear access.
 - 4. Elevated Equipment: Legible from the floor or working platform.
 - 5. Branch Devices: Adjacent to device.
 - 6. Interior Components: Legible from the point of access.
 - 7. Conduits: Legible from the floor.
 - 8. Boxes: Outside face of cover.
 - 9. Conductors and Cables: Legible from the point of access.
 - 10. Devices: Outside face of cover.
- C. Install identification products centered, level, and parallel with lines of item being identified.
- D. Secure nameplates to exterior surfaces of enclosures using stainless steel screws and to interior surfaces using self-adhesive backing or epoxy cement.
 - 1. Do not use adhesives on exterior surfaces except where substrate cannot be penetrated.
- E. Install self-adhesive labels and markers to achieve maximum adhesion, with no bubbles or wrinkles and edges properly sealed.
- F. Install underground warning tape above buried lines with one tape per trench at 3 inches below finished grade.
- G. Secure rigid signs using stainless steel screws.
- H. Mark all handwritten text, where permitted, to be neat and legible.

3.03 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements, for additional requirements.
- B. Replace self-adhesive labels and markers that exhibit bubbles, wrinkles, curling or other signs of improper adhesion.

FOR REFERENCE ONLY

END OF SECTION 26 05 53

SECTION 26 05 73 POWER SYSTEM STUDIES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Short-circuit study.
- B. Protective device coordination study.
- C. Arc flash and shock risk assessment.
 - 1. Includes arc flash hazard warning labels.
- D. Criteria for the selection and adjustment of equipment and associated protective devices not specified in this section, as determined by studies to be performed.

1.02 RELATED REQUIREMENTS

- A. Section 26 05 53 - Identification for Electrical Systems: Additional requirements for arc flash hazard warning labels.
- B. Section 26 11 16 - Secondary Unit Substations.
- C. Section 26 13 00 - Medium-Voltage Switchgear.
- D. Section 26 13 21 - Air Interrupter Switches.
- E. Section 26 18 39 - Medium-Voltage Motor Controllers.
- F. Section 26 21 00 - Low-Voltage Electrical Service Entrance.
 - 1. Includes Utility Company contact information.
- G. Section 26 23 00 - Low-Voltage Switchgear.
- H. Section 26 24 13 - Switchboards.
- I. Section 26 24 16 - Panelboards.
- J. Section 26 24 19 - Motor-Control Centers.
- K. Section 26 25 13 - Low-Voltage Busways.
- L. Section 26 28 13 - Fuses.
- M. Section 26 28 16.13 - Enclosed Circuit Breakers.
- N. Section 26 28 16.16 - Enclosed Switches.
- O. Section 26 29 13 - Enclosed Controllers.
- P. Section 26 33 23 - Central Battery Equipment.
- Q. Section 26 35 33.16 - Low-Voltage Power Factor Correction Equipment.

1.03 REFERENCE STANDARDS

- A. ANSI Z535.4 - American National Standard for Product Safety Signs and Labels; 2011 (Reaffirmed 2017).
- B. IEEE 141 - IEEE Recommended Practice for Electric Power Distribution for Industrial Plants; 1993 (Reaffirmed 1999).

- C. IEEE 242 - IEEE Recommended Practice for Protection and Coordination of Industrial and Commercial Power Systems; 2001, with Errata (2003).
- D. IEEE 399 - IEEE Recommended Practice for Industrial and Commercial Power Systems Analysis; 1997.
- E. IEEE 551 - IEEE Recommended Practice for Calculating Short-Circuit Currents in Industrial and Commercial Power Systems; 2006.
- F. IEEE 1584 - IEEE Guide for Performing Arc-Flash Hazard Calculations; 2018, with Errata (2019).
- G. NEMA MG 1 - Motors and Generators; 2021.
- H. NETA ATS - Standard For Acceptance Testing Specifications For Electrical Power Equipment And Systems; 2021.
- I. NFPA 70 - National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- J. NFPA 70E - Standard for Electrical Safety in the Workplace; 2024.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Electrical Drawings: The electrical drawings indicate short circuit bracing and withstand values for electrical equipment and protective devices based on design information available during the design process. The available short circuit current from the serving electrical utility may or may not have been available to the engineer. The contractor shall perform their own short circuit and arc flash studies based on the information given to the contractor from the serving power utility company. If the values for equipment bracing resulting from the contractors studies are lower than what is shown on the drawings, the equipment ratings shall be lowered to the appropriate values and a credit shall be provided to the Owner.
 - 2. Existing Installations: Coordinate with equipment manufacturer(s) to obtain data necessary for completion of studies.
 - 3. Coordinate the work to provide equipment and associated protective devices complying with criteria for selection and adjustment, as determined by studies to be performed.
 - 4. Notify LP Consulting Engineers, Inc. of any conflicts with or deviations from Contract Documents. Obtain direction before proceeding with work.
- B. Pre-Study Meeting: Conduct meeting with Owner to discuss system operating modes and conditions to be considered in studies.
- C. Sequencing:
 - 1. Submit study reports prior to or concurrent with product submittals.
 - 2. Do not order equipment until matching study reports and product submittals have both been evaluated by LP Consulting Engineers, Inc..
 - 3. Verify naming convention for equipment identification prior to creation of final drawings, reports, and arc flash hazard warning labels (where applicable).

- D. Scheduling:
 - 1. Arrange access to existing facility for data collection with Owner.
 - 2. Where work of this section involves interruption of existing electrical service, arrange service interruption with Owner.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Study preparer's qualifications.
- C. Field testing agency's qualifications.
- D. Study reports, stamped or sealed and signed by study preparer.
- E. Product Data: In addition to submittal requirements specified in other sections, include manufacturer's standard catalog pages and data sheets for equipment and protective devices indicating information relevant to studies.
 - 1. Include characteristic time-current trip curves for protective devices.
 - 2. Include impedance data for busway.
 - 3. Include impedance data for engine generators.
 - 4. Clearly indicate whether proposed short circuit current ratings are fully rated or, where acceptable, series rated systems.
 - 5. Include documentation of listed series ratings upon request.
 - 6. Identify modifications made in accordance with studies that:
 - a. Can be made at no additional cost to Owner.
 - b. As submitted will involve a change to the contract sum.
- F. Arc Flash Hazard Warning Label Samples: One of each type and legend specified.
- G. Site-specific arc flash hazard warning labels.
- H. Field quality control reports.
- I. Certification that field adjustable protective devices have been set in accordance with requirements of studies.
- J. Project Record Documents: Revise studies as required to reflect as-built conditions.
 - 1. Include hard copies with operation and maintenance data submittals.
 - 2. Include computer software files used to prepare studies with file name(s) cross-referenced to specific pieces of equipment and systems.

1.06 POWER SYSTEM STUDIES

- A. Scope of Studies:
 - 1. Perform analysis of new electrical distribution system as indicated on drawings.
 - a. Include portions of electrical distribution system designated as "future."
 - 2. Except where study descriptions below indicate exclusions, analyze system at each bus from primary protective devices of utility source down to each piece of equipment involved, including parts of system affecting calculations being performed (e.g. fault current contribution from motors).
 - 3. Include in analysis alternate sources and operating modes (including known future configurations) to determine worst case conditions.

- a. Known Operating Modes:
 - 1) Utility as source.
 - 2) Generator as source.
 - 3) Utility/generator in parallel.
 - 4) Bus tie breaker open/close positions.
 - 5) Maintenance settings.
- B. General Study Requirements:
 - 1. Comply with NFPA 70.
 - 2. Perform studies utilizing computer software complying with specified requirements; manual calculations are not permitted.
- C. Data Collection:
 - 1. The Contractor shall compile information on project-specific characteristics of actual installed equipment, protective devices, feeders, etc. as necessary to develop single-line diagram of electrical distribution system and associated input data for use in system modeling.
 - a. Utility Source Data: Include primary voltage, maximum and minimum three-phase and line-to-ground fault currents, impedance, X/R ratio, and primary protective device information.
 - 1) Obtain up-to-date information from Utility Company.
 - 2) Utility Company: As indicated on rawings.
 - (a) Point of Contact: As indicated on Drawings or as determined by contractor.
 - (b) Address: As indicated on Drawings or as determined by contractor..
 - (c) Phone: As indicated on Drawings or as determined by contractor.
 - (d) Email: As indicated on Drawings or as determined by contractor..
 - (e) Utility Company Project Reference Number: As indicated on Drawings or as determined by contractor.
 - b. Generators: Include manufacturer/model, kW and voltage ratings, and impedance.
 - c. Motors: Include manufacturer/model, type (e.g. induction, synchronous), horsepower rating, voltage rating, full load amps, and locked rotor current or NEMA MG 1 code letter designation.
 - d. Transformers: Include primary and secondary voltage ratings, kVA rating, winding configuration, percent impedance, and X/R ratio.
 - e. Protective Devices:
 - 1) Circuit Breakers: Include manufacturer/model, type (e.g. thermal magnetic, electronic trip), frame size, trip rating, voltage rating, interrupting rating, available field-adjustable trip response settings, and features (e.g. zone selective interlocking).
 - 2) Fuses: Include manufacturer/model, type/class (e.g. Class J), size/rating, and speed (e.g. time delay, fast acting).
 - f. Protective Relays: Include manufacturer/model, type, settings, current/potential transformer ratio, and associated protective device.

- g. Conductors: Include feeder size, material (e.g. copper, aluminum), insulation type, voltage rating, number per phase, raceway type, and actual length.
- 2. Existing Installations:
 - a. Provide the services of field testing agency or equipment manufacturer's representative to perform field data collection.
 - b. Collect data on existing electrical distribution system necessary for completion of studies, including field verification of available existing data (e.g. construction documents, previous studies). Include actual settings for field-adjustable devices.
 - c. Available Existing Data:
 - 1) Short circuit ratings of all existing electrical distribution equipment.
- D. Short-Circuit Study:
 - 1. Comply with IEEE 551 and applicable portions of IEEE 141, IEEE 242, and IEEE 399.
 - 2. For purposes of determining equipment short circuit current ratings, consider conditions that may result in maximum available fault current, including but not limited to:
 - a. Maximum utility fault currents.
 - b. Maximum motor contribution.
 - c. Known operating modes (e.g. utility as source, generator as source, utility/generator in parallel, bus tie breaker open/close positions).
 - 3. For each bus location, calculate the maximum available three-phase bolted symmetrical and asymmetrical fault currents. For grounded systems, also calculate the maximum available line-to-ground bolted fault currents.
- E. Protective Device Coordination Study:
 - 1. Comply with applicable portions of IEEE 242 and IEEE 399.
 - 2. Analyze alternate scenarios considering known operating modes (e.g. utility as source, generator as source, utility/generator in parallel, bus tie breaker open/close positions).
 - 3. Analyze protective devices and associated settings for suitable margins between time-current curves to provide adequate protection for equipment and conductors while achieving full selective coordination.
- F. Arc Flash and Shock Risk Assessment:
 - 1. Comply with NFPA 70E.
 - 2. Perform incident energy and arc flash boundary calculations in accordance with IEEE 1584 (as referenced in NFPA 70E Annex D), where applicable.
 - a. Where reasonable, study preparer may assume a maximum clearing time of two seconds in accordance with IEEE 1584, provided that the conditions are such that a worker's egress from an arc flash event would not be inhibited.
 - b. For single-phase systems, study preparer to perform calculations assuming three-phase system in accordance with IEEE 1584 using single phase bolted fault current, yielding conservative results.

3. For equipment with main devices mounted in separate compartmentalized sections, perform calculations on both the line and load side of the main device.
 4. Analyze alternate scenarios considering conditions that may result in maximum incident energy, including but not limited to:
 - a. Maximum and minimum utility fault currents.
 - b. Maximum and minimum motor contribution.
 - c. Known operating modes (e.g. utility as source, generator as source, utility/generator in parallel, bus tie breaker open/close positions).
- G. Study Reports:
1. General Requirements:
 - a. Identify date of study and study preparer.
 - b. Identify study methodology and software product(s) used.
 - c. Identify scope of studies, assumptions made, implications of possible alternate scenarios, and any exclusions from studies.
 - d. Identify base used for per unit values.
 - e. Include single-line diagram and associated input data used for studies; identify buses on single-line diagram as referenced in reports, and indicate bus voltage.
 - f. Include conclusions and recommendations.
 2. Short-Circuit Study:
 - a. For each scenario, identify at each bus location:
 - 1) Calculated maximum available symmetrical and asymmetrical fault currents (both three-phase and line-to-ground where applicable).
 - 2) Fault point X/R ratio.
 - 3) Associated equipment short circuit current ratings.
 - b. Identify locations where the available fault current exceeds the equipment short circuit current rating, along with recommendations.
 3. Protective Device Coordination Study:
 - a. For each scenario, include time-current coordination curves plotted on log-log scale graphs.
 - b. For each graph include (where applicable):
 - 1) Partial single-line diagram identifying the portion of the system illustrated.
 - 2) Protective Devices: Time-current curves with applicable tolerance bands for each protective device in series back to the source, plotted up to the maximum available fault current at the associated bus.
 - 3) Conductors: Damage curves.
 - 4) Transformers: Inrush points and damage curves.
 - 5) Generators: Full load current, overload curves, decrement curves, and short circuit withstand points.
 - 6) Motors: Full load current, starting curves, and damage curves.
 - 7) Capacitors: Full load current and damage curves.
 - c. For each protective device, identify fixed and adjustable characteristics with available ranges and recommended settings.

- 1) Circuit Breakers: Include long time pickup and delay, short time pickup and delay, and instantaneous pickup.
 - 2) Include ground fault pickup and delay.
 - 3) Include fuse ratings.
 - 4) Protective Relays: Include current/potential transformer ratios, tap, time dial, and instantaneous pickup.
- d. Identify cases where either full selective coordination or adequate protection is not achieved, along with recommendations.
4. Arc Flash and Shock Risk Assessment:
- a. For the worst case for each scenario, identify at each bus location:
 - 1) Calculated incident energy and associated working distance.
 - 2) Calculated arc flash boundary.
 - 3) Bolted fault current.
 - 4) Arcing fault current.
 - 5) Clearing time.
 - 6) Arc gap distance.
 - b. For purposes of producing arc flash hazard warning labels, summarize the maximum incident energy and associated data reflecting the worst case condition of all scenarios at each bus location.
 - c. Include recommendations for reducing the incident energy at locations where the calculated maximum incident energy exceeds 8 calories per sq cm.

1.07 QUALITY ASSURANCE

- A. Study Preparer Qualifications: Professional electrical engineer licensed in California and with minimum five years experience in preparation of studies of similar type and complexity using specified computer software.
 1. Study preparer may be employed by manufacturer of electrical distribution equipment.
 2. Study preparer may be employed by field testing agency.
- B. Field Testing Agency Qualifications: Independent testing organization specializing in testing, analysis, and maintenance of electrical systems with minimum five years experience; NETA Accredited Company.
 1. Field Supervisor: Certified electrical testing technician; NETA ETT Level III.
- C. Computer Software for Study Preparation: Use the latest edition of commercially available software utilizing specified methodologies.
 1. Products:
 - a. EasyPower LLC: www.easypower.com/#sle.
 - b. ETAP/Operation Technology, Inc: www.etap.com/#sle.
 - c. Power Analytics Corporation: www.poweranalytics.com/#sle.
 - d. SKM Systems Analysis, Inc: www.skm.com/#sle.
 - e. Substitutions: See Section 01 60 00 - Product Requirements.

PART 2 PRODUCTS

2.01 ARC FLASH HAZARD WARNING LABELS

- A. Provide warning labels complying with ANSI Z535.4 to identify arc flash hazards for each work location analyzed by the arc flash and shock risk assessment.
 - 1. Materials: Comply with Section 26 05 53.
 - 2. Minimum Size: 4 by 6 inches.
 - 3. Legend: Provide custom legend in accordance with NFPA 70E based on equipment-specific data as determined by arc flash and shock risk assessment.
 - a. Include orange header that reads "WARNING" unless otherwise indicated.
 - b. Include the text "Arc Flash and Shock Hazard; Appropriate PPE Required" or approved equivalent.
 - c. Include the following information:
 - 1) Arc flash boundary.
 - 2) Available incident energy and corresponding working distance.
 - 3) Site-specific PPE (personnel protective equipment) requirements.
 - 4) Nominal system voltage.
 - 5) Limited approach boundary.
 - 6) Restricted approach boundary.
 - 7) Equipment identification.
 - 8) Study preparer, report reference, and date calculations were performed.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install arc flash warning labels in accordance with Section 26 05 53.

3.02 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements, for additional requirements.
- B. Provide the services of field testing agency or equipment manufacturer's representative to perform inspection, testing, and adjusting.
- C. Inspect and test in accordance with NETA ATS, except Section 4.
- D. Adjust equipment and protective devices for compliance with studies and recommended settings.
- E. Notify LP Consulting Engineers, Inc. of any conflicts with or deviations from studies. Obtain direction before proceeding.
- F. Submit detailed reports indicating inspection and testing results, and final adjusted settings.

3.03 CLOSEOUT ACTIVITIES

- A. See Section 01 78 00 - Closeout Submittals, for closeout submittals.

- B. See Section 01 79 00 - Demonstration and Training, for additional requirements.
- C. Training: Include as part of the base bid training for Owner's personnel on electrical safety pertaining to arc flash and shock hazards.
 - 1. Use site-specific arc flash and shock risk assessment report as training reference, supplemented with additional training materials as required.
 - 2. Provide minimum of eight hours of training.
 - 3. Instructor: Representative of entity performing study.
 - 4. Location: At project site.

END OF SECTION 26 05 73

SECTION 26 05 83 WIRING CONNECTIONS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Electrical connections to equipment.

1.02 RELATED REQUIREMENTS

- A. Section 26 05 00 – Common Work Results for Electrical.
- B. Section 26 05 19 - Low-Voltage Electrical Power Conductors and Cables.
- C. Section 26 05 33.13 - Conduit for Electrical Systems.
- D. Section 26 05 33.16 - Boxes for Electrical Systems.
- E. Section 26 27 26 - Wiring Devices.
- F. Section 26 28 16.16 - Enclosed Switches.
- G. Section 26 29 13 - Enclosed Controllers.

1.03 REFERENCE STANDARDS

- A. NEMA WD 1 - General Color Requirements for Wiring Devices; 1999 (Reaffirmed 2020).
- B. NEMA WD 6 - Wiring Devices - Dimensional Specifications; 2021.
- C. NFPA 70 - National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Obtain and review shop drawings, product data, manufacturer's wiring diagrams, and manufacturer's instructions for equipment furnished under other sections.
 - 2. Determine connection locations and requirements.
- B. Sequencing:
 - 1. Install rough-in of electrical connections before installation of equipment is required.
 - 2. Make electrical connections before required start-up of equipment.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide wiring device manufacturer's catalog information showing dimensions, configurations, and construction.
- C. Manufacturer's Instructions: Indicate application conditions and limitations of use stipulated by product testing agency. Include instructions for storage, handling, protection, examination, preparation, and installation of product.

1.06 QUALITY ASSURANCE

- A. Conform to requirements of NFPA 70.
- B. Products: Listed, classified, and labeled as suitable for the purpose intended.
- C. Product Listing Organization Qualifications: An organization recognized by OSHA as a Nationally Recognized Testing Laboratory (NRTL) and acceptable to authorities having jurisdiction.

PART 2 PRODUCTS

2.01 MATERIALS

- A. Cords and Caps: NEMA WD 6; match receptacle configuration at outlet provided for equipment.
 - 1. Colors: Comply with NEMA WD 1.
 - 2. Cord Construction: NFPA 70, Type SO, multiconductor flexible cord with identified equipment grounding conductor, suitable for use in damp locations.
 - 3. Size: Suitable for connected load of equipment, length of cord, and rating of branch circuit overcurrent protection.
 - 4. Product: As noted on drawings or as required for the application.
 - 5. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Disconnect Switches: As described and in individual equipment sections.
- C. Wiring Devices: As specified in Section 26 27 26.
- D. Flexible Conduit: As specified in Section 26 05 33.13.
- E. Wire and Cable: As specified in Section 26 05 19.
- F. Boxes: As specified in Section 26 05 33.16.

2.02 EQUIPMENT CONNECTIONS

- A. Connection Types and Ratings::
 - 1. Electrical Connection: Flexible conduit, metallic or liquid tight flexible conduit as required by the application.
 - 2. Electrical Connection: Cord and plug (Verify NEMA configuration and rating with equipment installer at jobsite).
 - 3. Provide field-installed disconnect switch.
 - 4. Voltage: Verify with equipment nameplate.
 - 5. Load rating: Verify with equipment nameplate.
 - 6. FLA: Verify with equipment nameplate.
 - 7. WSA: Verify with equipment nameplate.
 - 8. Branch Circuit: Verify with equipment nameplate.
 - 9. Location: As indicated on drawings. Verify with equipment installer at jobsite.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that equipment is ready for electrical connection, wiring, and energization.

3.02 ELECTRICAL CONNECTIONS

- A. Make electrical connections in accordance with equipment manufacturer's instructions.
- B. Make conduit connections to equipment using flexible conduit. Use liquidtight flexible conduit with watertight connectors in damp or wet locations.
- C. Connect heat producing equipment using wire and cable with insulation suitable for temperatures encountered.
- D. Provide receptacle outlet to accommodate connection with attachment plug.
- E. Provide cord and cap where field-supplied attachment plug is required.
- F. Install suitable strain-relief clamps and fittings for cord connections at outlet boxes and equipment connection boxes.
- G. Install disconnect switches, controllers, control stations, and control devices to complete equipment wiring requirements.
- H. Install terminal block jumpers to complete equipment wiring requirements.
- I. Install interconnecting conduit and wiring between devices and equipment to complete equipment wiring requirements.
- J. Coolers and Freezers: Cut and seal conduit openings in freezer and cooler walls, floor, and ceilings.

END OF SECTION 26 05 83

SECTION 26 08 00

ELECTRICAL COMMISSIONING REQUIREMENTS

PART 1 - GENERAL

1.01 DESCRIPTION

- A. The purpose of this section is to specify the Contractor's responsibilities and participation in the commissioning process relative to division 26.
- B. The commissioning process is primarily the responsibility of the Commissioning Authority, with support for start-up, testing, and commissioning the responsibility of the Contractors. The commissioning process does not relieve the Contractor from participation in the process, or diminish the role and obligations to complete all portions of work in a satisfactory and fully operational manner.
- C. Work of Division 26 includes:
 - 1. Testing and start-up of the electrical equipment.
 - 2. Providing qualified personnel to assist in commissioning tests to verify equipment/ system performance.
 - 3. Completion and endorsement of pre-functional test checklists provided by the Commissioning Authority to assure that Division 26 equipment and systems are fully operational and ready for functional testing.
 - 4. Providing equipment, materials, and labor necessary to correct deficiencies found during the commissioning process which fulfill contract and warranty requirements.
 - 5. Providing training for the systems specified in Division 26 with coordination of owner by the Commissioning Authority.

1.02 RELATED WORK

- A. All testing and start-up procedures and documentation requirements specified within Division 26.
- B. Section 01 9100 - General Commissioning Requirements
- C. Commissioning functional test procedures that require participation of the Contractors.
- D. Cooperate with the Commissioning Authority in the following manner:
 - 1. Allow sufficient time before final completion dates so that testing can be accomplished.
 - 2. Provide labor and material to make corrections when required without undue delay.
 - 3. Coordinate all required support of that equipment which is provided to or installed with involvement of Division 23 contractors.

PART 2 - PRODUCTS

2.01 TEST EQUIPMENT

- A. Standard certified test equipment for commissioning shall be provided by the Division 26 Contractor.
- B. Proprietary test equipment required by the manufacturer, whether specified or not, shall be provided by the manufacturer of the equipment. Manufacturer shall provide the test equipment, demonstrate its use, and assist the Commissioning Authority in the commissioning process.

PART 3 - EXECUTION

3.01 WORK PRIOR TO COMMISSIONING

- A. Complete all phases of work so the system can be started, tested, balanced, and otherwise commissioned. Division 26 has temporary power and start-up responsibilities with obligations to complete systems, including all sub-systems so they are functional. This includes the complete installation of all equipment and materials per the contract documents and related directives, clarifications, change orders, etc.
- B. The Commissioning Authority will develop a Commissioning Plan. Upon request of the Commissioning Authority, the Contractor shall provide assistance and consultation. The Commissioning Plan will be developed prior to completion of the installation. The Contractor is obligated to assist the Commissioning Authority in preparing the Commissioning Plan by providing all necessary information pertaining to the actual equipment and installation.
- C. Specific pre-commissioning responsibilities of Division 26 are as follows:
 - 1. Normal start-up services required to bring each system into a fully operational state. The Commissioning Authority will not begin the commissioning process until each system is complete and documented, including normal contractor start-up.
 - 2. The Contractor shall perform pre-functional tests on the equipment and systems as noted in section 01 9100 General Commissioning Requirements.
 - 3. Contractor start-up forms may be substituted for the pre-functional test forms with prior approval by the Commissioning Authority.
 - 4. Pre-functional test forms will be kept in the Contractors job trailer in a Commissioning Field Notebook provided by the Commissioning Authority.
 - 5. Factory start-up services will be provided for key equipment and systems specified in Division 26. The Contractor shall coordinate this work with the manufacturer and the Commissioning Authority.
- D. Commissioning is intended to begin upon completion of a system. Commissioning may proceed prior to the completion of systems and/or sub-systems, if expediting this work is in the best interests of the Owner. Commissioning activities and schedule will be coordinated with the Contractor. Start of commissioning before system completion will not relieve the Contractor from completing those systems as per the

schedule.

- E. The Field Commissioning Notebook will be used to identify and track all pertinent commissioning documentation required during the Installation phase. This Notebook will be assembled by the Commissioning Authority and maintained by the Contractor. The Notebook provides a central location for the Commissioning Authority to identify, copy and organize all pertinent information and will include the following format:
 1. Summary describing Notebook contents and use.
 2. Copy of Commissioning Plan for contractor field reference.
 3. Listing of all specification documentation requirements listed by specification section, with sign off spots for appropriate contractors.
 4. Tabs for each specification section with copies of pre-functional test check sheets provided by coordination of subcontractors and Commissioning Authority for contractor completion and space for related contractor-supplied documents.
 5. Prior to functional testing the Commissioning Authority will use this book to verify that all appropriate contractors have completed their work and signed off that they have done so. Once the Commissioning Authority is satisfied that all components of a system are complete functional testing will begin.

3.02 PARTICIPATION IN COMMISSIONING

- A. Provide skilled technicians to start up and debug all systems within the division of work. These same technicians shall be made available to assist the Commissioning Authority in completing the commissioning program as it relates to each system and their technical specialty. Work schedules, time required for testing, etc., will be requested by the Commissioning Authority and coordinated by the Contractor. Contractor will ensure the qualified technician(s) are available and present during the agreed-upon schedules and of sufficient duration to complete the necessary tests, adjustments, and/or problem resolutions.
- B. The Commissioning Authority reserves the right to judge the appropriateness and qualifications of the technicians relative to each item of equipment, system, and/or sub-system. Qualifications of technicians include expert knowledge relative to the specific equipment involved, adequate documentation and tools to service/commission the equipment, and an attitude/willingness to work with the Commissioning Authority to get the job done. A liaison or intermediary between the Commissioning Authority and qualified factory representatives does not constitute the availability of a qualified technician for purposes of this work.

3.03 WORK TO RESOLVE DEFICIENCIES

- A. Maladjustments, misapplied equipment, and/or deficient performance under varying loads will result in a system that does not meet the original design intent. Correction of work will be completed under the direction of the Architect, with input from the Contractor, equipment supplier, and Commissioning Authority. Whereas all members will have input and the opportunity to discuss, debate, and work out problems, the Architect/Engineer of Record will have final jurisdiction on the necessary work to be done to achieve performance and or design intent.

3.04 ADDITIONAL COMMISSIONING

- A. Additional commissioning activities may be required after system adjustments, replacements, etc., are completed. The Contractor, suppliers, and Commissioning Authority shall include a reasonable reserve to complete this work as part of their standard contractual obligations.

3.05 SEASONAL COMMISSIONING AND OCCUPANCY VARIATIONS

- A. Seasonal commissioning pertains to testing under full-load conditions during peak heating and peak cooling seasons, as well as part-load conditions in the spring and fall. Initial commissioning will be done as soon as contract work is completed regardless of season. Subsequent commissioning may be undertaken at any time thereafter to ascertain adequate performance during the different seasons.
- B. All equipment and systems will be tested and commissioned in a peak season to observe full-load performance. The Contractor will be responsible to participate in the initial and the alternate peak season test of the systems required to demonstrate performance.
- C. Subsequent commissioning may be required under conditions of minimum and/or maximum occupancy or use. All equipment and systems affected by occupancy variations will be tested and commissioned at the minimum and peak loads to observe system performance. The Contractor will be responsible to participate in the occupancy sensitive testing of systems to provide verification of adequate performance.

3.06 TRAINING

- A. The Contractor will be required to participate in the training of the Owner's engineering and maintenance staff for each mechanical system and the related components. Training may be conducted in a classroom setting, with system and component documentation, and suitable classroom training aids, or in the field with the specific equipment. The type of training will be per the Owner's option.
- B. Training will be conducted jointly with the Commissioning Authority, the design engineers, the equipment vendors, and the Contractor. The Contractor will be responsible for the generic training, as well as instructing the Owner's staff on the system peculiarities specific to this project.

3.07 SYSTEMS DOCUMENTATION

- A. Contract Documents to incorporate field changes and revisions to system designs to account for actual constructed configurations will be addressed as required in Division 1. All drawings should be red-lined on two sets. Division 26 as-built drawings should include updated architectural floor plans, and the individual electrical systems in relation to actual building layout.
- B. Maintain as-built red-lines on the job site as required in Division 1.
- C. In addition to the stated requirements for operation and maintenance data, provide one copy of equipment technical literature, operation and maintenance literature,

FOR REFERENCE ONLY

and shop drawings to the Commissioning Authority as soon as they are available. This requirement is for review of these documents prior to distribution of multiple copies for the Owner's final use.

END OF SECTION 26 08 00

SECTION 26 09 23 LIGHTING CONTROL DEVICES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Occupancy sensors.
- B. Outdoor motion sensors.
- C. Time switches.
- D. In-wall time switches.
- E. In-wall interval timers.
- F. Outdoor photo controls.
- G. Daylighting controls.
- H. Lighting contactors.
- I. Accessories.

1.02 RELATED REQUIREMENTS

- A. Section 26 05 26 - Grounding and Bonding for Electrical Systems.
- B. Section 26 05 29 - Hangers and Supports for Electrical Systems
- C. Section 26 05 33.16 - Boxes for Electrical Systems.
- D. Section 26 05 53 - Identification for Electrical Systems: Identification products and requirements.
- E. Section 26 05 73 - Power System Studies.
- F. Section 26 09 18 - Remote Control Switching Devices: Remotely controlled devices for lighting control, including networked lighting controls, programmable relay panels, and remote control switching relays.
- G. Section 26 27 26 - Wiring Devices: Devices for manual control of lighting, including wall switches, wall dimmers, and fan speed controllers.
 - 1. Includes finish requirements for wall controls specified in this section.
 - 2. Includes accessory receptacles, switches, dimmers and wall plates, to match lighting controls specified in this section.
- H. Section 26 28 13 - Fuses.
- I. Section 26 51 00 - Interior Lighting.
- J. Section 26 56 00 - Exterior Lighting.

1.03 REFERENCE STANDARDS

- A. 47 CFR 15 - Radio Frequency Devices; current edition.
- B. ANSI C136.10 - American National Standard for Roadway and Area Lighting Equipment - Locking-Type Photocontrol Devices and Mating Receptacles - Physical and Electrical

Interchangeability and Testing; 2023.

- C. ANSI C136.24 - American National Standard for Roadway and Area Lighting Equipment - Nonlocking (Button) Type Photocontrols; 2020.
- D. NECA 1 - Standard for Good Workmanship in Electrical Construction; 2015.
- E. NECA 130 - Standard for Installing and Maintaining Wiring Devices; 2016.
- F. NEMA 250 - Enclosures for Electrical Equipment (1000 Volts Maximum); 2020.
- G. NEMA 410 - Performance Testing for Lighting Controls and Switching Devices with Electronic Drivers and Discharge Ballasts; 2023.
- H. NEMA ICS 2 - Industrial Control and Systems Controllers, Contactors and Overload Relays Rated 600 Volts; 2008 (Reaffirmed 2020).
- I. NEMA ICS 5 - Industrial Control and Systems: Control Circuit and Pilot Devices; 2017.
- J. NEMA ICS 6 - Industrial Control and Systems: Enclosures; 1993 (Reaffirmed 2016).
- K. NFPA 70 - National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- L. UL 773 - Plug-in, Locking Type Photocontrols for Use with Area Lighting; Current Edition, Including All Revisions.
- M. UL 773A - Nonindustrial Photoelectric Switches for Lighting Control; Current Edition, Including All Revisions.
- N. UL 916 - Energy Management Equipment; Current Edition, Including All Revisions.
- O. UL 917 - Clock-Operated Switches; Current Edition, Including All Revisions.
- P. UL 1472 - Solid-State Dimming Controls; Current Edition, Including All Revisions.
- Q. UL 60947-1 - Low-Voltage Switchgear and Controlgear - Part 1: General Rules; Current Edition, Including All Revisions.
- R. UL 60947-4-1 - Low-Voltage Switchgear and Controlgear - Part 4-1: Contactors and Motor-starters - Electromechanical Contactors and Motor-starters; Current Edition, Including All Revisions.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Coordinate the placement of lighting control devices with millwork, furniture, equipment, etc. installed under other sections or by others.
 - 2. Coordinate the placement of wall switch occupancy sensors with actual installed door swings.
 - 3. Coordinate the placement of occupancy sensors with millwork, furniture, equipment or other potential obstructions to motion detection coverage installed under other sections or by others.
 - 4. Coordinate the placement of photo sensors for daylighting controls with windows, skylights, and luminaires to achieve optimum operation. Coordinate placement with ductwork, piping, equipment, or other potential obstructions to light level measurement installed under other sections or by others.

5. Notify the Architect and/or the Electrical Engineer of Record of any conflicts or deviations from the contract documents to obtain direction prior to proceeding with work.
- B. Sequencing:
 1. Do not install lighting control devices until final surface finishes and painting are complete.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Include ratings, configurations, standard wiring diagrams, dimensions, colors, service condition requirements, and installed features.
 1. Occupancy Sensors: Include detailed motion detection coverage range diagrams.
- C. Shop Drawings:
 1. Occupancy Sensors: Provide lighting plan indicating location, model number, and orientation of each occupancy sensor and associated system component.
 2. Daylighting Controls: Provide lighting plan indicating location, model number, and orientation of each photo sensor and associated system component.
- D. Samples:
 1. Occupancy Sensors: One for each type and color specified.
 2. In-Wall Time Switches: One for each type and color specified.
 3. In-Wall Interval Timers: One for each type and color specified.
 4. Daylighting Control Photo Sensors: One for each type and color specified.
- E. Field Quality Control Reports.
- F. Manufacturer's Installation Instructions: Include application conditions and limitations of use stipulated by product testing agency. Include instructions for storage, handling, protection, examination, preparation, and installation of product.
- G. Operation and Maintenance Data: Include detailed information on device programming and setup.
- H. Maintenance Materials: Furnish the following for Owner's use in maintenance of project.
 1. See Section 01 60 00 - Product Requirements, for additional provisions.
 2. Extra Locking Receptacle-Mounted Outdoor Photo Controls: Five percent of total quantity installed for each type, but not less than two of each type.
 3. Electronic Trip Circuit Breakers: Provide one portable test set.
 4. Indicating Lights: Two of each different type.
- I. Project Record Documents: Record actual installed locations and settings for lighting control devices.

1.06 QUALITY ASSURANCE

- A. Conform to requirements of CEC.
- B. Maintain at the project site a copy of each referenced document that prescribes execution requirements.

- C. **Manufacturer Qualifications:** Company specializing in manufacturing the products specified in this section with minimum three years documented experience.
- D. **Product Listing Organization Qualifications:** An organization recognized by OSHA as a Nationally Recognized Testing Laboratory (NRTL) and acceptable to authorities having jurisdiction.

1.07 DELIVERY, STORAGE, AND PROTECTION

- A. Store products in a clean, dry space in original manufacturer's packaging in accordance with manufacturer's written instructions until ready for installation.

1.08 FIELD CONDITIONS

- A. Maintain field conditions within manufacturer's required service conditions during and after installation.

1.09 WARRANTY

- A. See Section 01 78 00 - Closeout Submittals, for additional warranty requirements.
- B. Provide five year manufacturer warranty for all occupancy sensors.
- C. Provide five year manufacturer warranty for utility grade locking receptacle-mounted outdoor photo controls.
- D. Provide two year manufacturer warranty for all daylighting controls.

PART 2 PRODUCTS

2.01 LIGHTING CONTROL DEVICES - GENERAL REQUIREMENTS

- A. **General Requirements**
 - 1. Provide products listed, classified, and labeled as suitable for the purpose intended.
 - 2. Unless specifically indicated to be excluded, provide all required conduit, wiring, connectors, hardware, components, accessories, etc. as required for a complete operating system.
 - 3. **Products for Switching of Electronic Ballasts/Drivers:** Tested and rated to be suitable for peak inrush currents specified in NEMA 410.

2.02 OCCUPANCY SENSORS

- A. **Manufacturers:**
 - 1. Acuity Brands, Inc: www.acuitybrands.com/#sle.
 - 2. Hubbell Incorporated: www.hubbell.com/#sle.
 - 3. Intermatic, Inc: www.intermatic.com/#sle.
 - 4. Legrand North America, Inc: www.legrand.us/#sle.
 - 5. Lutron Electronics Company, Inc: www.lutron.com/#sle.
 - 6. RAB Lighting, Inc: www.rablighting.com/#sle.
 - 7. Or approved equal..
 - 8. **Substitutions:** See Section 01 60 00 - Product Requirements.

9. Source Limitations: Furnish products produced by a single manufacturer and obtained from a single supplier.
- B. All Occupancy Sensors:
1. Description: Factory-assembled commercial specification grade devices for indoor use capable of sensing both major motion, such as walking, and minor motion, such as small desktop level movements, according to published coverage areas, for automatic control of load indicated.
 2. Sensor Technology:
 - a. Passive Infrared (PIR) Occupancy Sensors: Designed to detect occupancy by sensing movement of thermal energy between zones.
 - b. Ultrasonic Occupancy Sensors: Designed to detect occupancy by sensing frequency shifts in emitted and reflected inaudible sound waves.
 - c. Passive Infrared/Ultrasonic Dual Technology Occupancy Sensors: Designed to detect occupancy using a combination of both passive infrared and ultrasonic technologies.
 - d. Passive Infrared/Acoustic Dual Technology Occupancy Sensors: Designed to detect occupancy using a combination of both passive infrared and audible sound sensing technologies.
 3. Provide LED to visually indicate motion detection with separate color LEDs for each sensor type in dual technology units.
 4. Operation: Unless otherwise indicated, occupancy sensor to turn load on when occupant presence is detected and to turn load off when no occupant presence is detected during an adjustable turn-off delay time interval.
 5. Dual Technology Occupancy Sensors: Field configurable turn-on and hold-on activation with settings for activation by either or both sensing technologies.
 6. Passive Infrared Lens Field of View: Field customizable by addition of factory masking material, adjustment of integral blinders, or similar means to block motion detection in selected areas.
 7. Turn-Off Delay: Field adjustable, with time delay settings up to 30 minutes.
 8. Sensitivity: Field adjustable.
 9. Adaptive Technology: Field selectable; capable of self-adjusting sensitivity and time delay according to conditions.
 10. Integral Photocell: For field selectable and adjustable inhibition of automatic turn-on of load when ambient lighting is above the selected level.
 11. Compatibility (Non-Dimming Sensors): Suitable for controlling incandescent lighting, low-voltage lighting with electronic and magnetic transformers, fluorescent lighting with electronic and magnetic ballasts, and fractional motor loads, with no minimum load requirements.
 12. Load Rating for Line Voltage Occupancy Sensors: As required to control the load indicated on drawings.
 13. Isolated Relay for Low Voltage Occupancy Sensors: SPDT dry contacts, ratings as required for interface with system indicated.
 14. Where wired sensors are indicated, wireless sensors are acceptable provided that all components and wiring modifications necessary for proper operation are included.

15. Wireless Sensors:
 - a. RF Range: 30 feet through typical construction materials.
 - b. Electromagnetic Interference/Radio Frequency Interference (EMI/RFI) Limits: Comply with FCC requirements of 47 CFR 15, for Class B application.
 - c. Power: Battery-operated with minimum ten-year battery life.
- C. Wall Switch Occupancy Sensors:
 1. All Wall Switch Occupancy Sensors:
 - a. Description: Occupancy sensors designed for installation in standard wall box at standard wall switch mounting height with a field of view of 180 degrees, integrated manual control capability, and no leakage current to load in off mode.
 - b. Unless otherwise indicated or required to control the load indicated on drawings, provide line voltage units with self-contained relay.
 - c. Where indicated, provide two-circuit units for control of two separate lighting loads, with separate manual controls and separately programmable operation for each load.
 - d. Operation: Field selectable to operate either as occupancy sensor (automatic on/off) or as vacancy sensor (manual-on/automatic off).
 - e. Manual-Off Override Control: When used to turn off load while in automatic-on mode, unit to revert back to automatic mode after no occupant presence is detected during the delayed-off time interval.
 - f. Provide selectable audible alert to notify occupant of impending load turn-off.
 - g. Finish: Match finishes specified for wiring devices in Section 26 27 26, unless otherwise indicated.
 - h. Provide vandal resistant lenses for passive infrared (PIR) and dual technology wall switch occupancy sensors where indicated.
 2. Passive Infrared (PIR) Wall Switch Occupancy Sensors: Capable of detecting motion within an area of 900 square feet.
 3. Ultrasonic Wall Switch Occupancy Sensors: Capable of detecting motion within an area of 400 square feet.
 4. Passive Infrared/Ultrasonic Dual Technology Wall Switch Occupancy Sensors: Capable of detecting motion within an area of 900 square feet.
- D. Wall Dimmer Occupancy Sensors:
 1. General Requirements:
 - a. Description: Occupancy sensors designed for installation in standard wall box at standard wall switch mounting height with a field of view of 180 degrees, integrated dimming control capability , and no leakage current to load in off mode.
 - b. Operation: Field selectable to operate either as occupancy sensor (automatic on/off) or as vacancy sensor (manual-on/automatic off).
 - c. Manual-Off Override Control Capability: When used to turn off load while in automatic-on mode, unit to revert back to automatic mode after no occupant presence is detected during the delayed-off time interval.

- d. Dimmer: Solid-state with continuous full-range even control following square law dimming curve, integral radio frequency interference filtering, power failure preset memory, air gap switch accessible without removing wall plate, and listed as complying with UL 1472; type and rating suitable for load controlled.
 - e. Provide field adjustable dimming preset for occupied state.
 - f. Provide fade-to-off operation to notify occupant of impending load turn-off.
 - g. Finish: Match finishes specified for wiring devices in Section 26 27 26, unless otherwise indicated.
2. Passive Infrared (PIR) Wall Dimmer Occupancy Sensors: Capable of detecting motion within an area of 900 square feet.
- E. Ceiling Mounted Occupancy Sensors:
1. All Ceiling Mounted Occupancy Sensors:
 - a. Description: Low profile occupancy sensors designed for ceiling installation.
 - b. Unless otherwise indicated or required to control the load indicated on drawings, provide low voltage units, for use with separate compatible accessory power packs.
 - c. Provide field selectable setting for disabling LED motion detector visual indicator.
 - d. Occupancy sensor to be field selectable as either manual-on/automatic-off or automatic on/off.
 - e. Finish: White unless otherwise indicated.
 2. Passive Infrared (PIR) Ceiling Mounted Occupancy Sensors:
 - a. Standard Range Sensors: Capable of detecting motion within an area of 450 square feet at a mounting height of 9 feet, with a field of view of 360 degrees.
 - b. Extended Range Sensors: Capable of detecting motion within an area of 1,200 square feet at a mounting height of 9 feet, with a field of view of 360 degrees.
 3. Ultrasonic Ceiling Mounted Occupancy Sensors:
 - a. Standard Range Sensors: Capable of detecting motion within an area of 500 square feet at a mounting height of 9 feet, with a field of view of 360 degrees.
 - b. Medium Range Sensors: Capable of detecting motion within an area of 1,000 square feet at a mounting height of 9 feet, with a field of view of 360 degrees.
 - c. Extended Range Sensors: Capable of detecting motion within an area of 2,000 square feet at a mounting height of 9 feet.
 4. Passive Infrared/Ultrasonic Dual Technology Ceiling Mounted Occupancy Sensors:
 - a. Standard Range Sensors: Capable of detecting motion within an area of 450 square feet at a mounting height of 9 feet, with a field of view of 360 degrees.
 - b. Extended Range Sensors: Capable of detecting motion within an area of 1,200 square feet at a mounting height of 9 feet, with a field of view of 360

- degrees.
5. Passive Infrared/Acoustic Dual Technology Ceiling Mounted Occupancy Sensors:
 - a. Standard Range Sensors: Capable of detecting motion within an area of 450 square feet at a mounting height of 9 feet, with a field of view of 360 degrees.
 - b. Extended Range Sensors: Capable of detecting motion within an area of 1,200 square feet at a mounting height of 9 feet.
 - F. Directional Occupancy Sensors:
 1. All Directional Occupancy Sensors: Designed for wall or ceiling mounting, with integral swivel for field adjustment of motion detection coverage.
 - a. Unless otherwise indicated or required to control the load indicated on drawings, provide low voltage units, for use with separate compatible accessory power packs.
 - b. Provide field selectable setting for disabling LED motion detector visual indicator.
 - c. Finish: White unless otherwise indicated.
 2. Passive Infrared (PIR) Directional Occupancy Sensors:
 - a. Standard Range Sensors: Capable of detecting motion within a distance of 40 feet at a mounting height of 10 feet.
 - b. Long Range Sensors: Capable of detecting motion within a distance of 80 feet at a mounting height of 10 feet.
 - c. High Bay Sensors: Capable of detecting motion within a distance of 50 feet at a mounting height of 30 feet.
 3. Passive Infrared/Ultrasonic Dual Technology Directional Occupancy Sensors: Capable of detecting motion within a distance of 40 feet at a mounting height of 10 feet.
 - G. Luminaire Mounted Occupancy Sensors: Designed for direct luminaire installation and control, suitable for use with specified luminaires.
 1. Fluorescent High Bay Luminaire Mounted Occupancy Sensors: Passive infrared (PIR) type with a field of view of 360 degrees unless otherwise indicated.
 - a. Unless otherwise indicated or required to control the load indicated on drawings, provide line voltage units with self-contained relay.
 - b. Finish: White unless otherwise indicated.
 - c. Circular Coverage Sensors: Capable of detecting motion within a distance of 40 feet at a mounting height of 20 feet.
 - d. Linear Aisle Coverage Sensors: Capable of detecting motion within an area of 20 feet wide by 60 feet long at a mounting height of 40 feet.
 - e. Accessories:
 - 1) Provide mounting bracket for lowering occupancy sensor such that luminaire does not block sensor field of view where required.
 - H. Power Packs for Low Voltage Occupancy Sensors:
 1. Description: Plenum rated, self-contained low voltage class 2 transformer and relay compatible with specified low voltage occupancy sensors for switching of line voltage loads.

2. Provide quantity and configuration of power and slave packs with all associated wiring and accessories as required to control the load indicated on drawings.
 3. Input Supply Voltage: Dual rated for 120/277 V ac.
 4. Load Rating: As required to control the load indicated on drawings.
- I. Power Packs for Wireless Occupancy Sensors:
1. Description: Plenum rated, self-contained relay compatible with specified wireless occupancy sensors for switching of line voltage loads.
 2. Input Supply Voltage: Dual rated for 120/277 V ac.
 3. Load Rating: As required to control the load indicated on drawings.
 4. Provide auxiliary contact closure output where indicated.
 5. Rated Life of Relay: One million cycles.
- J. Accessories:
1. Provide heavy duty coated steel wire protective guards compatible with specified occupancy sensors where indicated on plans.
- K. OUTDOOR MOTION SENSORS
1. Manufacturers:
 - a. Acuity Brands, Inc: www.acuitybrands.com/#sle.
 - b. Hubbell Lighting, Inc: www.hubbellighting.com/#sle.
 - c. Legrand North America, Inc: www.legrand.us/#sle.
 - d. RAB Lighting, Inc: www.rablighting.com/#sle.
 - e. Or approved equal.
 - f. Substitutions: See Section 01 60 00 - Product Requirements.
 - g. Source Limitations: Furnish products produced by a single manufacturer and obtained from a single supplier.
 2. Description: Factory-assembled wet location listed device suitable for wall or ceiling/eave mounting, with integral swivel for field adjustment of coverage, capable of detecting motion for automatic control of load indicated.
 3. Sensor Technology: Passive Infrared (PIR) designed to detect occupancy by sensing movement of thermal energy between zones.
 4. Operation: Unless otherwise indicated, motion sensor to turn load on when motion is detected and to turn load off when no motion is detected during an adjustable turn-off delay time interval.
 5. Turn-Off Delay: Field adjustable, with time delay settings available up to 15 minutes.
 6. Integral Photocell: For dusk to dawn operation.
 7. Manual Override: Activated by switching power off to unit and then back on.
 8. Load Rating: 1,000 W incandescent and fluorescent load at 120 V ac.
 9. Coverage: Capable of detecting motion within a distance of 50 feet at a mounting height of 8 feet, with a field of view of 270 degrees.
 10. Finish: Color to be selected by architect.
 11. Provide integral lamp holders suitable for two 150 watt PAR 38 lamps.
- L. TIME SWITCHES
1. Manufacturers:
 - a. Intermatic, Inc: www.intermatic.com/#sle.

- b. Tork, a division of NSI Industries LLC: www.tork.com/#sle.
 - c. Or approved equal.
 - d. Substitutions: See Section 01 60 00 - Product Requirements.
 - e. Source Limitations: Furnish products produced by a single manufacturer and obtained from a single supplier.
2. Digital Electronic Time Switches:
- a. Description: Factory-assembled solid state programmable controller with LCD display, listed and labeled as complying with UL 916 or UL 917.
 - b. Program Capability:
 - 1) 24-Hour Time Switches: Single channel, with same schedule for each day of the week and skip-a-day feature to omit selected days.
 - 2) 7-Day Time Switches: Single channel, capable of different schedule for each day of the week with additional holiday schedule available to override normal schedule for selected days.
 - 3) Astronomic Time Switches: Single channel, capable of different schedule for each day of the week with additional holiday schedule available to override normal schedule for selected days and field-configurable astronomic feature to automatically adjust for seasonal changes in sunrise and sunset times.
 - c. Schedule Capacity: Not less than 16 programmable on/off operations.
 - d. Provide automatic daylight savings time and leap year compensation.
 - e. Provide power outage backup to retain programming and maintain clock.
 - f. Manual override: Capable of overriding current schedule both permanently and temporarily until next scheduled event.
 - g. Provide remote photocell input with light level adjustment.
 - h. Input Supply Voltage: As indicated on the drawings.
 - i. Output Switch Configuration: As required to control the load indicated on drawings.
 - j. Output Switch Contact Ratings: As required to control the load indicated on drawings.
 - k. Provide lockable enclosure; environmental type per NEMA 250 as specified for the following installation locations:
 - 1) Indoor clean, dry locations: Type 1.
 - 2) Outdoor locations: Type 3R.
 - l. Provide flush-mounted unit where indicated, where mounted in public areas, or where mounted adjacent to flush-mounted equipment.
3. Electromechanical Time Switches:
- a. Description: Factory-assembled controller with motor-operated timing dial mechanism and adjustable trippers for setting on/off operations, listed and labeled as complying with UL 917.
 - b. Program Capability:
 - 1) 24-Hour Time Switches: With same schedule for each day of the week and skip-a-day feature to omit selected days.
 - 2) 7-Day Time Switches: Capable of different schedule for each day of the week.

- 3) Astronomic Time Switches: With same schedule for each day of the week and skip-a-day feature to omit selected days with automatic adjustment for seasonal changes in sunrise and sunset times.
- c. Schedule Capacity:
 - 1) 24-Hour Time Switches: Accommodating not less than 12 pairs of selected on/off operations per day.
 - 2) 7-Day Time Switches: Accommodating not less than two pairs of selected on/off operations per day.
 - 3) Astronomic Time Switches: Capable of turning load on at sunset and off at either sunrise or selected fixed time.
- d. Provide spring reserve backup to maintain clock during power outage.
- e. Manual override: Capable of overriding current schedule both permanently and temporarily until next scheduled event.
- f. Input Supply Voltage: As indicated on the drawings.
- g. Output Switch Configuration: As required to control the load indicated on drawings.
- h. Output Switch Contact Ratings: As required to control the load indicated on drawings.
- i. Provide lockable enclosure; environmental type per NEMA 250 as specified for the following installation locations:
 - 1) Indoor clean, dry locations: Type 1.
 - 2) Outdoor locations: Type 3R.
- j. Provide flush-mounted unit where indicated, where mounted in public areas, or where mounted adjacent to flush-mounted equipment.

M. IN-WALL TIME SWITCHES

1. Manufacturers:
 - a. Intermatic, Inc: www.intermatic.com/#sle.
 - b. Tork, a division of NSI Industries LLC: www.tork.com/#sle.
 - c. Or approved equal.
 - d. Substitutions: See Section 01 60 00 - Product Requirements.
 - e. Source Limitations: Furnish products produced by a single manufacturer and obtained from a single supplier.
2. Digital Electronic In-Wall Time Switches:
 - a. Description: Factory-assembled solid state programmable controller with LCD display, suitable for mounting in standard wall box, and listed and labeled as complying with UL 916 or UL 917.
 - b. Program Capability:
 - 1) 7-Day Time Switches: Capable of different schedule for each day of the week.
 - 2) Astronomic Time Switches: Capable of different schedule for each day of the week and field-configurable astronomic feature to automatically adjust for seasonal changes in sunrise and sunset times.
 - c. Schedule Capacity: Not less than 40 programmable on/off operations.
 - d. Provide automatic daylight savings time compensation.
 - e. Provide power outage backup to retain programming and maintain clock.

- f. Manual override: Capable of overriding current schedule both permanently and temporarily until next scheduled event.
 - g. Switch Configuration: Suitable for use in either SPST or 3-way application.
 - h. Contact Ratings: As required to control the load indicated on drawings.
3. Electromechanical In-Wall Time Switches:
- a. Description: Factory-assembled controller with motor-operated timing dial mechanism and adjustable trippers for setting on/off operations, suitable for mounting in standard wall box, and listed and labeled as complying with UL 917.
 - b. Program Capability: 24-hour time switch with same schedule for each day of the week.
 - c. Schedule Capacity: Accommodating not less than 24 selected on/off operations per day.
 - d. Manual override: Capable of permanently overriding current schedule.
 - e. Switch Configuration: SPST.
 - f. Contact Ratings: As required to control the load indicated on drawings.
- N. IN-WALL INTERVAL TIMERS
1. Manufacturers:
- a. Intermatic, Inc: www.intermatic.com/#sle.
 - b. Tork, a division of NSI Industries LLC: www.tork.com/#sle.
 - c. Or approved equal.
 - d. Substitutions: See Section 01 60 00 - Product Requirements.
 - e. Source Limitations: Furnish products produced by a single manufacturer and obtained from a single supplier.
2. Digital Electronic In-Wall Interval Timers:
- a. Description: Factory-assembled solid state programmable controller with LCD display, suitable for mounting in standard wall box, and listed and labeled as complying with UL 916 or UL 917.
 - b. Program Capability: Designed to turn load off at end of preset time interval.
 - c. Time Interval: Field selectable range of presets available up to 12 hours.
 - d. Provide field selectable audible and visual indication to warn that end of interval operation is about to turn off load.
 - e. Provide power outage backup to retain programming and maintain clock.
 - f. Manual override: Capable of both turning load off and resetting timer to original preset time interval.
 - g. Switch Configuration: Suitable for use in either SPST or 3-way application.
 - h. Contact Ratings: As required to control the load indicated on drawings.
3. Spring Wound In-Wall Interval Timers:
- a. Description: Factory-assembled controller with mechanical spring wound timing mechanism requiring no electricity to operate; suitable for mounting in standard wall box; rotary control operator with matching wall plate factory marked with time interval units; listed and labeled as complying with UL 916 or UL 917.
 - b. Program Capability: Designed to turn load off at end of preset time interval.
 - c. Time Interval: User selectable from zero up to 15 minutes.

- d. Manual override: Provide hold feature to disable timer for constant on operation.
 - e. Switch Configuration: SPST.
 - f. Contact Ratings: As required to control the load indicated on drawings.
- O. OUTDOOR PHOTO CONTROLS
- 1. Manufacturers:
 - a. Intermatic, Inc: www.intermatic.com/#sle.
 - b. Tork, a division of NSI Industries LLC: www.tork.com/#sle.
 - c. Substitutions: See Section 01 60 00 - Product Requirements.
 - d. Source Limitations: Furnish products produced by a single manufacturer and obtained from a single supplier.
 - 2. Stem-Mounted Outdoor Photo Controls:
 - a. Description: Direct-wired photo control unit with threaded conduit mounting stem and field-adjustable swivel base, listed and labeled as complying with UL 773A.
 - b. Housing: Weatherproof, impact resistant polycarbonate.
 - c. Photo Sensor: Cadmium sulfide.
 - d. Provide external sliding shield for field adjustment of light level activation.
 - e. Light Level Activation: 1 to 5 footcandles turn-on and 3 to 1 turn-off to turn-on ratio with delayed turn-off.
 - f. Voltage: As required to control the load indicated on the drawings.
 - g. Failure Mode: Fails to the on position.
 - h. Load Rating: As required to control the load indicated on the drawings.
 - i. Provide accessory wall-mounting bracket where indicated or as required to complete installation.
 - 3. Locking Receptacle-Mounted Outdoor Photo Controls
 - a. Description: Plug-in locking type photo control unit complying with ANSI C136.10 for mounting on a compatible receptacle, listed and labeled as complying with UL 773.
 - b. Housing: Weatherproof, impact resistant UV stabilized polypropylene, color to be selected.
 - c. Photo Sensor: Cadmium sulfide.
 - d. Light Level Activation: 1 to 3 footcandles turn-on and 1.5 to 1 turn-off to turn-on ratio with instant turn-on and delayed turn-off.
 - e. Voltage: As required to control the load indicated on the drawings.
 - f. Failure Mode: Fails to the on position.
 - g. Load Rating: As required to control the load indicated on the drawings.
 - h. Surge Protection: 160 joule metal oxide varistor.
 - i. Provide the following accessories where indicated or as required to complete installation:
 - 1) Receptacle: Complying with ANSI C136.10.
 - 2) Mounting Bracket.
 - 3) Shorting Cap: Suitable for replacing locking photo control to complete circuit.

4. Button Type Outdoor Photo Controls
 - a. Description: Direct-wired photo control unit complying with ANSI C136.24 with weatherproof gasketed wall plate where required or indicated, listed and labeled as complying with UL 773A.
 - b. Housing: Weather resistant polycarbonate.
 - c. Photo Sensor: Cadmium sulfide.
 - d. Light Level Activation: 1 to 3 footcandles turn-on and 3 to 1 turn-off to turn-on ratio with delayed turn-off.
 - e. Voltage: As required to control the load indicated on the drawings.
 - f. Failure Mode: Fails to the on position.
 - g. Load Rating: As required to control the load indicated on the drawings.
- P. DAYLIGHTING CONTROLS
 1. Manufacturers:
 - a. Hubbell Control Solutions:
www.hubbell.com/hubbellcontrolsolutions/en/#sle.
 - b. Lutron Electronics Company, Inc: www.lutron.com/#sle.
 - c. Sensor Switch Inc: www.sensorswitch.com/#sle.
 - d. WattStopper: www.wattstopper.com/#sle.
 - e. Or approved equal.
 - f. Substitutions: See Section 01 60 00 - Product Requirements.
 - g. Source Limitations: Furnish products produced by a single manufacturer and obtained from a single supplier.
 2. System Description: Control system consisting of photo sensors and compatible control modules and power packs, contactors, or relays as required for automatic control of load indicated according to available natural light; capable of integrating with occupancy sensors and manual override controls.
 3. Daylighting Control Photo Sensors: Low voltage class 2 photo sensor units with output signal proportional to the measured light level and provision for zero or offset based signal.
 - a. Sensor Type: Filtered silicon photo diode.
 - b. Sensor Range:
 - 1) Indoor Photo Sensors: 5 to 100 footcandles.
 - 2) Outdoor Photo Sensors: 5 to 250 footcandles.
 - 3) Atrium Photo Sensors: 200 to 2,500 footcandles.
 - 4) Skylight Photo Sensors: 1,000 to 6,000 footcandles.
 - 5) Open Loop Photo Sensors: 3 to 6,000 footcandles.
 - c. Finish: White unless otherwise indicated.
 4. Where wired sensors are indicated, wireless sensors are acceptable provided that all components and wiring modifications necessary for proper operation are included.
 5. Wireless Daylighting Control Photo Sensors:
 - a. RF Range: 30 feet through typical construction materials.
 - b. Electromagnetic Interference/Radio Frequency Interference (EMI/RFI) Limits: Comply with FCC requirements of 47 CFR 15, for Class B application.

- c. Power: Battery-operated with minimum ten-year battery life.
- 6. Dimming Photo Sensors: Photo sensor units with integral controller compatible with specified dimming ballasts, for direct continuous dimming of up to 50 ballasts.
- 7. Daylighting Control Switching Modules for Low Voltage Sensors: Low voltage class 2 control unit compatible with specified photo sensors, for switching of compatible power packs, contactors, or relays in response to changes in measured light levels according to selected settings.
 - a. Operation: Unless otherwise indicated, load to be turned on when light level is below selected low set point and load to be turned off when light level is above selected high set point, with a no switching dead band between set points to prevent unwanted cycling.
 - b. Input Delay: To prevent unwanted cycling due to intermittent light level fluctuations.
 - c. Control Capability:
 - 1) Single Zone Switching Modules: Capable of controlling one programmable channel.
 - 2) Multi-Zone Switching Modules: Capable of controlling up to three separately programmable channels.
- Q. Daylighting Control Switching Modules for Wireless Sensors:
 - 1. Description: Plenum rated, self-contained relay compatible with specified wireless photo sensors for switching of line voltage loads in response to changes in measured light levels according to selected settings.
 - 2. Operation: Unless otherwise indicated, load to be turned on when light level is below selected low set point and load to be turned off when light level is above selected high set point, with a no switching dead band between set points to prevent unwanted cycling.
 - 3. Input Delay: To prevent unwanted cycling due to intermittent light level fluctuations.
 - 4. Control Capability: Capable of controlling one programmable channel.
 - 5. Input Supply Voltage: Dual rated for 120/277 V ac.
 - 6. Load Rating: As required to control the load indicated on drawings.
 - 7. Provide auxiliary contact closure output where indicated.
 - 8. Rated Life of Relay: One million cycles.
 - 9. Daylighting Control Dimming Modules for Low Voltage Sensors: Low voltage class 2 control unit compatible with specified photo sensors and with specified dimming ballasts, for both continuous dimming of compatible dimming ballasts and switching of compatible power packs, contactors, or relays in response to changes in measured light levels according to selected settings.
 - a. Operation: Unless otherwise indicated, specified load to be continuously brightened as not enough daylight becomes available and continuously dimmed as enough daylight becomes available.
 - b. Load to be turned off when available daylight is sufficient to fully dim the load, after the selected time delay.

- c. Control Capability: Capable of controlling up to three separately programmable channels, with up to 50 ballasts per channel.
 - d. Dimming and Fade Rates: Adjustable from 5 to 60 seconds.
 - e. Cut-Off Delay: Selectable and adjustable from 0 to 20 minutes.
 - f. Output Voltage: Compatible with specified dimming ballasts.
- R. Daylighting Control Dimming Modules for Wireless Sensors:
- 1. Description: Plenum rated control unit compatible with specified wireless photo sensors and with specified dimming ballasts, for continuous dimming of compatible dimming ballasts in response to changes in measured light levels according to selected settings.
 - 2. Operation: Unless otherwise indicated, specified load to be continuously brightened as not enough daylight becomes available and continuously dimmed as enough daylight becomes available.
 - 3. Load to be turned off when available daylight is sufficient to fully dim the load, after the selected time delay.
 - 4. Control Capability: Capable of controlling up to 32 ballasts with up to two separately programmable daylighting zones.
 - 5. Power Packs for Low Voltage Daylighting Control Modules:
 - a. Description: Plenum rated, self-contained low voltage class 2 transformer and relay compatible with specified low voltage daylighting control modules for switching of line voltage loads. Provide quantity and configuration of power and slave packs with all associated wiring and accessories as required to control the load indicated on drawings.
 - b. Input Supply Voltage: Dual rated for 120/277 V ac.
 - 6. Load Ratings: As required to control the load indicated on drawings.
 - 7. Accessories:
 - a. Where indicated, provide compatible accessory wall switches for manual override control.
 - 8. Where indicated, provide compatible accessory wireless controls for manual override control.
- S. LIGHTING CONTACTORS
- 1. Manufacturers:
 - a. ABB/GE: www.geindustrial.com/#sle.
 - b. Eaton Corporation: www.eaton.com/#sle.
 - c. Rockwell Automation Inc; Allen-Bradley Products: ab.rockwellautomation.com/#sle.
 - d. Schneider Electric; Square D Products: www.schneider-electric.us/#sle.
 - e. Siemens Industry, Inc: www.usa.siemens.com/#sle.
 - f. Or approved equal.
 - g. Substitutions: See Section 01 60 00 - Product Requirements.
 - 2. Description: Magnetic lighting contactors complying with NEMA ICS 2, and listed and labeled as complying with UL 60947-1 and UL 60947-4-1; noncombination type unless otherwise indicated; ratings, configurations and features as indicated on the drawings.

3. Combination Contactors: NEMA ICS 2, Class A combination controllers with magnetic contactor(s) and externally operable disconnect.
 - a. Disconnects: Circuit breaker or disconnect switch type as indicated.
 - 1) Disconnect Switches: Fusible or nonfusible type as indicated.
 - 2) Provide externally operable handle with means for locking in the OFF position. Provide safety interlock to prevent opening the cover with the disconnect in the ON position with capability of overriding interlock for testing purposes.
 - 3) Provide auxiliary interlock for disconnection of external control power sources where applicable.
 4. Short Circuit Current Rating:
 - a. Provide contactors with listed short circuit current rating not less than the available fault current at the installed location as determined by short circuit study performed in accordance with Section 26 05 73.
 5. Enclosures:
 - a. Comply with NEMA ICS 6.
 - b. Environment Type per NEMA 250: Unless otherwise indicated, as specified for the following installation locations:
 - 1) Indoor Clean, Dry Locations: Type 1 or Type 12.
 - 2) Outdoor Locations: Type 3R or Type 4.
 - c. Finish: Manufacturer's standard unless otherwise indicated.
- T. ACCESSORIES
1. Auxiliary Contacts:
 - a. Comply with NEMA ICS 5.
 - b. Provide number and type of contacts indicated or required to perform necessary functions, including holding (seal-in) circuit and interlocking, plus one normally open (NO) and one normally closed (NC) spare contact for each lighting contactor, minimum.
 2. Pilot Devices:
 - a. Comply with NEMA ICS 5; heavy-duty type.
 - b. Nominal Size: 30 mm.
 - c. Pushbuttons: Unless otherwise indicated, provide momentary, non-illuminated type with flush button operator; normally open or normally closed as indicated or as required.
 - d. Selector Switches: Unless otherwise indicated, provide maintained, non-illuminated type with knob operator; number of switch positions as indicated or as required.
 - e. Indicating Lights: Push-to-test type unless otherwise indicated.
 - f. Provide LED lamp source for indicating lights and illuminated devices.
 3. Control and Timing Relays:
 - a. Comply with NEMA ICS 5.
 - b. Provide number and type of relays indicated or required to perform necessary functions.
 - c. Timing Relays: Electronic or pneumatic as indicated.
 - 1) Adjustable Timing Range: As indicated on drawings.

4. Fire-Rated Device Enclosures:
 - a. Manufacturers:
 - 1) Fire Rated Product Specialties Corp: www.frpsonline.com/#sle.
 - 2) Or approved equal.
 - 3) Substitutions: See Section 01 60 00 - Product Requirements.
 - b. Provide as required to preserve fire resistance rating of building elements.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that field measurements are as indicated.
- B. Verify that outlet boxes are installed in proper locations and at proper mounting heights and are properly sized to accommodate devices and conductors in accordance with CEC 2007.
- C. Verify that openings for outlet boxes are neatly cut and will be completely covered by devices or wall plates.
- D. Verify that final surface finishes are complete, including painting.
- E. Verify that branch circuit wiring installation is completed, tested, and ready for connection to lighting control devices.
- F. Verify that the service voltage and ratings of lighting control devices are appropriate for the service voltage and load requirements at the location to be installed.
- G. Verify that conditions are satisfactory for installation prior to starting work.

3.02 PREPARATION

- A. Provide extension rings to bring outlet boxes flush with finished surface.
- B. Clean dirt, debris, plaster, and other foreign materials from outlet boxes.

3.03 INSTALLATION

- A. Install lighting control devices in accordance with NECA 1 (general workmanship) and, where applicable, NECA 130, including mounting heights specified in those standards unless otherwise indicated.
- B. Perform work in a neat and workmanlike manner in accordance with NECA 1, including mounting heights specified in that standard unless otherwise indicated.
- C. Coordinate locations of outlet boxes provided under Section 26 05 33.16 as required for installation of lighting control devices provided under this section.
 1. Orient outlet boxes for vertical installation of lighting control devices unless otherwise indicated.
 2. Locate wall switch occupancy sensors on strike side of door with edge of wall plate 3 inches from edge of door frame. Where locations are indicated otherwise, notify Architect and/or Owner's Representative to obtain direction prior to proceeding with work.
- D. Install lighting control devices in accordance with manufacturer's instructions.

- E. Unless otherwise indicated, connect lighting control device grounding terminal or conductor to branch circuit equipment grounding conductor and to outlet box with bonding jumper.
- F. Install lighting control devices plumb and level, and held securely in place.
- G. Where required and not furnished with lighting control device, provide wall plate in accordance with Section 26 27 26.
- H. Provide required supports in accordance with Section 26 05 29.
- I. Where applicable, install lighting control devices and associated wall plates to fit completely flush to mounting surface with no gaps and rough opening completely covered without strain on wall plate. Repair or reinstall improperly installed outlet boxes or improperly sized rough openings. Do not use oversized wall plates in lieu of meeting this requirement.
- J. Identify lighting control devices in accordance with Section 26 05 53.
- K. Occupancy Sensor Locations:
 - 1. Location Adjustments: Locations indicated are diagrammatic and only intended to indicate which rooms or areas require devices. Provide quantity and locations as required for complete coverage of respective room or area based on manufacturer's recommendations for installed devices.
 - 2. Locate ultrasonic and dual technology passive infrared/ultrasonic occupancy sensors a minimum of 4 feet from air supply ducts or other sources of heavy air flow and as per manufacturer's recommendations, in order to minimize false triggers.
- L. Outdoor Photo Control Locations:
 - 1. Where possible, locate outdoor photo controls with photo sensor facing north. If north facing photo sensor is not possible, install with photo sensor facing east, west, or down.
 - 2. Locate outdoor photo controls so that photo sensors do not face artificial light sources, including light sources controlled by the photo control itself.
- M. Install outdoor photo controls so that connections are weatherproof. Do not install photo controls with conduit stem facing up in order to prevent infiltration of water into the photo control.
- N. Daylighting Control Photo Sensor Locations:
 - 1. Location Adjustments: Locations indicated are diagrammatic and only intended to indicate which rooms or areas require devices. Provide quantity and locations as required for proper control of respective room or area based on manufacturer's recommendations for installed devices.
 - 2. Unless otherwise indicated, locate photo sensors for closed loop systems to accurately measure the light level controlled at the designated task location, while minimizing the measured amount of direct light from natural or artificial sources such as windows or pendant luminaires.
 - 3. Unless otherwise indicated, locate photo sensors for open loop systems to accurately measure the level of daylight coming into the space, while minimizing the measured amount of lighting from artificial sources.

- O. Combination Enclosed Lighting Contactors:
 - 1. Except where indicated to be mounted adjacent to the equipment they supply, mount lighting contactors such that the highest position of the operating handle does not exceed 79 inches above the floor or working platform.
 - 2. Provide fuses complying with Section 26 28 13 for fusible switches as indicated.
- P. Lamp Burn-In: Operate lamps at full output for minimum of 100 hours or prescribed period per manufacturer's recommendations prior to use with any dimming controls. Replace lamps that fail prematurely due to improper lamp burn-in.
- Q. Unless otherwise indicated, install power packs for lighting control devices above accessible ceiling or above access panel in inaccessible ceiling near the sensor location.
- R. Where indicated, install separate compatible wall switches for manual control interface with lighting control devices or associated power packs.
- S. Unless otherwise indicated, install switches on load side of power packs so that switch does not turn off power pack.
- T. Where indicated or required, provide cabinet or enclosure in accordance with Section 26 05 33.16 for mounting of lighting control device system components.
- U. Where indicated or required, provide cabinet or enclosure in accordance with Section 26 27 16 for mounting of lighting control device system components.

3.04 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements, for additional requirements.
- B. Inspect each lighting control device for damage and defects.
- C. Test occupancy sensors to verify proper operation, including time delays and ambient light thresholds where applicable. Verify optimal coverage for entire room or area. Record test results in written report to be included with submittals.
- D. Test time switches to verify proper operation.
- E. Test outdoor photo controls to verify proper operation, including time delays where applicable.
- F. Test daylighting controls to verify proper operation, including light level measurements and time delays where applicable. Record test results in written report to be included with submittals.
- G. Correct wiring deficiencies and replace damaged or defective lighting control devices.

3.05 ADJUSTING

- A. Adjust devices and wall plates to be flush and level.
- B. Adjust occupancy sensor settings to minimize undesired activations while optimizing energy savings, and to achieve desired function as indicated or as directed by manufacturer.
- C. Adjust position of directional occupancy sensors and outdoor motion sensors to achieve optimal coverage as required.

- D. Where indicated or as directed by Architect, install factory masking material or adjust integral blinders on passive infrared (PIR) and dual technology occupancy sensor lenses to block undesired motion detection.
- E. Adjust time switch settings to achieve desired operation schedule as indicated or as directed by Owner's Representative.. Record settings in written report to be included with submittals.
- F. Adjust external sliding shields on outdoor photo controls under optimum lighting conditions to achieve desired turn-on and turn-off activation as indicated or as directed by LP Consulting Engineers, Inc..
- G. Adjust daylighting controls under optimum lighting conditions after all room finishes, furniture, and window treatments have been installed to achieve desired operation as indicated or as directed by Architect. Record settings in written report to be included with submittals. Readjust controls calibrated prior to installation of final room finishes, furniture, and window treatments that do not function properly as determined by Ownere's Representative.

3.06 CLEANING

- A. Clean exposed surfaces to remove dirt, paint, or other foreign material and restore to match original factory finish.

3.07 COMMISSIONING

- A. See Section 01 91 13 - General Commissioning Requirements for commissioning requirements.

3.08 CLOSEOUT ACTIVITIES

- A. See Section 01 78 00 - Closeout Submittals, for closeout submittals.
- B. See Section 01 79 00 - Demonstration and Training, for additional requirements.
- C. Demonstration: Demonstrate proper operation of lighting control devices to District Representative, and correct deficiencies or make adjustments as directed.
- D. Training: Train Owner's (Owner's) personnel on operation, adjustment, programming, and maintenance of lighting control devices.
 - 1. Use operation and maintenance manual as training reference, supplemented with additional training materials as required.
 - 2. Provide minimum of two hours of training.
 - 3. Instructor: Qualified contractor familiar with the project and with sufficient knowledge of the installed lighting control devices.
 - 4. Location: At project site.

END OF SECTION 26 09 23

SECTION 26 24 13 SWITCHBOARDS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Switchboards and Distribution Panel.
- B. Overcurrent protective devices for switchboards.
- C. Switchboard and Distribution Panel accessories.

1.02 RELATED REQUIREMENTS

- A. Section 03 30 00 - Cast-in-Place Concrete: Concrete equipment pads.
- B. Section 26 05 26 - Grounding and Bonding for Electrical Systems.
- C. Section 26 05 29 - Hangers and Supports for Electrical Systems.
- D. Section 26 05 48 - Vibration and Seismic Controls for Electrical Systems.
 - 1. Includes requirements for the seismic qualification of equipment specified in this section.
- E. Section 26 05 53 - Identification for Electrical Systems: Identification products and requirements.
- F. Section 26 05 73 - Power System Studies: Additional criteria for the selection and adjustment of equipment and associated protective devices specified in this section.
- G. Section 26 21 00 - Low-Voltage Electrical Service Entrance.
 - 1. Includes Utility Company contact information.
- H. Section 26 25 13 - Low-Voltage Busways.
- I. Section 26 28 13 - Fuses: Fuses for fusible switches.
 - 1. Includes requirements for spare fuses and spare fuse cabinets.
- J. Section 26 43 00 - Surge Protective Devices.

1.03 REFERENCE STANDARDS

- A. FS W-C-375 - Circuit Breakers, Molded Case; Branch Circuit and Service; 2013e, with Amendments (2022).

~~~~~ **PROJECT NOTE** ~~~~~

OBSOLETE. See IEC 60051, Parts 1 and 2.

~~~~~ **END OF PROJECT NOTE** ~~~~~

- B. ANSI C39.1 - American National Standard Requirements for Electrical Analog Indicating Instruments; 1981 (R1992).

~~~~~ **PROJECT NOTE** ~~~~~

Obsolete document - see ANSI C12.1.

~~~ **END OF PROJECT NOTE** ~~~~

- C. IEEE C12.1 - American National Standard Code for Electricity Metering; Institute of Electrical and Electronic Engineers; 1988.
- D. IEEE C57.13 - IEEE Standard Requirements for Instrument Transformers; 2016.
- E. NECA 1 - Standard for Good Workmanship in Electrical Construction; 2015.
- F. NECA 400 - Standard for Installing and Maintaining Switchboards; 2007.
- G. NEMA 250 - Enclosures for Electrical Equipment (1000 Volts Maximum); 2020.
- H. NEMA KS 1 - Heavy Duty Enclosed and Dead-Front Switches (600 Volts Maximum); 2013.
- I. NEMA PB 2 - Deadfront Distribution Switchboards; 2011.
- J. NEMA PB 2.1 - General Instructions for Proper Handling, Installation, Operation, and Maintenance of Deadfront Distribution Switchboards Rated 1000 Volts or Less; 2023.
- K. NETA ATS - Standard For Acceptance Testing Specifications For Electrical Power Equipment And Systems; 2021.
- L. NFPA 70 - National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- M. UL 489 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit Breaker Enclosures; Current Edition, Including All Revisions.
- N. UL 891 - Switchboards; Current Edition, Including All Revisions.
- O. UL 1053 - Ground-Fault Sensing and Relaying Equipment; Current Edition, Including All Revisions.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Coordinate the work with other trades to avoid placement of ductwork, piping, equipment, or other potential obstructions within the dedicated equipment spaces and working clearances required by NFPA 70.
 - 2. Coordinate arrangement of electrical equipment with the dimensions and clearance requirements of the actual equipment to be installed.
 - 3. Verify with manufacturer that conductor terminations are suitable for use with the conductors to be installed.
 - 4. Coordinate with manufacturer to provide shipping splits suitable for the dimensional constraints of the installation.
 - 5. Notify LP Consulting Engineers, Inc. of any conflicts with or deviations from Contract Documents. Obtain direction before proceeding with work.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.

- B. Product Data: Provide manufacturer's standard catalog pages and data sheets for switchboards, enclosures, overcurrent protective devices, and other installed components and accessories.
- C. Shop Drawings: Indicate dimensions, voltage, bus ampacities, overcurrent protective device arrangement and sizes, short circuit current ratings, conduit entry locations, conductor terminal information, and installed features and accessories.
- D. Manufacturer's equipment seismic qualification certification.
- E. Project Record Documents: Record actual installed locations of switchboards and final equipment settings.
- F. Maintenance Materials: Furnish the following for Owner's use in maintenance of project.
 - 1. See Section 01 60 00 - Product Requirements, for additional provisions.
 - 2. Enclosure Keys: Two of each different key.
 - 3. Electronic Trip Circuit Breakers: Provide one portable test set.

1.06 QUALITY ASSURANCE

- A. Conform to requirements of CEC.
- B. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum five years documented experience.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Receive, inspect, handle, and store switchboards in accordance with manufacturer's instructions, NECA 400, and NEMA PB 2.1.
- B. Store in a clean, dry space having a uniform temperature to prevent condensation (including outdoor switchboards, which are not weatherproof until completely and properly installed). Where necessary, provide temporary enclosure space heaters or temporary power for permanent factory-installed space heaters.
- C. Maintain factory wrapping or provide an additional heavy canvas or heavy plastic cover to protect units from dirt, water, construction debris, and traffic.
- D. Handle carefully to avoid damage to switchboard internal components, enclosure, and finish.

1.08 FIELD CONDITIONS

- A. Maintain field conditions within required service conditions during and after installation.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Switchboards:
 - 1. ABB: www.electrification.us.abb.com/#sle.
 - 2. Eaton Corporation: www.eaton.com/#sle.

3. Schneider Electric: www.se.com/#sle.
4. Siemens Industry, Inc: www.new.siemens.com/#sle.
5. Substitutions: See Section 01 60 00 - Product Requirements.
6. Source Limitations: Provide switchboards and associated components produced by same manufacturer as other electrical distribution equipment used for project and obtained from single supplier.

2.02 DISTRIBUTION PANEL

- A. Provide switchboards consisting of all required components, control power transformers, instrumentation and control wiring, accessories, etc. as necessary for a complete operating system.
- B. Provide products listed, classified, and labeled as suitable for the purpose intended.
- C. Description: Dead-front switchboard assemblies complying with NEMA PB 2, and listed and labeled as complying with UL 891; ratings, configurations and features as indicated on the drawings.
- D. Front-Connected Switchboards:
 1. Main Device(s): Individually-mounted.
 2. Feeder Devices: Panel/group-mounted.
 3. Arrangement: Front accessible only (not rear accessible), rear aligned.
 4. Gutter Access: Bolted covers.
- E. Rear-Connected Switchboards:
 1. Main Device(s): Individually-mounted.
 2. Feeder Devices: Individually-mounted.
 3. Compartmentalization: Provide barriered compartments for each overcurrent protective device, distribution bus, and rear cable connection area.
 4. Arrangement: Rear accessible, front and rear aligned.
 5. Rear Access: Bolted covers.
- F. Switchboards With Busway Transitions: Configured for bussted connection to busway provided in accordance with Section 26 25 13.
- G. Service Conditions:
 1. Provide switchboards and associated components suitable for operation under the following service conditions without derating:
 - a. Altitude: Less than 6,600 feet.
 - b. Ambient Temperature:
 - 1) Switchboards Containing Molded Case or Insulated Case Circuit Breakers: Between 23 degrees F and 104 degrees F.
 - 2) Switchboards Containing Fusible Switches: Between -22 degrees F and 104 degrees F.
 2. Provide switchboards and associated components suitable for operation at indicated ratings under the service conditions at the installed location.
- H. Short Circuit Current Rating:
 1. Provide switchboards with listed short circuit current rating not less than the available fault current at the installed location as determined by short circuit

study performed in accordance with Section 26 05 73.

2. Minimum Rating: 65,000 rms symmetrical amperes.
3. Listed series ratings are not acceptable.
- I. Selectivity: Where the requirement for selectivity is indicated, furnish products as required to achieve selective coordination.
- J. Main Devices: Configure for top or bottom incoming feed as indicated or as required for the installation. Provide separate pull section and/or top-mounted pullbox as indicated or as required to facilitate installation of incoming feed.
- K. Bussing: Sized in accordance with UL 891 temperature rise requirements.
 1. Through bus (horizontal cross bus) to be fully rated through full length of switchboard (non-tapered). Tapered bus is not permitted.
 2. Provide fully rated neutral bus unless otherwise indicated, with a suitable lug for each feeder or branch circuit requiring a neutral connection.
 3. Provide solidly bonded equipment ground bus through full length of switchboard, with a suitable lug for each feeder and branch circuit equipment grounding conductor.
 4. Phase and Neutral Bus Material: Copper.
 5. Ground Bus Material: Copper.
- L. Conductor Terminations: Suitable for use with the conductors to be installed.
 1. Line Conductor Terminations:
 - a. Main and Neutral Lug Material: Aluminum, suitable for terminating aluminum or copper conductors.
 - b. Main and Neutral Lug Type: Mechanical.
 2. Load Conductor Terminations:
 - a. Lug Material: Aluminum, suitable for terminating aluminum or copper conductors.
 - b. Lug Type:
 - 1) Provide mechanical lugs.
- M. Enclosures:
 1. Environment Type per NEMA 250: Unless otherwise indicated, as specified for the following installation locations:
 - a. Indoor Clean, Dry Locations: Type 1 or Type 2 (drip-proof).
 - b. Outdoor Locations: Type 3R.
 2. Finish: Manufacturer's standard unless otherwise indicated.
 3. Outdoor Enclosures:
 - a. Enclosure Type: Non-walk-in type unless otherwise indicated.
 - b. Color: Manufacturer's standard.
 - c. Access Doors: Lockable, with all locks keyed alike.
- N. Future Provisions:
 1. Prepare designated spaces for future installation of devices including bussing, connectors, mounting hardware and all other required provisions.
 2. Equip distribution sections with full height vertical bussing to accommodate maximum utilization of space for devices.

3. Where designated spaces for future device provisions are not indicated, include provisions for minimum of 4 device(s) rated at 225 amperes.
 4. Arrange and equip through bus and ground bus to accommodate future installation of additional switchboard sections.
- O. Surge Protective Devices: Where factory-installed, internally mounted surge protective devices are provided in accordance with Section 26 43 00, list switchboards as a complete assembly including surge protective device.
- P. Ground Fault Protection: Where ground-fault protection is indicated, provide system listed and labeled as complying with UL 1053.
1. Where overcurrent protective devices equipped with integral ground fault protection are used, provide separate neutral current sensor where applicable.
 2. Where accessory ground fault sensing and relaying equipment is used, equip companion overcurrent protective devices with ground-fault shunt trips.
 - a. Provide test panel and field-adjustable ground fault pick-up and delay settings.
- Q. Arc Flash Energy-Reducing Maintenance Switching: For circuit breakers rated 1200 A or higher, provide a local accessory switch with status indicator light that permits selection of a maintenance mode with alternate electronic trip unit settings for reduced fault clearing time.
- R. Owner Metering:
1. Provide microprocessor-based digital electrical metering system including all instrument transformers, wiring, and connections necessary for measurements specified.
 2. Measured Parameters:
 - a. Voltage (Volts AC): Line-to-line, line-to-neutral for each phase.
 - b. Current (Amps): For each phase and neutral.
 - c. Frequency (Hz).
 - d. Real power (kW): For each phase, 3-phase total.
 - e. Reactive power (kVAR): For each phase, 3-phase total.
 - f. Apparent power (kVA): For each phase, 3-phase total.
 - g. Power factor.
 3. Meter Accuracy: Plus/minus 1.0 percent.
- S. Description: NEMA PB 2 switchboard with electrical ratings and configurations as indicated on plans.

2.03 OVERCURRENT PROTECTIVE DEVICES

- A. Circuit Breakers:
1. Interrupting Capacity:
 - a. Provide circuit breakers with interrupting capacity as required to provide the short circuit current rating indicated, but not less than specified minimum requirements.
 - b. Provide fully rated systems. Provide circuit breakers with interrupting capacity not less than the short circuit current rating indicated.
 - c. Series Rated Systems are not acceptable.

2. **Molded Case Circuit Breakers:**
 - a. Description: Quick-make, quick-break, over center toggle, trip-free, trip-indicating circuit breakers; listed and labeled as complying with UL 489, and complying with FS W-C-375 where applicable; ratings, configurations, and features as indicated on the drawings.
 - b. Thermal Magnetic Circuit Breakers: For each pole, furnish thermal inverse time tripping element for overload protection and magnetic instantaneous tripping element for short circuit protection.
 - c. Electronic Trip Circuit Breakers: Furnish solid state, microprocessor-based, true rms sensing trip units.
 - 1) Provide the following field-adjustable trip response settings:
 - (a) Long time pickup, adjustable by replacing interchangeable trip unit or by setting dial.
 - (b) Long time delay.
 - (c) Short time pickup and delay.
 - (d) Instantaneous pickup.
 - (e) Ground fault pickup and delay where ground fault protection is indicated.
 - d. Provide the following features and accessories where indicated or where required to complete installation:
 - 1) Shunt Trip: Provide coil voltage as required for connection to indicated trip actuator.
 - 2) Pad-Lock Provision: For locking circuit breaker handle in OFF position.
3. **Insulated Case Circuit Breakers:**
 - a. Description: Quick-make, quick-break, trip-free circuit breakers with two-step stored energy closing mechanism; standard 80 percent rated unless otherwise indicated; listed and labeled as complying with UL 489; ratings, configurations, and features as indicated on the drawings.
 - b. Construction:
 - 1) Provide fixed-mount circuit breakers unless otherwise indicated.
 - c. Trip Units: Solid state, microprocessor-based, true rms sensing.
 - 1) Provide the following field-adjustable trip response settings:
 - (a) Long time pickup, adjustable by replacing interchangeable trip unit or by setting dial.
 - (b) Long time delay.
 - (c) Short time pickup and delay.
 - (d) Instantaneous pickup.
 - (e) Ground fault pickup and delay where ground fault protection is indicated.
 - d. Provide the following features and accessories where indicated or where required to complete installation:
 - 1) Shunt Trip: Provide coil voltage as required for connection to indicated trip actuator.

2.04 SOURCE QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements, for additional requirements.
- B. Factory test switchboards according to NEMA PB 2, including the following production (routine) tests on each switchboard assembly or component:
 - 1. Dielectric tests.
 - 2. Mechanical operation tests.
 - 3. Grounding of instrument transformer cases test.
 - 4. Electrical operation and control wiring tests, including polarity and sequence tests.
 - 5. Ground-fault sensing equipment test.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that field measurements are as indicated.
- B. Verify that the ratings and configurations of the switchboards and associated components are consistent with the indicated requirements.
- C. Verify that mounting surfaces are ready to receive switchboards.
- D. Verify that conditions are satisfactory for installation prior to starting work.

3.02 INSTALLATION

- A. Install products in accordance with manufacturer's instructions.
- B. Install switchboards in accordance with NECA 1 (general workmanship), NECA 400, and NEMA PB 2.1.
- C. Arrange equipment to provide required clearances and maintenance access, including accommodations for any drawout devices.
- D. Where switchboard is indicated to be mounted with inaccessible side against wall, provide minimum clearance of 1/2 inch between switchboard and wall.
- E. Provide required support and attachment in accordance with Section 26 05 29.
- F. Install switchboards plumb and level.
- G. Unless otherwise indicated, mount switchboards on properly sized 4 inch high concrete pad constructed in accordance with Section 03 30 00.
- H. Provide grounding and bonding in accordance with Section 26 05 26.
- I. Install all field-installed devices, components, and accessories.
- J. Where accessories are not self-powered, provide control power source as indicated or as required to complete installation.
- K. Set field-adjustable circuit breaker tripping function settings as determined by overcurrent protective device coordination study performed in accordance with Section 26 05 73.

- L. Set field-adjustable ground fault protection pickup and time delay settings as indicated.
- M. Provide filler plates to cover unused spaces in switchboards.
- N. Identify switchboards in accordance with Section 26 05 53.

3.03 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements, for additional requirements.
- B. Disconnect surge protective devices (SPDs) prior to performing any high potential testing. Replace SPDs damaged by performing high potential testing with SPDs connected.
- C. Before energizing switchboard, perform insulation resistance testing in accordance with NECA 400 and NEMA PB 2.1.
- D. Inspect and test in accordance with NETA ATS, except Section 4.
- E. Perform inspections and tests listed in NETA ATS, Section 7.1.
- F. Molded Case and Insulated Case Circuit Breakers: Perform inspections and tests listed in NETA ATS, Section 7.6.1.1 for all main circuit breakers and circuit breakers larger than 100 amperes. Tests listed as optional are not required.
- G. Ground Fault Protection Systems: Test in accordance with manufacturer's instructions as required by NFPA 70.
 - 1. Perform inspections and tests listed in NETA ATS, Section 7.14. The insulation-resistance test on control wiring listed as optional is not required.
- H. Meters: Perform inspections and tests listed in NETA ATS, Section 7.11.2.
- I. Test shunt trips to verify proper operation.
- J. Correct deficiencies and replace damaged or defective switchboards or associated components.

3.04 ADJUSTING

- A. Adjust tightness of mechanical and electrical connections to manufacturer's recommended torque settings.
- B. Adjust alignment of switchboard covers and doors.

3.05 CLEANING

- A. Clean dirt and debris from switchboard enclosures and components according to manufacturer's instructions.
- B. Repair scratched or marred surfaces to match original factory finish.

3.06 CLOSEOUT ACTIVITIES

- A. See Section 01 78 00 - Closeout Submittals, for closeout submittals.
- B. See Section 01 79 00 - Demonstration and Training, for additional requirements.
- C. Training: Train Owner's personnel on operation, adjustment, and maintenance of switchboard and associated devices.

1. Use operation and maintenance manual as training reference, supplemented with additional training materials as required.
2. Provide minimum of two hours of training.
3. Instructor: Manufacturer's authorized representative.
4. Location: At project site.

3.07 PROTECTION

- A. Protect installed switchboards from subsequent construction operations.

END OF SECTION 26 24 13

SECTION 26 24 16 PANELBOARDS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Power distribution panelboards.
- B. Lighting and appliance panelboards.
- C. Load centers.
- D. Overcurrent protective devices for panelboards.

1.02 RELATED REQUIREMENTS

- A. Section 03 30 00 - Cast-in-Place Concrete: Concrete equipment pads.
- B. Section 26 05 26 - Grounding and Bonding for Electrical Systems.
- C. Section 26 05 29 - Hangers and Supports for Electrical Systems.
- D. Section 26 05 48 - Vibration and Seismic Controls for Electrical Systems.
 - 1. Includes requirements for the seismic qualification of equipment specified in this section.
- E. Section 26 05 53 - Identification for Electrical Systems: Identification products and requirements.
- F. Section 26 05 73 - Power System Studies: Additional criteria for the selection and adjustment of equipment and associated protective devices specified in this section.
- G. Section 26 22 00 - Low-Voltage Transformers: Small power centers with integral primary breaker, transformer, and panelboard.
- H. Section 26 28 13 - Fuses: Fuses for fusible switches and spare fuse cabinets.
- I. Section 26 43 00 - Surge Protective Devices.

1.03 REFERENCE STANDARDS

- A. FS W-C-375 - Circuit Breakers, Molded Case; Branch Circuit and Service; 2013e, with Amendments (2022).
- B. NECA 1 - Standard for Good Workmanship in Electrical Construction; 2015.
- C. NECA 407 - Standard for Installing and Maintaining Panelboards; 2015.
- D. NEMA 250 - Enclosures for Electrical Equipment (1000 Volts Maximum); 2020.
- E. NEMA ICS 2 - Industrial Control and Systems Controllers, Contactors and Overload Relays Rated 600 Volts; 2008 (Reaffirmed 2020).
- F. NEMA PB 1 - Panelboards; 2011.
- G. NEMA PB 1.1 - General Instructions for Proper Installation, Operation and Maintenance of Panelboards Rated 1000 Volts or Less; 2023.

- H. NETA ATS - Standard For Acceptance Testing Specifications For Electrical Power Equipment And Systems; 2021.
- I. NFPA 70 - National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- J. UL 50 - Enclosures for Electrical Equipment, Non-Environmental Considerations; Current Edition, Including All Revisions.
- K. UL 50E - Enclosures for Electrical Equipment, Environmental Considerations; Current Edition, Including All Revisions.
- L. UL 67 - Panelboards; Current Edition, Including All Revisions.
- M. UL 489 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit Breaker Enclosures; Current Edition, Including All Revisions.
- N. UL 869A - Reference Standard for Service Equipment; Current Edition, Including All Revisions.
- O. UL 943 - Ground-Fault Circuit-Interrupters; Current Edition, Including All Revisions.
- P. UL 1053 - Ground-Fault Sensing and Relaying Equipment; Current Edition, Including All Revisions.
- Q. UL 1699 - Arc-Fault Circuit-Interrupters; Current Edition, Including All Revisions.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Coordinate the work with other trades to avoid placement of ductwork, piping, equipment, or other potential obstructions within the dedicated equipment spaces and working clearances for electrical equipment required by NFPA 70.
 - 2. Coordinate arrangement of electrical equipment with the dimensions and clearance requirements of the actual equipment to be installed.
 - 3. Coordinate the work with other trades to provide walls suitable for installation of flush-mounted panelboards where indicated.
 - 4. Verify with manufacturer that conductor terminations are suitable for use with the conductors to be installed.
 - 5. Notify LP Consulting Engineers, Inc. of any conflicts with or deviations from Contract Documents. Obtain direction before proceeding with work.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide manufacturer's standard catalog pages and data sheets for panelboards, enclosures, overcurrent protective devices, and other installed components and accessories.
 - 1. Include characteristic trip curves for each type and rating of overcurrent protective device upon request.
- C. Shop Drawings: Indicate outline and support point dimensions, voltage, main bus ampacity, overcurrent protective device arrangement and sizes, short circuit current ratings, conduit entry locations, conductor terminal information, and installed

features and accessories.

1. Include dimensioned plan and elevation views of panelboards and adjacent equipment with all required clearances indicated.
 2. Include wiring diagrams showing all factory and field connections.
 3. Clearly indicate whether proposed short circuit current ratings are fully rated or, where acceptable, series rated systems.
 4. Identify mounting conditions required for equipment seismic qualification.
- D. Manufacturer's equipment seismic qualification certification.
- E. Source Quality Control Test Reports: Include reports for tests designated in NEMA PB 1 as routine tests.
- F. Field Quality Control Test Reports.
- G. Manufacturer's Installation Instructions: Indicate application conditions and limitations of use stipulated by product testing agency. Include instructions for storage, handling, protection, examination, preparation, and installation of product.
- H. Project Record Documents: Record actual installed locations of panelboards and actual installed circuiting arrangements.
- I. Maintenance Data: Include information on replacement parts and recommended maintenance procedures and intervals.
- J. Maintenance Materials: Furnish the following for Owner's (Owner's) use in maintenance of project.
1. See Section 01 60 00 - Product Requirements, for additional provisions.
 2. Panelboard Keys: Two of each different key.
 3. See Section 26 28 13 for requirements for spare fuses and spare fuse cabinets.

1.06 QUALITY ASSURANCE

- A. Conform to requirements of CEC.
- B. Maintain at the project site a copy of each referenced document that prescribes execution requirements.
- C. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum five years documented experience.
- D. Product Listing Organization Qualifications: An organization recognized by OSHA as a Nationally Recognized Testing Laboratory (NRTL) and acceptable to authorities having jurisdiction.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Receive, inspect, handle, and store panelboards in accordance with manufacturer's instructions and NECA 407.
- B. Store in a clean, dry space. Maintain factory wrapping or provide an additional heavy canvas or heavy plastic cover to protect units from dirt, water, construction debris, and traffic.
- C. Handle carefully in accordance with manufacturer's written instructions to avoid damage to panelboard internal components, enclosure, and finish.

1.08 FIELD CONDITIONS

- A. Maintain ambient temperature within the following limits during and after installation of panelboards:
 - 1. Panelboards Containing Circuit Breakers: Between 23 degrees F and 104 degrees F.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. ABB: www.electrification.us.abb.com/#sle.
- B. Eaton Corporation: www.eaton.com/#sle.
- C. Schneider Electric; Square D Products
- D. Siemens Industry, Inc: www.usa.siemens.com/#sle.
- E. Substitutions: See Section 01 60 00 - Product Requirements.
- F. Source Limitations: Furnish panelboards and associated components produced by the same manufacturer as the other electrical distribution equipment used for this project and obtained from a single supplier.

2.02 PANELBOARDS - GENERAL REQUIREMENTS

- A. Provide products listed, classified, and labeled as suitable for the purpose intended.
- B. Seismic Qualification: Provide panelboards and associated components suitable for application under the seismic design criteria specified in Section 26 05 48 where required. Include certification of compliance with submittals.
- C. Unless otherwise indicated, provide products suitable for continuous operation under the following service conditions:
 - 1. Altitude: Less than 6,600 feet.
 - 2. Ambient Temperature:
 - a. Panelboards Containing Circuit Breakers: Between 23 degrees F and 104 degrees F.
- D. Short Circuit Current Rating:
 - 1. Provide panelboards with listed short circuit current rating not less than the available fault current at the installed location as determined by short circuit study performed in accordance with Section 26 05 73.
 - 2. Listed series ratings are not acceptable, except where pre-approved by the Owner and LP Consulting Engineers, Inc.
- E. Panelboards Used for Service Entrance: Listed and labeled as suitable for use as service equipment according to UL 869A.
- F. Mains: Configure for top or bottom incoming feed as indicated or as required for the installation.
- G. Branch Overcurrent Protective Devices: Replaceable without disturbing adjacent devices.

- H. Bussing: Sized in accordance with UL 67 temperature rise requirements.
 - 1. Provide fully rated neutral bus unless otherwise indicated, with a suitable lug for each feeder or branch circuit requiring a neutral connection.
 - 2. Provide 200 percent rated neutral bus and lugs where indicated, where oversized neutral conductors are provided, or where panelboards are fed from K-rated transformers.
 - 3. Provide solidly bonded equipment ground bus in each panelboard, with a suitable lug for each feeder and branch circuit equipment grounding conductor.
 - 4. Provide separate isolated/insulated ground bus where indicated or where isolated grounding conductors are provided.
- I. Conductor Terminations: Suitable for use with the conductors to be installed.
- J. Enclosures: Comply with NEMA 250, and list and label as complying with UL 50 and UL 50E.
 - 1. Environment Type per NEMA 250: Unless otherwise indicated, as specified for the following installation locations:
 - a. Indoor Clean, Dry Locations: Type 1.
 - b. Outdoor Locations: Type 3R.
 - 2. Boxes: Galvanized steel unless otherwise indicated.
 - a. Provide wiring gutters sized to accommodate the conductors to be installed.
 - b. Increase gutter space as required where sub-feed lugs, feed-through lugs, gutter taps, or oversized lugs are provided.
 - c. Provide removable end walls for NEMA Type 1 enclosures.
 - d. Provide painted steel boxes for surface-mounted panelboards where indicated, finish to match fronts.
 - 3. Fronts:
 - a. Fronts for Surface-Mounted Enclosures: Same dimensions as boxes.
 - b. Fronts for Flush-Mounted Enclosures: Overlap boxes on all sides to conceal rough opening.
 - c. Finish for Painted Steel Fronts: Manufacturer's standard grey unless otherwise indicated.
 - 4. Lockable Doors: All locks keyed alike unless otherwise indicated. Provide door-in-door construction.
- K. Future Provisions: Prepare all unused spaces for future installation of devices including bussing, connectors, mounting hardware and all other required provisions.
- L. Surge Protective Devices: Where factory-installed, internally mounted surge protective devices are provided in accordance with Section 26 43 00, list and label panelboards as a complete assembly including surge protective device.
- M. Panelboard Contactors: Where panelboard contactors are indicated, provide electrically operated, mechanically held magnetic contactor complying with NEMA ICS 2.
 - 1. Ampere Rating: Not less than ampere rating of panelboard bus.
 - 2. Short Circuit Current Rating: Not less than the panelboard short circuit current rating.

3. Coil Voltage: As required for connection to control system indicated.
- N. Ground Fault Protection: Where ground-fault protection is indicated, provide system listed and labeled as complying with UL 1053.
 1. Where electronic circuit breakers equipped with integral ground fault protection are used, provide separate neutral current sensor where applicable.
 2. Where accessory ground fault sensing and relaying equipment is used, equip companion overcurrent protective devices with ground-fault shunt trips.
 - a. Use zero sequence ground fault detection method unless otherwise indicated.
 - b. Provide test panel and field-adjustable ground fault pick-up and delay settings.
 - c. Provide zone selective interlocking capability where indicated, capable of communicating with other electronic trip circuit breakers and external ground fault sensing systems to control ground fault delay functions for system coordination purposes.
- O. Selectivity: Where the requirement for selectivity is indicated, furnish products as required to achieve selective coordination.
- P. Multi-Section Panelboards: Provide enclosures of the same height, with feed-through lugs or sub-feed lugs and feeders as indicated or as required to interconnect sections.
- Q. Provide the following features and accessories where indicated or where required to complete installation:
 1. Feed-through lugs.
 2. Sub-feed lugs.

2.03 POWER DISTRIBUTION PANELBOARDS

- A. Description: Panelboards complying with NEMA PB 1, power and feeder distribution type, circuit breaker type, and listed and labeled as complying with UL 67; ratings, configurations and features as indicated on the drawings.
- B. Conductor Terminations:
 1. Main and Neutral Lug Material: Suitable for terminating aluminum or copper conductors.
 2. Main and Neutral Lug Type: Mechanical.
- C. Bussing:
 1. Phase and Neutral Bus Material: Copper.
 2. Ground Bus Material: Copper.
- D. Circuit Breakers:
 1. Provide bolt-on type.
 2. Provide thermal magnetic circuit breakers unless otherwise indicated.
 3. Provide electronic trip circuit breakers where indicated.
- E. Enclosures:
 1. Provide surface-mounted or flush-mounted enclosures unless otherwise indicated.

2. Fronts: Provide trims to cover access to load terminals, wiring gutters, and other live parts, with exposed access to overcurrent protective device handles.
 3. Fronts: Provide lockable hinged door with concealed hinges for access to overcurrent protective device handles without exposing live parts.
 4. Fronts: Provide door-in-door trim with hinged cover for access to load terminals and wiring gutters, and separate lockable hinged door with concealed hinges for access to overcurrent protective device handles without exposing live parts.
 5. Provide clear plastic circuit directory holder mounted on inside of door.
 6. Painted gray over rust inhibiting primer.
- F. Description: NEMA PB 1, circuit breaker type.
- G. Panelboard Bus: Copper, ratings as indicated. Provide copper ground bus in each panelboard.
- H. Minimum integrated short circuit rating: As indicated or as required by the short circuit study.
1. 240 Volt Panelboards: amperes rms symmetrical per plan.
 2. 480 Volt Panelboards: amperes rms symmetrical per plan.
- I. Molded Case Circuit Breakers: With integral thermal and instantaneous magnetic trip in each pole; UL listed. For air conditioning equipment branch circuits provide circuit breakers UL listed as Type HACR.
- J. Controllers: NEMA ICS 2, AC general-purpose Class A magnetic controller for induction motors rated in horsepower, with bimetal overload relay.
1. Coil operating voltage: 120 volts, 60 Hz.
 2. Size as shown on Drawings.
- K. Circuit Breaker Accessories: Trip units and auxiliary switches as indicated.
- L. Enclosure: NEMA PB 1, Type 1, 6 inches deep, 20 inches wide, cabinet box.
- M. Cabinet Front: Surface type, fastened with screws, hinged door with flush lock, metal directory frame, finished in manufacturer's standard gray enamel.
- N. Nameplate: Provide factory nameplate to include the following:
1. Manufacturer.
 2. Order number.
 3. Panelboard Type.
 4. System Voltage.
 5. Bus ampacity.
 6. Short circuit bracing rating.
 7. UL label.
 8. Service entrance label. (if applicable)

2.04 LIGHTING AND APPLIANCE PANELBOARDS

- A. Description: Panelboards complying with NEMA PB 1, lighting and appliance branch circuit type, circuit breaker type, and listed and labeled as complying with UL 67; ratings, configurations and features as indicated on the drawings.
- B. Conductor Terminations:

1. Main and Neutral Lug Material: Suitable for terminating aluminum or copper conductors. .
2. Main and Neutral Lug Type: Mechanical.
- C. Bussing:
 1. Phase Bus Connections: Arranged for sequential phasing of overcurrent protective devices.
 2. Phase and Neutral Bus Material: Copper.
 3. Ground Bus Material: Copper.
- D. Circuit Breakers: Thermal magnetic bolt-on type unless otherwise indicated.
- E. Enclosures:
 1. Provide surface-mounted or flush-mounted enclosures as indicated.
 2. Fronts: Provide lockable hinged door with concealed hinges for access to overcurrent protective device handles without exposing live parts.
 3. Fronts: Provide door-in-door trim with hinged cover for access to load terminals and wiring gutters, and separate lockable hinged door with concealed hinges for access to overcurrent protective device handles without exposing live parts.
 4. Provide clear plastic circuit directory holder mounted on inside of door.
- F. Provide column-width panelboards with accessory column-width cable trough and pullbox where indicated.
- G. Panelboard Bus: Copper, ratings as indicated. Provide copper ground bus in each panelboard ; provide insulated ground bus where scheduled.
- H. Minimum Integrated Short Circuit Rating: As indicated or as required by the short circuit study.
 1. 240 Volt Panelboards: 10,000 amperes rms symmetrical.
 2. 480 Volt Panelboards: 14,000 amperes rms symmetrical.
- I. Molded Case Circuit Breakers: Thermal magnetic trip circuit breakers, bolt-on type, with common trip handle for all poles; UL listed.
 1. Type SWD for lighting circuits.
 2. Type HACR for air conditioning equipment circuits.
 3. Class A ground fault interrupter circuit breakers where scheduled.
 4. Do not use tandem circuit breakers.
- J. Enclosure: NEMA PB 1, Type 1.
- K. Cabinet Box: 6 inches deep, 20 inches wide for 240 volt and less panelboards, 20 inches wide for 480 volt panelboards.
- L. Cabinet Front: Flush cabinet front with concealed trim clamps, concealed hinge, metal directory frame, and flush lock all keyed alike. Finish in manufacturer's standard gray enamel.
- M. Special Features:
 1. Provide blocking clips or lock-off devices on circuit breakers as indicated on the drawings.
 2. Provide barriered space for mounting contactors and control devices with a hinged door and lock, where shown or required.

3. Provide neutral bars with terminal for all active, spare, and inactive circuits.
4. Provide feed-thru lugs or sub-feed lugs for 2 and 3 section panels.
5. Equip bus bars for panelboard with main lugs, main fused switch, or main circuit breaker, capacity as required or as indicated.
6. Provide special features such as split bus, lighting contactors, extra-wide gutters as required or as indicated.
7. Provide panels with individual branch circuit power metering where noted on plans for connections to Facility Energy Management System. Provide Square D type NFMVP, NQMVP or approved equal.

2.05 LOAD CENTERS

- A. Description: Circuit breaker type load centers listed and labeled as complying with UL 67; ratings, configurations, and features as indicated on the drawings.
 1. Load centers are permitted only where called for specifically on the drawings
- B. Bussing:
 1. Phase Bus Connections: Arranged for sequential phasing of overcurrent protective devices.
 2. Bus Material: Copper.
- C. Circuit Breakers: Thermal magnetic plug-in type, quantity and ratings as indicated on drawings..
- D. Enclosures:
 1. Provide flush-mounted enclosures unless otherwise indicated.
 2. Fronts: Provide cover without door to cover access to load terminals, wiring gutters, and other live parts, with exposed access to overcurrent protective device handles.
 3. Fronts: Provide hinged door with concealed hinges for access to overcurrent protective device handles without exposing live parts.
 4. Provide circuit directory label on inside of door or individual circuit labels adjacent to circuit breakers.

2.06 OVERCURRENT PROTECTIVE DEVICES

- A. Molded Case Circuit Breakers:
 1. Description: Quick-make, quick-break, over center toggle, trip-free, trip-indicating circuit breakers listed and labeled as complying with UL 489, and complying with FS W-C-375 where applicable; ratings, configurations, and features as indicated on the drawings.
 2. Interrupting Capacity:
 - a. Provide circuit breakers with interrupting capacity as required to provide the short circuit current rating indicated, but not less than:
 - 1) 10,000 rms symmetrical amperes at 240 VAC or 208 VAC.
 - 2) 14,000 rms symmetrical amperes at 480 VAC.
 - b. Provide fully rated systems. Provide circuit breakers with interrupting capacity not less than the short circuit current rating indicated

- c. Provide fully rated systems. Provide circuit breakers with interrupting capacity not less than the short circuit current rating indicated.
- d. Series Rated Systems are not acceptable.
3. Conductor Terminations:
 - a. Provide mechanical lugs unless otherwise indicated.
 - b. Lug Material: Aluminum, suitable for terminating aluminum or copper conductors.
4. Thermal Magnetic Circuit Breakers: For each pole, furnish thermal inverse time tripping element for overload protection and magnetic instantaneous tripping element for short circuit protection.
5. Electronic Trip Circuit Breakers: Furnish solid state, microprocessor-based, true rms sensing trip units.
 - a. Provide the following field-adjustable trip response settings:
 - 1) Long time pickup, adjustable by setting dial.
 - 2) Long time delay.
 - 3) Short time pickup and delay.
 - 4) Instantaneous pickup.
 - 5) Ground fault pickup and delay where ground fault protection is indicated.
6. Multi-Pole Circuit Breakers: Furnish with common trip for all poles.
7. Provide the following circuit breaker types where indicated:
 - a. Ground Fault Circuit Interrupter (GFCI) Circuit Breakers: Listed as complying with UL 943, class A for protection of personnel.
8. Do not use tandem circuit breakers.
9. Provide multi-pole circuit breakers or circuit breaker handle-ties for multi-wire branch circuits as required by NFPA 70.
10. Provide the following features and accessories where indicated or where required to complete installation:
 - a. Shunt Trip: Provide coil voltage as required for connection to indicated trip actuator.
 - b. Handle Pad-Lock Provision: For locking circuit breaker handle in OFF position.

2.07 SOURCE QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements, for additional requirements.
- B. Factory test panelboards according to NEMA PB 1.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that field measurements are as indicated.
- B. Verify that the ratings and configurations of the panelboards and associated components are consistent with the indicated requirements.
- C. Verify that mounting surfaces are ready to receive panelboards.

- D. Verify that conditions are satisfactory for installation prior to starting work.

3.02 INSTALLATION

- A. Perform work in accordance with NECA 1 (general workmanship).
- B. Install products in accordance with manufacturer's instructions.
- C. Install panelboards in accordance with NECA 407 and NEMA PB 1.1.
- D. Arrange equipment to provide minimum clearances in accordance with manufacturer's instructions and NFPA 70.
- E. Provide required support and attachment in accordance with Section 26 05 29.
- F. Provide required seismic controls in accordance with Section 26 05 48.
- G. Install panelboards plumb and when recessed, flush with wall finishes. Provide all backing for equipment support. Fasten all free-standing equipment to concrete slab. Mounting bolts on floor mounted panels shall extend into pads only and shall not be in direct contact with building structural members.
- H. Install flush-mounted panelboards so that trims fit completely flush to wall with no gaps and rough opening completely covered.
- I. Mount panelboards such that the highest position of any operating handle for circuit breakers or switches does not exceed 6 feet 7 inches above the floor or working platform.
- J. Mount floor-mounted power distribution panelboards on properly sized 3 inch high concrete pad constructed in accordance with Section 03 30 00.
- K. Provide minimum of six spare 1 inch trade size conduits out of each flush-mounted panelboard stubbed into accessible space above ceiling and below floor.
- L. Provide grounding and bonding in accordance with Section 26 05 26.
 - 1. Terminate branch circuit equipment grounding conductors on solidly bonded equipment ground bus only. Do not terminate on isolated/insulated ground bus.
 - 2. Terminate branch circuit isolated grounding conductors on isolated/insulated ground bus only. Do not terminate on solidly bonded equipment ground bus.
- M. Install all field-installed branch devices, components, and accessories.
- N. Where accessories are not self-powered, provide control power source as indicated or as required to complete installation.
- O. Multi-Wire Branch Circuits: Group grounded and ungrounded conductors together in the panelboard as required by NFPA 70.
- P. Set field-adjustable circuit breaker tripping function settings as indicated.
- Q. Set field-adjustable circuit breaker tripping function settings as determined by overcurrent protective device coordination study performed according to Section 26 05 73.
- R. Set field-adjustable ground fault protection pickup and time delay settings as indicated.
- S. Install panelboards in accordance with NEMA PB 1.1 and NECA 1.

- T. Install panelboards plumb. Install recessed panelboards flush with wall finishes.
- U. Height: 6 feet 6 inches to top of panelboard; install panelboards taller than 6 feet with bottom no more than 4 inches above floor.
- V. Provide filler plates to cover unused spaces in panelboards.
- W. Provide circuit breaker lock-on devices to prevent unauthorized personnel from de-energizing essential loads where indicated. Also provide for the following:
 - 1. Emergency and night lighting circuits.
 - 2. Fire detection and alarm circuits.
 - 3. Communications equipment circuits.
 - 4. Intrusion detection and access control system circuits.
 - 5. Video surveillance system circuits.
- X. Identify panelboards in accordance with Section 26 05 53.
- Y. Provide computer-generated circuit directory card for each lighting and appliance panelboard and each power distribution panelboard provided with a door, clearly and specifically indicating the loads served. Identify spares and spaces.
- Z. Provide typed circuit directory for each branch circuit panelboard. Revise directory to reflect circuiting changes required to balance phase loads.
- AA. Provide engraved plastic nameplates under the provisions of Section 26 05 53.
- BB. Provide arc flash warning labels in accordance with NFPA 70.
- CC. Provide spare conduits out of each recessed panelboard to an accessible location above ceiling. Identify each as SPARE.
 - 1. Minimum spare conduits: 6 empty 1 inch.
- DD. Ground and bond panelboard enclosure according to Section 26 05 26.

3.03 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements, for additional requirements.
- B. Perform field inspection and testing in accordance with Section 01 40 00.
- C. Inspect and test in accordance with NETA ATS, except Section 4.
- D. Molded Case Circuit Breakers: Perform inspections and tests listed in NETA ATS, Section 7.6.1.1 for all main circuit breakers and circuit breakers larger than 100 amperes.. Tests listed as optional are not required.
- E. Ground Fault Protection Systems: Test in accordance with manufacturer's instructions as required by NFPA 70.
 - 1. Perform inspections and tests listed in NETA ATS, Section 7.14. The insulation-resistance test on control wiring listed as optional is not required.
- F. Test GFCI circuit breakers to verify proper operation.
- G. Test AFCI circuit breakers to verify proper operation.
- H. Test shunt trips to verify proper operation.
- I. Procure services of a qualified manufacturer's representative to observe installation and assist in inspection, testing, and adjusting. Include manufacturer's reports with

field quality control submittals.

- J. Correct deficiencies and replace damaged or defective panelboards or associated components.

3.04 ADJUSTING

- A. Adjust tightness of mechanical and electrical connections to manufacturer's recommended torque settings.
- B. Adjust alignment of panelboard fronts.
- C. Load Balancing: For each panelboard, rearrange circuits such that the difference between each measured steady state phase load does not exceed 20 percent and adjust circuit directories accordingly. Maintain proper phasing for multi-wire branch circuits.

3.05 CLEANING

- A. Clean dirt and debris from panelboard enclosures and components according to manufacturer's instructions.
- B. Repair scratched or marred exterior surfaces to match original factory finish.

END OF SECTION 26 24 16

SECTION 26 27 26 WIRING DEVICES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Wall switches.
- B. Wall dimmers.
- C. Fan speed controllers.
- D. Receptacles.
- E. Wall plates and covers.
- F. Floor box service fittings.
- G. Poke-through assemblies.
- H. Access floor boxes.
- I. Occupancy sensors

1.02 RELATED REQUIREMENTS

- A. Section 09 69 00 - Access Flooring.
- B. Section 26 05 00 – Common Work Results for Electrical.
- C. Section 26 05 19 - Low-Voltage Electrical Power Conductors and Cables: Manufactured wiring systems for use with access floor boxes with compatible pre-wired connectors.
- D. Section 26 05 26 - Grounding and Bonding for Electrical Systems.
- E. Section 26 05 33.16 - Boxes for Electrical Systems.
- F. Section 26 05 39 - Underfloor Raceways for Electrical Systems.
- G. Section 26 05 53 - Identification for Electrical Systems: Identification products and requirements.
- H. Section 26 05 83 - Wiring Connections: Cords and plugs for equipment.
- I. Section 26 09 23 - Lighting Control Devices: Devices for automatic control of lighting, including occupancy sensors, in-wall time switches, and in-wall interval timers.
- J. Section 27 10 00 - Structured Cabling: Voice and data jacks.

1.03 REFERENCE STANDARDS

- A. FS W-C-596 - Connector, Electrical, Power, General Specification for; 2014h, with Amendments (2017).
- B. FS W-S-896 - Switches, Toggle (Toggle and Lock), Flush Mounted (General Specification); 2014g, with Amendment (2017).
- C. NECA 1 - Standard for Good Workmanship in Electrical Construction; 2015.
- D. NECA 130 - Standard for Installing and Maintaining Wiring Devices; 2016.

- E. NEMA WD 1 - General Color Requirements for Wiring Devices; 1999 (Reaffirmed 2020).
- F. NEMA WD 6 - Wiring Devices - Dimensional Specifications; 2021.
- G. NFPA 70 - National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- H. UL 20 - General-Use Snap Switches; Current Edition, Including All Revisions.
- I. UL 498 - Attachment Plugs and Receptacles; Current Edition, Including All Revisions.
- J. UL 514D - Cover Plates for Flush-Mounted Wiring Devices; Current Edition, Including All Revisions.
- K. UL 943 - Ground-Fault Circuit-Interrupters; Current Edition, Including All Revisions.
- L. UL 1310 - Class 2 Power Units; Current Edition, Including All Revisions.
- M. UL 1449 - Standard for Surge Protective Devices; Current Edition, Including All Revisions.
- N. UL 1472 - Solid-State Dimming Controls; Current Edition, Including All Revisions.
- O. UL 1917 - Solid-State Fan Speed Controls; Current Edition, Including All Revisions.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Coordinate the placement of outlet boxes with millwork, furniture, equipment, etc. installed under other sections or by others.
 - 2. Coordinate wiring device ratings and configurations with the electrical requirements of actual equipment to be installed.
 - 3. Coordinate the placement of outlet boxes for wall switches with actual installed door swings.
 - 4. Coordinate the installation and preparation of uneven surfaces, such as split face block, to provide suitable surface for installation of wiring devices.
 - 5. Coordinate the core drilling of holes for poke-through assemblies with the work covered under other sections.
 - 6. Notify the Architect of any conflicts or deviations from the contract documents to obtain direction prior to proceeding with work.
- B. Sequencing:
 - 1. Do not install wiring devices until final surface finishes and painting are complete.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide manufacturer's catalog information showing dimensions, colors, and configurations.
 - 1. Wall Dimmers: Include derating information for ganged multiple devices.
 - 2. Surge Protection Receptacles: Include surge current rating, voltage protection rating (VPR) for each protection mode, and diagnostics information.

- C. Samples: One for each type and color of device and wall plate specified.
- D. Certificates for Surge Protection Receptacles: Manufacturer's documentation of listing for compliance with UL 1449.
- E. Field Quality Control Test Reports.
- F. Manufacturer's Installation Instructions: Indicate application conditions and limitations of use stipulated by product testing agency. Include instructions for storage, handling, protection, examination, preparation, and installation of product.
- G. Operation and Maintenance Data:
 - 1. Wall Dimmers: Include information on operation and setting of presets.
 - 2. GFCI Receptacles: Include information on status indicators.
 - 3. Surge Protection Receptacles: Include information on status indicators.
- H. Project Record Documents: Record actual installed locations of wiring devices.
- I. Maintenance Materials: Furnish the following for Owner's use in maintenance of project.
 - 1. See Section 01 60 00 - Product Requirements, for additional provisions.
 - 2. Screwdrivers for Tamper-Resistant Screws: Two for each type of screw.
 - 3. Extra Keys for Locking Switches: Two of each type.
 - 4. Extra Surge Protection Receptacles: Two of each type.
 - 5. Extra Wall Plates: One of each style, size, and finish.
 - 6. Extra Flush Floor Service Fittings: Two of each type.
 - 7. Extra Poke-Through Core Hole Closure Plugs: Two for each core size.

1.06 QUALITY ASSURANCE

- A. Comply with requirements of NFPA 70.
- B. Maintain at the project site a copy of each referenced document that prescribes execution requirements.
- C. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum five years documented experience.
- D. Products: Listed, classified, and labeled as suitable for the purpose intended.
- E. Product Listing Organization Qualifications: An organization recognized by OSHA as a Nationally Recognized Testing Laboratory (NRTL) and acceptable to authorities having jurisdiction.

1.07 DELIVERY, STORAGE, AND PROTECTION

- A. Store in a clean, dry space in original manufacturer's packaging until ready for installation.
- B. Products: Provide products listed and classified by Underwriters Laboratories Inc. as suitable for the purpose specified and indicated.

PART 2 PRODUCTS

2.01 WIRING DEVICES - GENERAL REQUIREMENTS

2.02 MANUFACTURERS

- A. Cooper Wiring Devices: www.cooperwiringdevices.com.
- B. GE Industrial: www.geindustrial.com.
- C. Leviton Manufacturing, Inc: www.leviton.com.
- D. Pass & Seymore.
- E. Hubbell.
- F. Bryant.
- G. Arrow-Hart.
- H. Or approved equal.

2.03 WIRING DEVICE APPLICATIONS

- A. Provide wiring devices suitable for intended use and with ratings adequate for load served.
- B. For single receptacles installed on an individual branch circuit, provide receptacle with ampere rating not less than that of the branch circuit.
- C. Provide weather-resistant GFCI receptacles with specified weatherproof covers for receptacles installed outdoors or in damp or wet locations. Receptacles to be clearly identified as weather resistant as required by CEC.
- D. Provide tamper resistant receptacles for receptacles installed in dwelling units.
- E. Provide GFCI protection for receptacles installed within 6 feet of sinks.
- F. Provide GFCI protection for receptacles installed in kitchens.
- G. Provide GFCI protection for receptacles serving electric drinking fountains.
- H. Provide isolated ground receptacles for receptacles serving computers and electronic cash registers.
- I. Unless noted otherwise, do not use combination switch/receptacle devices.
- J. For flush floor service fittings, use tile rings for installations in tile floors.
- K. For flush floor service fittings, use carpet flanges for installations in carpeted floors.

2.04 WIRING DEVICE FINISHES

- A. Provide wiring device finishes as described below unless otherwise indicated.
- B. Wiring Devices, Unless Otherwise Indicated: White with white nylon wall plate.
- C. Wiring Devices Installed in Finished Spaces: White with white nylon wall plate.
- D. Wiring Devices Installed in Unfinished Spaces: Gray with galvanized steel wall plate.

- E. Wiring Devices Installed in Wet or Damp Locations: White with specified weatherproof cover.
- F. Isolated Ground Convenience Receptacles: Orange.
- G. Surge Protection Receptacles: Blue.
- H. Wiring Devices Connected to Emergency Power: Red with red nylon wall plate.
- I. Clock Hanger Receptacles: Brown with stainless steel wall plate.
- J. Above-Floor Service Fittings: Gray wiring devices with satin aluminum housing.
- K. Flush Floor Box Service Fittings: Gray wiring devices with aluminum cover and ring/flange.
- L. Flush Poke-Through Service Fittings: Gray wiring devices with aluminum cover and aluminum flange.
- M. Access Floor Boxes: Gray wiring devices with gray steel cover with insert to match floor covering.

2.05 ALL WIRING DEVICES

~~~~~ *PROJECT NOTE* ~~~~~

Most authorities having jurisdiction with respect to electrical code enforcement accept Underwriters Laboratories listing and classification as evidence that a product meets adequate safety standards and, in the case of classification, is suitable for the classified environment or application. Many authorities also accept similar listing and classification from other testing agencies. The second choice permits other testing agencies, including Underwriters Laboratories, to provide such a determination.

~~~~ *END OF PROJECT NOTE* ~~~~

- A. Provide products listed and classified by Underwriters Laboratories Inc. as suitable for the purpose specified and indicated.

2.06 WALL SWITCHES

- A. Wall Switches - General Requirements: AC only, quiet operating, general-use snap switches with silver alloy contacts, complying with NEMA WD 1 and NEMA WD 6, and listed as complying with UL 20 and where applicable FS W-S-896; types as indicated on the drawings.
 - 1. Wiring Provisions: Terminal screws for side wiring and screw actuated binding clamp for back wiring with separate ground terminal screw.
- B. Standard Wall Switches: Industrial specification grade, 20 A, 120/277 V with standard toggle type switch actuator and maintained contacts; single pole single throw, double pole single throw, three way, or four way as indicated on the drawings.
 - 1. Products:
 - a. Single-pole: Hubbell #1221-I, Bryant #4901-GI, Pass & Seymour #20AC1-I.
 - b. Double-pole: Hubbell #1222-I, Brant #4902-GI, Pass & Seymour #20AC2-I.
 - c. Three-way: Hubbell #1223-I, Bryant #4903-GI, Pass & Seymour #20AC3-I.

- d. Four-way: Hubbell #1224-I, Bryant #4904-GI, Pass & Seymour #20AC4-I.
- e. Substitutions: See Section 01 60 00 - Product Requirements.
- C. Lighted Wall Switches: Industrial specification grade, 20 A, 120/277 V with illuminated standard toggle type switch actuator and maintained contacts; illuminated with load off; single pole single throw, double pole single throw, three way, or four way as indicated on the drawings.
- D. Pilot Light Wall Switches: Industrial specification grade, 20 A, 120/277 V with red illuminated standard toggle type switch actuator and maintained contacts; illuminated with load on; single pole single throw, double pole single throw, three way, or four way as indicated on the drawings.
 - 1. Products:
 - a. Hubbell #1221-PLR, Bryant #4901-PLR, Pass & Seymour #20AC1-PLR.
 - b. Or approved equal.
 - c. Substitutions: See Section 01 60 00 - Product Requirements.
- E. Locking Wall Switches: Industrial specification grade, 20 A, 120/277 V with barrel type keyed switch actuator and maintained contacts; switches keyed alike; single pole single throw, double pole single throw, three way, or four way as indicated on the drawings.
- F. Momentary Contact Wall Switches: Industrial specification grade, 20 A, 120/277 V with toggle type three position switch actuator and momentary contacts; single pole double throw, off with switch actuator in center position.
- G. Locking Momentary Contact Wall Switches: Industrial specification grade, 20 A, 120/277 V with lever type keyed three position switch actuator and momentary contacts; switches keyed alike; single pole double throw, off with switch actuator in center position.
- H. Wall Switches: Heavy Duty, AC only general-use snap switch, complying with NEMA WD 6 and WD 1.
 - 1. Body and Handle: white plastic with toggle handle.
 - 2. Indicator Light: Lighted handle type switch; red handle.
 - 3. Locator Light: Lighted handle type switch; red color handle.
 - 4. Ratings:
 - a. Voltage: 120 and 277 volts, AC.
 - b. Current: 20 amperes.
- I. Switch Types: Single pole, double pole, and 3-way.

2.07 WALL DIMMERS

- A. Wall Dimmers - General Requirements: Solid-state with continuous full-range even control following square law dimming curve, integral radio frequency interference filtering, power failure preset memory, air gap switch accessible without removing wall plate, complying with NEMA WD 1 and NEMA WD 6, and listed as complying with UL 1472; types and ratings suitable for load controlled as indicated on the drawings.
- B. Control: Slide control type with separate on/off switch.

- C. Power Rating, Unless Otherwise Indicated or Required to Control the Load Indicated on the Drawings:
 - 1. Incandescent: 600 W.
 - 2. Magnetic Low-Voltage: 600 VA.
 - 3. Electronic Low-Voltage: 400 VA.
 - 4. Fluorescent: 600 VA.
 - 5. LED: 600 VA
- D. Provide locator light, illuminated with load off.
- E. Provide accessory wall switches to match dimmer appearance when installed adjacent to each other.
- F. Incandescent Wall Dimmers: Semiconductor dimmer for incandescent lamps, Type as indicated on drawings, complying with NEMA WD 6 and WD 1.
 - 1. Body and Handle: white plastic with linear slide control.
 - 2. Voltage: 120 and 277 volts.
 - 3. Power Rating: 600 watts.
- G. LED Wall Dimmers: NEMA WD 1, Type II semiconductor dimmer for LED lamps.
 - 1. Power rating to match load shown on the drawings.
 - 2. Voltage as required for controlled LED fixtures.
- H. Provide accessory wall switches to match dimmer appearance when installed adjacent to each other.

2.08 FAN SPEED CONTROLLERS

- A. Description: 120 V AC, solid-state, full-range variable speed, slide control type with separate on/off switch, with integral radio frequency interference filtering, fan noise elimination circuitry, power failure preset memory, complying with NEMA WD 1 and NEMA WD 6, and listed as complying with UL 1917.
 - 1. Current Rating: 1.5 A unless otherwise indicated or required to control the load indicated on the drawings.

2.09 RECEPTACLES

- A. Receptacles - General Requirements: Self-grounding, complying with NEMA WD 1 and NEMA WD 6, and listed as complying with UL 498 and where applicable FS W-C-596; types as indicated on the drawings.
 - 1. Wiring Provisions: Terminal screws for side wiring or screw actuated binding clamp for back wiring with separate ground terminal screw.
 - 2. NEMA configurations specified are according to NEMA WD 6.
 - 3. Hospital Grade Receptacles: Listed as complying with UL 498 Supplement SD, with green dot hospital grade mark on device face.
- B. Convenience Receptacles:
 - 1. Standard Convenience Receptacles: Industrial specification grade, 20A, 125V, NEMA 5-20R; single or duplex as indicated on the drawings.
 - 2. Automatically Controlled Convenience Receptacles: Industrial specification grade, 20A, 125V, NEMA 5-20R; controlled receptacle marking on device face per

- NFPA 70; single or duplex as indicated on the drawings.
3. Isolated Ground Convenience Receptacles: Industrial specification grade, 20A, 125V, NEMA 5-20R, with ground contacts isolated from mounting strap; isolated ground triangle mark on device face; single or duplex as indicated on the drawings.
 4. Weather Resistant Convenience Receptacles: Industrial specification grade, 20A, 125V, NEMA 5-20R, listed and labeled as weather resistant type complying with UL 498 Supplement SD suitable for installation in damp or wet locations; single or duplex as indicated on the drawings.
 5. Tamper Resistant Convenience Receptacles: Industrial specification grade, 20A, 125V, NEMA 5-20R, listed and labeled as tamper resistant type; single or duplex as indicated on the drawings.
 6. Tamper Resistant and Weather Resistant Convenience Receptacles: Industrial specification grade, 20A, 125V, NEMA 5-20R, listed and labeled as tamper resistant type and as weather resistant type complying with UL 498 Supplement SD suitable for installation in damp or wet locations; single or duplex as indicated on the drawings.
 7. Illuminated Convenience Receptacles: Hospital grade, 20A, 125V, NEMA 5-20R; illuminated face or indicator light to indicate power is being supplied to receptacle; single or duplex as indicated on the drawings.
- C. GFCI Receptacles:
1. GFCI Receptacles - General Requirements: Self-testing, with feed-through protection and light to indicate ground fault tripped condition and loss of protection; listed as complying with UL 943, class A.
 - a. Provide test and reset buttons of same color as device.
 2. Standard GFCI Receptacles: Industrial specification grade, duplex, 20A, 125V, NEMA 5-20R, rectangular decorator style.
 3. Weather Resistant GFCI Receptacles: Industrial specification grade, duplex, 20A, 125V, NEMA 5-20R, rectangular decorator style, listed and labeled as weather resistant type complying with UL 498 Supplement SD suitable for installation in damp or wet locations.
 4. Tamper Resistant GFCI Receptacles: Industrial specification grade, duplex, 20A, 125V, NEMA 5-20R, rectangular decorator style, listed and labeled as tamper resistant type.
 5. Tamper Resistant and Weather Resistant GFCI Receptacles: Industrial specification grade, duplex, 20A, 125V, NEMA 5-20R, rectangular decorator style, listed and labeled as tamper resistant type and as weather resistant type complying with UL 498 Supplement SD suitable for installation in damp or wet locations.
- D. USB Charging Devices:
1. USB Charging Devices - General Requirements: Listed as complying with UL 1310.
 - a. Charging Capacity - Two-Port Devices: 2.1 A, minimum.
 - b. Charging Capacity - Four-Port Devices: 4.2 A, minimum.

2. USB Charging/Tamper Resistant Receptacle Combination Devices: Two-port (Type A) USB charging device and receptacle, commercial specification grade, duplex, 20A, 125V, NEMA 5-20R, listed and labeled as tamper resistant type; rectangular decorator style.
 3. USB Charging Noncombination Devices: Four-port (Type A); rectangular decorator style.
- E. Surge Protection Receptacles:
1. Surge Protection Receptacles - General Requirements: Listed and labeled as complying with UL 1449, Type 2 or 3.
 - a. Energy Dissipation: Not less than 240 J per mode.
 - b. Protected Modes: L-N, L-G, N-G.
 - c. UL 1449 Voltage Protection Rating (VPR): Not more than 700 V for L-N, L-G modes and 1200 V for N-G mode.
 - d. Diagnostics:
 - 1) Visual Notification: Provide indicator light to report functional status of surge protection.
 - 2) Audible Notification: Provide switchable audible alarm to report that surge protection is not functional.
 2. Standard Surge Protection Receptacles: Industrial specification grade, duplex, 20A, 125V, NEMA 5-20R, rectangular decorator style.
 3. Isolated Ground Surge Protection Receptacles: Industrial specification grade, duplex, 20A, 125V, NEMA 5-20R, rectangular decorator style, with ground contacts isolated from mounting strap.
- F. Locking Receptacles: Industrial specification grade, configuration as indicated on the drawings.
1. Standard Locking Convenience Receptacles: Single, 20A, 125V, NEMA L5-20R.
- G. Clock Hanger Receptacles: Single, 15A, 125V, NEMA 5-15R.
- H. Special Purpose Receptacle Outlet: .20A, 250V, 3 pole, 4 wire, 3 phase grounding, single: NEMA 15-20R; black (Hubbell 8420).
- I. Special Purpose Receptacle Outlet: 20A, 125/250V, 3 pole, 4 wire, 1 phase grounding, single: NEMA 14-20R; black (Hubbell 8410).
- J. Special Purpose Receptacle Outlet: 30A, 125V, 2 pole, 3 wire grounding, single; NEMA 5-30R; black (Hubbell 9308).
- K. Special Purpose Receptacle Outlet: 30A, 250V, 2 pole, 3 wire grounding, single; NEMA 6-30R; black (Hubbell 9330).
- L. Special Purpose Receptacle Outlet: 30A, 250V, 3 pole, 4 wire, 3 hose, grounding, single; NEMA 15-30R; black (Hubbell 8430A).
- M. Special Purpose Receptacle Outlet: 30A, 125/250V, 3 pole, 4 wire, 1 phase grounding, single; NEMA 14-30 R; black (Hubbell 9430A).
- N. Special Purpose Receptacle Outlet: 30A, 250V, 2 pole, 3 wire, 1 phase grounding, single, twist-lock; NEMA L6-30R; black (Hubbell 2620).

- O. Special Purpose Receptacle Outlet: 30A, 250V, 3 pole, 4 wire, 3 phase, grounding, single, twist-lock; NEMA L15-30R; black (Hubbell 2720).
- P. Special Purpose Receptacle Outlet: 50A, 250V, 2 pole, 3 wire, 1 phase, grounding, single; NEMA 6-50R; black (Hubbell 9367).
- Q. Special Purpose Receptacle Outlet: 50A, 250V, 2 pole, 3 wire, 1 phase, grounding, single, twist-lock; black (Hubbell 25505), with wall plate per NFPA 56A. Portable x-ray receptacle.
- R. Special Purpose Receptacle Outlet: 20A, 250V, 2 pole, 3 wire, 1 phase, grounding, single, twist-lock; NEMA L6-20R; black (Hubbell 2320).
- S. Special Purpose Receptacle Outlet: 50A, 125/250V, 3 pole, 4 wire, 1 phase, grounding, single; NEMA 14-50R; black (Hubbell 9450A).
- T. Special Receptacle: 20A, 4 pole, 5 wire, 3 phase Y, 120/208V; NEMA L21-20; black (Hubbell 2510).
- U. Special Receptacle: 30A, 4 pole, 5 wire, 3 phase Y, 120/208V; NEMA L21-30; black (Hubbell 2810).
- V. Special Purpose Receptacle Outlet: 15A, 125V, 2 pole, 3 wire, isolated ground, duplex; NEMA 5-15R; orange (Hubbell IG-5262).
- W. Special Purpose Receptacle Outlet: 20A, 125V, 2 pole, 3 wire, isolated ground, duplex; NEMA 5029R; orange (Hubbell IG-5362).
- X. Special Purpose Receptacle Outlet: 30A, 125V, 2 pole, 3 wire, 1 phase, grounding, single, twist-lock; NEMA L5-30R; black (Hubbell 2610).
- Y. Special Purpose Receptacle Outlet: 20A, 125V, 2 pole, 3 wire, single, twist-lock; NEMA L5-20R; black.
- Z. Special Receptacle Outlet: 30A, 250V, 2 pole, 3 wire, 1 phase grounding, single, twist lock, isolated ground; NEMA L6-30R; orange (Hubbell IG-2620).
- AA. Special Receptacle Outlet: 30A, 4 pole, 5 wire, 3 phase Y, 277/408V; NEMA L22-30, black.
- BB. Special Receptacle Outlet: 60A, 3 pole, 4 wire, 3 phase, 480V; watertight pin and sleeve type; red, Hubbell 460R7W with BB601W 15 degree angle back box.
- CC. Special Receptacle Outlet: 60A, 277/480V, 4 pole, 5 wire, single pin and sleeve.
 - 1. Manufacturers
 - a. Appleton.
 - b. Hubbell; Model 560R7W.
 - c. Or approved equal.
- DD. Special Receptacle Outlet: 60A, 250V, 3 pole, 4 wire, 3 phase, grounding, single; NEMA 15-60R; black.
 - 1. Manufacturers
 - a. Bryant; Model 8460.
 - b. Hubbell; Model 8460A.
 - c. Pass & Seymour; Model 5760-BL.
 - d. Or approved equal.

- EE. Other receptacle types as indicated on the drawings and/or as required for connection of designated equipment.

2.10 WALL PLATES AND COVERS

- A. Wall Plates: Comply with UL 514D.
 - 1. Configuration: One piece cover as required for quantity and types of corresponding wiring devices.
 - 2. Size: Standard.
 - 3. Screws: Metal with slotted heads finished to match wall plate finish.
 - 4. Provide screwless wallplates with concealed mounting hardware where indicated.
- B. Nylon Wall Plates: Smooth finish, high-impact thermoplastic.
- C. Stainless Steel Wall Plates: Brushed satin finish, Type 302 stainless steel.
- D. Brass Wall Plates: Brushed satin finish, factory-coated to inhibit oxidation.
- E. Aluminum Wall Plates: Smooth satin finish, clear anodized, factory-coated to inhibit oxidation.
- F. Chrome Wall Plates: Smooth finish, chrome plated steel.
- G. Galvanized Steel Wall Plates: Rounded corners and edges, with corrosion resistant screws.
- H. Pre-marked Wall Plates: Factory labeled as indicated; hot stamped for nylon wall plates and engraved for metal wall plates.
- I. Weatherproof Covers for Damp Locations: Gasketed, cast aluminum, with self-closing hinged cover and corrosion-resistant screws; listed as suitable for use in wet locations with cover closed.
- J. Weatherproof Covers for Wet or Damp Locations: Gasketed, cast aluminum, with hinged lockable cover and corrosion-resistant screws; listed as suitable for use in wet locations while in use with attachment plugs connected and identified as extra-duty type.
- K. Weatherproof Switch Covers for Wet or Damp Locations: Gasketed, metallic, with externally operable actuating means and corrosion-resistant screws; listed as suitable for use in wet locations.
- L. Decorative Cover Plates: white, nylon, verify color with architect .
- M. Jumbo Cover Plates: white, nylon, verify color with architect.
- N. Weatherproof Cover Plates: Gasketed cast metal with hinged.
- O. Inmate Areas: In Correctional Facilities
 - 1. Minimum Level Device Plate: Type 430 stainless steel, flush, satin finish, approximately 20 gauge.
 - a. Hollow Metal Jamb Posts: Arrow-Hart #T-1650; Bryant, Stainless Steel.
 - 2. Medium Level Device Plate: Stainless steel; Type 430.
 - 3. Maximum Level Device Plate:
 - a. Back Plate: Cold rolled steel; 10 gauge, prime painted.

- b. Cover Plate: Steel; 10 gauge, prime painted.
- c. Fasteners: Minimum for security fasteners.
- d. Manufacturers: Hubbell, Fail-Safe, Mark.
- e. Cast Metal Plate for Surface Type Boxes: Corrosive resistant, cast ferrous metal, designed for the application.
- f. Plastic Device Plates: Not permitted.
- g. Fasteners: Tamper proof metal fasteners under provisions of Section 05 05 23.
- h. Device Plates Installed in Housing Units: Patient Cells, Holding Cells, and Receiving Tanks shall be maximum level device plates.
- i. Device Plates Installed In Mechanical Rooms, Electrical Rooms, Control Rooms and areas 12 feet or more above finished floor shall be minimum level device plates.
- j. Device plates installed in other areas shall be Medium level device plates.

2.11 FLOOR BOX SERVICE FITTINGS

- A. Description: Service fittings compatible with floor boxes provided under Section 26 05 33.16 with components, adapters, and trims required for complete installation.
- B. Above-Floor Service Fittings:
 - 1. Single Service Pedestal Convenience Receptacles:
 - a. Configuration: One standard convenience duplex receptacle.
 - 2. Single Service Pedestal Communications Outlets:
 - a. Configuration: One 1 inch bushed opening.
 - b. Voice and Data Jacks: As specified in Section 27 30 00.
 - 3. Single Service Pedestal Furniture Feed:
 - a. Configuration: One 3/4 inch knockout.
 - 4. Dual Service Pedestal Combination Outlets:
 - a. Configuration:
 - 1) Power: One standard convenience duplex receptacle.
 - 2) Communications: One 1 inch bushed opening.
 - 3) Voice and Data Jacks: As specified in Section 27 30 00.
 - b. Provide barrier to separate line and low voltage compartments.
- C. Flush Floor Service Fittings:
 - 1. Single Service Flush Convenience Receptacles:
 - a. Cover: Rectangular.
 - b. Configuration: One standard convenience duplex receptacle(s) with duplex flap opening(s).
 - 2. Single Service Flush Communications Outlets:
 - a. Cover: Rectangular.
 - b. Voice and Data Jacks: As specified in Section 27 30 00.
 - 3. Single Service Flush Furniture Feed:
 - a. Cover: Rectangular.
 - b. Configuration: One 2-1/8 inch by 3/4 inch combination threaded opening(s).
 - 4. Dual Service Flush Combination Outlets:

- a. Cover: Rectangular.
- b. Configuration:
 - 1) Power: One standard convenience duplex receptacle(s) with duplex flap opening(s).
 - 2) Voice and Data Jacks: As specified in Section 27 30 00.
- 5. Dual Service Flush Furniture Feed:
 - a. Cover: Rectangular.
 - b. Configuration:
 - 1) Power: One 2-1/8 inch by 3/4 inch combination threaded opening(s).
 - 2) Communications: One 2-1/8 inch by 1 inch combination threaded opening(s).
- 6. Accessories:
 - a. Tile Rings: Finish to match covers; configuration as required to accommodate specified covers.
 - b. Carpet Flanges: Finish to match covers; configuration as required to accommodate specified covers.

2.12 POKE-THROUGH ASSEMBLIES

- A. Description: Assembly comprising floor service fitting, poke-through component, fire stops and smoke barriers, and junction box for conduit termination; fire rating listed to match fire rating of floor and suitable for floor thickness where installed.
- B. Above-Floor Service Fittings:
 - 1. Single Service Pedestal Convenience Receptacles:
 - a. Configuration: One standard convenience duplex receptacle.
 - 2. Single Service Pedestal Communications Outlets:
 - a. Configuration: One 1 inch bushed opening.
 - b. Voice and Data Jacks: As specified in Section 27 30 00.
 - 3. Single Service Pedestal Furniture Feed:
 - a. Configuration: One 3/4 inch knockout.
 - 4. Dual Service Pedestal Combination Outlets:
 - a. Configuration:
 - 1) Power: One standard convenience duplex receptacle.
 - 2) Communications: One 1 inch bushed opening.
 - 3) Voice and Data Jacks: As specified in Section 27 30 00.
 - b. Provide barrier to separate line and low voltage compartments.
- C. Flush Floor Service Fittings:
 - 1. Single Service Flush Convenience Receptacles:
 - a. Configuration: One standard convenience duplex receptacle(s) with duplex flap opening(s).
 - 2. Single Service Flush Communications Outlets:
 - a. Voice and Data Jacks: As specified in Section 27 30 00.
 - 3. Single Service Flush Furniture Feed:
 - a. Configuration: One 2 inch by 1-1/4 inch combination threaded opening(s).
 - 4. Dual Service Flush Combination Outlets:

- a. Cover: Hinged door(s).
- b. Configuration:
 - 1) Power: One standard convenience duplex receptacle(s).
 - 2) Voice and Data Jacks: As specified in Section 27 10 00.
5. Dual Service Flush Furniture Feed:
 - a. Configuration:
 - 1) Power: One 3/4 inch threaded opening(s).
 - 2) Communications: Two 1/2 inch threaded opening(s).
6. Accessories:
 - a. Closure Plugs: Size and fire rating as required to seal unused core hole and maintain fire rating of floor.

2.13 ACCESS FLOOR BOXES

- A. Manufacturers - Access Floor Boxes with Pre-wired Connectors for Manufactured Wiring Systems:
 1. AFC Cable Systems Inc: www.afcweb.com/#sle.
 2. RELOC Wiring Solutions, a brand of Acuity Brands, Inc: www.relocwiring.com/#sle.
 3. Wiremold, a brand of Legrand North America, Inc: www.legrand.us/#sle.
 4. Or approved equal.
 5. Substitutions: See Section 01 60 00 - Product Requirements.
 6. Source Limitations: Provide access floor boxes with pre-wired connectors produced by the same manufacturer as the manufactured wiring system used for this project.
- B. Description: Metallic multi-service box suitable for mounting in access floor system specified in Section 09 69 00.
- C. Access floor boxes with pre-wired connectors for manufactured wiring systems are permitted only where manufactured wiring systems are permitted as specified in Section 26 05 19.
- D. Configuration:
 1. Power: Two standard convenience duplex receptacle(s) unless noted otherwise on drawings.
 2. Voice and Data Jacks: As specified in Section 27 30 00.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that field measurements are as indicated.
- B. Verify that outlet boxes are installed in proper locations and at proper mounting heights and are properly sized to accommodate devices and conductors in accordance with NFPA 70.
- C. Verify that wall openings are neatly cut and will be completely covered by wall plates.
- D. Verify that final surface finishes are complete, including painting.

- E. Verify that floor boxes are adjusted properly.
- F. Verify that branch circuit wiring installation is completed, tested, and ready for connection to wiring devices.
- G. Verify that core drilled holes for poke-through assemblies are in proper locations.
- H. Verify that openings in access floor are in proper locations.
- I. Verify that conditions are satisfactory for installation prior to starting work.

3.02 PREPARATION

- A. Provide extension rings to bring outlet boxes flush with finished surface.
- B. Clean dirt, debris, plaster, and other foreign materials from outlet boxes.

3.03 INSTALLATION

- A. Perform work in accordance with NECA 1 (general workmanship) and, where applicable, NECA 130, except for mounting heights specified in those standards.
- B. Perform work in a neat and workmanlike manner in accordance with NECA 1, except for mounting heights specified in that standard.
- C. Coordinate locations of outlet boxes provided under Section 26 05 33.16 as required for installation of wiring devices provided under this section.
 - 1. Mounting Heights: Unless otherwise indicated, as follows:
 - a. Wall Switches: 48 inches above finished floor to top of box CEC 1117B.6(5).
 - b. Wall Dimmers: 48 inches above finished floor to top of box CEC 1117B.6(5).
 - c. Fan Speed Controllers: 48 inches above finished floor to top of box CEC 1117B.6(5).
 - d. Receptacles: 18 inches above finished floor or 6 inches above counter.
 - e.
 - 2. Orient outlet boxes for vertical installation of wiring devices unless otherwise indicated.
 - 3. Where multiple receptacles, wall switches, or wall dimmers are installed at the same location and at the same mounting height, gang devices together under a common wall plate.
 - 4. Locate wall switches on strike side of door with edge of wall plate 3 inches from edge of door frame. Where locations are indicated otherwise, notify Owner to obtain direction prior to proceeding with work.
 - 5. Locate receptacles for electric drinking fountains concealed behind drinking fountain according to manufacturer's instructions.
- D. Install wiring devices in accordance with manufacturer's instructions.
- E. Install permanent barrier between ganged wiring devices when voltage between adjacent devices exceeds 300 V.
- F. Where required, connect wiring devices using pigtails not less than 6 inches long. Do not connect more than one conductor to wiring device terminals.
- G. Connect wiring devices by wrapping conductor clockwise 3/4 turn around screw terminal and tightening to proper torque specified by the manufacturer. Where

present, do not use push-in pressure terminals that do not rely on screw-actuated binding.

- H. Unless otherwise indicated, connect wiring device grounding terminal to branch circuit equipment grounding conductor and to outlet box with bonding jumper.
- I. For isolated ground receptacles, connect wiring device grounding terminal only to identified branch circuit isolated equipment grounding conductor. Do not connect grounding terminal to outlet box or normal branch circuit equipment grounding conductor.
- J. Provide GFCI receptacles with integral GFCI protection at each location indicated. Do not use feed-through wiring to protect downstream devices.
- K. Where split-wired duplex receptacles are indicated, remove tabs connecting top and bottom receptacles.
- L. Install securely, in a neat and workmanlike manner, as specified in NECA 1.
- M. Install wiring devices plumb and level with mounting yoke held rigidly in place.
- N. Install wall switches with OFF position down.
- O. Install wall dimmers to achieve full rating specified and indicated after derating for ganging as instructed by manufacturer.
- P. Do not share neutral conductor on branch circuits.
- Q. Install vertically mounted receptacles with grounding pole on bottom and horizontally mounted receptacles with grounding pole on right.
- R. Install wall plates to fit completely flush to wall with no gaps and rough opening completely covered without strain on wall plate. Repair or reinstall improperly installed outlet boxes or improperly sized rough openings. Do not use oversized wall plates in lieu of meeting this requirement.
- S. Install blank wall plates on junction boxes and on outlet boxes with no wiring devices installed or designated for future use.
- T. Identify wiring devices in accordance with Section 26 05 53.
- U. Install identification label for wall switches and wall dimmers in accordance with Section 26 05 26 indicating load served when controlling loads that are not visible from the control location or multiple wall switches or wall dimmers are installed at one location.
- V. Install identification label for all receptacles in accordance with Section 26 05 26 indicating serving branch circuit.
- W. Install poke-through closure plugs in each unused core holes to maintain fire rating of floor.
- X. Install receptacles with grounding pole on bottom.
- Y. Connect wiring device grounding terminal to outlet box with bonding jumper.
- Z. Install decorative plates on switch, receptacle, and blank outlets in finished areas.
- AA. Connect wiring devices by wrapping conductor around screw terminal.
- BB. Use jumbo size plates for outlets installed in masonry walls.

- CC. Install galvanized steel plates on outlet boxes and junction boxes in unfinished areas, above accessible ceilings, and on surface mounted outlets.
- DD. Install protective rings on active flush cover service fittings.

3.04 CONSTRUCTION

- A. Interface with Other Work
 - 1. Coordinate locations of outlet boxes to obtain mounting heights specified unless otherwise indicated on drawings. All dimensions are to the center of the item.
 - 2. Install convenience receptacle four inches above backsplash of counters or four inches above counter if no backsplash. Mount horizontal where indicated
 - 3. Install electric water cooler outlet boxes centered behind unit, behind electric water cooler cover. Coordinate with equipment installer.
- B. Locate wall switches on the strike side of door with edge of wall plate three inches from edge of door frame. Where locations are indicated otherwise, notify the Electrical Engineer of Record to obtain direction prior to proceeding with work.

3.05 FIELD QUALITY CONTROL

- A. Site Test
 - 1. See Section 01 40 00 - Quality Requirements, for additional requirements.
 - 2. Operate each wall switch, wall dimmer and fan speed control with circuit energized and verify proper operation.
 - 3. Test each receptacle to verify operation and proper polarity.
 - 4. Verify that each receptacle is energized.
 - 5. Test each GFCI receptacle for proper tripping operation and proper polarity.
 - 6. Inspect each surge protection receptacle to verify surge protection is active.
- B. Inspect each wiring device for damage and defects.
- C. Correct wiring deficiencies and replace damaged or defective wiring devices.

3.06 ADJUSTING

- A. Adjust devices and wall plates to be flush and level.
- B. Adjust presets for wall dimmers according to manufacturer's instructions as directed by Owner's Representative.

3.07 CLEANING

- A. Clean exposed surfaces to remove dirt, paint, or other foreign material and restore to match original factory finish.

END OF SECTION 26 27 26

SECTION 26 28 13 FUSES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Fuses.
- B. Spare fuse cabinet.

1.02 RELATED REQUIREMENTS

- A. Section 26 05 00 – Common Work Results for Electrical.
- B. Section 26 05 53 - Identification for Electrical Systems: Identification products and requirements.
- C. Section 26 05 73 - Power System Studies: Additional criteria for the selection of protective devices specified in this section.
- D. Section 26 24 13 - Switchboards: Fusible switches.
- E. Section 26 24 16 - Panelboards: Fusible switches.
- F. Section 26 28 16.16 - Enclosed Switches: Fusible switches.

1.03 REFERENCE STANDARDS

- A. NEMA FU 1 - Low Voltage Cartridge Fuses; 2012.
- B. NFPA 70 - National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- C. UL 248-1 - Low-Voltage Fuses - Part 1: General Requirements; Current Edition, Including All Revisions.
- D. UL 248-4 - Low-Voltage Fuses - Part 4: Class CC Fuses; Current Edition, Including All Revisions.
- E. UL 248-8 - Low-Voltage Fuses - Part 8: Class J Fuses; Current Edition, Including All Revisions.
- F. UL 248-10 - Low-Voltage Fuses - Part 10: Class L Fuses; Current Edition, Including All Revisions.
- G. UL 248-12 - Low-Voltage Fuses - Part 12: Class R Fuses; Current Edition, Including All Revisions.
- H. UL 248-15 - Low-Voltage Fuses - Part 15: Class T Fuses; Current Edition, Including All Revisions.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Coordinate fuse clips furnished in equipment provided under other sections for compatibility with indicated fuses.
 - a. Fusible Enclosed Switches: See Section 26 28 16.16.

2. Coordinate fuse requirements according to manufacturer's recommendations and nameplate data for actual equipment to be installed.
3. Notify LP Consulting Engineers, Inc. of any conflicts with or deviations from Contract Documents. Obtain direction before proceeding with work.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide manufacturer's standard data sheets including voltage and current ratings, interrupting ratings, time-current curves, and current limitation curves.
 1. Spare Fuse Cabinet: Include dimensions.
- C. Maintenance Materials: Furnish the following for Owner's (Owner's) use in maintenance of project.
 1. See Section 01 60 00 - Product Requirements, for additional provisions.
 2. Extra Fuses: Three set(s) of three for each type and size installed.
 3. Fuse Pullers: One set(s) compatible with each type and size installed.
 4. Spare Fuse Cabinet Keys: Two.

1.06 QUALITY ASSURANCE

- A. Conform to requirements of CEC.
- B. Conform to requirements of NFPA 70.
- C. Product Listing Organization Qualifications: An organization recognized by OSHA as a Nationally Recognized Testing Laboratory (NRTL) and acceptable to authorities having jurisdiction.
- D. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum five years documented experience and with service facilities within 100 miles of Project.
- E. Products: Listed and classified by Underwriters Laboratories Inc. as suitable for the purpose specified and indicated.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Cooper Bussmann
- B. Ferraz Shawmut, Inc
- C. Littelfuse
- D. Gould
- E. Substitutions: See Section 01 60 00 - Product Requirements.

2.02 APPLICATIONS

- A. Service Entrance:
 1. Fusible Switches up to 600 Amperes: Class RK1, time-delay.

2. Fusible Switches Larger Than 600 Amperes: Class L, time-delay.
- B. Feeders:
 1. Fusible Switches up to 600 Amperes: Class RK1, time-delay.
 2. Fusible Switches Larger Than 600 Amperes: Class L, time-delay.
- C. General Purpose Branch Circuits: Class RK1, time-delay.
- D. Individual Motor Branch Circuits: Class RK1, time-delay.
- E. In-Line Protection for Pole-Mounted Luminaires: Class CC, time-delay.
- F. Primary Protection for Control Transformers: Class CC, time-delay.
- G. HVAC equipment: Provide fuses, size, type, and ratings in accordance with equipment nameplate data to be field verified by contractor.

2.03 FUSES

- A. Provide products listed, classified, and labeled as suitable for the purpose intended.
- B. Unless specifically indicated to be excluded, provide fuses for all fusible equipment as required for a complete operating system.
- C. Provide fuses of the same type, rating, and manufacturer within the same switch.
- D. Comply with UL 248-1.
- E. Unless otherwise indicated, provide cartridge type fuses complying with NEMA FU 1, Class and ratings as indicated.
- F. Voltage Rating: Suitable for circuit voltage.
- G. Class R Fuses: Comply with UL 248-12.
 1. Class RK1, Time-Delay Fuses:
 - a. Products:
 - 1) Bussmann, "Low-Peak"; 250V KTN-RK and 600V LPS-RK.
 - 2) Littlefuse, "Little-Peak" 250V LLN-RK and 600V LLS-RK.
 - 3) Gould "AMPTRAP II" 250V A2D-R and 600V A6D-R.
 - 4) Substitutions: See Section 01 60 00 - Product Requirements.
 2. Class RK1, Fast-Acting, Non-Time-Delay Fuses:
 - a. Products:
 - 1) Bussmann "Limitron", 250V KTN-RK and 600V KTS-RK..
 - 2) Littlefuse 250V RLN-R and 600V RLS-R.
 - 3) Gould "AMPTRAP" 250V A2K-R and 600V A6K-R..
 - 4) Substitutions: See Section 01 60 00 - Product Requirements.
 3. Class RK5, Time-Delay Fuses:
 - a. Products:
 - 1) Bussmann "Fusetron" 250V FRN-RK and 600V FRS-RK.
 - 2) Littlefuse "SLO-BLO" 250V FLN-R and 600V FLS-R.
 - 3) Gould "TRI-ONIC" 250V TR-R and 600V TRS-R.
 - 4) Substitutions: See Section 01 60 00 - Product Requirements.
 4. Class RK5, Fast-Acting, Non-Time-Delay Fuses:
 - a. Products:

- 1) Bussmann 300V "T-Tron" JIN, 600V "Limitron" JKS.
 - 2) Substitutions: See Section 01 60 00 - Product Requirements.
- H. Class J Fuses: Comply with UL 248-8.
1. Class J, Time-Delay Fuses:
 - a. Products:
 - 1)
 - 2) Substitutions: See Section 01 60 00 - Product Requirements.
 2. Class J, Fast-Acting, Non-Time-Delay Fuses:
 - a. Products:
 - 1) Bussmann 300V JIN, 600V JKS.
 - 2) Substitutions: See Section 01 60 00 - Product Requirements.
- I. Class L Fuses: Comply with UL 248-10.
1. Class L, Time-Delay Fuses:
 - a. Products:
 - 1) Bussmann "Hi-Cap" 600V, 601-6000A, Type KRP-C.
 - 2) Littlefuse "HI-INT" 600V, 601-6000A, Type KLP-C.
 - 3) Gould "AMPTRAP" 600V, 200-600A, Type A4BY.
 - 4) Substitutions: See Section 01 60 00 - Product Requirements.
 2. Class L, Fast-Acting, Non-Time-Delay Fuses:
 - a. Products:
 - 1) Bussmann 300V KTN-R, 600V KTS-R.
 - 2) Substitutions: See Section 01 60 00 - Product Requirements.
- J. Class T Fuses: Comply with UL 248-15.
1. Products:
 - a. Bussmann 300V JIN, 600V JJS.
 - b. Substitutions: See Section 01 60 00 - Product Requirements.
- K. Class CC Fuses: Comply with UL 248-4.
1. Class CC, Time-Delay Fuses:
 - a. Products:
 - 1) Bussmann 600V LP-CC.
 - 2) Substitutions: See Section 01 60 00 - Product Requirements.
 2. Class CC, Fast-Acting, Non-Time-Delay Fuses:
 - a. Products:
 - 1) Bussmann 600v, KTK-R.
 - 2) Substitutions: See Section 01 60 00 - Product Requirements.
- L. Selectivity: Where the requirement for selectivity is indicated, furnish products as required to achieve selective coordination.
- M. Provide the following accessories where indicated or where required to complete installation:
1. Fuseholders: Compatible with indicated fuses.
 2. Fuse Reducers: For adapting indicated fuses to permit installation in switch designed for fuses with larger ampere ratings.

2.04 SPARE FUSE CABINET

- A. Description: Wall-mounted sheet metal cabinet with shelves and hinged door with cylinder lock, suitably sized to store spare fuses and fuse pullers specified.
- B. Finish: Manufacturer's standard, factory applied grey finish unless otherwise indicated.
- C. Doors: Hinged, with hasp for Owner's (Owner's) padlock.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that fuse ratings are consistent with circuit voltage and manufacturer's recommendations and nameplate data for equipment.
- B. Verify that mounting surfaces are ready to receive spare fuse cabinet.
- C. Verify that conditions are satisfactory for installation prior to starting work.

3.02 INSTALLATION

- A. Do not install fuses until circuits are ready to be energized.
- B. Install fuses with label oriented such that manufacturer, type, and size are easily read.
- C. Install spare fuse cabinet in convenient location in main electrical room unless otherwise indicated on drawings.
- D. Identify spare fuse cabinet in accordance with Section 26 05 53.
- E. Provide identification nameplate for spare fuse cabinet in accordance with Section 26 05 53.

END OF SECTION 26 28 13

SECTION 26 43 00 SURGE PROTECTIVE DEVICES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Surge protective devices for service entrance locations.

1.02 RELATED REQUIREMENTS

- A. Section 26 05 00 – Common Work Results for Electrical Systems.
- B. Section 26 05 26 - Grounding and Bonding for Electrical Systems.
- C. Section 26 23 00 - Low-Voltage Switchgear.
- D. Section 26 24 13 - Switchboards.
- E. Section 26 24 16 - Panelboards.

1.03 ABBREVIATIONS AND ACRONYMS

- A. EMI/RFI: Electromagnetic Interference/Radio Frequency Interference.
- B. SPD: Surge Protective Device.

1.04 REFERENCE STANDARDS

- A. MIL-STD-220 - Method of Insertion Loss Measurement; 2009c (Validated 2019).
- B. NECA 1 - Standard for Good Workmanship in Electrical Construction; 2015.
- C. NEMA 250 - Enclosures for Electrical Equipment (1000 Volts Maximum); 2020.
- D. NETA ATS - Standard For Acceptance Testing Specifications For Electrical Power Equipment And Systems; 2021.
- E. NFPA 70 - National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- F. UL 1283 - Standard for Electromagnetic Interference Filters; Current Edition, Including All Revisions.
- G. UL 1449 - Standard for Surge Protective Devices; Current Edition, Including All Revisions.

1.05 ADMINISTRATIVE REQUIREMENTS

- A. Coordination: Coordinate size and location of overcurrent device compatible with the actual surge protective device and location to be installed. Notify LP Consulting Engineers, Inc. of any conflicts or deviations from Contract Documents to obtain direction prior to ordering equipment.

1.06 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.

- B. Product Data: Include detailed component information, voltage, surge current ratings, repetitive surge current capacity, voltage protection rating (VPR) for all protection modes, maximum continuous operating voltage (MCOV), nominal discharge current (I-n), short circuit current rating (SCCR), connection means including any required external overcurrent protection, enclosure ratings, outline and support point dimensions, weight, service condition requirements, and installed features.
 - 1. SPDs with EMI/RFI filter: Include noise attenuation performance.
- C. Shop Drawings: Include wiring diagrams showing all factory and field connections with wire and circuit breaker/fuse sizes.
- D. Certificates: Manufacturer's documentation of listing for compliance with the following standards:
 - 1. UL 1449.
 - 2. UL 1283 (for Type 2 SPDs).
- E. Field Quality Control Test Reports.
- F. Manufacturer's Installation Instructions: Include application conditions and limitations of use stipulated by product testing agency. Include instructions for storage, handling, protection, examination, preparation, and installation of product.
- G. Operation and Maintenance Data: Include information on status indicators and recommended maintenance procedures and intervals.
- H. Warranty: Submit sample of manufacturer's warranty and documentation of final executed warranty completed in Owner's (Owner's) name and registered with manufacturer.
- I. Project Record Documents: Record actual connections and locations of surge protective devices.

1.07 QUALITY ASSURANCE

- A. Comply with requirements of NFPA 70.
- B. Maintain at the project site a copy of each referenced document that prescribes execution requirements.
- C. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum five years documented experience.
- D. Product Listing Organization Qualifications: An organization recognized by OSHA as a Nationally Recognized Testing Laboratory (NRTL) and acceptable to authorities having jurisdiction.

1.08 DELIVERY, STORAGE, AND PROTECTION

- A. Store in a clean, dry space in accordance with manufacturer's written instructions.

1.09 FIELD CONDITIONS

- A. Maintain field conditions within manufacturer's required service conditions during and after installation.

1.10 WARRANTY

- A. See Section 01 78 00 - Closeout Submittals, for additional warranty requirements.
- B. Manufacturer's Warranty: Provide minimum five year warranty covering repair or replacement of surge protective devices showing evidence of failure due to defective materials or workmanship.
- C. Exclude surge protective devices from any clause limiting warranty responsibility for acts of nature, including lightning, stated elsewhere.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Field-Installed, Externally Mounted Surge Protective Devices:
 - 1. ABB/GE: www.geindustrial.com/#sle.
 - 2. Eaton Corporation: www.eaton.com
 - 3. Intermatic, Inc: www.intermatic.com/#sle.
 - 4. nVent ERICO: www.nvent.com/#sle.
 - 5. Schneider Electric; Square D Brand Surgellogic Products: www.surgellogic.com/#sle.
 - 6. Surge Suppression, LLC (SSI): www.surgesuppression.com/#sle.
 - 7. Or approved equal.
- B. Factory-installed, Internally Mounted Surge Protective Devices:
 - 1. Same as manufacturer of equipment containing surge protective device, to provide complete listed assembly including SPD.
- C. Substitutions: See Section 01 60 00 - Product Requirements.
- D. Source Limitations: Provide surge protective devices produced by single manufacturer and obtained from single supplier.

2.02 SURGE PROTECTIVE DEVICES - GENERAL REQUIREMENTS

- A. Description: Factory-assembled surge protective devices (SPDs) for 60 Hz service; listed, classified, and labeled as suitable for the purpose intended; system voltage as indicated on the drawings.
- B. Unless otherwise indicated, provide field-installed, externally mounted or factory-installed, internally mounted SPDs.
- C. List and label as complying with UL 1449, Type 1 when connected on line side of service disconnect overcurrent device and Type 1 or 2 when connected on load side of service disconnect overcurrent device.
- D. Protected Modes:
 - 1. Wye Systems: L-N, L-G, N-G, L-L.
 - 2. Delta Systems: L-G, L-L.
 - 3. Single Split Phase Systems: L-N, L-G, N-G, L-L.
 - 4. High Leg Delta Systems: L-N, L-G, N-G, L-L.

- E. UL 1449 Voltage Protection Ratings (VPRs):
 - 1. 208Y/120V System Voltage: Not more than 1,000 V for L-N, L-G, and N-G modes and 1,200 V for L-L mode.
 - 2. 480Y/277V System Voltage: Not more than 1,500 V for L-N, L-G, and N-G modes and 2,000 V for L-L mode.
- F. UL 1449 Maximum Continuous Operating Voltage (MCOV): Not less than 115% of nominal system voltage.
- G. Enclosure Environment Type per NEMA 250: Unless otherwise indicated, as specified for the following installation locations:
 - 1. Indoor clean, dry locations: Type 1.
 - 2. Outdoor locations: Type 3R.
- H. Mounting for Field-installed, Externally Mounted SPDs: Unless otherwise indicated, as specified for the following locations:
 - 1. Provide surface-mounted SPD where mounted in non-public areas or adjacent to surface-mounted equipment.
 - 2. Provide flush-mounted SPD where mounted in public areas or adjacent to flush-mounted equipment.
- I. Equipment Containing Factory-installed, Internally Mounted SPDs: Listed and labeled as a complete assembly including SPD.
 - 1. Switchboards: See Section 26 24 13.
 - 2. Panelboards: See Section 26 24 16.

2.03 SURGE PROTECTIVE DEVICES FOR SERVICE ENTRANCE LOCATIONS

- A. Surge Protective Device - Basis of Design: Surge Suppression, LLC (SSI); SpecPRO Series; Model SSMA8 (80 kA/phase, Type 2, I-n = 10 kA); www.surgesuppression.com/#sle.
 - 1. Voltage: As indicated on drawings.
 - 2. Features: Seven modes of protection; component-level thermal fusing; internal circuit board-mounted overcurrent fusing; 200 kAIC SCCR; 15 year warranty.
 - 3. Include the following options: (Enclosure type as indicated on drawings and/or as required by the environment)
 - a. AC10 - Basic internal audible alarm with dry relay contacts.
 - b. LP - Remote LED indicators in individual NEMA 4X housings.
 - c. S6 - Surge counter with reset button.
 - d. D1 - NEMA 1, 2, 3, 3S, 4X, and 12 composite enclosure with integral non-fused disconnect switch, with external handle
 - e. P - Flush mount plate.
- B. Surge Protective Device:
 - 1. Basis of Design: As indicated on drawings.
 - 2. Protection Circuits: Field-replaceable modular or non-modular.
 - 3. Surge Current Rating: Not less than 120 kA per mode/240 kA per phase.
 - 4. Repetitive Surge Current Capacity: Not less than 5,000 impulses.
 - 5. UL 1449 Nominal Discharge Current (I-n): 20 kA.

6. UL 1449 Short Circuit Current Rating (SCCR): Not less than the available fault current determined by the studies required in section 26 05 73.
 7. EMI/RFI Filtering: Provide EMI/RFI filter to attenuate electrical noise; listed as complying with UL 1283 for Type 2 SPDs (UL 1283 listing not available for Type 1 SPDs).
 - a. Noise Attenuation: Not less than 40 dB at 100 kHz using MIL-STD-220 insertion loss test method.
 8. Diagnostics:
 - a. Protection Status Monitoring: Provide indicator lights to report the protection for each phase.
 - b. Alarm Notification: Provide indicator light and audible alarm to report alarm condition. Provide button to manually silence audible alarm.
 - c. Remote Status Monitoring: Provide Form C dry type contacts (normally open and normally closed) for remote annunciation of status.
 - d. Surge Counter: Provide surge event counter with manual reset button, surge count retention upon power loss, and six digit LCD display that indicates quantity of surge events.
 9. Provide surge rated integral disconnect switch for SPDs not connected to a dedicated circuit breaker or fused switch or not direct bus connected.
- C. Products - Field-installed, Externally Mounted Surge Protective Devices:
1. Surge Suppression, LLC (SSI) Advantage Series; SSLx/CSLx (100 kA per phase).
 2. Surge Suppression, LLC (SSI) SpecPRO Series; SSM/CSM (80 kA per phase).
 3. Or approved equal.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that field measurements are as indicated.
- B. Verify that the service voltage and configuration marked on the SPD are consistent with the service voltage and configuration at the location to be installed.
- C. Verify that electrical equipment is ready to accept connection of the SPD and that installed overcurrent device is consistent with requirements of drawings and manufacturer's instructions.
- D. Verify system grounding and bonding is in accordance with Section 26 05 26, including bonding of neutral and ground for service entrance and separately derived systems where applicable. Do not energize SPD until deficiencies have been corrected.
- E. Verify that conditions are satisfactory for installation prior to starting work.

3.02 INSTALLATION

- A. Perform work in accordance with NECA 1 (general workmanship).
- B. Install products in accordance with manufacturer's instructions.
- C. Arrange equipment to provide minimum clearances in accordance with manufacturer's instructions and NFPA 70.

- D. Unless indicated otherwise, connect service entrance surge protective device on load side of service disconnect main overcurrent device.
- E. Provide conductors with minimum ampacity as indicated on the drawings, as required by NFPA 70, and not less than manufacturer's recommended minimum conductor size.
- F. Install conductors between SPD and equipment terminations as short and straight as possible, not exceeding manufacturer's recommended maximum conductor length. Breaker locations may be reasonably rearranged in order to provide leads as short and straight as possible. Twist conductors together to reduce inductance.
- G. Do not energize SPD until bonding of neutral and ground for service entrance and separately derived systems is complete in accordance with Section 26 05 26 where applicable. Replace SPDs damaged by improper or missing neutral-ground bond.
- H. Disconnect SPD prior to performing any high potential testing. Replace SPDs damaged by performing high potential testing with SPD connected.

3.03 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements, for additional requirements.
- B. Inspect and test in accordance with NETA ATS, except Section 4.
- C. Perform inspections and tests listed in NETA ATS Section 7.19.1.
- D. Procure services of a qualified manufacturer's representative to observe installation and assist in inspection, testing, and adjusting. Include manufacturer's reports with field quality control submittals.

3.04 CLEANING

- A. Repair scratched or marred exterior surfaces to match original factory finish.

END OF SECTION 26 43 00

SECTION 26 51 00 INTERIOR LIGHTING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Interior luminaires.
- B. Exit signs.
- C. Drivers.

1.02 RELATED REQUIREMENTS

- A. Section 26 05 00 – Common Work Results for Electrical.
- B. Section 26 05 29 - Hangers and Supports for Electrical Systems.
- C. Section 26 05 33.16 - Boxes for Electrical Systems.
- D. Section 26 05 48 - Vibration and Seismic Controls for Electrical Systems.
- E. Section 26 05 53 - Identification for Electrical Systems: Identification products and requirements.
- F. Section 26 09 23 - Lighting Control Devices.
 - 1. Includes automatic controls for lighting including occupancy sensors, outdoor motion sensors, time switches, outdoor photo controls, and daylighting controls.
 - 2. Includes lighting contactors.
- G. Section 26 27 26 - Wiring Devices: Manual wall switches and wall dimmers.
- H. Section 26 56 00 - Exterior Lighting.

1.03 REFERENCE STANDARDS

- A. 47 CFR 15 - Radio Frequency Devices; current edition.
- B. IEC 60529 - Degrees of Protection Provided by Enclosures (IP Code); 1989 (Corrigendum 2019).
- C. IEEE C62.41.2 - IEEE Recommended Practice on Characterization of Surges in Low-Voltage (1000 V and less) AC Power Circuits; 2002 (Corrigendum 2012).
- D. IES LM-63 - Approved Method: IES Standard File Format for the Electronic Transfer of Photometric Data and Related Information; 2019.
- E. IES LM-79 - Approved Method: Optical and Electrical Measurements of Solid-State Lighting Products; 2019.
- F. IES LM-80 - Approved Method: Measuring Maintenance of Light Output Characteristics of Solid-State Light Sources; 2021.
- G. NECA 1 - Standard for Good Workmanship in Electrical Construction; 2015.
- H. NECA/IESNA 500 - Standard for Installing Indoor Lighting Systems; 2006.
- I. NECA/IESNA 502 - Standard for Installing Industrial Lighting Systems; 2006.

- J. NEMA 410 - Performance Testing for Lighting Controls and Switching Devices with Electronic Drivers and Discharge Ballasts; 2023.
- K. NEMA LE 4 - Recessed Luminaires, Ceiling Compatibility; 2023.
- L. NFPA 70 - National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- M. NFPA 101 - Life Safety Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- N. UL 844 - Luminaires for Use in Hazardous (Classified) Locations; Current Edition, Including All Revisions.
- O. UL 924 - Emergency Lighting and Power Equipment; Current Edition, Including All Revisions.
- P. UL 1598 - Luminaires; Current Edition, Including All Revisions.
- Q. UL 8750 - Light Emitting Diode (LED) Equipment for Use in Lighting Products; Current Edition, Including All Revisions.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Coordinate the installation of luminaires with mounting surfaces installed under other sections or by others. Coordinate the work with placement of supports, anchors, etc. required for mounting. Coordinate compatibility of luminaires and associated trims with mounting surfaces at installed locations.
 - 2. Coordinate the placement of luminaires with structural members, ductwork, piping, equipment, diffusers, fire suppression system components, and other potential conflicts installed under other sections or by others.
 - 3. Coordinate the placement of exit signs with furniture, equipment, signage or other potential obstructions to visibility installed under other sections or by others.
 - 4. Notify Architect and/or Owner of any conflicts or deviations from the contract documents to obtain direction prior to proceeding with work.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Shop Drawings:
 - 1. Indicate dimensions and components for each luminaire that is not a standard product of the manufacturer.
 - 2. Provide photometric calculations where luminaires are proposed for substitution.
 - 3. Provide shop drawings for continuous row luminaires.
- C. Product Data: Provide manufacturer's standard catalog pages and data sheets including detailed information on luminaire construction, dimensions, ratings, finishes, mounting requirements, listings, service conditions, photometric performance, installed accessories, and ceiling compatibility; include model number nomenclature clearly marked with all proposed features.

1. LED Luminaires:
 - a. Include estimated useful life, calculated based on IES LM-80 test data.
 - b. Include IES LM-79 test report upon request.
 2. Provide electronic files of photometric data certified by a National Voluntary Laboratory Accreditation Program (NVLAP) lab or independent testing agency in IES LM-63 standard format upon request.
 3. Drivers: Include wiring diagrams and list of compatible lamp configurations.
- D. Samples:
1. Provide one sample(s) of each specified luminaire where indicated.
 2. Provide one sample(s) of each custom luminaire.
 3. Provide one sample(s) of each luminaire proposed for substitution upon request.
 4. Provide one sample(s) of each product finish illustrating color and texture upon request.
- E. Field quality control reports.
- F. Manufacturer's Installation Instructions: Indicate application conditions and limitations of use stipulated by product testing agency. Include instructions for storage, handling, protection, examination, preparation, and installation of product.
- G. Operation and Maintenance Data: Instructions for each product including information on replacement parts.
- H. Maintenance Materials: Furnish the following for Owner's (Owner's) use in maintenance of project.
1. See Section 01 60 00 - Product Requirements, for additional provisions.
 2. Extra Lenses and Louvers: Two percent of total quantity installed for each type, but not less than one of each type.
 3. Extra LED Drivers: Two percent of total quantity installed for each type, but not less than one of each type.
- I. Project Record Documents: Record actual connections and locations of luminaires and any associated remote components.

1.06 QUALITY ASSURANCE

- A. Conform to requirements of CEC, and ICBO.
- B. Maintain at the project site a copy of each referenced document that prescribes execution requirements.
- C. Conform to requirements of NFPA 70 and NFPA 101.
- D. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum five years documented experience.
- E. Product Listing Organization Qualifications: An organization recognized by OSHA as a Nationally Recognized Testing Laboratory (NRTL) and acceptable to authorities having jurisdiction.

1.07 DELIVERY, STORAGE, AND PROTECTION

- A. Receive, handle, and store products according to NECA/IESNA 500 (commercial lighting) and manufacturer's written instructions.
- B. Keep products in original manufacturer's packaging and protect from damage until ready for installation.

1.08 FIELD CONDITIONS

- A. Maintain field conditions within manufacturer's required service conditions during and after installation.

1.09 WARRANTY

- A. See Section 01 78 00 - Closeout Submittals, for additional warranty requirements.
- B. Provide 3-year manufacturer warranty for LED luminaires, including drivers.
- C. Provide 10-year pro-rata warranty for batteries for self-powered exit signs.
- D. Products: Listed and classified by Underwriters Laboratories Inc. as suitable for the purpose specified and indicated.

PART 2 PRODUCTS

2.01 MANUFACTURERS - LUMINAIRES

- A. Furnish products as indicated in Lighting Fixture Schedule included on the Drawings
 1. General: Lighting fixtures as hereinafter specified are identified by type as noted on drawings. Fixture specifications are based on construction and performance. Manufacturer's catalog numbers are of general nature and indicate the level of quality required, but do not necessarily reflect complete options and accessories required. Approval shall be based on description and specification of fixture as well as catalog number indicated. Verify fixture voltage requirements with circuitry shown on drawings and provide appropriate equipment.

2.02 LUMINAIRE TYPES

- A. Furnish products as indicated in luminaire schedule included on the drawings.
- B. Substitutions: See Section 01 60 00 - Product Requirements.

2.03 LUMINAIRES

- A. Manufacturers:
 1. Acuity Brands, Inc: www.acuitybrands.com/#sle.
 2. Alloy LED; www.alloyled.com/#sle.
 3. Cooper Lighting, a division of Cooper Industries: www.cooperindustries.com/#sle.
 4. Electro-Matic Visual, Inc; www.empvisual.com/#sle.
 5. Hubbell Lighting, Inc: www.hubbellighting.com/#sle.

6. Philips Lighting North America Corporation;
www.lightingproducts.philips.com/#sle.
7. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Provide products that comply with requirements of NFPA 70.
- C. Provide products that are listed and labeled as complying with UL 1598, where applicable.
- D. Provide products listed, classified, and labeled as suitable for the purpose intended.
- E. Provide products complying with Federal Energy Management Program (FEMP) requirements.
- F. Unless otherwise indicated, provide complete luminaires including lamp(s) and all sockets, drivers, reflectors, lenses, housings and other components required to position, energize and protect the lamp and distribute the light.
- G. Unless specifically indicated to be excluded, provide all required conduit, boxes, wiring, connectors, hardware, supports, trims, accessories, etc. as necessary for a complete operating system.
- H. Provide products suitable to withstand normal handling, installation, and service without any damage, distortion, corrosion, fading, discoloring, etc.
- I. Recessed Luminaires:
 1. Ceiling Compatibility: Comply with NEMA LE 4.
 2. Luminaires Recessed in Insulated Ceilings: Listed and labeled as IC-rated, suitable for direct contact with insulation and combustible materials.
 3. Luminaires Recessed in Sloped Ceilings: Provide suitable sloped ceiling adapters.
- J. Hazardous (Classified) Location Luminaires: Listed and labeled as complying with UL 844 for the classification of the installed location.
- K. LED Luminaires:
 1. Components: UL 8750 recognized or listed as applicable.
 2. Tested in accordance with IES LM-79 and IES LM-80.
 3. LED Estimated Useful Life: Minimum of 50,000 hours at 70 percent lumen maintenance, calculated based on IES LM-80 test data.
- L. LED Tape Lighting Systems: Provide all power supplies, drivers, cables, connectors, channels, covers, mounting accessories, and interfaces as necessary to complete installation.
 1. LED Tape - General Requirements:
 - a. Listed.
 - b. Designed for field cutting in accordance with listing.
 - c. Wet Location Applications: IEC 60529, IP 68 (waterproof) rated.
 2. White LED Tape:
 - a. Correlated Color Temperature (CCT): 3500 K unless otherwise indicated.
 - b. Color Rendering Index (CRI): Not less than 90.
- M. Track Lighting Systems: Provide track compatible with specified track heads, with all connectors, power feed fittings, dead ends, hangers and canopies as necessary to complete installation.

- N. Luminaires Mounted in Continuous Rows: Provide quantity of units required for length indicated, with all accessories required for joining and aligning.

2.04 EXIT SIGNS

- A. Description: Exit signs and similar signs for special purpose applications such as area of refuge/rescue assistance.
- B. Description: Exit signs complying with NFPA 101 and applicable state and local codes, and listed and labeled as complying with UL 924.
1. Number of Faces: Single- or double-face as indicated or as required for installed location.
 2. Directional Arrows: As indicated or as required for installed location.
- C. Powered Exit Signs: Internally illuminated with LEDs unless otherwise indicated.
1. Manufacturers:
 - a. Acuity Brands, Inc: www.acuitybrands.com/#sle.
 - b. Cooper Lighting, a division of Cooper Industries;: www.cooperindustries.com/#sle.
 - c. Hubbell Lighting, Inc: www.hubbellighting.com/#sle.
 - d. Philips Lighting North America Corporation; www.lightingproducts.philips.com/#sle.
 - e. Or approved equal.
 - f. Substitutions: See Section 01 60 00 - Product Requirements.
- D. Accessories:
1. Provide compatible accessory high-impact polycarbonate vandal shields where indicated.
 2. Provide compatible accessory wire guards where indicated.
- E. Manufacturers: Furnish products as indicated in Lighting Fixture Schedule included on the Drawings
- F. Exit Signs: Exit sign fixture suitable for use as emergency lighting unit.
1. Provide fixtures complying with NFPA 101.
 2. Lamps: LED.
 3. Directional Arrows: Universal type for field adjustment.
 4. Mounting: Universal, for field selection.
 5. Battery: 6 or 12 volt, nickel-cadmium type, with 1.5 hour capacity.
 6. Battery Charger: Dual-rate type, with sufficient capacity to recharge discharged battery to full charge within twelve hours.
 7. Lamps: Manufacturer's standard.

2.05 BALLASTS AND DRIVERS

- A. Manufacturers:
1. Alloy LED; www.alloyled.com/#sle.
 2. General Electric Company/GE Lighting: www.gelighting.com/#sle.
 3. Lutron Electronics Company, Inc: www.lutron.com/#sle.
 4. OSRAM Sylvania, Inc: www.osram.us/ds/#sle.

5. Philips Lighting North America Corporation; www.usa.lighting.philips.com/#sle.
 6. Substitutions: See Section 01 60 00 - Product Requirements.
 7. Where a specific manufacturer or model is indicated elsewhere in the luminaire schedule or on the drawings, substitutions are not permitted unless explicitly indicated.
- B. Ballasts/Drivers - General Requirements:
1. Provide ballasts containing no polychlorinated biphenyls (PCBs).
 2. Minimum Efficiency/Efficacy: Provide ballasts complying with all current applicable federal and state ballast efficiency/efficacy standards.
 3. Electronic Ballasts/Drivers: Inrush currents not exceeding peak currents specified in NEMA 410.
- C. LED Drivers:
1. Luminaires shall be equipped with an LED driver(s) that accepts the voltage as indicated on the Fixture Schedule on the drawings. Individual driver(s) shall be replaceable
 2. Driver(s) shall be UL8750 class 2 compliant for their intended use.
 3. Total harmonic distortion (THD) for current: $\leq 20\%$.
 4. Driver(s) shall be rated to operate between -30 degrees C to 50 degrees C minimum.
 5. Individual drivers shall be equipped with surge protection (6kV minimum) in accordance with IEEE/ANSI C62.4.1. Driver(s) shall be protected against damage due to either an open circuit or short circuit fault condition on the driver output.
 6. Driver(s) shall have a minimum efficiency of 85 percent.
 7. LED driver(s) shall have a minimum lifetime of 50,000+ hours at 40 degrees C and shall have a minimum efficiency of 80 lumens per watt.
 8. LED dies shall be tested in accordance with I.E.S.N.A. LM-80-08 standards.
 9. Thermal management shall be passive by design and shall consist of heat sinks with no fans, pumps, or liquids.
 10. Dimming Range: Continuous dimming from 100 percent to ten percent relative light output unless dimming capability to lower level is indicated, without flicker.
 11. Control Compatibility: Fully compatible with the dimming controls to be installed.
 - a. Wall Dimmers: See Section 26 27 26.
 - b. Daylighting Controls: See Section 26 09 23.
 12. Product(s):
 - a. Lutron Hi-Lume Premier 0.1% Constant Voltage (L3D0-Series): 3-wire and digital control; 0.1 percent dimming with Soft-On and Fade-to-Black low end performance; www.lutron.com/#sle.
 - b. Lutron Hi-Lume 1% (L3D-Series): 3-wire and digital control; one percent dimming; www.lutron.com/#sle.
 - c. Lutron Hi-Lume 1% Soft-on Fade-to-Black (LDE1-Series): Digital control; one percent dimming with Soft-On and Fade-to-Black low end performance; www.lutron.com/#sle.

2.06 ACCESSORIES

- A. Stems for Suspended Luminaires: Steel tubing, minimum 1/2" size, factory finished to match luminaire or field-painted as directed.
- B. Threaded Rods for Suspended Luminaires: Zinc-plated steel, minimum 1/4" size, field-painted as directed.
- C. Provide accessory plaster frames for luminaires recessed in plaster ceilings.
- D. Provide wire guards for lighting fixtures and equipment where indicated on the drawings.

2.07 SPARE PARTS

- A. The Contractor shall furnish to the Owner at the completion of the project, a minimum of 5 percent spare LED driver assemblies and light engines for each LED fixture type. LED drivers shall be turned over to the Owner's Representative in their manufacturer's protective packaging. LED drivers not in their protective packaging will not be acceptable.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that field measurements are as indicated.
- B. Verify that outlet boxes are installed in proper locations and at proper mounting heights and are properly sized to accommodate conductors in accordance with NFPA 70.
- C. Verify that suitable support frames are installed where required.
- D. Verify that branch circuit wiring installation is completed, tested, and ready for connection to luminaires.
- E. Verify that conditions are satisfactory for installation prior to starting work.

3.02 PREPARATION

- A. Provide extension rings to bring outlet boxes flush with finished surface.
- B. Clean dirt, debris, plaster, and other foreign materials from outlet boxes.

3.03 INSTALLATION

- A. Coordinate locations of outlet boxes provided under Section 26 05 33.16 as required for installation of luminaires provided under this section.
- B. Perform work in accordance with NECA 1 (general workmanship).
- C. Install products in accordance with manufacturer's instructions.
- D. Install luminaires securely, in a neat and workmanlike manner, as specified in NECA 500 (commercial lighting) and NECA 502 (industrial lighting).
- E. Provide required support and attachment in accordance with Section 26 05 29.

- F. Provide required seismic controls in accordance with Section 26 05 48.
- G. Provide seismic sway bracing restraints when an installed suspended luminaire's distance from the nearest permanent object (structural, mechanical, etc.) is less than 0.707 of the total suspension cable (stem) length.
- H. Install luminaires plumb and square and aligned with building lines and with adjacent luminaires.
- I. Suspended Ceiling Mounted Luminaires:
 - 1. Do not use ceiling tiles to bear weight of luminaires.
 - 2. Do not use ceiling support system to bear weight of luminaires unless ceiling support system is certified as suitable to do so.
 - 3. Secure surface-mounted and recessed luminaires to ceiling support channels or framing members or to building structure.
 - 4. Secure pendant-mounted luminaires to building structure.
 - 5. Secure lay-in luminaires to ceiling support channels using listed safety clips at four corners.
 - 6. In addition to ceiling support wires, provide two galvanized steel safety wire(s), minimum 12 gauge, connected from opposing corners of each recessed luminaire to building structure.
 - 7. See appropriate Division 9 section where suspended grid ceiling is specified for additional requirements.
- J. Recessed Luminaires:
 - 1. Install trims tight to mounting surface with no visible light leakage.
 - 2. Non-IC Rated Luminaires: Maintain required separation from insulation and combustible materials according to listing.
 - 3. Luminaires Recessed in Fire-Rated Ceilings: Install using accessories and firestopping materials to meet regulatory requirements for fire rating.
 - 4. Install recessed luminaires to permit removal from below.
 - 5. Install clips to secure recessed grid supported luminaires in place. Secure lay-in luminaires to ceiling support channels using listed safety clips at four corners.
 - 6. In addition to ceiling support wires, provide two galvanized steel safety wire(s), minimum 12 gauge, connected from opposing corners of each recessed luminaire to building structure.
- K. Suspended Luminaires:
 - 1. Unless otherwise indicated, specified mounting heights are to bottom of luminaire.
 - 2. Install using the suspension method indicated, with support lengths and accessories as required for specified mounting height.
 - 3. Provide minimum of two supports for each luminaire equal to or exceeding 4 feet nominal length, with no more than 4 feet between supports.
 - 4. Install canopies tight to mounting surface.
 - 5. Unless otherwise indicated, support pendants from swivel hangers.
 - 6. Provide seismic sway bracing where indicated or as required by the application.

- L. Wall-Mounted Luminaires: Unless otherwise indicated, specified mounting heights are to center of luminaire.
- M. Install fixtures securely, in a neat and workmanlike manner, as specified in NECA 500 (commercial lighting).
- N. Install suspended luminaires and exit signs using pendants supported from swivel hangers. Provide pendant length required to suspend luminaire at indicated height.
- O. Support luminaires larger than 2 x 4 foot size independent of ceiling framing.
- P. Install surface mounted luminaires and exit signs plumb and adjust to align with building lines and with each other. Secure to prevent movement.
- Q. Exposed Grid Ceilings: Support surface mounted luminaires in grid ceiling directly from building structure.
- R. Install wall mounted luminaires and exit signs at height as indicated on Drawings.
- S. Install accessories furnished with each luminaire.
- T. Make wiring connections to branch circuit using building wire with insulation suitable for temperature conditions within fixture; use flexible conduit.
- U. Make wiring connections to branch circuit using building wire with insulation suitable for temperature conditions within luminaire.
- V. Bond products and metal accessories to branch circuit equipment grounding conductor.
- W. Exit Signs:
 - 1. Unless otherwise indicated, connect unit to unswitched power from same circuit feeding normal lighting in same room or area. Bypass local switches, contactors, or other lighting controls.
 - 2. Install lock-on device on branch circuit breaker serving units.
 - 3. Install pendant exit signs at height indicated. Where not indicated, mount 90 inches above finished floor in space over door frame where applicable
- X. Remote Drivers: Install in accessible location as indicated or as required to complete installation, using conductors per manufacturer's recommendations not exceeding manufacturer's recommended maximum conductor length to luminaire.
- Y. Identify luminaires connected to emergency power system in accordance with Section 26 05 53.

3.04 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements, for additional requirements.
- B. Inspect each product for damage and defects.
- C. Operate each luminaire after installation and connection to verify proper operation.
- D. Test self-powered exit signs to verify proper operation upon loss of normal power supply.
- E. Correct wiring deficiencies and repair or replace damaged or defective products. Repair or replace excessively noisy ballasts as determined by LP Consulting Engineers,

Inc..

- F. Re-lamp luminaires that have failed lamps at substantial completion.

3.05 ADJUSTING

- A. Aim and position adjustable luminaires to achieve desired illumination as indicated or as directed by LP Consulting Engineers, Inc.. Secure locking fittings in place.
- B. Aim and position adjustable emergency lighting unit lamps to achieve optimum illumination of egress path as required or as directed by LP Consulting Engineers, Inc. or authority having jurisdiction.
- C. Air-Handling Luminaires with Air Control Blades or Heat Removal Dampers: Adjust as indicated or as required for proper airflow as directed by LP Consulting Engineers, Inc..
- D. Exit Signs with Field-Selectable Directional Arrows: Set as indicated or as required to properly designate egress path as directed by LP Consulting Engineers, Inc. or authority having jurisdiction.
- E. Aim and adjust fixtures as indicated and/or as directed by the Architect or Electrical Engineer of Record.
- F. Position exit sign directional arrows as indicated.

3.06 CLEANING

- A. Clean surfaces according to NECA 500 (commercial lighting), NECA 502 (industrial lighting), and manufacturer's instructions to remove dirt, fingerprints, paint, or other foreign material and restore finishes to match original factory finish.
- B. Clean electrical parts to remove conductive and deleterious materials.
- C. Remove dirt and debris from enclosures.
- D. Clean finishes and touch up damage.
- E. Clean photometric control surfaces as recommended by manufacturer.

3.07 CLOSEOUT ACTIVITIES

- A. See Section 01 78 00 - Closeout Submittals, for closeout submittals.
- B. See Section 01 79 00 - Demonstration and Training, for additional requirements.
- C. Demonstration: Demonstrate proper operation of luminaires to LP Consulting Engineers, Inc. or designated representative, and correct deficiencies or make adjustments as directed.
- D. Just prior to Substantial Completion, replace all lamps that have failed.

3.08 PROTECTION

- A. Protect installed luminaires from subsequent construction operations.

3.09 SCHEDULE - SEE DRAWINGS

END OF SECTION 26 51 00

SECTION 28 46 00 FIRE DETECTION AND ALARM

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Fire alarm system design and installation, including all components, wiring, and conduit.
- B. Transmitters for communication with supervising station.
- C. Circuits from protected premises to supervising station, including conduit.
- D. Replacement and removal of existing fire alarm system components, wiring, and conduit indicated.
- E. Maintenance of fire alarm system under contract for specified warranty period.
- F. The fire alarm system shall consist of all necessary hardware equipment and software programming to perform the following functions:
 - 1. Fire alarm detection operations
 - 2. Control and monitoring of elevators, smoke control equipment and other equipment as indicated in the drawings and specifications.
 - 3. System components shall tie into the existing Fire-Lite MS-9600UDLS and be fully integrated.
- G. Thoroughly inspect the existing system and site conditions before bid. Advise the District's Representative of all conditions requiring immediate attention or might cause difficulties that are not addressed, or inferred to, in the contract drawings and specifications prior to new construction and the commencement of the guarantee period.
- H. Review the Drawings and Specifications for work and material provided by others that will affect work specified under this Section. Carefully coordinate with other trades, equipment suppliers, contractors, etc. as required to provide a high quality reliable installation with a minimum of construction delays. All work required to be re-accomplished due to lack of coordination shall be done at the Contractor's expense.

2.01 RELATED REQUIREMENTS

- A. Section 07 84 00 - Firestopping: Materials and methods for work to be performed by this installer.
- B. Section 08 71 00 - Door Hardware: Electrically operated locks and door holder devices to be monitored and released by fire alarm system.
- C. Section 21 13 00 - Fire-Suppression Sprinkler Systems: Supervisory, alarm, and actuating devices installed in sprinkler system.
- D. Section 23 33 00 - Air Duct Accessories: Smoke dampers monitored and controlled by fire alarm system.

2.02 REFERENCE STANDARDS

- A. ADA Standards - 2010 ADA Standards for Accessible Design; 2010.
- B. IEEE C62.41 - IEEE Recommended Practice on Surge Voltages in Low-Voltage Power Circuits; 1991 (R1995).
- C. NFPA 70 - National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- D. NFPA 72 - National Fire Alarm and Signaling Code; Most Recent Edition Cited by Referring Code or Reference Standard.
- E. NFPA 101 - Life Safety Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.

2.03 AMERICANS WITH DISABILITIES ACT (ADA)

- A. All visual Notification appliances and manual pull stations shall comply with the requirements of the Americans with Disabilities Act or 2022 CBC, whichever is more stringent.

2.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Proposal Documents: Submit the following with cost/time proposal:
 - 1. NFPA 72 "Record of Completion", filled out to the extent known at the time.
 - 2. Manufacturer's detailed data sheet for each control unit, initiating device, and notification appliance.
 - 3. Certification by that the system design will comply with Contract Documents.
 - 4. Proposed maintenance contract.
- C. Drawings must be prepared using AutoCAD Release 2019.
 - 1. Owner will provide floor plan drawings for 's use; verify all dimensions on Owner-provided drawings.
- D. Evidence of designer qualifications.
- E. Design Documents: Submit all information required for plan review and permitting by authorities having jurisdiction, including but not limited to floor plans, riser diagrams, and description of operation:
 - 1. Copy (if any) of list of data required by authority having jurisdiction.
 - 2. NFPA 72 "Record of Completion", filled out to the extent known at the time.
 - 3. Clear and concise description of operation, with input/output matrix similar to that shown in NFPA 72 Appendix A-7-5-2.2(9), and complete listing of software required.
 - 4. System zone boundaries and interfaces to fire safety systems.
 - 5. Location of all components, circuits, and raceways; mark components with identifiers used in control unit programming.
 - 6. Circuit layouts; number, size, and type of raceways and conductors; conduit fill calculations; spare capacity calculations; notification appliance circuit voltage drop calculations.
 - 7. List of all devices on each signaling line circuit, with spare capacity indicated.

8. Manufacturer's detailed data sheet for each component, including wiring diagrams, installation instructions, and circuit length limitations.
 9. Description of power supplies; if secondary power is by battery include calculations demonstrating adequate battery power.
 10. Certification by either the manufacturer of the control unit or by the manufacturer of each other component that the components are compatible with the control unit.
 11. Certification by the manufacturer of the control unit that the system design complies with Contract Documents.
 12. Certification by that the system design complies with Contract Documents.
 13. Do not show existing components to be removed.
- F. Evidence of installer qualifications.
- G. Evidence of instructor qualifications; training lesson plan outline.
- H. Evidence of maintenance contractor qualifications, if different from installer.
- I. Inspection and Test Reports:
1. Submit inspection and test plan prior to closeout demonstration.
 2. Submit documentation of satisfactory inspections and tests.
 3. Submit NFPA 72 "Inspection and Test Form," filled out.
- J. Operating and Maintenance Data: Revise and resubmit until acceptable; have one set available during closeout demonstration:
1. Complete set of specified design documents, as approved by authority having jurisdiction.
 2. Additional printed set of project record documents and closeout documents, bound or filed in same manuals.
 3. Contact information for firm that will be providing contract maintenance and trouble call-back service.
 4. List of recommended spare parts, tools, and instruments for testing.
 5. Replacement parts list with current prices, and source of supply.
 6. Detailed troubleshooting guide and large scale input/output matrix.
 7. Preventive maintenance, inspection, and testing schedule complying with NFPA 72; provide printed copy and computer format acceptable to Owner.
 8. Detailed but easy to read explanation of procedures to be taken by non-technical administrative personnel in the event of system trouble, when routine testing is being conducted, for fire drills, and when entering into contracts for remodeling.
- K. Project Record Documents: Have one set available during closeout demonstration:
1. Complete set of floor plans showing actual installed locations of components, conduit, and zones.
 2. "As installed" wiring and schematic diagrams, with final terminal identifications.
 3. "As programmed" operating sequences, including control events by device, updated input/output chart, and voice messages by event.
- L. Closeout Documents:

1. Certification by manufacturer that the system has been installed in compliance with manufacturer's installation requirements, is complete, and is in satisfactory operating condition.
 2. NFPA 72 "Record of Completion", filled out completely and signed by installer and authorized representative of authority having jurisdiction.
 3. Certificate of Occupancy.
 4. Maintenance contract.
 5. Report on training results.
- M. Maintenance Materials, Tools, and Software: Furnish the following for Owner's use in maintenance of project.
1. See Section 01 60 00 - Product Requirements, for additional provisions.
 2. Furnish spare parts of same manufacturer and model as those installed; deliver in original packaging, labeled in same manner as in operating and maintenance data and place in spare parts cabinet.
 3. In addition to the items in quantities indicated in PART 2, furnish the following:
 - a. All tools, software, and documentation necessary to modify the fire alarm system using Owner's personnel; minimum modification capability to include addition and deletion of devices, circuits, and zones, and changes to system description, operation, and evacuation and instructional messages.
 - b. One copy of all software not resident in read-only-memory.

2.05 QUALITY ASSURANCE

- A. Copies of Design Criteria Documents: Maintain at the project site for the duration of the project, bound together, an original copy of NFPA 72, the relevant portions of applicable codes, and instructions and guidelines of authorities having jurisdiction; deliver to Owner upon completion.
- B. Designer Qualifications: NICET Level III or IV (3 or 4) certified fire alarm technician or registered fire protection engineer, employed by fire alarm control panel manufacturer, , or installer , with experience designing fire alarm systems in the jurisdictional area of the authorities having jurisdiction
- C. Installer Qualifications: Firm with minimum 3 years documented experience installing fire alarm systems of the specified type and providing contract maintenance service as a regular part of their business.
 1. Authorized representative of control unit manufacturer; submit manufacturer's certification that installer is authorized; include name and title of manufacturer's representative making certification.
 2. Installer Personnel: At least 2 years of experience installing fire alarm systems.
 3. Supervisor: NICET level III or IV (3 or 4) certified fire alarm technician; furnish name and address.
 4. Contract maintenance office located within 100 miles of project site.
 5. Certified in California as fire alarm installer.
- D. Maintenance Contractor Qualifications: Same entity as installer.

- E. Instructor Qualifications: Experienced in technical instruction, understanding fire alarm theory, and able to provide the required training; trained by fire alarm control unit manufacturer.
- F. WARRANTY
 - 1. See Section 01 78 00 - Closeout Submittals, for additional warranty requirements.
 - 2. Provide control panel manufacturer's warranty that system components other than wire and conduit are free from defects and will remain so for 1 year after date of Substantial Completion.
 - 3. Provide installer's warranty that the installation is free from defects and will remain so for 1 year after date of Substantial Completion.

PART 2 PRODUCTS

3.01 MANUFACTURERS (MATCH CAMPUS EXISTING SYSTEM)

- A. Fire Alarm Control Units - Basis of Design: Honeywell Security & Fire Solutions/Fire-Lite: www.firelite.com. No known equal.
- B. Existing Fire-Lite fire alarm control panel shall accommodate the new components. This integration shall result in a fully functional and integrated system as described in the plans and specifications.
- C. Fire Alarm Control Units and Accessories:
 - 1. Honeywell Security & Fire Solutions/Fire-Lite: www.firelite.com/#sle.
- D. Initiating Devices and Notification Appliances:
 - 1. Honeywell Security & Fire Solutions/Fire-Lite: www.firelite.com/#sle.
- E. Substitutions: See Section 01 60 00 - Product Requirements.
 - 1. For substitution of products by manufacturers not listed, submit product data showing features and certification by that the design will comply with Contract Documents.

3.02 FIRE ALARM SYSTEM

- A. Fire Alarm System: Provide modifications and extensions to the existing automatic fire detection and alarm system:
 - 1. Provide all components necessary, regardless of whether shown in Contract Documents or not.
 - 2. Protected Premises: Entire building shown on drawings.
 - 3. Comply with the following; where requirements conflict, order of precedence of requirements is as listed:
 - a. ADA Standards.
 - b. The requirements of Department of State Architects.
 - c. The requirements of the local authority having jurisdiction.
 - d. Applicable local codes.
 - e. Contract Documents (drawings and specifications).
 - f. NFPA 101.

- g. NFPA 72; where the word "should" is used consider that provision mandatory; where conflicts between requirements require deviation from NFPA 72, identify deviations clearly on design documents.
- 4. Evacuation Alarm: Multiple smoke zones; allow for evacuation notification of any individual zone or combination of zones, in addition to general evacuation of entire premises.
- 5. Voice Notification: Provide emergency voice/alarm communications with multichannel capability; digital.
- 6. General Evacuation Zones: Each smoke zone is considered a general evacuation zone unless otherwise indicated, with alarm notification in all zones on the same floor, on the floor above, and the floor below.
- 7. Program notification zones as directed by Owner.
- 8. Hearing Impaired Occupants: Provide visible notification devices in all public areas and in dwelling units.
- 9. Fire Command Center: Location indicated on drawings.
- 10. Fire Alarm Control Unit: Existing, located at fire command center.
- 11. Combined Systems: Do not combine fire alarm system with other non-fire systems.
- B. Supervising Stations and Fire Department Connections:
 - 1. Public Fire Department Notification: By on-premises supervising station.
 - 2. Remote Supervising Station: UL-listed central station under contract to facility.
 - 3. Means of Transmission to Remote Supervising Station: Digital alarm communicator transmitter (DACT), 2 telephone lines.
- C. Circuits:
 - 1. Initiating Device Circuits (IDC): Class B, Style A.
 - 2. Signaling Line Circuits (SLC) Within Single Building: Class B, Style 0.5.
 - 3. Notification Appliance Circuits (NAC): Class B, Style W.
- D. Spare Capacity:
 - 1. Initiating Device Circuits: Minimum 25 percent spare capacity.
 - 2. Notification Appliance Circuits: Minimum 25 percent spare capacity.
 - 3. Fire Alarm Control Units: Capable of handling all circuits utilized to capacity without requiring additional components other than plug-in control modules.
- E. Power Sources:
 - 1. Primary: Dedicated branch circuits of the facility power distribution system.
 - 2. Secondary: Storage batteries.
 - 3. Capacity: Sufficient to operate entire system for period specified by NFPA 72.

3.03 EXISTING COMPONENTS

- A. Existing Fire Alarm System: Remove existing components indicated and incorporate remaining components into new system, under warranty as if they were new; do not take existing portions of system out of service until new portions are fully operational, tested, and connected to existing system.
- B. Clearly label components that are "Not In Service."

- C. Remove unused existing components and materials from site and dispose of properly.

3.04 FIRE SAFETY SYSTEMS INTERFACES

- A. HVAC:
 - 1. Duct Smoke Detectors: Close dampers indicated; shut down air handlers indicated.

3.05 COMPONENTS

- A. General:
 - 1. Provide flush mounted units where installed in finish areas; in unfinished areas, surface mounted unit are acceptable.
 - 2. Provide legible, permanent labels for each control device, using identification used in operation and maintenance data.
- B. Fire Alarm Control Units: Analog, addressable type; listed, classified, and labeled as suitable for the purpose intended.
- C. Master Control Unit: As specified for Basis of Design above, or equivalent.
- D. Initiating Devices:
 - 1. Addressable Manual Pull Stations: Fire-Lite BG-12LX.
 - a. Provide 1 extra.
 - 2. Smoke Detectors: Fire-Lite SD365.
 - a. Sensor base: Fire-Lite B300-6.
 - 1) Provide 1 extra.
 - 3. Duct Smoke Detectors: Fire-Lite Photoelectric type with Simplex 2098-series sampling tube of design and dimensions as recommended by the manufacturer for the specific duct size and installation conditions where applied..
 - a. Provide 1 extra.
 - 4. Heat Detectors: Fire-Lite H365, H365HT.
 - a. Provide 1 extra.
- E. Notification Appliances:
 - 1. Weatherproof Speaker: System Sensor SPSRK.
 - a. Provide 1 extra.
 - 2. Strobes: System Sensor SWLED.
 - a. Provide 1 extra.
 - 3. Strobes/Speaker: System Sensor SPSCWL.
 - a. Provide 1 extra.
 - 4. Notification Appliance Circuit provides synchronization of strobes at a rate of 1Hz and operates horns with a Temporal Code Pattern operation. The circuit shall provide the capability to silence the audible signals, while the strobes continue to flash, over a single pair of wires. The capability to synchronize multiple notification appliance circuits shall be provided.
- F. NAC Power Extender: Fire-Lite FL-PS10 with 20981-9274 batteries.
- G. The NAC Power Extender panel shall be a stand-alone panel capable of powering a minimum of 4 notification appliance circuits. Notification appliance circuits shall be

Class B Style Y rated at 2 amps each. Panel shall provide capability to be expanded to 8 notification appliance circuits.

- H. The internal power supply & battery charger shall be capable of charging up 12.7 Ah batteries internally mounted or 18Ah batteries mounted in an external cabinet.
- I. The NAC extender panel may be mounted close to the host control panel or can be remotely located. The Addressable NAC Extender Panel when connected to an addressable panel shall connect to the host panel. Addressable NAC can be individually controlled for general alarm or selective area notification.
- J. Alarms from the host fire panel shall signal the NAC power extender panel to activate. The panel shall monitor itself and each of its NACs for trouble conditions and shall report trouble conditions to the host panel.
- K. Emergency Power Supply:
 - 1. General: Components include battery, charger, and an automatic transfer switch.
 - 2. Battery: Sealed lead-acid or nickel cadmium type. Provide sufficient capacity to operate the complete alarm system in normal or supervisory (non-alarm) mode for a period of 24 hours. Following this period of operation on battery power, the battery shall have sufficient capacity to operate all components of the system, including all alarm indicating devices in alarm or supervisory mode for a period of 5 minutes.
- L. Accessories: The contractor shall furnish the necessary accessories
- M. Circuit Conductors: Copper; provide 200 feet extra; color code and label.
- N. Locks and Keys: Deliver keys to Owner.
 - 1. Provide the same standard lock and key for each key operated switch and lockable panel and cabinet; provide 5 keys of each type
- O. Instruction Charts: Printed instruction chart for operators, showing steps to be taken when a signal is received (normal, alarm, supervisory, and trouble); easily readable from normal operator's station.
 - 1. Frame: Stainless steel or aluminum with polycarbonate or glass cover.
 - 2. Provide one for each control unit where operations are to be performed.
 - 3. Obtain approval of Owner prior to mounting; mount in location acceptable to Owner.
 - 4. Provide extra copy with operation and maintenance data submittal.
- P. Storage Cabinet for Spare Parts and Tools: Steel with baked enamel finish, size appropriate to quantity of parts and tools.
 - 1. Padlock eye and hasp for lock furnished by Owner.
 - 2. Locate as directed by Owner.

PART 3 EXECUTION

4.01 INSTALLATION

- A. Install in accordance with applicable codes, NFPA 72, CEC 2022, and the contract documents.

- B. Installation personnel shall be supervised by persons who are qualified and experienced in the installation, inspection, and testing of fire alarm systems. Examples of qualified personnel shall include, but not be limited to, the following:
 - 1. Factory trained and certified personnel.
 - 2. National Institute of Certification in Engineering Technologies (NICET) fire alarm level II certified personnel.
 - 3. Personnel licensed or certified by state or local authority.
- C. Conceal all wiring, conduit, boxes, and supports where installed in finished areas.
- D. Install all wiring in conduit, 3/4" minimum. No exception.
- E. Existing Fire Alarm Equipment shall be maintained, and new control equipment and devices shall be 100% compatible with the existing system.
- F. Water-Flow and Valve Supervisory Switches: Connect for each sprinkler valve required to be supervised.
- G. Install instruction cards and labels.

4.02 CLEANING AND ADJUSTING

- A. Cleaning: Remove paint splatters and other spots, dirt, and debris. Clean unit internally using methods and materials recommended by manufacturer.
- B. Occupancy Adjustments: When requested within one year of date of Substantial Completion, provide on-site assistance in adjusting sound levels and adjusting controls and sensitivities to suit actual occupied conditions. Provide up to three visits to the site for this purpose.

4.03 INSPECTION AND TESTING FOR COMPLETION

- A. Notify Owner 7 days prior to beginning completion inspections and tests.
- B. Notify authorities having jurisdiction and comply with their requirements for scheduling inspections and tests and for observation by their personnel.
- C. Provide the services of the installer's supervisor or person with equivalent qualifications to supervise inspection and testing, correction, and adjustments.
- D. Prepare for testing by ensuring that all work is complete and correct; perform preliminary tests as required.
- E. Provide all tools, software, and supplies required to accomplish inspection and testing.
- F. Perform inspection and testing in accordance with NFPA 72 and requirements of local authorities; document each inspection and test.
- G. Correct defective work, adjust for proper operation, and retest until entire system complies with Contract Documents.
- H. Diagnostic Period: After successful completion of inspections and tests, Operate system in normal mode for at least 14 days without any system or equipment malfunctions.
 - 1. Record all system operations and malfunctions.

2. If a malfunction occurs, start diagnostic period over after correction of malfunction.
3. Owner will provide attendant operator personnel during diagnostic period; schedule training to allow Owner personnel to perform normal duties.
4. At end of successful diagnostic period, fill out and submit NFPA 72 "Inspection and Testing Form."

4.04 OWNER PERSONNEL INSTRUCTION

- A. Provide the following instruction to designated Owner personnel:
 1. Hands-On Instruction: On-site, using operational system.
 2. Classroom Instruction: Owner furnished classroom, on-site or at other local facility.
 3. Factory Instruction: At control unit manufacturer's training facility.
- B. Basic Operation: One-hour sessions for attendant personnel, security officers, and engineering staff; combination of classroom and hands-on:
 1. Initial Training: 1 session pre-closeout.
- C. Detailed Operation: Two-hour sessions for engineering staff; assume NICET level I qualifications or equivalent; combination of classroom and hands-on:
 1. Initial Training: 1 session pre-closeout.
- D. Maintenance Technicians: Detailed training for electrical technicians, on programming, maintaining, repairing, and modifying; factory training:
 1. Initial Training: One 3-day session, pre-closeout.
- E. Furnish the services of instructors and teaching aids; have copies of operation and maintenance data available during instruction.
- F. Provide means of evaluation of trainees suitable to type of training given; report results to Owner.

4.05 CLOSEOUT

- A. Closeout Demonstration: Demonstrate proper operation of all functions to Owner.
 1. Be prepared to conduct any of the required tests.
 2. Have at least one copy of operation and maintenance data, preliminary copy of project record drawings, input/output matrix, and operator instruction chart(s) available during demonstration.
 3. Have authorized technical representative of control unit manufacturer present during demonstration.
 4. Demonstration may be combined with inspection and testing required by authority having jurisdiction; notify authority having jurisdiction in time to schedule demonstration.
 5. Repeat demonstration until successful.

4.06 MAINTENANCE

- A. See Section 01 70 00 - Execution and Closeout Requirements, for additional requirements relating to maintenance service.

- B. Provide to Owner, at no extra cost, a written maintenance contract for entire manufacturer's warranty period, to include the work described below.
- C. Perform routine inspection, testing, and preventive maintenance required by NFPA 72, including:
 - 1. Maintenance of fire safety interface and supervisory devices connected to fire alarm system.
 - 2. Repairs required, unless due to improper use, accidents, or negligence beyond the control of the maintenance contractor.
 - 3. Record keeping required by NFPA 72 and authorities having jurisdiction.
- D. Provide trouble call-back service upon notification by Owner:
 - 1. Provide on-site response within 24 hours of notification.
 - 2. Include allowance for call-back service during normal working hours at no extra cost to Owner.
 - 3. Owner will pay for call-back service outside of normal working hours on an hourly basis, based on actual time spent at site and not including travel time; include hourly rate and definition of normal working hours in maintenance contract.
- E. Provide a complete description of preventive maintenance, systematic examination, adjustment, cleaning, inspection, and testing, with a detailed schedule.
- F. Maintain a log at each fire alarm control unit, listing the date and time of each inspection and call-back visit, the condition of the system, nature of the trouble, correction performed, and parts replaced. Submit duplicate of each log entry to Owner's representative upon completion of site visit.
- G. Comply with Owner's requirements for access to facility and security.

END OF SECTION

EARTHWORK

PART 1 - GENERAL

1.02 RELATED WORK SPECIFIED ELSEWHERE

- A. Section 01 50 00, Construction Facilities and Temporary Controls.
- A. Section 01 57 13, Erosion Control
- B. Section 32 16 00, Site Concrete.
- C. Section 32 80 00, Irrigation.
- D. Section 32 90 00, Landscaping.

1.03 QUALITY ASSURANCE

- A. Use only new materials and products, unless existing materials or products are specifically shown otherwise on the Drawings to be salvaged and re-used.
- B. All materials, components, assemblies, workmanship and installation are to be observed by the Owner's Inspector of Record. Work not so inspected is subject to uncovering and replacement.
- C. The representatives of the Owner's testing lab will not act as supervisor of construction, nor will they direct construction operations. Neither the presence of the Owner's testing lab representatives nor the testing by the Owner's testing lab shall excuse the contractors or subcontractors for defects discovered in their work during or following completion of the project. Correcting of inadequate compaction or moisture content is the sole responsibility of the contractor.
- D. Tests (See Part 3 for Compaction Testing).
- E. Contractor shall be solely responsible for all subgrades built. Failures resulting from inadequate compaction or moisture content are the responsibility of the contractor. Contractor shall be solely responsible for any and all repairs.

1.04 SUBMITTALS

- A. Manufacturer's Data: Submit list and complete descriptive data of all products proposed for use. Include manufacturer's specifications, published warranty or guarantee, installation instructions, and maintenance instructions.

1.05 WARRANTY

- A. Refer to General Conditions and Section 01 78 36.

1.06 REFERENCES AND STANDARDS

- A. General: Site survey, included in the drawings, was prepared by Warren Consulting Engineers and is the basis for data regarding current conditions. While the survey is deemed generally accurate, there exists discrepancies and variations due to elapsed time, weather, etc. Existing dirt grades may vary 0.2 ft. from that shown.
- B. Site Visitation: All bidders interfacing with existing conditions shall visit the site prior to bid to verify general conditions of improvements. Discrepancies must be reported prior to the bid for clarification.
- C. ASTM International (ASTM):
 - 1. D698-00 - Test Methods for Moisture-Density Relations of Soils and Soil-Aggregate Mixtures, Using 5.5 lb (2.49 Kg) Rammer and 12 inch (304.8 mm) Drop.
 - 2. D1556-00 - Test Method for Density of Soil in Place by the Sand-Cone Method.
 - 3. D1557-12E1 - Test Methods for Moisture-Density Relations of Soils and Soil-Aggregate Mixtures Using 10 lb. (4.54 Kg) Rammer and 18 inch (457 mm) Drop.
 - 4. D3017-05 Test Methods for Moisture Content of Soils and Soil-Aggregate Mixture by Nuclear Methods (Shallow Depth).
 - 5. D422-63(2007) e1 Test Method for Particle Size Analysis of Soil.
 - 6. D4318-17E1 Test Method for Liquid Limit, Plastic Limit, and Plasticity Limit.
- D. CALTRANS Standard Specifications Section 17.
- E. CAL-OSHA, Title 8, Section 1590 (e).
- F. Any work within the street, highway or right-of-way shall be performed in accordance with the requirement of the governmental agencies having jurisdiction, and shall not begin until all of those governing authorities have been notified.

1.07 DELIVERY, STORAGE AND HANDLING

- A. Transport, store and handle in strict accord with the local jurisdiction.
- B. Make delivery to job when notified by Contractor verifying that the job is ready to receive the work of this Section and that arrangements have been made to properly store, handle and protect such materials and work.

1.08 PROJECT CONDITIONS

- A. Existing civil, mechanical and electrical improvements are shown on respective site plans to the extent known. Should the Contractor encounter any deviation between actual conditions and those shown, he is to immediately notify the Architect before continuing work.
- B. Excavation dewatering may be necessary. Contractor shall provide any and all tools, equipment and labor necessary for excavation dewatering no matter what the source. Dewatering shall be continuous until all site utilities are installed and backfilled.

1.09 EXISTING SITE CONDITIONS

- A. Contractor shall acquaint himself with all site conditions. If unknown active utilities are encountered during work, notify Architect promptly for instructions. Failure to notify will make Contractor liable for damage to these utilities arising from Contractor's operations subsequent to discovery of such unknown active utilities.

1.10 ON SITE UTILITY VERIFICATION AND REPAIR PROCEDURES

- A. Ground-breaking requirements:
 - 1. All underground work performed by a Contractor must be authorized by the District's Construction Manager or the Low Voltage Consultant prior to start of construction.
 - 2. The Contractor is to obtain and keep the original School's construction utility site plans on site during all excavation operations. Contractor can contact the District's Construction Manager, Facilities Manager, or the Low Voltage Consultant to procure the drawings.
- B. Underground Utility Locating:
 - 1. The contractor shall hire an Underground Utility Locating Service to locate existing underground utility pathways in areas affected by the scope of work for excavation.
 - 2. Contractor must use an underground utility locator service with a minimum of 3 years' experience. The equipment operator must have demonstrated experience.
 - 3. The Underground Utility Locator Service must have the use of equipment with the ability to locate by means of inductive clamping, induction, inductive metal detection, conductive coupling, or TransOnde (Radio detection) to generate signals, passive locating (free scoping) for "hot" electric, and metal detector.
 - 4. The Underground Utility Locator Service must be able to locate existing utilities at a depth of at least 72".
 - 5. The Underground Utility Locator Service must be able to locate but are not limited to locating the following types of utility pathways:
 - a) All conduit pathways containing 110 volt or greater 50-60Hz electrical wire.
 - b) All conduit pathways containing an active cable TV system.
 - c) All conduit pathways containing wire or conductor in which a signal can be attached and generated without damaging or triggering the existing systems.
 - d) All empty conduit pathways or pipe in which a signal probe or sonde (miniature transmitter) can be inserted.
 - e) All conduit pathways containing non-conductive cables or wires in which a signal probe or sonde (miniature transmitter) can be inserted.
 - f) All plastic and other nonconductive water lines in which a TransOnde Radio detection) or other "transmitter" can be applied to create a low frequency pressure waive (signal) without damaging or triggering the existing systems.

- g) All copper or steel waterlines and plastic or steel gas lines
- 6. All markings made by the Underground Utility Locator Service or other shall be clear and visible.
- 7. The contractor shall maintain all markings made by Underground Utility Locator Service or other throughout the entire length of the project.
- 8. The Underground Utility Locator Service shall provide the contractor with two sets of maps showing the location of utilities and average depth. They will be referenced to permanent buildings. Contractor will deliver one copy to the district at no additional charge.
- 9. Contractor is responsible to contact Underground Service Alert (U.S.A. 800/227-2600) and receive clearance prior to any excavation operations.
- 10. Contractor shall inform the (District's Construction Manager) (Architect) (Owner) no later than five (5) days prior to the date scheduled for the utility locator service to be on site.

1.11 PROTECTION

- A. Adequate protection measures shall be provided to protect workmen and passers-by on and off the site. Adjacent property shall be fully protected throughout the operations. Blasting will not be permitted. Prevent damage to adjoining improvements and properties both above and below grade. Restore such improvements to original condition should damage occur. Replace trees and shrubs outside building area disturbed by operations.
- B. In accordance with generally accepted construction practices, the Contractor shall be solely and completely responsible for working conditions at the job site, including safety of all persons and property during performance of the work. This requirement shall apply continuously and shall not be limited to normal working hours.
- C. Any construction review of the Contractor's performance conducted by the Geotechnical Engineer is not intended to include review of the adequacy of the Contractor's safety measures, in, on, or near the construction site.
- D. Provide shoring, sheeting, sheet piles and or bracing to prevent caving, erosion or gulying of sides of excavation.
- E. Surface Drainage: Provide for surface drainage during period of construction in manner to avoid creating nuisance to adjacent areas. The contractor shall make a reasonable effort on a daily basis to keep all excavations and the site free from water during entire progress of work, regardless of cause, source, or nature of water.
- F. Adjacent streets and sidewalks shall be kept free of mud, dirt or similar nuisances resulting from earthwork operations.
- G. The site and adjacent influenced areas shall be watered as required to suppress dust nuisance. Dust control measures shall be in accordance with the local jurisdiction.

1.12 SEASONAL LIMITS

- A. No fill material shall be placed, spread or rolled during unfavorable weather conditions. When work is interrupted by rains, fill operations shall not be resumed until field tests indicate that moisture content and density of fill are satisfactory.
- B. Excessively wet fill material shall be bladed and aerated per section 3.08, B.

1.13 TESTING

- A. General: Refer to Section 01 45 00 – Quality Requirements.
- B. Geotechnical Engineer: Owner is retaining a Geotechnical Engineer to determine compliance of fill with Specifications, and to direct adjustments in fill operations. Costs of Geotechnical Engineer will be borne by Owner; except those costs incurred for re-tests or re-inspection will be paid by Owner and back charged to Contractor.
 - 1. If Contractor elects to process or mine onsite materials for use as Suitable Fill, Aggregate Sub Base, Aggregate Base, Rock, Crushed Rock or sand the cost of all testing of this material shall be paid for by the Contractor.
 - 2. Testing of import fill for compliance with Department of Toxic Substance Control (DTSC) shall be paid for by the Contractor.

PART 2 - PRODUCTS

2.01 MATERIALS

- A. Engineered Fill Materials: All fill shall be of approved local materials supplemented by imported fill if necessary. "Approved" local materials are defined as local soils tested and approved by Geotechnical Engineer free from debris, and concentrations of clay and organics; and contain rocks no larger than 3-inches in greatest dimension. The soil and rock should be thoroughly blended so that all rock is surrounded by soil. This may require mixing of the soil and rock with a dozer prior to placement and compaction. Clods, rocks, hard lumps or cobbles exceeding 3-inches in final size shall not be allowed in the upper 12 inches of any fill.
- B. Imported Engineered Fill Material: Imported fill may be required to complete work. Proposed import fill material shall meet the above requirements; shall be similar to the native soils. Import fill shall meet the above requirements; shall have plasticity index of 12 or less; an Expansion Index of 20 or less; be free of particles greater than 3-inches in largest dimension; be free of contaminants and have corrosion characteristics within the acceptable limits. All import fill material shall be tested and approved by Soils Engineer prior to transportation to the site. Proposed fill material shall comply with DTSC guidelines to include Phase 1 environmental site assessment and related tests. Refer to the October 2001 DTSC Information Advisory for clean imported fill material.
 - 1. DTSC TESTING: Site work contractor is to coordinate testing with an analytical lab, hired by the owner, licensed by the State of California for the DTSC testing. The costs associated with the testing will be paid by the contractor.
 - 2. DTSC testing shall include documentation as to the previous land use, location, and history. Soils shall be analyzed for all compounds of concern to ensure the imported soil is uncontaminated and acceptable. Testing shall be performed per the recommendations included in DTSC Imported Fill Advisory

http://www.dtsc.ca.gov/Schools/upload/SMP_FS_Cleanfill-Schools.pdf). Soils shall be tested prior to import to the project site.

Lab shall determine geographically which tests and analysis comparison will be appropriate for the testing. (CAM 17 / Title 22); (RWQCB) Regional Water Quality Control Board; or (OEHHA) Office of Environmental Health Hazard Assessment.

3. Frequency of testing shall be conducted in accordance with DTSC's Imported Fill Advisory as follows;

Fill Material Sampling Schedule

| Area of Individual Borrow Area | Sampling Requirements |
|---------------------------------------|---|
| 2 Acres or less | Minimum of 4 samples |
| 2 to 4 Acres | Minimum of 1 sample every ½ Acre |
| 4 to 10 Acres | Minimum of 8 Samples |
| Greater than 10 Acres | Minimum of 8 locations with 4 subsamples per location |

Volume of Borrow Area Stockpile

| | |
|--------------------------------|---|
| Up to 1,000 Cubic Yards | 1 sample per 250 cubic yards |
| 1,000 to 5,000 Cubic Yards | 4 samples for the first 1000 cubic Yards + 1 sample per each additional 500 cubic yards |
| Greater than 5,000 Cubic Yards | 12 samples for the first 5,000 cubic yards + 1 sample per each additional 1,000 cubic yards |

4. Reports/ Documentation
 - a. Results of the testing analysis shall be sent to the Owner; Architect; Project Inspector, Project Civil Engineer, DTSC, and DSA. Letter shall reference DSA file and application numbers.
- C. Landscape Backfill Material:
1. The top 3" of native topsoil stripped from the site may be used for landscape backfill material provided it meets the requirements as specified in Section 329000.
 2. Imported Topsoil may be required to complete work. See Section 329000 for requirements. Proposed Topsoil material shall comply with DTSC guidelines to include Phase 1 environmental site assessment and related tests. Refer to the October 2001 DTSC Information Advisory for clean imported fill material.
- D. Water: Furnish all required water for construction purposes, including compaction and dust control. Water shall be potable.
- E. Aggregate Base: Provide Class 2 3/4" Aggregate Base conforming to standard gradation as

specified in Cal Trans Standard Specifications, Section 26,-1.02A.

PART 3 – EXECUTION

3.01 INSPECTION LAYOUT AND PREPARATION

- A. Prior to installation of the work of this Section, carefully inspect and verify by field measurements that installed work of all other trades is complete to the point where this installation may properly commence
- B. Layout all work, establish grades, locate existing underground utilities, set markers and stakes, setup and maintain barricades and protection facilities; all prior to beginning actual earthwork operations. Layout and staking shall be done by a licensed Land Surveyor or Professional Civil Engineer.
- C. Verify that specified items may be installed in accordance with the approved design.
- D. In event of discrepancy, immediately notify Owner and the Architect. Do not proceed in discrepant areas until discrepancies have been fully resolved.

3.02 PERFORMANCE

- A. GENERAL:
 - 1. General: Do all grading, excavating and cutting necessary to conform finish grade and contours as shown. All cuts shall be made to true surface of subgrade.
 - 2. Archaeological Artifacts: Should any artifacts of possible historic interest be encountered during earthwork operations, halt all work in area of discovery and immediately contact the Architect for notification of appropriate authorities.
 - 3. Degree of Compaction: Percentage of maximum density, hereinafter specified as degree of compaction required, means density equivalent to that percentage of maximum dry density determined by ASTM D1557 Compaction Test method, and such expressed percentage thereof will be minimum acceptable compaction for specified work.
 - 4. Moisture Content: Moisture content shall be as noted below and as called for on the plans. Moisture content shall be maintained until subgrade is covered by surfacing materials.

3.03 DEMOLITION, DISPOSAL AND DISPOSITION OF UNDESIRABLE MAN-MADE FEATURES

- A. All other obstructions, such as abandoned utility lines, septic tanks, concrete foundations, and the like shall be removed from site. Excavations resulting from these removal activities shall be cleaned of all loose materials, dish shaped, and widened as necessary to permit access for compaction equipment. Areas exposed by any required over-excavation should be scarified to a depth of 12", moisture-conditioned to 2% above optimum moisture content, and recompacted to at least 90% of the maximum dry density.

3.04 TESTING AND OBSERVATION

- A. All grading and earthwork operations shall be observed by the Geotechnical Engineer or his representative, serving as the representative of the Owner.

- B. Field compaction tests shall be made by the Geotechnical Engineer or his representative. If moisture content and/or compaction are not satisfactory, Contractor will be required to change equipment or procedure or both, as required to obtain specified moisture or compaction. Notify Geotechnical Engineer at least 48 hours in advance of any filling operation.
- C. Earthwork shall not be performed without the notification or approval of the Geotechnical Engineer or his representative. The Contractor shall notify the Geotechnical Engineer at least two (2) working days prior to commencement of any aspect of the site earthwork.
- D. If the Contractor should fail to meet the compaction or design requirements embodied in this document and on the applicable plans, he shall make the necessary readjustments until all work is deemed satisfactory, as determined by the Geotechnical Engineer or Architect/Engineer.
- E. After each rain event Geotechnical Engineer shall test fill material for optimum moisture. Do not place any fill material until desired moisture is achieved.

3.05 CLEARING AND GRUBBING

- A. Prior to grading, remove all debris off-site. Remove trees and brush including the root systems. Holes resulting from tree and brush removal should be prepared and backfilled in accordance with paragraphs 3.07, 3.08, 3.09, and 3.10. This may require deepening and/or widening the holes to adequately remove disturbed soil and provide room for compaction equipment. Strip the surface of all organics. Stripping's meeting the requirements of Section 32 90 00 may be used in landscape areas only.

3.06 CUTTING

- A. Do all cutting necessary to bring finish grade to elevations shown on Drawings.
- B. When excavation through roots is necessary, cut roots by hand.
- C. Carefully excavate around existing utilities to avoid unnecessary damage. The contractor shall anticipate and perform hand work near existing utilities as shown on the survey, without additional claims or cost.

3.07 STRUCTURAL EXCAVATION

- A. Unsuitable Ground: Any errors in structural excavation, soft ground, or clay soils found when excavating shall be reported to Architect. In no case shall work be built on any such soft or clayey unsuitable surface without direction from the Architect. Restore excavations to proper elevation with engineered fill material compacted to 90% of dry density.

3.08 SUBGRADE PREPARATION

- A. Grade compact and finish all subgrades within a tolerance of 0.10' of grades as indicated on Drawings and so as not to pool water. Subgrade within concrete walks shall be within 0.05' of grades indicated.
- B. After clearing, grubbing and cutting, subsurface shall be plowed or scarified to a depth of at least 12", until surface is free from ruts, hummocks or other uneven features and uniform and free from large clods. Moisture condition to 2% above optimum moisture content and recompact to at least 90% of the maximum dry density as determined by ASTM Test Method D1557. If the existing soils are at a water content higher than specified, the contractor shall provide multiple

daily aerations by ripping, blading, and/or disking to dry the soils to a moisture content where the specified degree of compaction can be achieved. After seven consecutive working days of daily aerations, and the moisture content of the soil remains higher than specified, the contractor shall notify the architect. If the existing soils have a moisture content lower than specified, the contractor shall scarify, rip, water and blade existing soil to achieve specified moisture content. The contractor shall make proper allowance in schedule and methods to complete this work.

- C. Subgrade in areas to receive landscaping shall be compacted to 90%.
- D. Where Contractor over-excavates building pads through error, resulting excavation shall be recompacted as engineered fill at Contractor's expense.

3.09 PLACING, SPREADING AND COMPACTING FILL MATERIAL IN PAVEMENT AREAS

- A. Selected fill material shall be placed in layers which, when compacted, shall not exceed 6 inches in compacted thickness. Each layer shall be spread evenly and thoroughly mixed to insure uniformity in moisture content.
- B. Selected fill material shall be moisture-conditioned to specified moisture content. Selected fill material shall be unfrozen. When moisture content of fill material is below that specified, add water until proper moisture content is achieved. When moisture content is above that specified, aerate by blading or other methods mentioned in 3.08 B until moisture content is satisfactory.
- C. After each layer has been placed, mixed and spread evenly, it shall be thoroughly compacted to a minimum of 90% as determined by the ASTM D1557 Compaction Test. Compact each layer over its entire area until desired density has been obtained.
- D. Recompaction of Fill in Trenches and Compaction of Fill Adjacent to Walls: Where trenches must be excavated, backfill with material excavated. Place in lifts that when compacted do not exceed 6", moisture conditioned to 2% above optimum moisture content, and compact to a minimum of 90% relative compaction in building pad and paved areas, and to 90% relative compaction in landscape areas.
- E. Jetting of fill materials will not be allowed.

3.10 FINAL SUBGRADE COMPACTION

- A. Paved Areas: Upper 12" of all final subgrades supporting pavement sections and all other flatwork shall be brought to specified moisture content and shall be uniformly compacted to not less than 90% of maximum dry density, regardless of whether final subgrade elevation is attained by filling, excavation, or is left at existing grade. After acceptance of final compaction test, contractor shall maintain the required moisture content of subgrade until concrete flatwork is placed.
- B. Other Fill and Backfill: Upper 12" of all other final subgrades or finish grades shall be compacted to 90% of maximum dry density.
- C. Gravel Fill: Do not place compacted gravel fill until after underground work and foundations are in place. Compact gravel fill with vibratory plate or similar equipment to preclude settlement.

3.11 PLACING, SPREADING, AND COMPACTION OF LANDSCAPE BACKFILL MATERIALS

- A. All landscaped areas shall receive topsoil. After subgrade under landscape area has been scarified and brought to 90% maximum dry density, top soil shall be placed evenly to depth of 12" at 85% of maximum dry density.
- B. Project Inspector must verify that materials are uniformly spread to minimum depth specified.

3.13 SLOPE CONSTRUCTION

- A. Cut slopes shall be constructed to no steeper than 3:1 (horizontal:vertical). Fill slopes shall be constructed to no steeper than 3:1 (horizontal:vertical). Prior to placement of fill on an existing slope the existing slope shall be benched. The benches shall be in a ratio of 3 horizontal to 1 vertical. The face of the fill slopes shall be compacted as the fill is placed, or the slope may be overbuilt and then cut back to the design grade. Compaction by track walking will not be allowed.

3.14 FINISH GRADING

- A. At completion of project, site shall be finished graded, as indicated on Drawings. Finish grades shall be "flat graded" to grades shown on the drawing. Mounding of finish grades will not be allowed unless otherwise directed on the landscape drawings. Tolerances for finish grades in drainage swales shall be $\pm 0.05'$. Tie in new and existing finish grades. Leave all landscaped areas in finish condition for lawn seeding. Landscaped planters shall be graded uniformly from edge of planter to inlets. If sod is used for turf areas the finish grade on which it is placed shall be lowered to allow for sod thickness.
- B. All landscape areas shall be left free of rock or foreign material as specified in Section 32 90 00.
- C. All landscape areas shall be approved by Architect prior to any planting.

3.15 SURPLUS MATERIAL

- A. Excavated material not required for grading or backfill shall be removed from site at contractor's expense.

3.16 CLEANING

- A. Remove from fill all vegetation, wood, form lumber, casual lumber, and shavings, in contact with ground; buried wood will not be permitted in any fill.

END OF SECTION

FOR REFERENCE ONLY
SECTION 31 23 33
TRENCHING AND BACKFILLING

PART 1 – GENERAL

1.01 RELATED WORK SPECIFIED ELSEWHERE

- A. Section 01 50 00, Construction Facilities and Temporary Controls.
- B. Section 31 00 00, Earthwork.
- C. Section 33 40 00, Site Drainage.
- D. Section 33 00 00, Site Utilities.
- E. Section 32 80 00, Irrigation.
- F. Section 32 12 00, Asphalt Concrete Paving

1.02 QUALITY ASSURANCE

- A. Use only new materials and products, unless existing materials or products are specifically shown otherwise on the Drawings to be salvaged and re-used.
- B. All materials, components, assemblies, workmanship and installation are to be observed by the Owner's Inspector of Record. Work not so inspected is subject to uncovering and replacement.
- C. Contractor / Installer shall have been in business for five (5) years providing/finishing similar size projects and complexity.

1.03 SUBMITTALS

- A. Submit Manufacturers data and shop drawings.

1.04 WARRANTY

- A. Submit fully executed warranty for work and materials in this section.

1.05 REFERENCES AND STANDARDS

- A. California Building Code current edition.
- B. California Plumbing Code current edition.

1.06 DELIVERY, STORAGE AND HANDLING

- A. Transport, store and handle in strict accord with the local jurisdiction.
- B. Make delivery to job when notified by Contractor verifying that the job is ready to receive the work of this Section and that arrangements have been made to properly store, handle and protect such materials and work.

1.07 PROJECT CONDITIONS

- A. Contractor shall acquaint himself with all existing site conditions. If unknown active utilities are encountered during work, notify Architect promptly for instructions. Failure to notify will make Contractor liable for damage to these utilities arising from Contractor's operations subsequent to discovery of such unknown active utilities.
- B. Field verify that all components, backing, etc. by others are installed correctly to proceed with installation of products as herein specified.
- C. Trench dewatering may be necessary. Contractor shall provide any and all tools, equipment and labor necessary for trench dewatering no matter what the source. Dewatering shall be continuous until all site utilities are installed and backfilled.

1.09 PROTECTION

- A. Adequate protection measures shall be provided to protect workers and passers-by on and off the site. Adjacent property shall be fully protected throughout the operations. Blasting will not be permitted. Prevent damage to adjoining improvements and properties both above and below grade. Restore such improvements to original condition should damage occur. Replace trees and shrubs outside building area disturbed by operations. Repair all trenches in grass areas with new sod (seeding not permitted) and "stake-off" for protection.
- B. Contractor shall be solely and completely responsible for working conditions at the job site, including safety of all persons and property during performance of the work. This requirement shall apply continuously and shall not be limited to normal working hours.
- C. Any construction review of the Contractor's performance conducted by the Architect or Owner is not intended to include review of the adequacy of the Contractor's safety measures, in, on or near the construction site.
- D. Provide shoring, sheeting, sheet piles and or bracing to prevent caving, erosion or gulying of sides of excavation.
- E. Surface Drainage: Provide for surface drainage during period of construction in manner to avoid creating nuisance to adjacent areas. Keep all excavations free from water during entire progress of work, regardless of cause, source or nature of water.
- F. Adjacent streets and sidewalks shall be kept free of mud, dirt or similar nuisances resulting from earthwork operations.
- G. The site and adjacent influenced areas shall be watered as required to suppress dust nuisance.
- H. Trees: Carefully protect existing trees which are to remain.

1.10 TRENCH SAFETY PROVISIONS

- A. General Contractor shall be solely responsible for safety design, construction and coordination with agencies having jurisdiction. If such plan varies from shoring system standards established by Construction Safety Orders, plan shall be prepared by registered civil or structural engineer.

- B. Nothing herein shall be deemed to allow use of shoring, sloping or protective system less effective than that required by Construction Safety Orders of California State Division of Industrial Safety.
- C. When trenching through paved surface, provide steel trench plates to cover open trenches daily until trenches are backfilled.

1.11 SEASONAL LIMITS

- A. No backfill material shall be placed, spread or rolled during unfavorable weather conditions. When work is interrupted by heavy rains, full operations shall not be resumed until field tests indicate that moisture content and density of fill are satisfactory.
- B. Material above optimum moisture shall be processed per section 31 00 00, 3.08, B.

1.12 TESTING

- A. General: Refer to Section 01 45 00 – Quality Requirements.

PART 2 – PRODUCTS

2.01 MATERIALS

- A. Backfill materials: Pipeline and conduit trench backfill as shown on the plans and as specified below.
 - 1. ¾ inch crush rock.
 - 2. Native Materials: Soil native to Project Site, free of wood, organics, and other deleterious substances. Rocks shall not be greater than ___-inches.
 - 3. Sand: Fine granular material, free of organic matter, mica, loam or clay.
 - 4. Lean Mix Concrete/Controlled Density Backfill: 2 sacks cement slurry.
 - 5. Class 2 aggregate base, ¾” rock, per Caltrans section 26-1.02B
- B. Water: Furnish all required water for construction purposes, including compaction and dust control. Water shall be potable.
- C. Provide other bedding and backfill materials as described and specified in Section 31 00 00, Section 33 40 00 and Divisions 15 and 16.

PART 3 – EXECUTION

3.01 INSPECTION

- A. Verification of Conditions:
 - 1. Examine areas and conditions under which work is to be performed.

2. Identify conditions detrimental to proper or timely completion of work and coordinate with General Contractor to rectify.

3.02 COORDINATION

- A. General Contractor shall coordinate work as herein specified, in accordance with drawings and as required to complete scope of work with all related trades.

3.03 INSTALLATION

- A. Perform work in accordance with pipe manufacturer’s recommendations, as herein specified and in accordance with drawings.

3.04 TRENCHING

- A. Make all trenches open vertical construction with sufficient width to provide free working space at both sides of trench around installed item as required for caulking, joining, backfilling and compacting; not less than 12 inches wider than pipe or conduit diameter, unless otherwise noted.
- B. Carefully excavate around existing utilities to avoid unnecessary damage. The contractor shall anticipate and perform hand work near existing utilities as shown on the survey, without additional claims or cost.
- C. Trench straight and true to line and grade with bottom smooth and free of edges or rock points.
- D. Where depths are not shown on the plans, trench to sufficient depth to give minimum fill above top of installed item measured from finish grade above the utility as follows:
 1. Sewer pipe: depth to vary
 2. Storm drain pipe: depth to vary
 3. Water pipe - Fire Supply: 36 inches
 4. Water pipe – Domestic Supply: 30 inches
- E. Where trench through existing pavement saw cut existing pavement in straight lines. Grind existing asphalt on each side of trench 3” wide x ½ the depth of the section. Apply tack coat to vertical surfaces before installing new asphalt. Replace asphalt and concrete pavement sections to matched existing conditions. All new asphalt patch shall receive two coats seal coat. In concrete pavement provide expansion and control joints to match existing joint layout.

3.05 BACKFILL

- A. Pipe Trench Backfill is divided into two zones:
 1. Bedding: Layer of material directly under the pipe upon which the pipe is laid.
 2. Initial Backfill: Backfill from the top of the bedding to 12 inches (compacted) over the top of the pipe.

B. Bedding and Initial Backfill:

1. Type of material for Bedding and Pipe Zone shall be as required by Drawings.
2. Compaction of Bedding and Initial Backfill shall be achieved by vibratory plate as necessary to consolidate material.
3. Backfill shall be brought up at substantially the same rate on both sides of the pipe and care shall be taken so that the pipe is not floated or displaced. Material shall not be dropped directly on pipe.

C. Backfill Compaction:

1. Backfill shall be placed in layers which, when compacted shall not exceed 6 inches in thickness. Each layer shall be spread evenly and thoroughly mixed to insure uniformity. Do not backfill over, wet, frozen or soft subgrade surfaces. Employ a placement method that does not disturb or damage foundation walls, perimeter drainage, foundation damp-proofing, waterproofing or protective cover.
2. When moisture content of fill material is below that required to achieve specified density, add water until proper moisture content is achieved. When moisture content is above that required, aerate by blading or other methods until specified moisture content is met, see section 310000, 3.08, B.
3. After each layer has been placed, mixed and spread evenly, it shall be thoroughly compacted to ____% of maximum dry density while at specified moisture content. Compact each layer over its entire area until desired density has been obtained.
4. The top ____ inches of subgrade compaction under pavement or building shall be per Earthwork section 31 00 00.
5. Compaction: All backfill operations shall be observed by the Inspector of Record and/or Geotechnical Engineer. Field density tests shall be made to check compaction of fill material. If densities are not satisfactory, Contractor will be required to change equipment or procedure or both, as required to obtain specified densities. Notify Inspector and Architect at least 24 hours in advance of any operation.

E. Backfill in Areas Previously Lime or Cement Treated

1. If trenching is necessary in areas that have been previously lime treated the contractor shall backfill the trench with class 2 aggregate base, with minimum section equal to the lime treated section and compacted to 95%.

3.06 TRENCH AND SITE RESTORATION

- A. Finished surface of trenches shall be restored to a condition equal to, or better than the condition as existed prior to excavation work.

3.07 PROTECTION

- A. Protect existing surfaces, structures, and utilities from damage. Protect work by others from damage. In the event of damage, immediately repair or replace to satisfaction of Owner.

- B. Repair existing landscaped areas to as new condition. Replant trees, shrubs or groundcover with existing materials if not damaged or with new materials if required. Replace damaged lawn areas with sod, no seeding will be permitted.
- C. Replace damaged pavement with new compatible matching materials. Concrete walks to be removed to nearest expansion joint and entire panel replaced. Asphalt to be cut neatly and replaced with new materials.
- D. Any existing materials removed or damaged due to trenching to be returned to new condition.

3.08 SURPLUS MATERIAL

- A. Remove excess excavated material, unused materials, damaged or unsuitable materials from site.

3.09 CLEANING

- A. Contractor will keep the work areas in a clean and safe condition so his rubbish, waste, and debris do not interfere with the work of others throughout the project and at the completion of work.
- B. After completion of work in this section, remove all equipment, materials, and debris. Leave entire area in a neat, clean, acceptable condition.

END OF SECTION

SECTION 32 11 23 AGGREGATE BASE COURSES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Aggregate base course.
- B. Paving aggregates.
- C. Soil sterilization.

1.02 RELATED REQUIREMENTS

- A. Section 31 22 00 - Grading: Preparation of site for base course.
- B. Section 31 23 16.13 - Trenching: Compacted fill over utility trenches under base course.
- C. Section 31 23 23 - Fill: Compacted fill under base course.
- D. Section 32 12 16 - Asphalt Paving: Finish and binder asphalt courses.
- E. Section 32 13 13 - Site Concrete: Finish concrete surface course.

1.03 REFERENCE STANDARDS

- A. AASHTO T 180 - Standard Method of Test for Moisture-Density Relations of Soils Using a 4.54-kg (10-lb) Rammer and a 457-mm (18-in.) Drop.
- B. ASTM D698 - Standard Test Methods for Laboratory Compaction Characteristics of Soil Using Standard Effort (12,400 ft-lbf/ft³ (600 kN-m/m³)).
- C. ASTM D1556/D1556M - Standard Test Method for Density and Unit Weight of Soil in Place by Sand-Cone Method.
- D. ASTM D1557 - Standard Test Methods for Laboratory Compaction Characteristics of Soil Using Modified Effort (56,000 ft-lbf/ft³ (2,700 kN-m/m³)).
- E. ASTM D2487 - Standard Practice for Classification of Soils for Engineering Purposes (Unified Soil Classification System).
- F. ASTM D6938 - Standard Test Methods for In-Place Density and Water Content of Soil and Soil-Aggregate by Nuclear Methods (Shallow Depth).
- G. SSPWC (Greenbook) - Standard Specifications for Public Works Construction.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Samples: 10 lb sample of each type of aggregate; submit in air-tight containers to testing laboratory.
- C. Materials Sources: Submit name of imported materials source.
- D. Certificates of Conformance: Aggregate and sterilant materials.
- E. Installer's Qualification Statement.

- F. Aggregate Composition Test Reports: Results of laboratory tests on proposed and actual materials used.
- G. Compaction Density Test Reports.

1.05 QUALITY ASSURANCE

- A. Regulatory Requirements: Where reference is made to Standard Specifications, the following shall apply.
 - 1. Perform off-site Work in public rights-of-way in accordance with requirements of authorities having jurisdiction, including SSPWC (Greenbook). For conditions not indicated otherwise on Contract Drawings, conform to Standard Details adopted by authorities having jurisdiction.
 - 2. Perform on-site Work as indicated and referenced on Contract Drawings and as specified herein.
- B. The quantity of volatile organic compounds (VOC) used in weed killer, tack coat, primer and other materials shall not exceed limits permitted under current regulations of:
 - 1. South Coast Air Quality Management District (AQMD).
- C. Source Quality Control: Obtain materials from one source throughout.

1.06 DELIVERY, STORAGE, AND HANDLING

- A. When necessary, store materials on site in advance of need.
- B. When aggregate materials need to be stored on site, locate where directed by District.
- C. Aggregate Storage, General:
 - 1. Separate differing materials with dividers or stockpile separately to prevent intermixing.
 - 2. Prevent contamination.
 - 3. Protect stockpiles from erosion and deterioration of materials.

PART 2 PRODUCTS

2.01 MATERIALS

- A. Aggregate Type Class II: Coarse or crushed aggregate, conforming to Municipality, SSPWC Section 200-2.2..
- B. Coarse Aggregate: Pit run washed stone; free of shale, clay, friable material and debris.
 - 1. Graded in accordance with ASTM D2487 Group Symbol GW.
- C. Herbicide: Comply with all applicable environmental protection and hazardous materials laws and regulations .
 - 1. Comply with current EPA acceptable standard and the California Department of Pesticide Regulations for soils sterilant.
 - 2. Comply with the "Healthy Schools Act" as amended in 2014.
 - 3. Obtain product approval from District, prior to purchase and use.
 - 4. Sterilant: Commercial grade for commercial application.
 - a. Selected as appropriate for the environment in which is it to be placed.

FOR REFERENCE ONLY

5. Contractor shall be licensed with the State of California to apply sterilant.
6. Sterilant: Commercial grade for commercial application.
7. Payment for soil sterilization: Include full compensation for application and all materials and incidental work required.
8. Application Rate: Follow manufacturer recommendations.
9. Acceptable Manufacturers:
 - a. Dow AgroSciences; Spike 80DF: www.dowagro.com.
 - b. Pro-Serve Inc.; Bare-Spot Monobor-Chlorate: www.pro-serveinc.com.
 - c. Casoron 50W by Uniroyal Chemical Co., Inc.
 - d. Substitutions: See Section 01 60 00 - Product Requirements.
- D. Geotextile Fabric: Non-biodegradable, non-woven, placed under base;.

2.02 SOURCE QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements for general requirements for testing and analysis of aggregate materials.
- B. Where aggregate materials are specified using ASTM D2487 classification, testing of samples for compliance shall be provided before delivery to site.
- C. If tests indicate materials do not meet specified requirements, change material and retest.
- D. Provide materials of each type from same source throughout the Work.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Establishment of Grades
 1. Set grade stakes per Section 01 70 00 - Execution and Closeout Requirements.
 2. All work shall conform to the lines, elevations, and grades shown on the Drawings.
 - a. Use three consecutive points set on the same slope together so that any variation from a straight grade can be detected.
 - b. Report any such variation to the Architect. Contractor shall be responsible for any error in the grade of the finished work.
 3. Grade or location stakes lost or disturbed, shall be reset by the Surveyor at no additional expense to District.
 4. Areas having drainage gradients of 2 percent or more, provide elevation stakes, set with instrument, at grid intervals of 25 feet.
 - a. Intermediate stakes may be set by using a tightly-drawn string line over the tops of adjacent stakes.
 - b. Grade stakes must be set at all grade breaks, grade changes, etc.
 5. Areas having drainage gradients of less than 2 percent; provide elevation stakes, set with instrument, at 10 foot intervals.
 - a. Grade stakes must be set at all grade breaks, grade changes, etc.

- B. Verify that survey bench marks and intended elevations for the work are as indicated.
- C. Verify substrate has been inspected, gradients and elevations are correct, and is dry.

3.02 PREPARATION

- A. Stockpiling:
 - 1. Clear and level storage sites prior to stockpiling of material.
 - 2. Stockpile all materials, including approved material available from excavation and grading, in the manner and at the locations designated.
 - 3. Aggregates shall be stockpiled on the cleared and leveled areas designated by the Construction Manager to prevent segregation.
 - 4. Materials obtained from different sources shall be stockpiled separately.
- B. Soil Sterilant:
 - 1. Sterilize soil areas to receive paving.
 - 2. Apply soil sterilant in accordance with manufacturer's instructions and applicable environmental regulations.
 - 3. Take care to confine application to the areas to be paved. Sterilant shall not be applied within 2 feet of planting areas.
- C. Correct irregularities in substrate gradient and elevation by scarifying, reshaping, and re-compacting.
- D. Do not place aggregate on soft, muddy, or frozen surfaces.

3.03 INSTALLATION

- A. Place and compact aggregate base material in accordance with SSPWC (Greenbook), Subsection 301-2. Place aggregate base below curbs and gutters and paving also, compacted to 95 percent at vehicular traffic and 90 percent at pedestrian-only traffic.
- B. Application of Base Course:
 - 1. After preparing the subgrade, Avoid all vehicular or machine traffic on the subgrade.
 - a. Should it be necessary to haul over the prepared subgrade, drag and roll the traveled way as frequently as may be necessary to remove ruts, cuts, and breaks in the surface.
 - b. Rake and hand tamp all cuts, ruts, and breaks in the surface of the subgrade that are not removed by the above operations.
 - c. Equip with pneumatic tires all equipment used for transporting materials over the prepared subgrade.
 - 2. Do not permit continued use of sections of prepared subgrade for hauling, so as to cut up or deform it from the true cross-section. Protect the prepared subgrade from all traffic.
 - 3. Maintain the surface in its finished condition until the succeeding layer is placed.
- C. Under Bituminous Concrete Paving:
 - 1. Compact to 95 percent of maximum dry density and 90 percent at pedestrian-only traffic.

FOR REFERENCE ONLY

2. It is required that areas of exterior asphalt pavement be underlain by a layer of aggregate base material which meets the requirements, Thickness of base layer is as shown on the Drawings and varies per the Usage Type area.
 - a. It is required that the upper 12 inches of soils below asphalt pavement base material be over-excavated and consist predominantly of satisfactory soil materials and/or approved imported fill.
 - 1) Engineered Fill: See Section 31 23 23 - Fill.
 - b. It is required that the exposed bottom surface soils, below overexcavation, be scarified to the recommended depth of 8 inches, moisture conditioned to achieve optimum moisture content, but not higher than 2 percent above optimum, and then re-compacted to a minimum 90 percent relative compaction before any fill materials are placed.
 3. The above subgrade preparation recommendations are based on the assumption that soils encountered during field exploration are representative of soils throughout the site.
 - a. However, there can be unforeseen and unanticipated variations in soils between points of subsurface exploration. For this reason, the actual subgrade preparation will have to be determined on the basis of in-grading observations and testing performed by representatives of the project geotechnical consultant.
 4. Provide grade stakes and elevations by a California Licensed Surveyor (LS) for the Geotechnical Engineer.
 - a. Verify that the over-excavation depths, shown on the construction drawings for asphalt concrete pavement structural sections, have been achieved prior to re-compaction.
 5. Correct irregularities by dressing down or filling as may be required, to bring areas to true subgrade elevations.
 6. Where filling is required, scarify the subgrade to bond the new material to the in place material; use additional material as required at no additional cost. Subject to the approval of the Architect.
 7. Remove excess material from the site to a legal disposal area.
- D. Under Portland Cement Concrete Paving:
1. Compact to 95 percent of maximum dry density and 90 percent at pedestrian-only traffic.
- E. Place aggregate in maximum 4 inch layers and roller compact to specified density.
- F. Level and contour surfaces to elevations and gradients indicated.
- G. Add small quantities of fine aggregate to coarse aggregate as appropriate to assist compaction.
- H. Add water to assist compaction. If excess water is apparent, remove aggregate and aerate to reduce moisture content.
- I. Use mechanical tamping equipment in areas inaccessible to compaction equipment.
- J. Apply herbicide to finished surface.

3.04 TOLERANCES

- A. Subgrade Tolerances:
 - 1. Subgrade for Pavement: Do not vary more than 0.02 ft..
 - 2. Subgrade for Subbase or Base Material: Do not vary more than 0.04 ft..
 - 3. Variations within the above specified tolerances shall be compensating so that the average grade and cross section specified are met.
- B. Flatness: Maximum variation of 1/4 inch measured with 10 foot straight edge.
- C. Scheduled Compacted Thickness: Within 1/4 inch.
- D. Variation From Design Elevation: Within 1/2 inch.

3.05 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements for general requirements for field inspection and testing.
- B. Compaction density testing shall be performed on compacted aggregate base course in accordance with ASTM D1556 or ASTM D6938.
- C. Results will be evaluated in relation to compaction curve determined by testing uncompacted material in accordance with AASHTO T 180, ASTM D698 ("standard Proctor"), or ASTM D1557 ("modified Proctor").
- D. If tests indicate work does not meet specified requirements, remove work, replace and retest.
- E. Proof roll compacted aggregate at surfaces that are under slabs-on-grade and paving.

3.06 CLEANING

- A. Remove unused stockpiled materials, leave area in a clean and neat condition. Grade stockpile area to prevent standing surface water.
- B. Leave borrow areas in a clean and neat condition. Grade to prevent standing surface water.

END OF SECTION

ASPHALT CONCRETE PAVING

PART 1 - GENERAL

1.02 RELATED WORK SPECIFIED ELSEWHERE

- A. Section 01 50 00, Construction Facilities and Temporary Controls.
- B. Section 31 00 00, Earthwork.
- C. Section 31 23 33, Trenching and Backfilling.
- D. Section 32 80 00, Irrigation
- E. Section 33 40 00, Site Drainage.

1.03 QUALITY ASSURANCE

- A. Use only new materials and products, unless existing materials or products are specifically shown otherwise on the Drawings to be salvaged and re-used.
- B. All materials, components, assemblies, workmanship and installation are to be observed by the Owner's Inspector of Record. Work not so inspected is subject to uncovering and replacement.
- C. The representatives of the Owner's testing lab will not act as supervisor of construction, nor will they direct construction operations. Neither the presence of the Owner's testing lab representatives nor the testing by the Owner's testing lab shall excuse the contractors or subcontractors for defects discovered in their work during or following completion of the project. Correcting inadequate compaction is the sole responsibility of the contractor.
- D. Contractor shall provide verification that asphalt mix temperature meets the requirements of this specification at time of application.
- E. Contractor shall be solely responsible for all subgrades built. Any repairs resulting from inadequate compaction are the responsibility of the contractor.
- F. Sieve analysis from testing laboratories identifying rock/sand percentages within the asphalt mix shall have a testing date within 90 days of contract signing.
- G. Sieve analysis from a testing laboratory identifying rock/sand percentages within the class 2 aggregate base rock shall have a testing date within 90 days of contract signing.

1.04 SUBMITTALS

- A. Manufacturer's Data: Submit list and complete descriptive data of all products proposed for use. Include manufacturer's specifications, published warranty or guarantee, installation instructions, and maintenance instructions.

1.05 WARRANTY

- A. Refer to General Conditions.

1.06 REFERENCES AND STANDARDS

- A. ANSI/ASTM D698-00 - Test Methods for Moisture-Density Relations of Soils and Soil-Aggregate Mixtures, Using 5.5 lb (2.49 Kg) Rammer and 12 inch (304.8 mm) Drop.
- B. ANSI/ASTM D1556-00 - Test Method for Density of Soil in Place by the Sand-Cone Method.
- C. ANSI/ASTM D1557-02 - Test Methods for Moisture-Density Relations of Soils and Soil-Aggregate Mixtures Using 10 lb. (4.54 Kg) Rammer and 18 inch (457 mm) Drop.
- D. ANSI/ASTM D 3017-05 Test Methods for Moisture Content of Soils and Soil-Aggregate Mixture by Nuclear Methods (Shallow Depth).
- E. ANSI/ASTM D 4318-05 Test Method for Liquid Limit, Plastic Limit, and Plasticity Limit.
- F. CALTRANS Standard Specifications.
- G. CAL-OSHA, Title 8, Section 1590 (e).
- H. Any work within the street, highway or right-of-way shall be performed in accordance with the requirement of the governmental agencies having jurisdiction, and shall not begin until all of those governing authorities have been notified.

1.07 DELIVERY, STORAGE AND HANDLING

- A. Transport, store and handle in strict accord with the local jurisdiction.
- B. Make delivery to job when notified by Contractor verifying that the job is ready to receive the work of this Section and that arrangements have been made to properly store, handle and protect such materials and work.

1.08 PROJECT CONDITIONS

- A. Environmental Requirements:
 - 1. Base Course: Do not lay base course on muddy subgrade, during wet weather, or when atmospheric temperature is below 40 degrees F.
 - 2. Asphalt Surfacing: Do not apply asphaltic surfacing on wet base, during wet weather, or when atmospheric temperature is below 50 degrees F.

1.09 EXISTING SITE CONDITIONS

- A. Contractor shall acquaint himself with all site conditions. If unknown active utilities are encountered during work, notify Architect promptly for instructions. Failure to notify will make Contractor liable for damage to these utilities arising from Contractor's operations subsequent to discovery of such unknown active utilities.

1.10 PROTECTION

- A. Adequate protection measures shall be provided to protect workmen and passers-by on and off

the site. Adjacent property shall be fully protected throughout the operations. Blasting will not be permitted. Prevent damage to adjoining improvements and properties both above and below grade. Restore such improvements to original condition should damage occur. Replace trees and shrubs outside building area disturbed by operations.

- B. In accordance with generally accepted construction practices, the Contractor shall be solely and completely responsible for working conditions at the job site, including safety of all persons and property during performance of the work. This requirement shall apply continuously and shall not be limited to normal working hours.
- C. Any construction review of the Contractor's performance conducted by the owner's representative is not intended to include review of the adequacy of the Contractor's safety measures, in, on, or near the construction site.
- D. Surface Drainage: Provide for surface drainage during period of construction in manner to avoid creating nuisance to adjacent areas. The contractor shall make a reasonable effort on a daily basis to keep all excavations and the site free from water during entire progress of work, regardless of cause, source, or nature of water.
- E. Adjacent streets and sidewalks shall be kept free of mud, dirt or similar nuisances resulting from earthwork operations.
- F. The site and adjacent influenced areas shall be watered as required to suppress dust nuisance. Dust control measures shall be in accordance with the local jurisdiction.

1.11 SEASONAL LIMITS

- A. No fill material shall be placed, spread or rolled during unfavorable weather conditions. When work is interrupted by rains, fill operations shall not be resumed until field tests indicate that moisture content and density of fill are satisfactory.

1.12 TESTING

- A. General: Refer to Section 01 40 00 – Quality Requirements.
- B. Geotechnical Engineer: Owner is retaining a Geotechnical Engineer to determine compliance of fill with Specifications, and to direct adjustments in fill operations. Costs of Geotechnical Engineer will be borne by Owner; except those costs incurred for re-tests or re-inspection will be paid by Owner and backcharged to Contractor.

PART 2 - PRODUCTS

2.01 MATERIALS

- A. Sterilant: Soil sterilizer shall be Esplanade 200 SC or approve equal and approved for use in California.
 - 1. Soil sterilizer shall be applied in strict accordance with manufacturer's instructions.
- B. Base Course Aggregate: State Specifications, Section 26, Class 2 aggregate base (3/4" max.).
- C. Asphalt Binder: Steam-refined paving asphalt conforming to State Specifications, Section 92,

viscosity grade PG 64-10. Asphalt binder additives for HMA per Caltrans approved list of manufacturer's.

- D. Liquid Asphalt Tack Coat: Per CALTRANS section 94.
- E. Surface Course Aggregate: Mineral aggregates for Class "A" asphalt concrete, conforming to State Specifications 39-2.02, ½" maximum, medium gradation. 3/8" maximum gradation at Playcourt.
- F. Seal Coat: shall be a pre-mixed asphalt emulsion blended with select fillers and fibers such as, or equal to:
 - 1. "Park-Top No. 302", Western Colloid Products.
 - 2. "OverKote", Reed and Gram.
 - 3. "Drivewalk", Conoco Oil.
- G. Wood Headers and Stakes: Pressure treated.
- H. Pavement Marking: Colors as directed by Architect. Colors of painted traffic stripes and pavement markings must comply with ASTM D 6628.
 - 1. Waterborne traffic line - colors white, yellow and black, State specification PTWB-01R2.
 - 2. Waterborne traffic line for the international symbol of accessibility and other curb markings – blue, red and green, Federal specification TT-P-1952F.
- I. Precast Concrete Bumpers: 3000 psi at 28 day minimum strength; 48" length unless otherwise indicated; provide with steel dowel anchors and concrete epoxy.
- J. Pavement Epoxy; K-Lite; Ktepx-590; Ennis Epoxy HPS2 or an approved equal.
- K. Crack Filler;
 - 1. Cracks up to ½": QPR model CAR08, 10oz asphalt crack filler; Star STA-FLEX Trowel Grade crack filler or approved equal.
 - 2. Cracks ¼" – 1": "Docal 1100 Viscolastic, distributed by Conoco, Inc., Elk Grove, CA, (916) 685-9253, or approved equal.
 - 3. Cracks greater than 1": Hot Mix, Topeka.
- L. Reclaimed Asphalt Paugment (RAP). HMA Class A may be produced using RAP providing it does not exceed 15% of the aggregate blend.

2.02 MIXES

- A. General: Plant mixed conforming to State Specifications, Section 39, Class A, ½" maximum, medium gradation. 3/8" maximum gradation shall be used at hardcourt.
- B. Temperature of Hot Mix Asphalt: Not less than 275 degrees F nor more than 325 degrees F when added to aggregate.

- C. Temperature of Hot Mix Aggregate: Not less than 250 degrees F nor more than 325 degrees F when asphalt is added.
- D. Temperature of Hot Mix Asphalt Concrete: Asphalt shall be not less than 285 degrees at time of application, nor more than 350 degrees. Asphalt not meeting the required temperature shall not be used.
- E. Temperature of Warm Mix Asphalt: Mixing and placement; Per the approved manufactures heat range recommendations for mixing and placement.

PART 3 - EXECUTION

3.01 EXAMINATION OF CONDITIONS

- A. Conditions of Work in Place: Subsurfaces which are to receive materials specified under this Section shall be carefully examined before beginning work hereunder, and any defects therein shall be reported, in writing, to the Architect. Work shall not be started until such defects have been corrected. Starting of work shall imply acceptance of conditions as they exist.

3.02 PREPARATION

- A. Sub-Grade: Clean, shape and compact to hard surface free from elevations or depressions exceeding 0.05' in 10' from true plan. Compact per Section 31 00 00. Compaction and moisture content shall be verified immediately prior to placement of aggregate base. Proof roll subbase in presence of geotechnical engineer prior to placement of aggregate base.
- B. Cleaning: Existing surfaces and new surface shall be clean of all dirt, sand, oil or grease. All cracks shall be cleaned and free of all debris and vegetation. Hose down entire area with a strong jet of water to remove all debris.

3.03 INSTALLATION

- A. Headers:
 - 1. General: Install as edging to asphalt paving, except where adjoining existing pavement, concrete curbs, walks or building.
 - 2. Existing Headers: Remove existing headers where new paving will join existing. Saw cut existing asphalt to provide clean edge.
 - 3. Lines and Levels: Install true to line and grade. Cut off tops of stakes 2-inches below top of header so they will not be visible on completion of job.
- B. Asphalt Paving:
 - 1. Base Course: Install in accord with State Specifications, Section 26. Compact to relative compaction of not less than 95%, ASTM D1557. The material shall be deposited on the subgrade in such a manner as to provide a uniform section of material within five percent tolerance of the predetermined required depth. Deposition will be by spreader box or bottom dump truck to prevent segregation of the material. The material so deposited on the subgrade shall have sufficient moisture which, in the opinion of the project inspector is adequate to prevent excessive segregation. It shall then be

immediately spread to its planned grade and cross section. Undue segregation of material, excessive drifting or spotting of material will not be permitted. If in the opinion of the site geotechnical engineer, the material is unsuitably segregated, it shall be removed or completely reworked to provide the desired uniformity of the material.

- a. Moisture content and compaction of base material shall be tested immediately prior to placement of asphalt paving.
2. Sterilant: Apply specified material at manufacturer's recommended rate. Applicator of sterilant material shall be responsible for determining location of all planter areas. Apply specified material over entire base course area just prior to application of asphalt. Follow manufacturer's printed directions.
3. Liquid Asphalt Tack Coat: Apply as "tack coat" to all vertical surfaces of existing paving, curbs, walks, and construction joints in surfacing against which paving is to be placed.
4. Asphalt Concrete Surface Course:
 - a. Comply with State Specifications, 39-6 except as modified below.
 - 1) Final gradation shall be smooth, uniform and free of ruts, humps, depressions or irregularities, with a minimum density of 91% of the theoretical maximum specific gravity determined by California Test Method #309. Maximum variation 1/8 inch in 10' when measured with steel straightedge in any one direction. Test paved areas for proper drainage by applying water to cover area. Correct portions that do not drain properly by patching with plant mix. In no case shall accessible parking spaces or loading and unloading areas exceed 2% slope in any direction.
 - 2) Asphalt material shall be delivered to the project site in a covered condition to maintain acceptable temperature. Onsite inspector shall verify temperature of asphalt upon truck arrival to the site.
5. Placement and adjustment of Frames, Covers, Boxes and Grates: The Contractor shall set and adjust to finish grade all proposed and existing frames, covers, boxes, and grates of all manholes, drop inlets, drain boxes, valves, cleanouts, electrical boxes and other appurtenant structures prior to placement of asphaltic concrete.
6. Water Testing: All paved areas shall be water tested, to check drainage, in the presence of the project inspector prior to placement of seal coat. The surface of asphalt paving shall not vary more than 1/8 inch above or below the grade established on the plans. If variations in grade are present, they will be corrected by overlaying paving and/or pavement removal and replacement as directed by the Architect.
7. Patching: Cut existing paving square and plumb at all edges to be joined by new paving. In trenches; grind existing asphalt on each side of trench 6" wide x 1/2 the depth of the section. Apply tack coat to vertical surfaces before installing new work. Warp carefully to flush surface, with seal over joints, and feather edge. Sawcut, remove and patch existing paving where cutting is necessary for installation of piping or conduits under Divisions 2, 15 and 16. Apply two coats seal coat to all trench patches.

C. Seal Coat:

1. Apply seal coat to all new asphalt paving surfaces, paved areas or trench patch. Seal coat shall be applied no sooner than 30 days from time of asphalt placement, no exceptions.
 2. Surface Preparation: surface and cracks shall be clean of all dirt, sand, oil or grease. All cracks shall be filled to a level condition after curing. Make multiple fill applications until a level condition is achieved. Failure to do so will be the reason for rejection. Hose down entire area with a strong jet of water to remove all debris. Remove soft, loose, or otherwise damaged areas of asphalt concrete to full depth of damage and replace with compacted hot mix asphalt concrete as specified herein. Minor holes and imperfections may be patched using hot mix asphalt or mastic using sand/SS-1-H. Use wire brush for removal of oil and grease; prime with shellac or synthetic resin as recommended by manufacturer of pavement sealer material.
 3. Seal Coat Seal Application: Thoroughly mix materials and apply in the presence of the onsite inspector. Failure to do so will be cause for rejection. Apply in accordance with manufacturer's written instructions.
 - a. The minimum application rate for each applied coat shall be 30gals per 1000 sq. ft. Two coats of sealcoat will be required.
 - b. Clean-Up and Precautions: As recommended by pavement sealer material manufacturer.
- D. Asphalt Concrete Overlay Paving:
1. Comply with State Specifications, 39-6 except as modified below.
 2. Grind or remove existing asphalt concrete paving at limits of overlay paving to provide a minimum 1-1/2" overlay thickness. Limits of grinding or removal shall be field verified to insure that finished paving surface will have a one percent minimum slope.
 3. Thoroughly clean surface to remove vegetation, dirt, sand, gravel and water from surface and from cracks. Vegetation shall be treated 7 days prior to removal with an herbicide.
 4. Cracks greater than 1 inch shall be filled with hot mix asphalt and rolled and compacted. Cracks less than one inch shall be filled with crack filler. Potholes shall be filled with hot-mix rolled and compacted. Contractor shall have Engineer approve crack and pothole repair prior to overlay. Provide leveling courses of hot mix asphalt as required to achieve finish grades shown on the drawings.
 - a. Cracks less than one inch in width shall be level after curing. Contractor shall make multiple filling applications as necessary to achieve a level condition.
 5. Place overlay when ambient air temperature is 40 degrees F. and rising, and when pavement is dry.
 6. An asphalt tack coat shall be applied to existing surface area at a rate of 0.20 gallons per square yard. Application width shall be width of fabric plus 2 to 6 inches.
 7. Place, spread and compact asphalt overlay to provide a minimum density of 95% of maximum theoretical unit weight as determined by California Test Method #304.

FOR REFERENCE ONLY

Maximum variation 1/8" in 10' when measured with steel straight edge in any one direction. Test paved areas for proper drainage by applying water to cover area. Correct portions that do not drain properly by patching with plant mix. Minimum compacted overlay thickness 1 1/2 inches.

[EDIT NOTE] USE ONLY FOR SITE THAT REQUIRE SANDSEAL MIX.

D. Sandseal application:

1. Coat No. 1 and 2: Add 300 lbs of #30 mesh sand and 1 gallon of SS-1 to 100 gallons of pavement sealer. Apply at 2.0 gallons per 100 sq. ft.
2. Coat No. 3: Apply pavement sealer at minimum rate of 1.0 gallon per 100 sq. ft.

E. Pavement Marking: pavement markings shall be done only after the seal coat has thoroughly dried. Existing surfaces to be striped with traffic paint shall be cleaned of dust, dirt, grime, oil, rust or other contaminants which will impair the quality of work or interfere with proper bond of paint coats. Surfaces shall be thoroughly cleaned by whatever means necessary that will satisfactorily accomplish the purpose without damage to asphalt concrete. Provide measured layouts, temporary markings, templates, and other means necessary to provide required marking. Prepare and apply paint in accordance with manufacturer's instructions; paint shall be applied by spray and shall achieve complete coverage free from voids and thin spots. Where indicated on the Drawings, paint parking stall strips, lettering, arrows, accessible symbols, playfield markings, etc. on asphalt concrete paving. Paint strips shall be 4 inches wide (except otherwise indicated) and applied with two (2) coats of herein specified Traffic Line Paint; white (except as otherwise specified or indicated).

1. Paints shall be delivered to the site in unopened containers.
 - a. Paint shall not be diluted, or watered down.
 - b. Paint shall be applied in 10-12 wet mil thickness (4-6 mil dried). Each coat thickness shall be verified by the project inspector.
2. International Accessible Symbol: Symbol shall be white figures on a blue background. Blue shall be equal to PMS 293C. Lines and symbols shall be accurately formed and true to line and form; lines shall be straight and uniform in width. Painted edges shall be clean cut and free from raggedness, and corners shall be cut sharp and square. Tolerances: Apply striping within a tolerance 1/2 inch in 50 feet. Apply markings and striping to widths indicated with a tolerance of 1/4 inch on straight sections and 1/2 inch on curved sections.

F. Colors: As directed by Architect

G. Precast Concrete Bumpers: Install in location where shown, using steel rebar dowels, and epoxy.

3.04

DEFECTIVE ASPHALT;

Defective asphalt is as described below.

- A. Exposed rock pockets on the finished surface that lack the # 8- #200 fines that is required per the sieve analysis.
- B. Asphalt not placed to the design grades.

- C. Asphalt that ponds water.
- D. Asphalt that was compacted below the minimum required temperature and is cracked.
- E. Asphalt that fails to meet the minimum compaction requirements.
- F. Asphalt that lacks the minimum thickness required per plan.
- G. New asphalt contaminated by a petroleum product, or spilled paint.
- H. Asphalt that has depressions, cracks, scored divits from dumpster wheels, heavy equipment use, heavy construction products,
- I. Asphalt placed on pumping, unstable sub-grades.

3.05 CLEANING

- A. Upon completion of work of this Section promptly remove from the working area all scraps, debris and surplus material of this Section.
- B. Clean excess material from surface of all concrete walks and utility structures.

END OF SECTION

SECTION 32 14 13 PRECAST CONCRETE UNIT PAVING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Non-interlocking concrete paver units and detectable warning pavers.
- B. Detectable warning pavers.
- C. Edge restraints.

1.02 RELATED REQUIREMENTS

- A. Section 32 13 13 - Site Concrete: Concrete subbase for pavers.

1.03 REFERENCE STANDARDS

- A. ASTM C33/C33M - Standard Specification for Concrete Aggregates.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide characteristics of paver unit, detectable warning pavers, dimensions, and special shapes.
- C. Product Data: Provide characteristics of polymeric sand, including base material, additive(s), compressive strength, and color.
- D. Samples: Submit two samples of each paver type, illustrating style, size, color range and surface texture of units being provided.
- E. Manufacturer's Installation Instructions: Indicate substrate requirements and installation methods.
- F. Maintenance Materials: Provide the following for District's use in maintenance of project.
 - 1. See Section 01 60 00 - Product Requirements, for additional provisions.
 - 2. Extra Pavers: 10 of each type and size.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Non-interlocking Concrete Pavers:
 - 1. Oldcastle: www.oldcastle.com/#sle.
 - 2. Orco Pavingstones: orcopaverwalls.com.
 - 3. Stepstone Inc: www.stepstoneinc.com.
 - 4. Tectura Designs, a division of Wausau Tile Inc: www.tecturadesigns.com/#sle.
 - 5. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.

2.02 MATERIALS

- A. Non-interlocking Pavers: Precast concrete.
 - 1. Compressive Strength: Minimum of 7200 pounds per square inch.
 - 2. Absorption: 5 percent average, with maximum of 7 percent.
 - 3. Air Entrainment: 5 to 7 percent.
 - 4. Size: 12 by 12 inches.
 - 5. Thickness: 2 inches.
 - 6. Color: Selected from manufacturer's full range.
- B. Detectable Warning Pavers: Cast concrete with truncated domes, yellow color.
- C. Edging: Concrete curb, as detailed.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that substrate is level or to correct gradient, smooth, capable of supporting pavers and imposed loads, and ready to receive work of this Section.
- B. Verify gradients and elevations of substrate are correct.
- C. Verify dry weather forecast without rain for a minimum of 24 hours with temperatures above 55 degrees Fahrenheit.

3.02 PREPARATION

- A. Treat soil with herbicide to retard plant growth.
- B. See Section 32 13 13 for concrete subbase.

3.03 INSTALLATION OF SOLID PAVER UNITS

- A. Spread sand bedding evenly over prepared substrate surface to a maximum thickness of 1-1/2 inch.
- B. Dampen and roller compact sand to level and even surface.
- C. Screed and scarify top 1 inch to 1 1/2 inch of sand.
- D. Cut paver units at edges with masonry saw.
- E. Place half units at edge and interruptions. Maintain tight joints.
- F. Tamp and level paver units with mechanical vibrator until units are firmly bedded, level, and to correct elevation and gradients. Do not tamp unrestrained edges.

3.04 CLEANING

- A. Do not clean pavers until pavers and mortar are dry.
- B. Clean soiled surfaces using cleaning solution. Do not harm pavers, joint materials, or adjacent surfaces.
- C. Use non-metallic tools in cleaning operations.
- D. Rinse surfaces with clean water.

FOR REFERENCE ONLY

- E. Broom clean paving surfaces. Dispose of excess sand.
- F. See Section 01 74 19 for construction waste management and disposal.

3.05 PROTECTION

- A. Do not permit traffic over unprotected paver surface.
- B. Do not permit traffic for 48 hours after pavement placement.

3.06 MAINTENANCE

- A. See Section 01 70 00 - Execution and Closeout Requirements, for additional requirements relating to maintenance service.
- B. Provide a separate maintenance contract for specified maintenance service.

END OF SECTION

SECTION 32 15 00 AGGREGATE SURFACING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Crushed stone surfacing. (Stabilized decomposed granite walkways)
- B. Walkway edging installation.

1.02 RELATED REQUIREMENTS

- A. Section 31 10 00 - Site Clearing.
- B. Section 31 22 00 - Grading: Preparation of subbase.

1.03 REFERENCE STANDARDS

- A. ASTM C136/C136M - Standard Test Method for Sieve Analysis of Fine and Coarse Aggregates.
- B. ASTM D1557 - Standard Test Methods for Laboratory Compaction Characteristics of Soil Using Modified Effort (56,000 ft-lbf/ft³ (2,700 kN-m/m³)).
- C. ASTM D2419 - Standard Test Method for Sand Equivalent Value of Soils and Fine Aggregate.
- D. ASTM D4873/D4873M - Standard Guide for Identification, Storage, and Handling of Geosynthetic Rolls and Samples.
- E. {RSTEMP#10005085}
- F. SSPWC (Greenbook) - Standard Specifications for Public Works Construction.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Products Data: For each product specified. Submit a 5 lb. sample and sieve analysis for grading of decomposed granite or crushed 3/8" or 1/4" minus aggregate to be sent to Manufacturer prior to any construction – (allow 2 week turn around).
- C. Test Reports:
 - 1. Submit sieve analysis of proposed material to insure it meets grading requirements.
 - 2. Test Results: Supplied by an independent testing laboratory for compliance of gradation of decomposed granite material in accordance with ASTM C136/C136M.
- D. Sieve analysis and color of decomposed granite screenings shall be approved in writing from the Architect before any material is delivered to the project site.
- E. Manufacturer's Instructions: Include aggregate base course placement, installation procedures, and fill placement.
- F. Manufacturer's qualification statement.
- G. Installer's qualification statement.
- H. Samples:

FOR REFERENCE ONLY

1. Products: Five lb. sample and sieve analysis for grading of decomposed granite. Color shall be as specified on the Drawings, or as selected by Architect.
- I. Certificates: Certify that products of this section meet or exceed specified requirements.
- J. Provide Construction Manager with the following excess materials for use in future Stabilized Aggregate repair: 40 to 50 lb. Bags of the Stabilized Aggregate blended with proper amount of Stabilizer

1.05 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing products specified in this section, with not less than three years of documented experience.
- B. Installer Qualifications: Company specializing in installing work of the type specified in this section, and with at least three years of documented experience and approved by manufacturer.
- C. Paving: Replace without additional cost to the District all areas of decomposed granite surface that may become defective within one (1) year after date of acceptance.
- D. Sterilization: Maintain all areas of decomposed granite surface free of vegetation growing through from below for (90) days after date of acceptance. Any procedure required for eradication of such vegetation growth shall be done by the Contractor at no additional cost to the District.
- E. Regulatory Requirements:
 1. Placement of surfacing to comply with {RS#10005085}-302 Floor and Ground Surfaces, 11B-303 Changes in Level, and 11B-403 Walking Surfaces.
 2. Surfacing shall be stable, firm, and slip resistant and shall comply with {RS#10005085}-302 and 11B-403.

1.06 MOCK-UPS:

- A. Install 4 ft. wide x 10 ft. long mock-up of decomposed granite with stabilizer additive at location as directed by Architect.
- B. Mock to be the standard from which the work will be judged and incorporated into the work.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. See Section 01 60 00 - Product Requirements for additional requirements.
- B. Identify, store, and handle geosynthetics according to ASTM D4873/D4873M.
- C. Protect geosynthetic materials from sunlight and other ultraviolet light sources during storage.
- D. Handle geosynthetics with care and prevent dragging, dropping, or imbalanced lifting.

1.08 FIELD CONDITIONS

- A. Use lightweight hauling equipment.
- B. Exercise care in using equipment, avoiding damage to adjacent paving, walls and plant materials.
- C. Do not install decomposed granite surface material during rainy conditions or below 40 degrees.

FOR REFERENCE ONLY

- D. Temperature Requirements: Do not place geosynthetic when ambient air or base surface temperature is less than 40 degrees F or above 140 degrees F (60 degrees C).
- E. Surface Requirements: Do not place geosynthetic when the receiving surface is saturated or has ponded water.

1.09 WARRANTY

- A. See Section 01 78 00 - Closeout Submittals for additional warranty requirements.
- B. Manufacturer Warranty: Provide one year manufacturer warranty for performance. Complete forms in District's name and register with manufacturer.
- C. Installer Special Warranty: Provide 2-month (60 days) warranty for unconditional maintenance and repairs as required commencing on the Date of Substantial Completion.

PART 2 PRODUCTS

2.01 MANUFACTURER

- A. Basis of Design Product: Decomposed Granite as manufactured by Gail Materials, or approved equal.
- B. Acceptable Supplier:
 - 1. Gail Materials: www.gailmaterials.net
 - 2. Southwest Boulder & Stone: www.southwestboulder.com, or equal.
 - 3. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.

2.02 MATERIALS

- A. Crushed Stone Surfacing: Natural, washed, 3/8 inch (1 cm) stone; free of shale, clay, friable material, and debris.
 - 1. Decomposed Natural Friable Granite Screenings for Walkways.
 - 2. Conform to the grading requirements shown below.
 - a. Do not use limestone screenings or stone dust.
 - 3. Color(s): To be selected by Architect from manufacturer's full range.
 - 4. Sieve Analysis: In accordance with ASTM C136/C136M.

| SIEVE DESIGNATION | PERCENT PASSING |
|--------------------|-----------------|
| 1/2 inch | 100 |
| 3/8 inch | 90 - 100 |
| No. 4 | 50 - 100 |
| No. 30 (0.600 mm) | 25 - 55 |
| No. 100 (0.150 mm) | 10 - 20 |
| No. 200 (0.075 mm) | 5 - 18 |

- a. Sand Equivalent: 30 minimum in accordance with ASTM D2419.
 - 5. Provide screenings of clean, hard, durable particles of fragments of select granite.
 - a. Evenly mix fines throughout the aggregate.

- b. Material with one fractured face produced from gravel; Provide 50 percent retained on a No. 4 sieve, by weight.
- 6. Source Quality Control:
 - a. See Section 01 40 00 - Quality Requirements, for additional requirements.
 - b. Provide the entire quantity required from a single supply source.
- B. Stabilizer Binder:
 - 1. Patented, non-toxic, organic binder that is a colorless and odorless concentrated powder that binds decomposed granite together to produce a firm surface.
 - 2. Products:
 - a. Basis of Design Product: Natracil as Distributed by Gail Materials, or approved equal.
 - b. Minick Materials; Natracil: www.minickmaterial.com.
 - c. Stabilizer Solutions, Inc.; Stabilizer® for Stabilized Aggregate: stabilizersolutions.com.
 - d. Technisoil Global, Inc.; TechniSoil G3 - Commercial Stabilizer : technisoil.com.
 - e. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- C. Geosynthetic Fabric: Comply with SSPWC (Greenbook) Section 213-2 – “Geosynthetics”, Type N90.
- D. Aggregate Base Course: According to surface reinforcement manufacturer's recommendations.

2.03 ACCESSORIES

- A. Steel Edging:
 - 1. Dimensions: 3/16 inch thick by 4 inches deep, with overlapping joints.
 - 2. Stakes: 3/16 inch by 16 inches long x 1-3/4 inch wide at top tapering to point at bottom; located 36 inches o.c. maximum.
 - 3. Finish: Baked-on green paint, Baked-on brown paint, Baked-on black paint, or Hot-dipped galvanized.
 - 4. Color(s): To be selected by Architect from manufacturer's full range.
- B. Recycled Plastic Lumber Edging:
 - 1. Material: Lumber made from recycled polyethylene and UV stabilizers.
 - 2. Dimensions: Nominal 2 x 4 inches.
 - 3. Steel Stakes: 3/16 inch by 16 inches long x 1-3/4 inch wide at top tapering to point at bottom; located 36 inches o.c. maximum.
 - 4. Color(s): To be selected by Architect from manufacturer's full range.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that subgrade has been prepared correctly, is smooth, and is at proper grade and level.
- B. Do not begin work until subgrade is correct.

3.02 INSTALLATION

- A. Edging: Install flush with stabilized decomposed granite surfacing.
 - 1. Provide sufficient stakes to secure in place.
- B. Install aggregate base course according to surface reinforcement manufacturer's recommendations.
 - 1. Base shall be 3 inch compacted layer of recommended crushed granular road base. Make any corrections necessary to base furnished and installed to bring gravel to the elevations shown on the drawing.
 - 2. Pre-soak base material with water and compact to 95% determined by Test Method ASTM D1557 prior to installing Stabilized Aggregate. Compaction testing to be provided by project owner, one test per 2,000 square feet of base.
 - 3. Although porous, it is recommended to have proper drainage available to ensure no standing water on surface or adjacent to Stabilized Aggregate, including downspouts when placed under roof overhang and surface drains.
 - 4. Blending Stabilizer:
 - a. Thoroughly pre-mix stabilizer with aggregate at the rate of 15-lbs of stabilizer per 1-ton of aggregate. Verify with manufacturer correct stabilizer rate for your project and climate. Drop spreading of stabilizer over pre-placed aggregate or mixing by rototilling is not acceptable. Mechanically pre-mix stabilizer per manufacturer's recommendations using an approved mechanical blending unit to adequately blend stabilizer with aggregate (Bucket blending is not an approved blending apparatus). Always dry blend stabilizer and aggregate.
 - 5. Placement:
 - a. After pre-blending, place Stabilized Aggregate directly on prepared sub-grade. Level to desired grade and cross section. Depth of pathways shall be 3" for heavy foot traffic and light vehicles. DO NOT place on filter fabric. Contact manufacturer for installation on slopes greater than 8%.
 - 6. Watering:
 - a. Water heavily for full-depth moisture penetration of profile. Water activates stabilizer. Apply 25 to 45-gallons of water per 1-ton to achieve saturation. Randomly test for depth using a probing device, which reaches full depth.
 - b. Wait a minimum of 6 – 72 hours or until such time that the stabilized aggregate is able to accept compaction from a 1 to 5 ton roller without separation, plowing or any other physical compromise of the aggregate.
 - c. If surface aggregate dries significantly quicker than subsurface material, lightly mist surface before compaction.
 - 7. Compaction:
 - a. Compact stabilized aggregate to 85% relative compaction by equipment such as; a 2 to 5-ton double drum roller making 3 to 4 passes. Do not begin compaction for 6 hours after placement and up to 72 hours. DO NOT use a vibratory plate compactor or vibration feature on roller, as vibration separates large aggregate particles. If pumping or pancaking of surface occurs, surface is still too wet to roll.

FOR REFERENCE ONLY

- b. Take care in compacting surface when adjacent to planting and irrigation systems, use 8" or 10" hand tamp. Install stabilized aggregate more than 3" thick, in lifts. If 4" thick compacted (2) 2" lifts. If 5" thick compacted (2) 2.5" lifts. If stabilized aggregate is pre-moistened before installation entire 4" or 5" lift may be installed.
 - c. Lightly spray surface area following compaction. Do not disturb aggregate surface with spray action.
- C. Place surfacing or aggregate-turf pavement in maximum 4 inch (100 mm) layers.

3.03 CLEANING

- A. Remove unused or stockpiled fill, base, and reinforcement.
- B. Clean adjacent surfaces of excess sand, gravel, soil, and debris. Sweep broom clean.

3.04 PROTECTION

- A. Furnish and install construction fence around new surface to prevent public access. Fencing to be maintained in place for a minimum of 12 - 72 hours after completion of installation, or as directed by the Construction Manager. Drying period may take longer due to weather conditions.
- B. Contractor shall notify Construction Manager that landscape irrigation shall be restricted near Stabilized Aggregate surface until drying period is complete. Standing water on surface and adjacent to path shall be restricted at all times.

3.05 MAINTENANCE

- A. Remove debris, such as paper, grass clippings, or organic material by mechanically blowing or hand raking as needed. When plowing snow, use rubber baffle on plow blade or wheels on plow to lift blade 1/4" off the surface.
- B. During first year, minor amounts of loose aggregate may appear on surface (1/16 to 1/4"). If material exceeds a 1/4", redistribute over entire surface. Water to 1" depth and compact with power roller of no less than 1000-lbs. Repeat as needed. If cracking occurs, sweep fines into cracks, water thoroughly and hand tamp with an 8" – 10" hand tamp.

3.06 REPAIRS

- A. Excavate damaged area to the depth of the Stabilized Aggregate and square off sidewalls.
- B. If area is dry, moisten damaged portion lightly.
- C. Pre-blend the dry required amount of Stabilizer® with the proper amount of aggregate in a concrete mixer.
- D. Add water to the pre-blended Stabilized Aggregate. Thoroughly moisten mix with 25 to 45 gallons per 1-ton of pre-blended material or to approximately 10% moisture content.
- E. Apply moistened pre-blended Stabilized Aggregate to excavated area to finish grade.
- F. Compact with an 8" to 10" hand tamp or 250 to 300 pound roller. Keep traffic off areas for 12 to 48 hours after repair has been completed.

END OF SECTION

PART 1 - GENERAL

1.01 SECTION INCLUDES

- A. The Section describes the requirements for providing portland cement concrete paving, including accessibility ramps, sidewalks, accessible routes of travel, vehicular travel, drain structures, sewer structures, thrust blocks and for other non-structural or non-vehicular applications.

1.03 RELATED WORK SPECIFIED ELSEWHERE

- A. Section 01 45 00, Testing Lab Services.
- B. Section 31 00 00, Earthwork.

1.04 QUALITY ASSURANCE

- A. Use only new materials and products.
- B. Use materials and products of one manufacturer whenever possible.
- C. All materials, components, assemblies, workmanship and installation are to be observed by the Owner's Inspector of Record. Work not so inspected is subject to uncovering and replacement.
- D. Sieve analysis from testing laboratories identifying rock/sand percentages within the concrete mix; or class 2 aggregate base shall have the current project name and project location identified on the report. Outdated analytical reports greater than 90 days old will not be accepted

1.05 SUBMITTALS

- A. Manufacturer's Data: Submit list and complete descriptive data of all products proposed for use. Include manufacturer's specifications, published warranty or guarantee, installation instructions, and maintenance instructions.
- B. Materials list: Submit to the Architect a complete list of all materials proposed to be used in this portion of the work. Submitted items should include but are not limited to sand, gravel, admixtures, surface treatments, coloring agents, sealers, fibers, cast-in-place accessories, forming and curing products and concrete mix designs.
- C. With concrete submittal, provide documented history of mix design performance.

1.06 WARRANTY

- A. Refer to General Conditions and Section 01 78 36.

1.07 REFERENCES AND STANDARDS

- A. California Building Code, latest edition.

- B. ACI Standards, ACI 301-20.
- C. ASTM C-94, Specification for Ready-Mixed Concrete.
- D. Concrete Reinforcing Steel Institute (CRSI) Manual of Standard Practice (latest edition).
- E. ASTM – American Society for Testing and Materials.

1.08 DELIVERY, STORAGE AND HANDLING

- A. Deliver undamaged products to job in manufacturer's sealed containers and/or original bundles with tags and labels intact.
- B. Store materials in protected, dry conditions off of ground and in areas so as to not interfere with the progress of the work.
- C. Transport, store and handle in strict accord with the manufacturer's written recommendations.
- D. Make delivery to job when notified by Contractor verifying that the job is ready to receive the work of this Section and that arrangements have been made to properly store, handle and protect such materials and work.
- E. Store cement in weather tight building, permitting easy inspection and identification. Protect from dampness. Lumpy or stale cement will be rejected.
- F. Aggregates: Prevent excessive segregation, or contamination with other materials or other sizes of aggregate. Use only one supply source for each aggregate stock pile.

1.09 TESTING

- A. General: Refer to Section 01 40 00 – Quality Requirements.

1.10 ADEQUACY AND INSPECTION

- A. Design, erect, support, brace and maintain formwork and shoring to safely support all vertical and lateral loads that might be applied until such loads can be carried by concrete.
- B. Notify Inspector, Architect and DSA at least 48 hours prior to placing of concrete.

1.11 PROTECTION

- A. Finish surfaces shall be protected at all times from concrete pour. Inspect forming against such work and establish tight leak-proof seal before concrete is poured. Finish work damaged, defaced or vandalized during the course of construction shall be replaced by contractor at contractor expense.

1.12 FIELD MEASUREMENTS

- A. Make and be responsible for all field dimensions necessary for proper fitting, slopes and completion of work. Report discrepancies to Architect before proceeding.

PART 2 - PRODUCTS

2.01

MATERIALS

- A. Cement: Portland cement, ASTM C150, Type II, per ACI 301-20.
- B. Concrete Aggregates: Normal weight aggregates shall conform to ASTM C33, except as modified by this section. Combined grading shall meet limits of ASTM C33. Lightweight aggregate shall conform to ASTM C330, suitably processed, washed and screened, and shall consist of durable particles without adherent coatings.
- C. Water: Clean and free from deleterious amounts of acids, alkalis, scale, or organic materials and per ACI 301-20.
- D. Fly Ash: Western Fly Ash, conforming to ASTM C618 for Class N or Class F materials (Class C is not permitted). Not more than 15% (by mass) may be substituted for portland cement.
- E. Water Reducing Admixture: Admixture to improve placing, reduce water cement ratio, and ultimate shrinkage may be used. Provide WRDA 64 by Grace Construction Products or approved equal. Such admixture must receive prior approval and shall be included in original design mix.
- F. Air-entraining Admixture: Daravair 1000 by Grace Construction Products or approved equal.
- G. Surface Retarder (for exposed aggregate finishes): Rugasol-S by Sika Corporation or approved equal.
- H. Form Coating: Material which will leave no residue on concrete surface that will interfere with surface coating, as approved by the Architect.
- I. Reinforcement Bars: New billet steel deformed bars conforming to requirements of ASTM A615 or ASTM A706; Grade 60. Dowels for installation through expansion joints or construction joints to existing sidewalks or concrete features shall be smooth or shall be sleeved on one end for slippage.
- J. Reinforcing supports: Galvanized metal chairs or spacers or metal hangers, accurately placed 3'-0" O.C.E.W. Staggered and each support securely fastened to steel reinforcement in place. Bottom bars in footings may be supported with 3" concrete blocks with embedded wire ties. Concrete supports without wire ties will not be allowed.
- H. Truncated Domes: Vitrified Polymer Composite (VPC), Cast-In-Place Detectable/Tactile Warning Surface Tiles; "Armor-Tile", "Access Tile Tactile Systems", or approved equal. Tiles shall comply with Americans with Disabilities Act and the California Code of Regulations (CCR) Title 24, Part 2, Chapter 11B (dome spacing shall be 2.35"). Install tiles as recommended by manufacturer. Detectable warning surface shall be yellow and approximate 33538 of SAE AMS-STD-595A.
- K. Curing Compound (for exterior slabs only): Burke Aqua Resin Cure by Burke by Edoco, 1100 Clear by W.R. Meadows or accepted equal.
- L. Concrete Bonding Agent: Weld-Crete by Larson Products Corp., Daraweld C by Grace Construction Products or accepted equal.
- M. Patching Mortar: Meadow-Crete GPS, one-component, trowel applied, polymer enhanced, shrinkage-compensated, fiber reinforced, cementitious repair mortar for horizontal, vertical and overhead applications as manufactured by W.R. Meadows or accepted equal.

- N. Non-shrink Grout: Masterflow 713 Plus by Master Builders or approved equal. Premixed, non-metallic, no chlorides, non-staining and non-shrinking per CRD-C621, Corps of Engineers Specification and ASTM C 1107, Grades B and C.
- O. Aggregate Base: Class 2 AB per Caltrans specification section 26-1.02A.
- P. Expansion Joint Material: Preformed 3/8" fiber material, full depth of concrete section, with bituminous binder manufactured for use as concrete expansion joint material, as accepted by the Architect.
- Q. Joint sealant for expansion joints: Single component silicone sealant, Type S, ASTM D5893.
 - 1. Reference Standard: ASTM C920, Grade P, Class 25, Use T.
 - 2. Dow Corning 890-SL (self-leveling) Silicone, or accepted equal.
 - 3. Dow Corning 888-NS (non-sagging) Silicone, at slopes exceeding 5%. May not be used at asphalt surfaces.
 - 4. Color: Custom color as selected by Architect.
- R. Pre- Formed plastic Expansion Joint; W.R. Meadows 3/8" "Snap Cap", Tex-Trude expansion joint cap, or an approved equal.
- S. Adhesive Anchoring (Epoxy): Hilty HIT-HY 200 Safe Set, or approved equal.

2.02 CONCRETE DESIGN AND CLASS

- A. Class "B": Concrete shall have 1" max. size aggregate, shall have 3000 psi min. at 28 day strength with a maximum water to cementitious ratio no greater than 0.50. Use for exterior slabs, including walks, vehicular paved surfaces, manhole bases, poured-in-place drop inlets, curbs, valley gutters, curb & gutter and other concrete of like nature.
- B. Slump Limits: Provide concrete, at point of final discharge, of proper consistency determined by Test Method ASTM C143 with a slumps of 4" plus or minus 1".
- C. Mix Design: All concrete used in this work will be designed for strength in accordance with provisions of ACI 301-20. Should the Contractor desire to pump concrete, a modified mix design will need to be submitted for review. Fly ash may be used in concrete to improve workability in amounts up to 15% of the total cementitious weight.
- D. Air Entrainment; Per the Local Jurisdiction minimum requirements, or 3% minimum.

2.03 MIXING OF CONCRETE

- A. Conform to requirements of CBC, Chapter 19A.
- B. All concrete shall be mixed until there is uniform distribution of material and mass is uniform and homogenous; mixer must be discharged completely before the mixer is recharged.
- C. Concrete shall be Ready-mixed Concrete.
 - 1. Placement of concrete shall occur as rapidly as possible after batching and in a manner

which will assure that the required quality of the concrete is maintained. In no case may concrete be placed more than 90 minutes from batch time.

2. Water may be added to the mix only if neither the maximum permissible water-cement ratio nor the maximum slump is exceeded. In no case shall more than 10 gallons of water shall be added to a full 9 yard load, or 1 gal. per yard on remaining concrete within the drum providing load tag indicates at time of mixing at plant will allow for additional water.

2.04 MATERIALS TESTING

- A. Testing of concrete shall be performed per article 3.12 of this specification.

2.05 EQUIPMENT

- A. Handling and mixing of concrete: Project Inspector may order removal of any equipment which in his opinion is insufficient or in any way unsuitable.

PART 3 - EXECUTION

3.01 APPROVAL OF FORMS AND REINFORCEMENTS

- A. Forms and reinforcements are subject to approval by the Project Inspector, and notice of readiness to place first pour shall be given 48 hours prior to placement of concrete. Before placing concrete, clean tools, equipment and remove all debris from areas to receive concrete. Clean all reinforcing and other embedded items off all coatings oil, and mud that may impair bond with concrete.
- B. All reinforcing steel shall be adequately supported by approved devices on centers close enough to prevent any sagging.
- C. All reinforcing bar lap splices shall be staggered a minimum of 5 ft.
- D. Additional reinforcing steel shall be placed around all utility boxes, valve boxes, manhole frames and covers that are located within the concrete placements.
 1. The bars shall be placed so that there will be a minimum of 1 ½" clearance and a maximum of 3" clearance. The reinforcing steel shall be placed mid-depth of concrete slab.
- E. At all right angles or intersections of concrete walks, additional 2'x2' #5, 90 degree bars shall be added at all inside corners for additional crack control. The bars shall be placed 2" from concrete forms and supports at mid-depth of slab.

3.02 PROTECTION

- A. Protect work and materials of this Section prior to and during installation, and protect the installed work and materials of other trades.
- B. In the event of damage, make all repairs and replacements necessary to the approval of the Architect at no additional cost to the Owner.

- C. Sub-Grade in vehicular concrete paved areas: Subgrade shall be clean, shaped and compact to hard surface free from elevations or depressions exceeding 0.05' in 10' from true plan. Compact per Section 31 00 00. Compaction and moisture content shall be verified immediately prior to placement of concrete. Proof roll subbase in presence of geotechnical engineer prior to placement of aggregate base.

3.03 CLEANING

- A. Reinforcement and all other embedded items at time of placing concrete to be free of rust, dirt oil or any other coatings that would impair bond to concrete.
- B. Remove all wood chips, sawdust, dirt, loose concrete and other debris just before concrete is to be poured. Use compressed air for inaccessible areas. Remove all standing water from excavations.

3.04 FORMING

- A. Form material shall be straight, true, sound and able to withstand deformation due to loading and effects of moist curing. Materials which have warped or delaminated, or require more than minor patching of contact surfaces, shall not be reused.
- B. Build forms to shapes, lines, grades and dimensions indicated. Construct form work to maintain tolerances required by ACI 301-20. Forms shall be substantial, tight to prevent leakage of concrete, and properly braced and tied together to maintain position and shape. Butt joints tightly and locate on solid backing. Chamfer corners where indicated. Form bevels, grooves and recesses to neat, straight lines. Construct forms for easy removal without hammering, wedging or prying against concrete.
- C. Space clamps, ties, hangers and other form accessories so that working capacities are not exceeded by loads imposed from concrete or concreting operations.
- D. Build openings into vertical forms at regular intervals if necessary to facilitate concrete placement, and at bottoms of forms to permit cleaning and inspection.
- E. Build in securely braced temporary bulkheads, keyed as required, at planned locations of construction joints.
- F. Slope tie-wires downward to outside of wall.
- G. Brace, anchor and support all cast-in items to prevent displacement or distortion.
- H. During and immediately after concrete placing, tighten forms, posts and shores. Readjust to maintain grades, levels and camber.
- I. Concrete paving, Curbs, Curb and Gutters, Ramps:
 - 1. Expansion Joints: Install at locations indicated, and so that maximum distance between joints is 20' for exterior concrete unless otherwise shown. Expansion joint material shall be full depth of concrete section. Recess for backer rod and sealant where required. Expansion joints shall not exceed ¼ inch depth measured from finish surface to top of felt or sealant, and ½ inch width.
 - 2. Curbs, Valley Gutter, and Curb & Gutter: Install expansion joints at 60' on center, except

when placing adjacent to concrete walks, the expansion joints shall align with the expansion joints shown for the concrete walks. Expansion joint material shall be full depth of concrete section. Recess for backer rod and sealant will be required.

3. Isolation Joints: 3/8" felt between walls and exterior slabs or walks so that paved areas are isolated from all vertical features, unless specifically noted otherwise on plans.
4. Exterior Concrete Paving: Install expansion joints at 20' on center maximum, both directions, unless shown otherwise on plans.
5. Ramps; whether shown or not all ramps shall have control joints and expansion joints.
 - a. Control joints on ramps shall be aligned and be placed in between with the vertical posts for the handrails. The curbs, if required shall have control joints that align with the handrail posts.
 - b. Expansion joints shall be placed at the upper, intermediate, and bottom landings.

3.05 FORM COATING

- A. Before placement of reinforcing steel, coat faces of all forms to prevent absorption of moisture from concrete and to facilitate removal of forms. Apply specified material in conformance with manufacturer's written directions.
- B. Before re-using form material, inspect, clean thoroughly and recoat.
- C. Seal all cut edges.

3.06 INSTALLATION

- A. General: Reinforcement shall be accurately placed at locations indicated on the drawings within required tolerances and providing required clearances. Reinforcement shall be secured prior to placement of concrete such that tolerances and clearances are maintained. Coverage shall be in accordance with Section 1907A.7 of the CBC. Keep a person on the job to maintain position of reinforcing as concrete is placed. Reinforcement must be in place before concreting is begun. Install dowels as shown on drawings. Give notice whenever pipes, conduits, sleeves, and other construction interferes with placement; obtain method of procedure to resolve interferences. All expansion and construction joints in concrete shall have dowels of size and spacing as shown, or as approved by Architect.
- B. Placing Tolerances:
 1. Per ACI 301-20 recommended practice for placing reinforcing bars, unless otherwise shown.
- C. Splices:
 1. General: Unless otherwise shown on drawings, splice top reinforcing at midspan between supports, splice bottom reinforcing at supports and stagger splices at adjacent splices 5 foot minimum. Bar laps shall be wired together. Reinforcing steel laps shall be as follows:

- a. Lap splices in concrete: Lap splice lengths shall not be less than 62 bar diameter for No. 5 bar, 56" minimum for No. 6 bars. No. 4 bar shall have a minimum of 24" splice.
- b. All splices shall be staggered at 5 feet minimum.

3.07 INSPECTION

- A. Slope of concrete forms and finish condition shall be checked with a two foot (2') digital level.

3.08 PLACING OF CONCRETE

- A. Adjacent finish surfaces shall be protected at all times during the concrete pour and finishing. Verify that all formwork is tight and leak-proof before concrete is poured. Finish work defaced during the concrete pour and finishing shall be replaced at no extra cost to the owner.
- B. Transport concrete from mixer to place of final deposit as rapidly as practicable by methods which will prevent separation or loss of ingredients. Deposit as close as practicable in final position to avoid re-handling or flowing. Partially hardened concrete must not be deposited in work. Concrete shall not be wheeled directly on top of reinforcing steel.
- C. Placing: Once started, continue concrete pour continuously until section is complete between predetermined construction joints. Prevent splashing of concrete onto adjacent forms or reinforcement and remove such accumulation of hardened or partially hardened concrete from forms or reinforcement before work proceeds in that area.
- D. Remove form spreaders as placing of concrete progresses.
- E. Place footings as monolithic and in one continuous pour.
- F. Keep excavations free of standing water, but moisture condition sub-grade before concrete placement.
- G. Compacting: All concrete shall be compacted by mechanical vibrators. Concrete shall be thoroughly worked around reinforcement and embedded fixtures and into corners of forms. Vibrating shall not be applied to concrete which has already begun to initially set nor shall it be continued so long as to cause segregation of materials.
- H. Concrete Flatwork:
 - 1. All flatwork shall be formed and finished to required line and grades. Flatwork shall be true and flat with a maximum tolerance of 1/8" in 10' for flatness. Flatwork which is not flat and are outside of the maximum specified tolerances shall be made level by the Contractor at no additional expense to the Owner.
 - 2. Thoroughly water and soak the flatwork subgrade as required to achieve required moisture content prior to the concrete pour. Provide damming as required to keep water within the formed area and to allow for proper saturation of the subgrade.
 - 3. Concrete vibrator shall be used to assist concrete placement. Contractor shall have spare concrete vibrator on site during concrete placement.
- I. Placing in hot weather: Comply with ACI 305R-10. Concrete shall not exceed 95 degrees F at

time of placement. Concrete shall be delivered, placed and finished in a sufficiently short period of time to avoid surface dry checking. Concrete shall be kept wet continuously after tempering until implementation of curing compound procedure in accordance with this specification.

- J. Placing in cold weather: Comply with ACI 306R-16. Protect from frost or freezing. No antifreeze admixtures are permitted. When deposited concrete during freezing or near-freezing weather, mix shall have temperature of at least 50 degrees F but not more than 90 degrees F. Concrete shall be maintained at temperature of at least 50 degrees F for not less than 72 hours after placing or until it has thoroughly hardened. Provide necessary thermal coverings for any flat work exposed to freezing temperatures.
- K. Horizontal construction joint: Keep exposed concrete face of construction joints continuously moist from time of initial set until placing of concrete; thoroughly clean contact surface by chipping entire surface not earlier than 5 days after initial pour to expose clean hard aggregate solidly embedded, or by approved method that will assure equal bond, such as green cutting. If contact surface becomes contaminated with soil, sawdust or other foreign matter, clean entire surface and re-chip entire surface to assure proper adhesion.

3.09 CONCRETE FINISHES

- A. Concrete Finishing: Surface shall be free from trowel marks, depressions, ridges or other blemishes. Tolerance for flatness shall be 1/8" in 10'. Provide final finish as follows:
 - 1. Flatwork and Curbs medium broom finish: Typical finish to be used at all exterior walks and stairs.
 - 2. Ramps, heavy broom finish: Concrete surfaces with slope greater than 5% including all ramps. Brooming direction shall run perpendicular to slope to form non-slip surface
 - 3. Under no circumstances can water be added to the top surface of freshly placed concrete.
- B. Seat Walls: Steel trowel.
- C. Joints and Edges: Mark-off exposed joints, where indicated, with 1/4" radius x 1" deep jointer or edging tool. Joints to be clean, cut straight, parallel or square with respect to concrete walk edge. Tool all edges of exposed expansion and contraction joints, walk edges, and wherever concrete walk adjoins other material or vertical surfaces.
 - 1. The expansion joints shall be full depth as shown in the plan details. Failure to do so will result in non-compliance and shall be immediately machine cut by the contractor at his expense.
- D. Stair Treads and Risers: Tool exterior stair tread nosing per ADA requirements and as detailed. Paint or stain tooled area at every stair tread nosing or as detailed. Stair tread nosing shall contain no pockets, voids or spalls. Patching is not allowed. Damaged nosing shall be replaced.

3.10 CURING

- A. Flatwork/Variable Height Curbs, Curb and gutter, Valley Gutter: Cure utilizing Curing Compound. If applicable, the Contractor shall verify that the approved Curing Compound is compatible with the approved colorant system. Upon completion of job, wash clean per manufacturer's recommendations.

1. Curing compound shall be applied in a wet puddling application. Spotty applications shall be reason for rejection and possibly concrete removal and replacement at the contractor's expense with no compensation from the owner.
- B. No Curing Compound shall be applied to areas scheduled to receive resilient track surface including, curbs, ramps, run ways, etc.

3.11 DEFECTIVE CONCRETE

- A. Determination of defective concrete shall be made by the Architect or Engineer. His opinion shall be final in identifying areas to be replaced, repaired or patched.
- B. The Owner reserves the right to survey the flatwork, if it is determined to be outside of the maximum tolerance for flatness. If the flatwork is found to be out of tolerance, then the Contractor will be required to replace concrete. The Contractor will be responsible for reimbursing the Owner for any surveying costs incurred. Determination of flatwork flatness, surveying and any remedial work must be completed far enough in advance so that the project schedule is maintained, delays are avoided and the new flatwork or flatwork repairs are properly cured.
- C. As directed by Architect or Engineer, cut out and replace defective concrete. All defective concrete shall be removed from the site. No patching is to be done until surfaces have been examined by Architect and permission to begin patching has been provided.
- D. Permission to patch any area shall not be considered waiver of right, by the Owner, to require removal of defective work, if patching does not, in opinion of Architect or Engineer, satisfactorily restore quality and appearance of surface.
- E. Defective concrete is:
 1. Concrete that does not match the approved mix design for the given installation type.
 2. Concrete not meeting specified 28-day strength.
 3. Concrete which contains rock pockets, voids, spalls, transverse cracks, exposed reinforcing, or other such defects which adversely affect strength, durability or appearance.
 4. Concrete which is incorrectly formed, out of alignment or not plumb or level.
 5. Concrete containing embedded wood or debris.
 6. Concrete having large or excessive patched voids which were not completed under Architect's direction.
 7. Concrete not containing required embedded items.
 8. Excessive Shrinkage, Traverse cracking, Cracking, Curling; or Defective Finish. Remove and replace if repair to an acceptable condition is not feasible.
 9. Concrete that is unsuitable for placement or has set in truck drum for longer than 90 minutes from the time it was batched.

10. Expansion joint felt that is not isolating the full depth of the concrete section, and recessed as required for backer rod and sealant where required.
 11. Concrete that is excessively wet or excessively dry and will not meet the minimum or maximum slump required per mix design.
 12. Finished concrete with oil stains from equipment use, and or rust spots that cannot be removed.
 13. Control joints (weakened planed joints) that do not meet the required minimum depth shown on the drawings.
- F. Patching: Install specified Patching Mortar per manufacturer's recommendations.

3.12 CONCRETE TESTING

- A. Comply with CBC Section 1903A, 1905A.1.16, 1910A and 1705A.3 and as specified in B. below. Costs of tests will be borne by the Owner.
- B. Four identical cylinder samples for strength tests of each class of concrete placed each day shall be taken not less than once a day, or not less than once for each 50 cubic yards of concrete, or not less than once for each 2,000 square feet of surface area for slabs or walls. In addition, samples for strength tests for each class of concrete shall be taken for seven-day tests at the beginning of the concrete work or whenever the mix or aggregate is changed.
- C. Strength tests will be conducted by the Testing Lab on one cylinder at seven (7) days and two cylinders at twenty-eight (28) days. The fourth remaining cylinder will be available for testing at fifty-six (56) days if the 28-day cylinder test results do not meet the required design strength.
- D. On a given project, if the total volume of concrete is such that the frequency of testing required by paragraph B. above would provide less than five strength tests for a given class of concrete, tests shall be made from at least five randomly selected batches or from each batch if fewer than five batches are used.
- E. Cost of retests and coring due to low strength or defective concrete will be paid by Owner and back-charged to the Contractor.
- F. Each truck shall be tested for slump before concrete is placed.

3.13 REMOVAL OF FORMS

- A. Remove without damage to concrete surfaces.
- B. Sequence and timing of form removal shall insure complete safety of concrete structure.
- C. Forms shall remain in place for not less than the following periods of time. These periods represent cumulative number of days during which temperature of air in contact with concrete is 60 degrees F and above.
 1. Vertical forms of foundations, walls and all other forms not covered below: 5 days.
 2. Slab edge screeds or forms: 7 days.

FOR REFERENCE ONLY

3. Concrete columns and beam soffits: 28 days.
- D. Concrete shall not be subjected to superimposed loads (structure or construction equipment) until it has attained its full design strength and not for a period of at least 21 days after placing. Concrete systems shall not be subjected to construction loads in excess of design loads.

3.14

CLEANING

- A. Upon completion of work of this Section promptly remove from the working area all scraps, debris and surplus material of this Section.
- B. Clean excess material from surface of all concrete walks and utility structures.
- C. Power wash all concrete surfaces to remove stains, dried mud, tire marks, and rust spots.

END OF SECTION

SECTION 32 17 13 CONCRETE WHEEL STOPS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Precast concrete parking bumpers and anchorage.

1.02 RELATED REQUIREMENTS

- A. Section 32 17 23 - Pavement Markings.

1.03 REFERENCE STANDARDS

- A. ASTM A615/A615M - Standard Specification for Deformed and Plain Carbon-Steel Bars for Concrete Reinforcement.
- B. ASTM C150/C150M - Standard Specification for Portland Cement.
- C. ASTM C260/C260M - Standard Specification for Air-Entraining Admixtures for Concrete.
- D. ASTM C330/C330M - Standard Specification for Lightweight Aggregates for Structural Concrete.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide unit configuration, dimensions.

PART 2 PRODUCTS

2.01 MATERIALS

- A. Parking Bumpers: Precast concrete, complying with the following:
 1. Profile: Manufacturer's standard.
 2. Cement: ASTM C150/C150M, Portland Type I - Normal; white color.
 3. Concrete Materials: ASTM C330/C330M aggregate, water, and sand.
 4. Reinforcing Steel: ASTM A615/A615M, deformed steel bars; unfinished, strength and size commensurate with precast unit design.
 5. Air Entrainment Admixture: ASTM C260/C260M.
 6. Concrete Mix: Minimum 5,000 psi compressive strength after 28 days, air entrained to 5 to 7 percent.
 7. Use rigid molds, constructed to maintain precast units uniform in shape, size and finish. Maintain consistent quality during manufacture.
 8. Embed reinforcing steel, and drill or sleeve for two dowels.
 9. Cure units to develop concrete quality, and to minimize appearance blemishes such as non-uniformity, staining, or surface cracking.

FOR REFERENCE ONLY

- 10. Minor patching in plant is acceptable, providing appearance of units is not impaired.
- B. Dowels: Cut reinforcing steel, 1/2 inch diameter, 18 inch long, pointed tip.
- C. Adhesive: Epoxy type.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install units without damage to shape or finish. Replace or repair damaged units.
- B. Install units in alignment with adjacent work.
- C. Fasten units in place with 2 dowels per unit.

END OF SECTION

SECTION 32 17 23 PAVEMENT MARKINGS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Painted pavement markings.
 - 1. Accessible Parking Spaces.
 - a. Passenger Loading Zone
 - 2. Existing Striping: Confirm compliance at all accessible parking spaces on site and path of travel with California Building Code and Access requirements.
 - a. Remove non-compliant and provide all striping and modifications necessary for compliance.

1.02 RELATED REQUIREMENTS

- A. Section 32 12 16 - Asphalt Paving.
- B. Section 32 13 13 - Site Concrete.
- C. Section 32 17 26 - Tactile Warning Surfacing.

1.03 REFERENCE STANDARDS

- A. AASHTO M 247 - Standard Specification for Glass Beads Used in Pavement Markings.
- B. AASHTO MP 24 - Standard Specification for Waterborne White and Yellow Traffic Paints.
- C. ADA Standards - 2010 ADA Standards for Accessible Design.
- D. CBC Chapter 11B - California Building Code-Chapter 11B.
- E. FS TT-B-1325 - Beads (Glass Spheres) Retro-Reflective.
- F. FS TT-P-1952 - Paint, Traffic and Airfield Marking, Waterborne.
- G. SAE AMS-STD-595 - Colors Used in Government Procurement.
- H. {RSTEMP#10005409}
- I. SCAQMD 1113 - Architectural Coatings.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordination: Coordinate the work of this section with adjoining work.
- B. Preinstallation Meeting: Conduct a preinstallation meeting one week prior to the start of the work of this section; require attendance by affected installers.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Manufacturer's data sheets on each product to be used.
- C. Certificates: Submit for each batch stating compliance with specified requirements.

1. Painted pavement markings.
- D. Manufacturer's Instructions:
 1. Preparation instructions and recommendations.
 2. Storage and handling requirements and recommendations.
 3. Installation methods.
- E. Manufacturer's qualification statement.
- F. Installer's qualification statement.
- G. Maintenance Materials: Furnish the following for District's use in maintenance of project.
 1. See Section 01 60 00 - Product Requirements for additional provisions.
 2. Extra Paint: 2 containers, 1 gallon size, of each type and color.
 3. Extra Markers: 5 percent, of each type and color.

1.06 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing products specified in this section, with not less than three years of documented experience.
- B. Installer Qualifications: Company specializing in performing work of the type specified and with at least three years of documented experience.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Deliver paint in containers of at least 5 gallons accompanied by batch certificate.
- B. Deliver glass beads in containers suitable for handling and strong enough to prevent loss during shipment, accompanied by batch certificate.
- C. Store products in manufacturer's unopened packaging until ready for installation.
- D. Store and dispose of solvent-based materials, and materials used with solvent-based materials, in accordance with requirements of local authorities having jurisdiction.

1.08 FIELD CONDITIONS

- A. Do not install products under environmental conditions outside manufacturer's absolute limits.
- B. Do not apply paint if temperature of surface to be painted or the atmosphere is less than 50 degrees F or more than 95 degrees F.
 1. Do not apply marking paint when weather is foggy or rainy, or when such conditions are anticipated within eight hours of application.
 2. Do not apply marking paint when wind velocity causes uncontrollable overspray or excessively rapid drying.
- C. Sequence and Schedule: Apply pavement markings after asphaltic concrete and portland cement concrete and interlocking concrete paving Work are complete and properly cured and, if applicable, sealer has been applied to asphaltic concrete and landscaping Work is complete.
 1. Allow new pavement surfaces to cure for a period of not less than 14 days before application of marking materials.

1.09 SEQUENCING

- A. Allow new pavement surfaces to cure for a period of not less than 14 days before application of markings.

PART 2 PRODUCTS

2.01 REGULATORY REQUIREMENTS:

- A. Comply with CalGreen requirements.
 - 1. Comply at time of installation with Air Quality standards of:
 - a. South Coast Air Quality Management District, SCAQMD 1113.
 - b. California Air Resources Board (CARB).
- B. For accessibility markings see Part 3 Article "Installation".
- C. Conform to State of California, Department of Transportation (CALTRANS) Standard Specifications, Section 84, Traffic Control Markings, as amended and adopted by authorities having jurisdiction.
- D. Where reference is made to Standard Specifications, the following shall apply.
 - 1. Perform off-site Work in public rights-of-way in accordance with requirements of authorities having jurisdiction. For conditions not indicated otherwise on Contract Drawings, conform to Standard Details adopted by authorities having jurisdiction, including SSPWC Greenbook.
 - 2. Perform on-site Work as indicated and referenced on the Contract Drawings and as specified herein.

2.02 MANUFACTURERS

- A. Painted Pavement Markings: FS TT-P-1952 Type II.
 - 1. Behr: www.behr.com.
 - 2. Dunn-Edwards Corporation; Vin-L-Stripe Specialty Interior/Exterior Flat Zone Marking Paint.
 - 3. PPG Traffic Solutions; Ennis Flint Fast Dry Waterborne Traffic Paint, 9852x Series.
 - 4. Sherwin Williams; 2 Coats of SW Armorseal 8100 with Armorseal High Wear Additive in second coat: www.sherwin.com.
 - 5. Vista Paint Corporation; 6700 100% Acrylic Traffic Marking Paint: www.vistapaint.com.
 - 6. Substitutions: See Section 01 60 00 - Product Requirements.

2.03 PAINTED PAVEMENT MARKINGS

- A. General: Provide standard factory-mixed, quick drying and non-bleeding colors, conforming to Standard Specifications, as amended and adopted by the AHJ, City, and County, as applicable.
- B. Painted Pavement Markings: As indicated on drawings.
 - 1. Marking Paint: In accordance with AASHTO MP 24 or FS TT-P-1952; water emulsion-based traffic paint.

- a. Parking Lots: Color(s) as indicated.
 - 1) Fast-dry type. If required by authorities having jurisdiction for Work in public rights-of-way, include reflective material in paint. Paint for marking curbs shall not require reflective material. See Color Schedule in Part 3.
- b. Symbols and Text: Color(s) as indicated.
 - 1) Accessibility Symbols: Provide blue and white, per CBC Chapter 11B-503 and CBC Chapter 11B-703.7.2.
 - (a) Blue shall conform to Color No. 15090; {RS#10005409} (formerly 595C).
 2. Reflective Glass Beads at Accessible Parking Spaces: Type 1 (low index of refraction), Gradation A (coarse, drop-on); with silicone or other suitable waterproofing coating to ensure free flow, in accordance with AASHTO MP 24 or FS TT-P-1952.
 - a. Comply with CBC Chapter 11B-502.6.4 Marking.
 3. Comply with CALTRANS State Specification No. 8010-51J-22, Type II, and CBC Chapter 11B-502.6 Identification.
 4. Obliterating Paint: Type I, in accordance with AASHTO MP 24 or FS TT-P-1952.
 - a. Bituminous Pavement: Black.
 - b. Concrete Pavement: Gray.
- C. Temporary Marking Tape: Preformed, reflective, pressure sensitive adhesive tape in color(s) required; Contractor is responsible for selection of material of sufficient durability as to perform satisfactorily during period for which its use is required.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Identify existing markings for removal.
- B. Verification of Conditions: Verify that pavement is dry and ready for installation.
- C. Notify Architect of unsatisfactory conditions before proceeding.

3.02 PREPARATION

- A. Establish survey control points for locating and dimensioning of markings.
 1. Lay out markings as shown on Drawings. Use guide lines, templates and forms for precise edges and spacings.
 - a. At off-site and on-site public rights-of-way, obtain review and approval of layout by authorities having jurisdiction.
- B. Clean surfaces prior to installation.
 1. Remove dust, dirt, and other debris.
 2. Remove rubber deposits, existing paint markings, and other coatings.
- C. Temporary Markings: Apply as directed by Architect.
- D. Apply paint stencils by type and color at necessary intervals.

3.03 INSTALLATION

- A. Regulatory Accessibility Requirements for Installation:
1. Pavement markings for accessibility requirements shall meet requirements of California Building Code (CBC), Title 24, Part 2, CBC Chapter 11B and ADA Standards, per latest amendments.
 - a. Accessible parking spaces serving a particular building or facility shall be located on the shortest accessible route to an entrance complying with CBC Chapter 11B-208.3.1.
 - b. Accessible parking spaces serving more than one accessible entrance shall be dispersed and located on the shortest accessible route to the accessible entrances.
 - c. Accessible parking spaces in a parking facility not serving a particular building or facility shall be located on the shortest accessible route to an accessible pedestrian entrance of the parking facility. CBC Chapter 11B-208.3.1
 - d. Minimum number of required accessible parking spaces shall be provided in accordance with CBC Chapter 11B Table-208.2 for each parking facility provided on a site.
 - e. For every six or fraction of six accessible parking spaces, at least one shall be an accessible van parking space. CBC Chapter 11B-208.2.4
 - f. Accessible parking spaces and access aisles shall comply with CBC Chapter 11B-502 and shall be dimensioned to the centerline of the marked lines as follows:
 - 1) Parking spaces and access aisles shall be marked according to CBC Chapter 11B Figures 11B-502.2, 11B-502.3, and 11B-502.3.3.
 - (a) Their surfaces shall comply with CBC Chapter 11B-302 and shall be at the same level with slopes not steeper than 1:48 in any direction. CBC Chapter 11B-502.4.
 - 2) Parking spaces shall be 9 x 18 feet minimum and van parking spaces shall be 12 x 18 feet minimum with an adjacent access aisle of 5 x 18 feet minimum.
 - (a) Access aisles shall be placed on either side of the parking spaces except be located on the passenger side for van parking spaces.
 - (b) Van parking spaces shall be permitted to be 9 x 18 feet minimum where the access aisle is 8 x 18 feet minimum.
 - 3) Access aisles shall be marked by a blue painted borderline around their perimeter.
 - (a) The area within the blue borderlines shall be marked with hatched lines a maximum of 36 inches on center in a color contrasting with that of the aisle surface, preferably blue or white.
 - (b) Access aisle markings may extend beyond the minimum required length. CBC Chapter 11B-502.3.3
 - (c) At drive aisle provide minimum 12 inch high white letters with the text "NO PARKING" per {RS#10005085} Figure 11B-502.3.3.
 - 4) Access aisles (parking spaces as well- similar application) shall not overlap the vehicular way. CBC Chapter 11B-502.3.4

FOR REFERENCE ONLY

- 5) A vertical clearance of 98 inches minimum shall be provided for accessible parking spaces, access aisles, and vehicular routes serving them. CBC Chapter 11B-502.5
 2. Passenger Drop-Off and Loading Zones: At least one passenger loading zone shall be provided in every continuous 100 linear feet of loading zone space, or fraction thereof, complying with CBC Chapter 11B-209 and 11B-503 as follows:
 - a. Vehicle pull-up spaces shall be 8 x 20 feet minimum.
 - 1) Access aisles shall be 5 feet wide minimum x full length of vehicle pull-up spaces they serve and shall be adjacent and parallel to the vehicular pull-up spaces.
 - 2) They shall be at the same level with slopes not steeper than 1:48 in any direction.
 - 3) Access aisle shall adjoin an accessible route and shall not overlap the vehicular way.
 - b. Access aisles for passenger drop-off and loading zone shall be marked with a painted borderline around their perimeter.
 - 1) The area within the borderlines shall be marked with hatched lines a maximum of 36 inches on center in a color contrasting with that of the aisle surface. CBC Chapter 11B-503.3.3.
 - (a) Blue perimeter lines with blue interior hatch lines are preferred for concrete surfaces and blue perimeter lines with white interior hatch lines are preferred for asphalt surfaces.
 - (b) Where white hatch lines are used, hatch lines shall be interrupted at 12 inch high "No Parking" text so that legibility is maintained.
 - c. A vertical clearance of 114 inches minimum shall be provided for vehicle pull-up spaces, access aisles, and a vehicular route serving them connecting a vehicular entrance and a vehicular exit. CBC Chapter 11B-503.5.
 3. Bus loading zones and bus stops shall comply with CBC Chapter 11B-209 and 11B-810.2 as follows:
 - a. Boarding and alighting areas shall be of 8 x 5 feet minimum, with 8 feet measured perpendicular to the curb or vehicle roadway edge, and with 5 feet measured parallel to the vehicle roadway.
 - 1) Slopes in 8 foot direction shall be 1:48 maximum.
 - 2) Slopes in 5 foot direction shall be the same as that of the roadway, to the maximum extent practicable. CBC Chapter 11B Figure 11B-810.2.2.
 - b. Newly constructed bus stop boarding and alighting areas shall provide a detectable transition between the boarding/alighting area and the roadway; the detectable transition shall consist of a curb with the face sloped at 35 degrees maximum from vertical or detectable warnings complying with CBC Chapter 11B-705.1.1 and 11B-705.1.2.4.
- B. General:
1. Position pavement markings as indicated on drawings.

2. Field location adjustments require approval of Architect.
- C. Painted Pavement Markings:
 1. Apply in accordance with manufacturer's instructions.
 2. Obliterating Paint: Apply as necessary to cover existing markings completely.
 3. Marking Paint: Apply uniformly, with sharp edges.
 - a. Applications: One coat.
 - b. Wet Film Thickness: 0.015 inch, minimum.
 - c. Stencils: Lay flat against pavement, align with striping, remove after application.
 - d. Glass Beads: Apply directly to paint, 10 second lag time, 6 lbs/gal of paint, uniform thickness and coverage.
 - e. Length Tolerance: Plus or minus 3 inches.
 - f. Width Tolerance: Plus or minus 1/8 inch.
 4. Curbs: Paint full vertical face and first 6-inches of horizontal plane at top of curb or combination curb/paving. Provide minimum 2 coats paint.
 - a. Provide stenciled text in the height, spacing and typeface as indicated on Drawings.
 5. Parking Lots: Apply parking space lines, entrance and exit arrows, painted curbs, and other markings indicated on drawings.
 - a. Mark the International Symbol of Accessibility at indicated parking spaces.
 - 1) Accessibility Logo: Provide minimum of 2 coats paint.
 - (a) Comply with CBC Chapter 11B Figure 703.7.2.1.
 - 2) Stall Marking:
 - (a) Use single-line style striping between parking stalls, unless otherwise indicated.
 - (b) Comply with local agency regulatory requirements.
 - (c) Accessible Stalls: Comply with ADA Standards, CBC Chapter 11B, and local agency regulatory requirements.
 - (1) Painted lines and markings on pavement shall be minimum 3 inches wide, color as indicated on Drawings
 - (2) Tactile warning lines shall comply with CBC Chapter 11B-705.1.2.5 Hazardous Vehicular Areas.
 - (3) Tactile warning devices shall comply with CBC Chapter 11B, see Section 32 17 26 - Tactile Warning Surfacing.
 - 3) Hatching: Provide hatching in parking areas, including accessible parking stalls, as indicated on Contract Drawings or as required by Standard Details. Should Contract Drawings and Standard Details conflict, comply with the more stringent.
 - b. Hand application by pneumatic spray is acceptable.
 6. Symbols: Use a suitable template that will provide a pavement marking with true, sharp edges and ends, of the design and size indicated.

3.04 TOLERANCES

- A. Maximum Variation From True Position: 3 inches (76 mm).
- B. Maximum Offset From True Alignment: 3 inches (76 mm).

3.05 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements for additional requirements.
- B. Perform field inspection for deviations from true alignment or material irregularities.
- C. If inspections indicate work does not meet specified requirements, rework and reinspect at no cost to District.
- D. Allow the pavement marking to set at least the minimum time recommended by manufacturer.

3.06 CLOSEOUT ACTIVITIES

- A. See Section 01 78 00 - Closeout Submittals for additional requirements.
- B. Temporary Markings: Remove without damaging surfaces.

3.07 PROTECTION

- A. Replace damaged or removed markings at no additional cost to District.
- B. Preserve survey control points until pavement marking acceptance.

3.08 COLOR SCHEDULE

- A. Parking and On-Site Roadways

| <u>Location</u> | <u>Color</u> | <u>Reflectance*</u> |
|--|--|---------------------|
| Driving lane striping | White | 82% |
| Parking space striping | White | 82% |
| Accessible Parking, field behind ISA, and zone markings | Blue No. 15090 per {RS#10005409} (formerly FED-STD-595C) | 52% |
| Accessible Parking ISA, loading and cross-hatching | A. White with Blue perimeter at Asphalt Paving. | 82% / 52% |
| | B. Blue at Concrete Paving* | 52% |
| 12 inch high Text: "NO PARKING", "LOADING ZONE", and "FIRE LANE", etc. | White | 82% |
| Firelanes / No Parking zone markings Special Use Markings | Red No. 31350 per {RS#10005409} (formerly FED-STD-595C) | 52% |
| Loading zone markings | Orange Yellow No. 33538 | 52% |

FOR REFERENCE ONLY

| | | |
|---|---|-----|
| | per{RS#10005409} (formerly FED-STD-595C) | |
| Directional arrows | White | 82% |
| Speed Bumps | Orange Yellow No. 33538 per {RS#10005409} (formerly FED-STD-595C) | 52% |
| Black special-use pavement markings, if indicated on Drawings | Black No. 37038 per {RS#10005409} (formerly FED-STD-595C) | NA |

*Contrasting color per CBC.

a. See also Division of the State Architect IR 11B-7.

**Daylight directional reflectance (without glass beads) , when tested in accordance with Federal Test Method Standard 141A, Method 612.

END OF SECTION

SECTION 32 17 26 TACTILE WARNING SURFACING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Tactile warning surfacing for pedestrian walking surfaces.

1.02 RELATED REQUIREMENTS

- A. Section 32 13 13 - Site Concrete: Concrete sidewalks.
- B. Section 32 17 23 - Pavement Markings: Crosswalk and curb markings.

1.03 REFERENCE STANDARDS

- A. 49 CFR 37 - Transportation Services for Individuals with Disabilities (ADA).
- B. AASHTO LRFD - Bridge Design Specifications.
- C. ADA Standards - 2010 ADA Standards for Accessible Design.
- D. ASTM A666 - Standard Specification for Annealed or Cold-Worked Austenitic Stainless Steel Sheet, Strip, Plate, and Flat Bar.
- E. ASTM B117 - Standard Practice for Operating Salt Spray (Fog) Apparatus.
- F. ASTM C501 - Standard Test Method for Relative Resistance to Wear of Unglazed Ceramic Tile by the Taber Abraser.
- G. ASTM C903 - Standard Practice for Preparing Refractory Specimens by Cold Gunning.
- H. ASTM D2047 - Standard Test Method for Static Coefficient of Friction of Polish-Coated Flooring Surfaces as Measured by the James Machine.
- I. ASTM D543 - Standard Practices for Evaluating the Resistance of Plastics to Chemical Reagents.
- J. ASTM D570 - Standard Test Method for Water Absorption of Plastics.
- K. ASTM D638 - Standard Test Method for Tensile Properties of Plastics.
- L. ASTM D695 - Standard Test Method for Compressive Properties of Rigid Plastics.
- M. ASTM D790 - Standard Test Methods for Flexural Properties of Unreinforced and Reinforced Plastics and Electrical Insulating Materials.
- N. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials.
- O. ASTM G155 - Standard Practice for Operating Xenon Arc Lamp Apparatus for Exposure of Materials.
- P. ATBCB PROWAG - Proposed Accessibility Guidelines for Pedestrian Facilities in the Public Right-of-Way.
- Q. {RSTEMP#10005085}
- R. SAE AMS-STD-595 - Colors Used in Government Procurement.
- S. {RSTEMP#10005409}

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Submit manufacturer's product data, standard details, details specific to this project; written installation and maintenance instructions.
- C. Samples: For each product specified provide two samples, 8 inches square, minimum; show actual product, color, and patterns.
- D. Shop Drawings: Submit plan and detail drawings. Indicate:
 - 1. Locations on project site. Demonstrate compliance with referenced accessibility standards.
 - 2. Sizes and layout.
 - 3. Pattern spacing and orientation.
 - 4. Attachment and fastener details, if applicable
- E. Manufacturer's Qualification Statement.
- F. Installer's Qualification Statement.
- G. Warranty: Submit manufacturer warranty; complete forms in District's name and register with manufacturer.

1.05 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing products specified in this section, with not less than five years documented experience.
- B. Installer Qualifications: Company certified in writing by product manufacturer as having successfully completed work substantially similar to the work of this section.

1.06 DELIVERY, STORAGE, AND HANDLING

- A. Deliver to project site in manufacturer's protective wrapping and in manufacturer's unopened packaging.
- B. Store covered and elevated above grade and in manufacturer's unopened packaging until ready for installation. Maintain at ambient temperature between 40 and 90 degrees F.

1.07 WARRANTY

- A. See Section 01 78 00 - Closeout Submittals, for additional warranty requirements.
- B. Plastic Tiles: Provide manufacturer's standard five year warranty against manufacturing defects, breakage or deformation.

PART 2 PRODUCTS

2.01 REGULATORY REQUIREMENTS

- A. Detectable warnings shall comply with California Building Code, {RS#10005085}-705.1 requirements, {RS#10005085}-705.1.2 Locations and {RS#10005085}-705.1.2.5 Blended Transitions, for special warnings for disabled persons.
- B. Nominal dimensions meeting {RS#10005085}-705.1.2 Locations.

- C. Detectable warning surfaces at transit boarding platform edges, bus stops, hazardous vehicle areas, reflecting pools, and track crossings shall be yellow and approximate to Federal Color No. 33538 of {RS#10005409} (Table IV of Federal Standard No. 595A).
 - 1. Detectable warning surfaces at other locations shall be the aforementioned yellow or a color providing a 70 percent minimum visual contrast with that of adjacent walking surfaces.
 - 2. The material used to provide visual contrast shall be an integral part of the surface. {RS#10005085}-705.1.1.3.
- D. Detectable warning surfaces shall differ from adjoining surfaces in resiliency or sound-on-cane contact. Such constraint shall not be required for detectable warning surfaces at curb ramps, islands, or cut-through medians. {RS#10005085}-705.1.1.4 Resiliency.
- E. Truncated dome pattern in-line, not staggered.

2.02 MANUFACTURERS

- A. Plastic Tactile and Detectable Warning Surface Tiles:
 - 1. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.

2.03 TACTILE AND DETECTABLE WARNING DEVICES

- A. Plastic Tactile and Detectable Warning Tiles: Comply with ADA Standards, glass fiber and carbon fiber reinforced, exterior grade, matte finish polyester sheet with truncated dome pattern, solid color throughout, internal reinforcing of sheet and of truncated domes, integral radius cut lines on back face of tile; with factory-applied removable protective sheeting.
 - 1. Material Properties:
 - a. Water Absorption: 0.20 percent, maximum, when tested in accordance with ASTM D570.
 - b. Slip Resistance: 0.50 minimum dry static coefficient of friction, when tested in accordance with ASTM D2047.
 - c. Compressive Strength: 25,000 pounds per square inch, minimum, when tested in accordance with ASTM D695.
 - d. Tensile Strength: 10,000 pounds per square inch, minimum, when tested in accordance with ASTM D638.
 - e. Flexural Strength: 25,000 pounds per square inch minimum, when tested in accordance with ASTM D790.
 - f. Chemical Stain Resistance: No reaction to 1 percent hydrochloric acid, motor oil, calcium chloride, gum, soap solution, bleach, or antifreeze, when tested in accordance with ASTM D543.
 - g. Abrasion Resistance: 300, minimum, when tested in accordance with ASTM C501.
 - h. Flame Spread Index: 25, maximum, when tested in accordance with ASTM E84.
 - i. Accelerated Weathering: Delta-E of less than 5.0 at 2,000 hours exposure, when tested in accordance with ASTM G155.
 - j. Adhesion: No delamination of tile prior to board failure in a temperature range of 20 to 180 degrees F, when tested in accordance with ASTM C903.

FOR REFERENCE ONLY

- k. Loading: No damage when tested according to AASHTO LRFD test method HS20.
 - l. Salt and Spray Performance: No deterioration or other defect after 200 hours of exposure, when tested in accordance with ASTM B117.
2. Asphalt Installation Method: Surface applied.
 3. Concrete Installation Method: Cast in place.
 4. Shape: Rectangular.
 5. Dimensions: 36 inches by 48 inches, nominal. Other sizes may be indicated on Drawings.
 6. Pattern: In-line pattern of truncated domes complying with ADA Standards.
 7. Edge: ADA Standards compliant bevel.
 8. Joint: Butt.
 9. Color: SAE AMS-STD-595, Table IV, Federal Yellow No. 33538.
 10. At Asphalt Application Basis of Design Product: SSTD Traditional Mat System as manufactured by Safety Step TD; www.safetysteptd.com, or approved equal.
 11. Surface Applied Products:
 - a. Access Tile, a brand of Access Products, Inc; Surface Applied Tile: www.accesstile.com/#sle.
 - b. ADA Solutions, a division of SureWerx USA; Surface Applied System: www.adatale.com/#sle.
 - c. Detectable Warning Systems, Inc.; redimat (Surface Applied): detectable-warning.com.
 - d. Safety StepTD, Inc.; SSTD-Traditional Mat System: www.safetystepTD.com.
 - e. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
 12. At Flush Concrete Application Basis of Design Product: Armor-Tile as manufactured by Engineered Plastics, or approved equal.
 13. Concrete Recessed/Flush Products:
 - a. Access Tile, a brand of Access Products, Inc; Cast in Place Replaceable Tactile Warning Tile: www.accesstile.com/#sle.
 - b. ADA Solutions, a division of SureWerx USA; Cast in Place Replaceable (Wet-Set): www.adatale.com/#sle.
 - c. Armor Tile by Engineered Plastics Inc.; Vitriified Polymer Composite (VPC) Cast In Place Detectable/Tactile Warning Surface Tile: armor-tile.com.
 - d. Detectable Warning Systems, Inc.; alertcast (Replaceable Cast-in-Place): detectable-warning.com.
 - e. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.

2.04 ACCESSORIES

- A. Fasteners: ASTM A666, Type 304 stainless steel
 1. Type: Countersunk, color matched composite sleeve anchors
 2. Size: 1/4 inch diameter and 1-1/2 inches long.

- B. Adhesive: Type recommended and approved by surfacing tile manufacturer.
- C. Sealant: Elastomeric sealant of color to match adjacent surfaces; approved by surfacing tile manufacturer.

PART 3 EXECUTION

3.01 EXAMINATION

- A. When installation location is near site boundary or property line, verify required location using property survey.
- B. Verify that work area is ready to receive work:
 - 1. Examine work area with installer present.
 - 2. If existing conditions are not as required to properly complete the work of this section, notify Architect.
 - 3. Do not proceed with installation until deficiencies in existing conditions have been corrected.
- C. Verify that dimensions, tolerances, and attachment methods for work in this section are properly coordinated with other work on site.

3.02 INSTALLATION, GENERAL

- A. Install in accordance with manufacturer's written instructions.
 - 1. Do not install damaged, warped, bowed, dented, abraded, or otherwise defective units.
 - 2. Do not install when ambient or substrate temperature has been below 40 degrees F during the preceding 8 daylight hours.
- B. Field Adjustment:
 - 1. Cut units to size and configuration shown on drawings. (If required)
 - 2. Do not cut plastic tiles to less than 9 inches wide in any direction.
 - 3. Locate relative to curb line in compliance with ATBCB PROWAG, Sections 304 and 305.
 - 4. Orient so dome pattern is aligned with the direction of ramp.
 - 5. Align truncated dome pattern between adjacent units.
- C. Install units fully seated to substrate, square to straight edges and flat to required slope.
- D. Align units so that tops of adjacent units are flush and joints between units are uniform in width.

3.03 INSTALLATION, CAST IN PLACE PLASTIC TILES

- A. Concrete:
 - 1. See Section 32 13 13 - Site Concrete.
 - 2. Slump: 4 to 7 percent.
- B. When installing multiple adjacent units, leave a 3/16 inch gap between units to allow for expansion.
- C. Tamp and vibrate units as recommended by manufacturer.

- D. Place and position weights on units while concrete cures as recommended by manufacturer. Ensure no voids or air pockets exist between top surface of concrete and underside of units.

3.04 INSTALLATION, SURFACE APPLIED PLASTIC TILES

- A. Cure asphalt surfaces for a minimum of 4 days before installing units.
- B. Verify substrate is clean and dry; free of voids, projections and loose material. Remove dust, oil, grease, curing compounds, sealers and other substances that may interfere with adhesive bond or sealant adhesion.
- C. Mechanically roughen surface as required to remove contaminants and prepare surface for adhesive and sealant application.
- D. When installing multiple adjacent units, leave a 1/8 inch gap between tiles to allow for expansion.
- E. Drill fastener holes straight, true and to depth recommended by manufacturer.
- F. Apply adhesive to back of unit as recommended by manufacturer.
- G. Mechanically fasten to substrate. Avoid striking or damaging the unit itself during installation.
- H. Apply sealant to edges in cove profile.

3.05 CLEANING PLASTIC UNITS

- A. Remove protective plastic sheeting within 24 hours of installation.
- B. Remove excess sealant or adhesive from joints and edges.
- C. Clean four days prior to date of scheduled inspection.

3.06 PROTECTION

- A. Protect installed units from traffic, subsequent construction operations or other imposed loads until concrete is fully cured.
- B. Touch-up, repair or replace damaged products prior to Date of Substantial Completion.

END OF SECTION

SECTION 32 31 19 DECORATIVE METAL FENCES AND GATES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Decorative steel fences.
- B. Excavation for post bases; concrete foundation for posts and center drop for gates.

1.02 RELATED REQUIREMENTS

- A. Section 05 50 00 - Metal Fabrications: Custom fabricated metal components.
- B. Section 31 23 16 - Excavation: Excavation for footings.
- C. Section 32 13 13 - Concrete Paving: : Concrete anchorage for posts.

1.03 REFERENCE STANDARDS

- A. ADA Standards - 2010 ADA Standards for Accessible Design.
- B. ASTM A276/A276M - Standard Specification for Stainless Steel Bars and Shapes.
- C. ASTM A500/A500M - Standard Specification for Cold-Formed Welded and Seamless Carbon Steel Structural Tubing in Rounds and Shapes.
- D. ASTM A653/A653M - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process.
- E. ASTM B117 - Standard Practice for Operating Salt Spray (Fog) Apparatus.
- F. ASTM D523 - Standard Test Method for Specular Gloss.
- G. ASTM D714 - Standard Test Method for Evaluating Degree of Blistering of Paints.
- H. ASTM D822/D822M - Standard Practice for Filtered Open-Flame Carbon-Arc Exposures of Paint and Related Coatings.
- I. ASTM D1654 - Standard Test Method for Evaluation of Painted or Coated Specimens Subjected to Corrosive Environments.
- J. ASTM D2244 - Standard Practice for Calculation of Color Tolerances and Color Differences from Instrumentally Measured Color Coordinates.
- K. ASTM D2794 - Standard Test Method for Resistance of Organic Coatings to the Effects of Rapid Deformation (Impact).
- L. ASTM D3359 - Standard Test Methods for Rating Adhesion by Tape Test.
- M. ASTM F2408 - Standard Specification for Ornamental Fences Employing Galvanized Steel Tubular Pickets.
- N. AWS D1.1/D1.1M - Structural Welding Code - Steel.
- O. SSPC-Paint 20 - Zinc-Rich Coating (Type I - Inorganic, and Type II - Organic).

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Preinstallation Meeting: Conduct a preinstallation meeting one week prior to start of work of this section; require attendance by affected installers.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Submit manufacturer's data sheets on each product to be used, including:
 - 1. Preparation instructions and recommendations.
 - 2. Storage and handling requirements and recommendations.
 - 3. Installation methods.
- C. Shop Drawings:
 - 1. Indicate plan layout, spacing of components, post foundation dimensions, hardware anchorage, gates, and schedule of components.
- D. Installer's Qualification Statement.
- E. Project Record Documents: Accurately record actual locations of property perimeter posts relative to property lines.
- F. Field Inspection Records: Provide installation inspection records that include post settings, framework, fittings and accessories, gates, and workmanship.
- G. Manufacturer's Warranty.
- H. Maintenance Materials: Furnish the following for District's use in maintenance of project:
 - 1. See Section 01 60 00 - Product Requirements, for additional provisions.

1.06 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing products specified in this section with minimum five years documented experience.
- B. Installer Qualifications: Experienced with type of construction involved and materials and techniques specified and approved by fence manufacturer.
- C. Fabricator's Qualifications: Fabricator of light structural steel framing members and other miscellaneous metal fabrications of structural character shall have a minimum 5 years experience fabricating similar fences and gates and shall be approved by the Building Official in accordance with applicable Code provisions.
- D. Welder's Qualifications: Welding shall be performed by certified welders qualified in accordance with procedures specified in applicable referenced AWS standard, using materials, procedures and equipment of the type required for the Work. Certify that each welder has satisfactorily passed AWS qualification tests for welding processes involved and, if pertinent, has undergone re-certification.
- E. Coordination: Provide templates and sleeves for incorporation of embedded items into the work specified elsewhere herein or in other Sections.
- F. Field-Verified Dimensions: Prior to fabrication, field verify dimensions and details of construction. Immediately report variances in writing to Architect.

1.07 DELIVERY, STORAGE AND HANDLING

- A. Store materials in a manner to ensure proper ventilation and drainage. Protect against damage, weather, vandalism and theft.

1.08 WARRANTY

- A. See Section 01 78 00 - Closeout Submittals, for additional warranty requirements.
- B. Correct defective Work within a five year period after Date of Substantial Completion.
- C. Provide ten year warranty for finish.

PART 2 PRODUCTS

2.01 REGULATORY REQUIREMENTS:

- A. Provide fences and gates meeting life safety and accessibility requirements of California Building Code (CBC) Title 24, Part 2, Chapters 10 and 11B; and ADA Standards, per latest amendments.
 - 1. Gates that are part of the accessible route shall meet all the requirements of an accessible door in compliance with CBC Section 11B-404 and 11B-206.5.
 - 2. Gate Hardware: Meet the requirements of CBC 11B-206.5 and 11B-404.2.9.
 - a. Latch: Latch, including padlock eye as integral part of latch, mounted 40 inches above finish grade. Comply with California Fire Code.
 - b. Hardware shall comply with local Fire Authority, California Building Code (CBC) Title 24, Section 1010.2, and California Fire Code (CFC) Section 503.5.2.
 - c. The lever of lever actuated latches or locks for an accessible gate shall be curved with a return to within 1/2 inch of the (face of) gate to prevent catching on the clothing or persons. California Referenced Standards Code T-24 Part 12, Section 12-10-202, Item (F).
 - d. Hand activated opening hardware, handles, pulls, latches, locks, and other operating devices for and accessible gate shall have a shape that is easy to grasp with one hand and does not require tight grasping, tight pinching, or twisting of the wrist to operate. CBC Section 11B-404.2.7 and 11B-309.4.
 - 3. Swing doors and gate surfaces within 10 inches of the finish floor or ground shall have a smooth surface on the push side extending the full width of the door or gate. Parts creating horizontal or vertical joints in these surfaces shall be within 1/16 inch of the same plane as the other and be free of sharp or abrasive edges. Cavities created by added kick plates shall be capped. CBC Section 11B-404.2.10
 - 4. The bottom of the gate shall be within 3 inches of the finish surface of the path of travel. The maximum effort to operate a gate shall not exceed 5 lbf. CBC Section 11B-404.2.9.

2.02 MANUFACTURERS

- A. Decorative Metal Fences and Gates:
 - 1. Ametco Manufacturing Corporation: www.ametco.com.
 - 2. Ameristar Perimeter Security, USA; _____: www.ameristarperimeter.com/#sle.

3. Grating Pacific, Inc.: www.gratingpacific.com.
 4. Substitutions: See Section 01 60 00 - Product Requirements.
- B. Automatic Gate Operators:
1. DKS DoorKing: www.doorking.com.
 2. HySecurity: www.hysecurity.com.
 3. Lift Master: www.liftmaster.com.
 4. Substitutions: See Section 01 60 00 - Product Requirements.

2.03 FENCES

- A. Fences: Complete shop-fabricated system of posts and panels, accessories, fittings, and fasteners; finished with specified coating, and having the following performance characteristics:
1. Capable of resisting vertical load, horizontal load and infill performance requirements for fence categories defined in ASTM F2408.
- B. Electro-Deposition Coating: Multistage pretreatment/wash with zinc phosphate, followed by epoxy primer and acrylic topcoat.
1. Total Coating Thickness: 2 mils, minimum.
 2. Color: As selected by Architect from manufacturer's standard range.
 3. Coating Performance: Comply with general requirements of ASTM F2408.
 - a. Adhesion: ASTM D3359 (Method B); Class 3B with 90 percent or more of coating remaining in tested area.
 - b. Corrosion Resistance: ASTM B117, ASTM D714 and ASTM D1654; 1/8 inch coating loss or medium No.8 blisters after 1,500 hours.
 - c. Impact Resistance: ASTM D2794; 60 inch pounds.
 - d. Weathering Resistance: ASTM D523, ASTM D822/D822M and ASTM D2244; less than 60 percent loss of gloss.
- C. Steel: ASTM A653/A653M; tensile strength 45,000 psi, minimum.
1. Hot-dip galvanized; ASTM A653/A653M, G60.
 2. 62 percent recycled steel, minimum.
- D. Fasteners: ASTM A276/A276M, Type 302 stainless steel; finished to match fence components.
1. Tamper-proof security bolts.
 2. Self-drilling hex-head screws.

2.04 WELDED STEEL FENCE

- A. Provide fence meeting requirements for Industrial class as defined by ASTM F2408.
- B. Fence Panels: Fusion welded; 8 feet high by 10 feet long.
1. Panel Style: As indicated on Drawings.
 2. Attach panels to posts by welding.
- C. Posts: Steel tube.

FOR REFERENCE ONLY

1. Size: As indicated on Drawings.
 2. Post Cap: Flush plate, watertight.
- D. Rails: Manufacturer's standard, double-wall steel channel 1-3/4 inch square by 12 gage, 0.1094 inch with prepunched picket holes.
1. Picket Retaining Rods: 0.125 inch galvanized steel.
 2. Picket-to-Rail Intersection Seals: PVC grommets.
- E. Pickets: Steel tube.
1. Spacing: 3-3/4 inch clear.
 2. Size: 1 inch square by 14 gage, 0.0785 inch.
 3. Style: Pickets with finial extend above top rail.
 4. Finial: Pointed picket finial.
- F. Flexibility: Capable of following variable slope of up to 1:2.
- G. Color: Black.
- H. Hinged Gates:
1. Steel Gate: Fabricated steel gate, ASTM A500/A500M, Grade B., Size as indicated on Drawings. See Section 05 50 00 - Metal Fabrications.
 2. Construction: Match adjacent fence
 - a. Pedestrian Swing Gates: Self-closing; gate leaf no larger than 48 inches width.
 - b. Provide cable kits for additional trussing for all gates leaves over 6 ft..
 - c. Infill Panel:
 - 1) Perforated Panels: ASTM A653/A653M G90 Galvanized steel panel, staggered perforated pattern. Paint to match fence.
 - d. Gate Kick Plate: Provide on push side, full width to minimum 10 inches high above finish surface, 0.1382 inch thick, galvanized ASTM A653/A653M welded to gate frame.

2.05 SPECIALITY HARDWARE

- A. Pedestrian Gate Hardware: Provide non-lift-off type and 180 degree opening hinges, latches, drop bolts, and other hardware required.
1. See Section 08 71 00 - Door Hardware for specific item requirements.
 2. Hardware to comply with local Fire Authority, California Building Code (CBC) Title 24 section 1013; and California Fire Code (CFC) section 503.5.2.
 - a. Hardware to comply with CBC Section 11B-309.4.
 3. Double and Single Leaf Gates: Provide with mechanisms for padlocking gates in open position.
 4. Double Gates Not in Path of Travel or Egress: Provide gate stops set in concrete to engage center drop rod or plunger bar. Include locking device and padlock eyes as integral part of latch, permitting both gate leaves to be locked with single padlock.

5. Gates across an exit to a public way or to a safe dispersal area shall have panic hardware. No padlocks or cane bolts shall be allowed.
- B. Gate Hardware, Not on on Path of Travel: <>
 1. Hinges:
 - a. Size and type as determined by manufacturer.
 - b. Provide 2 hinges for each leaf up to 6 feet high and 1 additional hinge for each additional 24 inches in height or fraction thereof.
 2. Latch: 3/4 inch diameter slide bolt to accommodate padlock.
 3. For double gates provide padlockable, 5/8 inch diameter center cane bolt assembly and strike.
- C. Hinges: Finished to match fence components.
 1. Closing: Self.
 2. Mechanism: Hydraulic.
 3. Material: Steel.
 4. Mounting: External.
 5. Brackets: Round.
 6. Bearings: Plain.
 7. Products:
 - a. Loconix; Mammoth: www.loconix.com.
 - b. Substitutions: See Section 01 60 00 - Product Requirements.

2.06 FABRICATION

- A. Metal Fences, Gates and Components: Fabricated of galvanized steel construction, all welded with welds ground smooth. Provide steel anchors for securing into adjoining construction. Weld anchors to frames not more than 12 inches from both top and bottom and space anchors not more than 24 inches apart.

2.07 ACCESSORIES

- A. Concrete: Ready-mixed, complying with ASTM C 94/C 94M; normal Portland cement; 2,500 psi strength at 28 days, 3 inch slump; 3/4 inch nominal size aggregate.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Do not begin installation until substrates have been properly prepared.
- B. If substrate preparation is the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.
- C. Field Inspection of Fabricated Products: Prior to installation, inspect products for damage and verify markings and dimensions against reviewed submittals.

- D. Coordination: Coordinate fence and gate Work with Work specified in other Sections so that related Work shall be accurately and properly joined. Furnish templates for exact location of items to be embedded in concrete or masonry.

3.02 PREPARATION

- A. Clean surfaces thoroughly prior to installation.
- B. Obtain Architect's review prior to site cutting or making adjustments not indicated on Drawings and reviewed shop drawings.
- C. Clean and strip site primed steel items to bare metal where site welding is necessary.
- D. Make provision for erection loads with temporary bracing. Keep work in alignment.
- E. Provide items required to be cast into concrete with setting templates. Coordinate placement with adjacent Work.
- F. Clean and prime field welds. Touch up galvanized steel with cold repair compound.

3.03 INSTALLATION

- A. Installation, General: Install items plumb and level, accurately fitted, free from distortion or defects.
- B. Install in accordance with fabricator's instructions.
- C. Set fence posts in accordance with the approved spacing.
- D. Perform field welding in accordance with AWS D1.1/D1.1M. All welds ground smooth.
- E. When cutting rails immediately seal the exposed surfaces by:
 - 1. Removing metal shavings from cut area.
 - 2. Apply zinc-rich primer or galvanizing patch compound to thoroughly cover cut edge and drilled hole; allow to dry.
 - 3. Apply two coats of custom finish spray paint matching fence color.
- F. Space gate posts according to the manufacturers' drawings, dependent on standard out-to-out gate leaf dimensions and gate hardware selected.
 - 1. Base type and quantity of gate hinges on the application, weight, height, and number of gate cycles.
 - 2. Identify the necessary hardware required for the application on the manufacturer's gate drawings.
 - 3. Provide gate hardware as specified for the gate and install per manufacturer's recommendations
- G. Excavate post holes in accordance with Section 31 23 16.
- H. Install posts in concrete by means of pipe sleeve inserts set and anchored in concrete. Fill annular space between pipe posts and sleeve inserts with grouting compound.
- I. Set line posts in concrete footing.
 - 1. Diameter: 12 inch minimum to maintain 3 inch concrete cover. Unless otherwise indicated or detailed on Drawings.
 - 2. Provide 36 inches minimum embedment of posts up to 8'-0".

3. Provide 6 inches minimum concrete beneath post bottom.

3.04 TOLERANCES

- A. Maximum Variation From Plumb: 1/4 inch.
- B. Maximum Offset From Indicated Position: 1 inch.
- C. Minimum Distance from Property Line: 6 inches.

3.05 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements, for additional requirements.
- B. Layout: Verify that fence installation markings are accurate to design, paying attention to gate locations, underground utilities, and property lines.
- C. Post Settings: Randomly inspect three locations against design for:
 1. Hole diameter.
 2. Hole depth.
 3. Hole spacing.
- D. Fence Height: Randomly measure fence height at three locations or at areas that appear out of compliance with design.
- E. Gates: Inspect for level, plumb, and alignment.
- F. Workmanship: Verify neat installation free of defects.

3.06 CLEANING

- A. Leave immediate work area neat at end of work day.
- B. Clean jobsite of excess materials; scatter excess material from post hole excavations uniformly away from posts. Remove excess material if required.
- C. Clean fence with mild household detergent and clean water rinse well.
- D. Touch up scratched surfaces using visually materials recommended by manufacturer. Match touchup paint color to fence finish.
 1. Galvanized Touch-Up: Touch up surfaces immediately after installation, including field welding. Prepare surface and apply cold repair compound in compliance with the product manufacturer's instructions and recommendations.
 - a. Material: SSPC-Paint 20, Type I - Inorganic, complying with VOC limitations of authorities having jurisdiction. Provide finish coat to match galvanized finish.
- E. See Section 01 74 19 - Construction Waste Management and Disposal, for additional requirements.

3.07 CLOSEOUT ACTIVITIES

- A. See Section 01 78 00 - Closeout Submittals, for closeout submittals.
- B. See Section 01 79 00 - Demonstration and Training, for additional requirements.
- C. Demonstrate proper operation of equipment to District's designated representative.
- D. Demonstration: Demonstrate operation of system to District's personnel.

FOR REFERENCE ONLY

1. Use operation and maintenance data as reference during demonstration.
2. Briefly describe function, operation, and maintenance of each component.

3.08 PROTECTION

- A. Protect installed products until completion of project.
- B. Touch-up, repair, or replace damaged products before Date of Substantial Completion.

END OF SECTION

SECTION 32 84 23 IRRIGATION SYSTEM

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Pipe and fittings, valves, sprinkler heads, emitters, bubblers, and accessories.
- B. Recycled Water System.
- C. Extension and repair to existing system.
- D. Control system.

1.02 RELATED REQUIREMENTS

- A. Division 26 - Electrical:
 - 1. Low-Voltage Electrical Power Conductors and Cables.
 - 2. Conduit.
- B. Section 31 23 16.13 - Trenching: Excavating and backfilling for irrigation piping.

1.03 REFERENCE STANDARDS

- A. ASME B1.20.1 - Pipe Threads, General Purpose, Inch.
- B. ASME B1.20.7 - Hose Coupling Screw Threads (Inch).
- C. ASTM D1785 - Standard Specification for Poly(Vinyl Chloride) (PVC) Plastic Pipe, Schedules 40, 80, and 120.
- D. ASTM D2235 - Standard Specification for Solvent Cement for Acrylonitrile-Butadiene-Styrene (ABS) Plastic Pipe and Fittings.
- E. ASTM D2241 - Standard Specification for Poly(Vinyl Chloride) (PVC) Pressure-Rated Pipe (SDR Series).
- F. ASTM D2466 - Standard Specification for Poly(Vinyl Chloride) (PVC) Plastic Pipe Fittings, Schedule 40.
- G. ASTM D2464 - Standard Specification for Threaded Poly(Vinyl Chloride) (PVC) Plastic Pipe Fittings, Schedule 80.
- H. ASTM D2564 - Standard Specification for Solvent Cements for Poly(Vinyl Chloride) (PVC) Plastic Piping Systems.
- I. ASTM D2672 - Standard Specification for Joints for IPS PVC Pipe Using Solvent Cement.
- J. ASTM D2855 - Standard Practice for the Two-Step (Primer and Solvent Cement) Method of Joining Poly (Vinyl Chloride) (PVC) or Chlorinated Poly (Vinyl Chloride) (CPVC) Pipe and Piping Components with Tapered Sockets.
- K. ASTM F402 - Standard Practice for Safe Handling of Solvent Cements, Primers, and Cleaners Used for Joining Thermoplastic Pipe and Fittings.
- L. MSS SP-107 - Transition Union Fittings for Joining Metal and Plastic Products.

- M. ASTM F656 - Standard Specification for Primers for Use in Solvent Cement Joints of Poly(Vinyl Chloride) (PVC) Plastic Pipe and Fittings.
- N. NEMA 250 - Enclosures for Electrical Equipment (1000 Volts Maximum).
- O. UL 493 - Thermoplastic-Insulated Underground Feeder and Branch-Circuit Cables.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordination: Coordinate the work with site backfilling, landscape grading and delivery of plant life.
- B. Preinstallation Meeting: Convene one week prior to commencing work of this Section.

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide component and control system and wiring diagrams.
- C. Shop Drawings: Indicate piping layout to water source, location of sleeves under pavement, location and coverage of sprinkler heads, components, plant and landscaping features, site structures, schedule of fittings to be used.
- D. Samples: Provide one outlet of each type, with housing. Accepted samples may be used in the Work.
- E. Operation and Maintenance Data:
 - 1. Provide instructions for operation and maintenance of system and controls, seasonal activation and shutdown, and manufacturer's parts catalog.
 - 2. Provide watering schedule that complies with the State Water Ordinance.
- F. Record Documents: Record actual locations of all concealed components piping system.
 - 1. Three laminated copies of the system map/station controller chart.
- G. Maintenance Materials: Provide the following for District's use in maintenance of project.
 - 1. See Section 01 60 00 - Product Requirements, for additional provisions.
 - 2. Extra Sprinkler Heads: Six of each type and size.
 - 3. Extra Valve Keys for Manual Valves: Two, 30 inch.
 - 4. Extra Valve Box Keys: Two.
 - 5. Extra Valve Marker Keys: Two.
 - 6. Extra Quick Coupler Keys: Four keys and quick coupler locking four ways.
 - 7. Extra Controller Box Keys: Six.
 - 8. Extra Ball Valve: One, five foot long valve handle to fit specified valve.
 - 9. Wrenches: Two for each type head core and for removing and installing each type head.

1.06 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing products specified in this section, with not less than three years of documented experience.
- B. Installer Qualifications: Company specializing in performing the work of this section with minimum three years of experience.

PART 2 PRODUCTS

2.01 REGULATORY REQUIREMENTS

- A. Comply with applicable code for piping and component requirements.

2.02 PERFORMANCE REQUIREMENTS

- A. General Requirements: Designed for uniform coverage over entire spray area indicated at available water pressure.
- B. Location and Arrangement: Drawings indicate diagrammatic location and arrangement of piping systems. Install piping as generally indicated unless deviations are approved on Coordination Drawings.
- C. Irrigation Zone Control: Automatic operation with controller and automatic control valves.
- D. Location of Sprinklers and Specialties: Design location is approximate. Make minor adjustments necessary to avoid plantings and obstructions such as signs and light standards. Maintain 100 percent irrigation coverage of areas indicated.

2.03 IRRIGATION SYSTEM

- A. Electric solenoid controlled underground irrigation system, with low point self drain.
 - 1. Source Power: 120 volt, 20 A., 1 phase.
 - 2. Low Voltage Controls: 24 volt, 0.45 A.
- B. Manufacturers:
 - 1. Calsense: www.calsense.com.
 - 2. Rain Bird Sales, Inc: www.rainbird.com.
 - 3. Toro Company: www.toro.com.
 - 4. Hunter: www.hunterindustries.com.
 - 5. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.

2.04 PIPE MATERIALS

- A. PVC Pipe: ASTM D2241; 280 psi pressure rated upstream from controls, 200 psi downstream; solvent welded sockets.
- B. Fittings: Type and style of connection to match pipe.
- C. Pipe Risers at Valves: 200 psi PVC pipe.
- D. Solvent Cement: ASTM D2564 for PVC pipe and fittings.
 - 1. Primer: ASTM F656.
- E. Sleeve Material: PVC.

2.05 RECYCLE WATER PIPE MATERIALS

- A. Purple PVC Pipe: ASTM D2241; 280 psi pressure rated upstream from controls, 200 psi downstream; solvent welded sockets.
- B. Purple PVC Pipe: ASTM D1785, PVC 1120 compound, Schedules 40 and 80.

- C. Fittings: Type and style of connection to match pipe.
 - 1. Purple PVC Socket Fittings: ASTM D2466, Schedules 40 and 80.
 - 2. Purple PVC Threaded Fittings: ASTM D2464, Schedule 80.
 - 3. Purple PVC Socket Unions: Construction similar to MSS SP-107, except both headpiece and tailpiece to be PVC with socket ends.
- D. Purple Pipe Risers at Valves: 200 psi PVC pipe.
- E. Solvent Cement: ASTM D2564 for PVC pipe and fittings.
 - 1. Primer: ASTM F656.
- F. Sleeve Material: Purple PVC.

2.06 WARNING TAPE FOR BURIED PIPE

- A. Plastic Warning Tape: Inert plastic film specifically formulated for prolonged underground use.
- B. Minimum thickness: 4 mils.
- C. Overall Tape Width: 12 inches for 8-inch and larger pipe and 6 inches for 6-inch and smaller pipe.
- D. Lettering:
 - 1. Potable Water: Blue background with the following words in black letters: "CAUTION: POTABLE WATER-LINE BURIED BELOW".
 - 2. Recycled Water: Purple background with the following words in black letters: "CAUTION: RECYCLED WATER-LINE BURIED BELOW".

2.07 WARNING LABELS FOR EXPOSED PIPE AND APPURTENANCES

- A. Labels: Inert plastic film specifically formulated for prolonged exposure.
- B. Minimum Thickness: 4 mils for adhesive backed labels and 10 mils for tag type labels.
- C. Tag type labels shall have reinforced tie holes and shall be attached with heavy-duty nylon fasteners.
- D. Provide with 1/2-inch high black letters (minimum):
 - 1. Potable Water: Blue background with the following words in black letters: "POTABLE WATER".
 - 2. Recycled Water: Purple background with the following words in black letters: "CAUTION: RECYCLED WATER – DO NOT DRINK"
 - 3. The size and type of label will be dictated by each individual application and subject to acceptance by the Water District.

2.08 WITNESS MARKERS

- A. Design:
 - 1. High visibility.
 - 2. Equipped with a barb or other such device to secure marker in the surrounding soil.
- B. Materials: UV-resistant fiberglass.

C. Identification:

1. Potable Water: Blue background with the following words in black letters: "POTABLE WATER".
2. Recycled Water: Purple background with the following words in black letters: "RECYCLED WATER".

2.09 OUTLETS

- A. Outlets: Brass construction.
- B. Rotary Type Sprinkler Head with purple ID cap approved for recycled water use: Pop-up type with screens; fully adjustable for flow and pressure; size as indicated; with letter or symbol designating degree of arc and arrow indicating center of spray pattern.
- C. Spray Type Sprinkler Head: Pop-Up head with pattern as indicated on Drawings.
- D. Emitter: Adjustable outlet, non-clogging, .
- E. Bubbler: Adjustable outlet and pressure compensating.
 1. Pop-up Bubblers, with purple caps.
- F. Quick Coupler:
 1. Factory-fabricated, brass, two-piece assembly approved for non-potable use as indicated on Drawings.
 - a. Include coupler water-seal valve; removable upper body with spring-loaded or weighted, rubber-covered cap; hose swivel with ASME B1.20.7, 3/4-11.5NH threads for garden hose on outlet; and operating key.
 - b. Locking-Top Option: Vandal-resistant locking feature. Include two matching key(s).

2.10 VALVES

- A. Gate Valves: Bronze construction non-rising stem.
- B. Valves: As indicated on Drawings.
- C. Backflow Preventers: Reduced pressure zone type.
 1. Basis of Design Product: Reduce Pressure as manufactured by Febco, or approved equal.
- D. Valve Box and Cover:
 1. Plastic Boxes:
 - a. Description: Purple Box and cover, with open bottom and openings for piping; designed for installing flush with grade.
 - 1) Size: As required for valves and service.
 - 2) Shape: Round or rectangular.
 - 3) Sidewall Material: PVC.
 - 4) Cover Material: PVC.
 - b. Lettering: Heat brand each lid per irrigation details as indicated on Drawings.
- E. Drain Valve: Spring-loaded-ball type of corrosion-resistant construction and designed to open for drainage if line pressure drops below 2-1/2 to 3 psig.

- F. Drainage Backfill: Cleaned gravel or crushed stone, graded from 3/4 inch minimum to 3 inches maximum.

2.11 CONTROLS

- A. Manufacturers:
 - 1. Calsense: www.calsense.com.
 - 2. Hunter Industries: www.hunterindustries.com.
 - 3. Rainbird: www.rainbird.com.
 - 4. Or Equal Substitutions: See Section 01 60 00 - Product Requirements.
- B. Controller: Automatic controller, microprocessor solid state control with visible readout display, temporary override feature to bypass cycle for inclement weather, timer for a 6 station system, programmable for 14 days in quarter hour increments, with automatic start and shutdown.
 - 1. Manual or Semiautomatic Operation: Allows this mode without disturbing preset automatic operation.
 - 2. Nickel-Cadmium Battery and Trickle Charger: Automatically powers timing device during power outages.
 - 3. Surge Protection: Metal-oxide-varistor type on each station and primary power.
 - 4. Moisture Sensor: Adjustable from one to seven days, to shut off water flow during rain.
- C. Controller Housing: NEMA 250 Type 4; weatherproof, watertight, with lockable access door.
 - 1. Locking cover and two matching keys; include provision for grounding.
 - 2. Body Material: Stainless-steel sheet metal.
 - 3. Mounting: Freestanding type for concrete base.
- D. Concrete Base: Reinforced precast concrete not less than 36 by 24 by 4 inches thick, and 6 inches greater in each direction than overall dimensions of controller. Include opening for wiring.
- E. Valves: Electric Solenoid; normally closed; wiring, including required fittings and accessories.
- F. Wire Conductors: Color coded.
 - 1. UL 493, Type UF multiconductor, with solid-copper conductors; insulated cable; suitable for direct burial.
 - a. Feeder-Circuit Cables: No. 12 AWG minimum, between building and controllers.
 - b. Low-Voltage, Branch-Circuit Cables: No. 14 AWG minimum, between controllers and automatic control valves; color-coded different from feeder-circuit-cable jacket color; with jackets of different colors for multiple-cable installation in same trench.
 - c. Splicing Materials: Manufacturer's packaged kit consisting of insulating, spring-type connector or crimped joint and epoxy resin moisture seal; suitable for direct burial.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify location of existing utilities.
- B. Verify that required utilities are available, in proper location, and ready for use.

3.02 PREPARATION

- A. Piping layout indicated is diagrammatic only. Route piping to avoid plants, ground cover, and structures.
- B. Layout and stake locations of system components.
- C. Review layout requirements with other affected work. Coordinate locations of sleeves under paving to accommodate system.

3.03 TRENCHING

- A. Trench and backfill in accordance with Section 31 23 16.13.
- B. Trench Size:
 - 1. Minimum Width: 8 inches.
 - 2. Minimum Cover Over Installed Supply Piping: 24 inches.
 - 3. Minimum Cover Over Installed Branch Piping: 12 inches.
 - 4. Minimum Cover Over Installed Outlet/Drain Piping: 12 inches.
 - 5. Minimum Cover Over Sleeves: 18 inches.
- C. Trench to accommodate grade changes and slope to drains.
- D. Install warning tape directly above pressure piping, 12 inches below finished grades, except 6 inches below subgrade under pavement and slabs.
 - 1. Longitudinally center over pipe.
 - 2. Install warning tape continuously for the length of the pipe.
- E. Maintain trenches free of debris, material, or obstructions that may damage pipe.

3.04 INSTALLATION

- A. Install pipe, valves, controls, and outlets in accordance with manufacturer's instructions.
- B. Install groups of pipes parallel to each other, spaced to permit valve servicing.
- C. Install fittings for changes in direction and branch connections.
- D. Install unions adjacent to valves and to final connections to other components with NPS 2 or smaller pipe connection.
- E. Install flanges adjacent to valves and to final connections to other components with NPS 2-1/2 or larger pipe connection.
- F. Install expansion loops in control-valve boxes for plastic piping.
- G. Install PVC piping in dry weather when temperature is above 40 deg F. Allow joints to cure at least 24 hours at temperatures above 40 deg F before testing.

H. Joint Construction:

1. Ream ends of pipes and tubes and remove burrs. Bevel plain ends of steel pipe.
2. Remove scale, slag, dirt, and debris from inside and outside of pipe and fittings before assembly.
3. Threaded Joints: Thread pipe with tapered pipe threads according to ASME B1.20.1. Cut threads full and clean using sharp dies. Ream threaded pipe ends to remove burrs and restore full ID. Join pipe fittings and valves as follows:
 - a. Apply appropriate tape or thread compound to external pipe threads unless dry seal threading is specified.
 - b. Damaged Threads: Do not use pipe or pipe fittings with threads that are corroded or damaged. Do not use pipe sections that have cracked or open welds.
4. Flanged Joints: Select rubber gasket material, size, type, and thickness for service application. Install gasket concentrically positioned. Use suitable lubricants on bolt threads.
5. PE Piping Fastener Joints: Join with insert fittings and bands or fasteners according to piping manufacturer's written instructions.
6. PVC Piping Solvent-Cemented Joints: Clean and dry joining surfaces. Join pipe and fittings according to:
 - a. Comply with ASTM F402 for safe-handling practice of cleaners, primers, and solvent cements.
 - b. PVC Pressure Piping: Join schedule number, ASTM D1785, PVC pipe and PVC socket fittings according to ASTM D2672. Join other than schedule number PVC pipe and socket fittings according to ASTM D2855.
 - c. PVC Nonpressure Piping: Join according to ASTM D2855.

I. Connect to utilities.

J. Set outlets and box covers at finish grade elevations.

K. Provide for thermal movement of components in system.

L. Slope piping at minimum uniform slope of 0.5 percent for self drainage to drain valves or gravel filled well point.

1. Lay piping on solid subbase, uniformly sloped without humps or depressions.

M. Use threaded nipples for risers to each outlet.

N. Automatic Irrigation-Control System Installation:

1. Equipment Mounting: Install exterior freestanding controllers on precast concrete bases.
 - a. Place and secure anchorage devices. Use setting drawings, templates, diagrams, instructions, and directions furnished with items to be embedded.
 - b. Install anchor bolts to elevations required for proper attachment to supported equipment.
2. Install control cable in same trench as irrigation piping and at least 2 inches below piping. Provide conductors of size not smaller than recommended by controller manufacturer. Install cable in separate sleeve under paved areas.

FOR REFERENCE ONLY

- O. Install control conduit and wiring in accordance with Section 26 05 19. Provide 10 inch expansion coil at each valve to which controls are connected, and at 100 ft intervals. Bury conduit beside mainline pipe.
- P. Valves: Install for underground piping in boxes for automatic control valves as indicated on the Drawings.
- Q. Identification:
 - 1. Identify system components. Comply with requirements for identification specified in Division 22 - Plumbing.
 - 2. Equipment Nameplates and Signs: Install engraved plastic-laminate equipment nameplates and signs on each automatic controller.
 - a. Text: In addition to identifying unit, distinguish between multiple units, inform operator of operational requirements, indicate safety and emergency precautions, and warn of hazards and improper operations.
 - 3. Warning Tapes: Arrange for installation of continuous, underground, detectable warning tapes over underground piping during backfilling of trenches. See Division 33 - Utilities for warning tapes.
- R. Mark valves with neoprene valve markers containing locking device. Set valve markers in pipe risers extending from top of valve to finish grade.
- S. After piping is installed, but before outlets are installed and backfilling commences, open valves and flush system with full head of water.
- T. Sprinkler (Outlet) Installation:
 - 1. Install sprinklers after hydrostatic test is completed.
 - 2. Install sprinklers at manufacturer's recommended heights.
 - 3. Locate part-circle sprinklers to maintain a minimum distance of 4 inches from walls and 2 inches from other boundaries unless otherwise indicated.

3.05 INSTALLATION OF WARNING LABELS

- A. Install warning labels on all appurtenances in vaults, such as, but not limited to, air release valves, blow offs, and meters, and on designated facilities, such as, but not limited to, controller panels, wash down or blow off hydrants, on water trucks, and temporary construction services.
- B. Location of labels will be dictated by each individual application and subject to acceptance by the Water District.
- C. Firmly attach warning labels to all appurtenances using heavy-duty nylon fasteners.
- D. Painted labels may, at the Water District's discretion be acceptable in lieu of plastic labels.

3.06 INSTALLATION OF WITNESS MARKERS (UNPAVED AREAS)

- A. Install witness markers over all pipe in unpaved areas and open space areas at intervals not greater than 200 feet.
- B. Install witness markers at all appurtenances, including but not limited to valves, valve boxes, air release/vacuum breaks, dead ends, inflection points, and tees.

- C. Embed witness markers into the soil at least 18-inches or as directed by manufacturer; the more stringent requirement shall apply.

3.07 FIELD QUALITY CONTROL

- A. Field inspection and testing will be performed under provisions of Section 01 40 00 - Quality Requirements.
- B. Prior to backfilling, test system for leakage at main piping to maintain 100 psi pressure for one hour.
- C. System is acceptable if no leakage or loss of pressure occurs and system self drains during test period.
- D. Operational Test: After electrical circuitry has been energized, operate controllers and automatic control valves to confirm proper system operation.
- E. Test and adjust controls and safeties. Replace damaged and malfunctioning controls and equipment.
- F. Prepare test and inspection reports.

3.08 BACKFILLING

- A. Provide 3 inch sand cover over piping.
- B. Backfill trench and compact to specified subgrade elevation. Protect piping from displacement.

3.09 SYSTEM STARTUP

- A. Prepare and start system in accordance with manufacturer's instructions.
- B. Adjust control system to achieve time cycles required.
- C. Adjust automatic control valves to provide flow rate at rated operating pressure required for each sprinkler circuit.
- D. Adjust sprinklers and devices, except those intended to be mounted aboveground, so they will be flush with, or not more than 1/2 inch, finish grade.
- E. Adjust head types for full water coverage as directed.

3.10 CLOSEOUT ACTIVITIES

- A. Instruct District's personnel in operation and maintenance of system, including adjusting of sprinkler heads. Use operation and maintenance data as basis for demonstration.

3.11 MAINTENANCE

- A. See Section 01 70 00 - Execution and Closeout Requirements, for additional requirements relating to maintenance service.
- B. Provide a separate maintenance contract for specified maintenance service.
- C. Provide one complete spring start-up and a fall shutdown by installer, at no extra cost to District.

3.12 PIPING SCHEDULE

- A. Install components having pressure rating equal to or greater than system operating pressure.

- B. Piping in control-valve boxes and aboveground may be joined with flanges or unions instead of joints indicated.
- C. Underground irrigation main piping, 2 inches to 4 inches:
 - 1. Schedule 40, PVC pipe and socket fittings, and solvent-cemented joints.
- D. Lateral piping, 3/4 inch to 2-1/2 inch:
 - 1. Schedule 40, PVC pipe and socket fittings; and solvent-cemented joints.
- E. Circuit piping, 3/4 inch to 2-1/2 inch:
 - 1. Schedule 40, PVC pipe and socket fittings; and solvent-cemented joints.
- F. Underground Branches and Offsets at Sprinklers and Devices:
 - 1. Schedule 80, PVC pipe; threaded PVC fittings; and threaded joints.
 - 2. Option: Plastic swing-joint assemblies, with offsets for flexible joints, manufactured for this application.
- G. Risers to Aboveground Sprinklers and Specialties:
 - 1. Schedule 80, PVC pipe and socket fittings; and solvent-cemented joints, off unless indicated otherwise on Drawings.
- H. Drain piping:
 - 1. Schedule 40, PVC pipe and socket fittings; and solvent-cemented joints.

3.13 VALVE SCHEDULE

- A. Underground, Shutoff-Duty Valves: Use the following:
 - 1. NPS 2 and Smaller: Curb valve, curb-valve casing, and shutoff rod.
 - 2. NPS 3 and Larger: Iron gate valve, resilient seated; iron gate valve casing; and operating wrench(es).
- B. Aboveground, Shutoff-Duty Valves:
 - 1. NPS 2 and Smaller: Brass or Bronze ball valve.
 - 2. NPS 2-1/2 and Larger: Iron ball valve.
- C. Throttling-Duty Valves:
 - 1. NPS 2 and Smaller: Bronze automatic control valve.
 - 2. NPS 2 and Smaller: Brass or Bronze ball valve.
 - 3. NPS 2-1/2 and NPS 3: Bronze automatic control valve.
 - 4. NPS 2-1/2 and NPS 3: Iron ball valve.
- D. Drain Valves:
 - 1. NPS 1/2 and NPS 3/4: Automatic drain valve.
 - 2. NPS 1/2 and NPS 3/4: Brass or Bronze ball valve.
 - 3. NPS 1 to NPS 2: Brass or Bronze ball valve.

END OF SECTION

FOR REFERENCE ONLY

SECTION 32 91 19 LANDSCAPE GRADING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Topsoil placement.
- B. Finish grading.

1.02 RELATED REQUIREMENTS

- A. Section 31 10 00 - Site Clearing.
- B. Section 31 22 00 - Grading.

1.03 PRICE AND PAYMENT PROCEDURES

1.04 REFERENCE STANDARDS

- A. 29 CFR 1910.266 - Logging Operations.
- B. ASTM D5268 - Standard Specification for Topsoil Used for Landscaping and Construction Purposes.

1.05 SUBMITTALS

- A. Project Record Documents: Accurately record actual locations of utilities remaining by horizontal dimensions, elevations or inverts, and slope gradients.
- B. Field Quality Control Submittals: Topsoil depth measurements.

1.06 QUALITY ASSURANCE

- A. Perform work in accordance with City of _____, Public Works Department standards.
 - 1. Maintain one copy on-site.

1.07 FIELD CONDITIONS

- A. Place topsoil during dry weather.
- B. Ambient Conditions: Terminate work during hazardous environmental conditions in accordance with 29 CFR 1910.266.
- C. Existing Conditions: See site drawing; see Section 00 31 00 - Available Project Information.

PART 2 PRODUCTS

2.01 MATERIALS

- A. Topsoil: Comply with ASTM D5268.
- B. Topsoil: Topsoil excavated on-site.
 - 1. Free of roots, rocks larger than 1/2 inch, subsoil, debris, large weeds and foreign matter.

2. Acidity Range (pH): 5.5 to 7.5.
3. Mechanical Analysis:
 - a. Sand: 70 to 85 percent.
 - b. Silt: 10 to 20 percent.
 - c. Clay: 10 to 15 percent.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify grading and intended elevations are as indicated on drawings.
- B. Verify absence of standing or ponding water.

3.02 PREPARATION

- A. Protect site features to remain, including bench marks, survey control points, existing structures, fences, sidewalks, paving, and curbs.
- B. Protect trees, plants, lawns, and other features to remain.
- C. Remove debris, roots, branches, stones, in excess of 1/2 inch in size.
- D. Scarify surface to depth of 3 inches.
- E. Clear site; see Section 31 10 00.
- F. Grade substrate, see Section 31 22 00.

3.03 TOPSOIL PLACEMENT

- A. Uniformly distribute and spread topsoil.
- B. Place topsoil in areas where seeding, sodding, and planting as indicated on drawings.
- C. Place topsoil to the following compacted thicknesses:
 1. Areas Indicated Seeded with Grass: 6 inches.
 2. Areas Indicated as Sodded: 4 inches.
 3. Shrub Beds: 18 inches.
 4. Flower Beds: 12 inches.

3.04 FINISH GRADING

- A. Maintain profiles and contour of subgrade.
- B. Remove roots, weeds, rocks, and foreign material while spreading.
- C. Maintain uniform topsoil thickness.
- D. Lightly compact placed topsoil.
- E. Maintain stability of topsoil during inclement weather. Replace eroded topsoil.

3.05 TOLERANCES

- A. Topsoil Thickness: 1/2 inch plus/minus.

FOR REFERENCE ONLY

3.06 CLEANING

- A. See Section 01 70 00 - Execution and Closeout Requirements for additional requirements.
- B. Remove unused topsoil. Grade stockpile area to prevent standing water.

3.07 PROTECTION

- A. Protect from stormwater runoff and subsequent construction operations.
- B. Do not permit traffic until established.

END OF SECTION

SECTION 32 93 00 PLANTING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Preparation of subsoil.
- B. New trees, plants, and ground cover.
- C. Relocated trees, plants, and ground cover.
- D. Mulch and Fertilizer.
- E. Tree Pruning.

1.02 RELATED REQUIREMENTS

- A. Section 31 22 00 - Grading: Topsoil material.
- B. Section 31 23 23 - Fill: Topsoil material.
- C. Section 32 01 90 - Operation and Maintenance of Planting: Post-occupancy maintenance.

1.03 DEFINITIONS

- A. Weeds: Include Dandelion, Jimsonweed, Quackgrass, Horsetail, Morning Glory, Rush Grass, Mustard, Lambsquarter, Chickweed, Cress, Crabgrass, Canadian Thistle, Nutgrass, Poison Oak, Blackberry, Tansy Ragwort, Bermuda Grass, Johnson Grass, Poison Ivy, Nut Sedge, Nimble Will, Bindweed, Bent Grass, Wild Garlic, Perennial Sorrel, and Brome Grass.
- B. Plants: Living trees, plants, and ground cover specified in this Section , and described in ANSI Z60.1.

1.04 REFERENCE STANDARDS

- A. ANSI/AHIA Z60.1 - American National Standard for Nursery Stock.
- B. ANSI A300 Part 1 - American National Standard for Tree Care Operations - Tree, Shrub, and Other Woody Plant Management - Standard Practices (Pruning).

1.05 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Maintenance Data: Include cutting and trimming method; types, application frequency, and recommended coverage of fertilizer.
- C. Submit list of plant life sources.
- D. Maintenance Contract.

1.06 QUALITY ASSURANCE

- A. Nursery Qualifications: Company specializing in growing and cultivating the plants with three years documented experience.

- B. Installer Qualifications: Company specializing in installing and planting the plants with three years experience.
- C. Tree Pruner Qualifications: Company specializing in pruning trees with proof of Arborist Certification.
- D. Tree Pruning: Comply with ANSI A300 Part 1.
- E. Maintenance Services: Performed by installer.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Deliver fertilizer in waterproof bags showing weight, chemical analysis, and name of manufacturer.
- B. Protect and maintain plant life until planted.
- C. Deliver plant life materials immediately prior to placement. Keep plants moist.

1.08 FIELD CONDITIONS

- A. Do not install plant life when ambient temperatures may drop below 35 degrees F or rise above 100 degrees F.
- B. Do not install plant life when wind velocity exceeds 30 mph.

1.09 WARRANTY

- A. See Section 01 78 00 - Closeout Submittals, for additional warranty requirements.
- B. Provide one year warranty.
- C. Warranty: Include coverage for one continuous growing season; replace dead or unhealthy plants.
- D. Replacements: Plants of same size and species as specified, planted in the next growing season, with a new warranty commencing on date of replacement.

1.10 MAINTENANCE (SEE END OF SECTION)

- A. See Section 01 70 00 - Execution and Closeout Requirements, for additional requirements relating to maintenance service.
- B. Provide a separate maintenance contract for specified maintenance service.
- C. Provide a separate maintenance contract for the service and maintenance of work specified in this section for one years from Date of Substantial Completion.

PART 2 PRODUCTS

2.01 PLANTS

- A. Plants: Species and size identified in plant schedule, grown in climatic conditions similar to those in locality of the work.

2.02 SOIL AMENDMENT MATERIALS

- A. Fertilizer: Amend soil based on soil report prepared prior to any planting.

- B. Fertilizer: Containing fifty percent of the elements derived from organic sources; of proportion necessary to eliminate any deficiencies of topsoil, as indicated in analysis.
 - 1. Nitrogen: 20 percent.
 - 2. Phosphoric Acid: 10 percent.
 - 3. Soluble Potash: 5 percent.
- C. Planting Tablets: Tightly compressed chip-type, long-lasting, slow-release, commercial-grade planting fertilizer in tablet form. Tablets shall break down with soil bacteria, converting nutrients into a form that can be absorbed by plant roots.
 - 1. Agriform Blue Chip Tablets.
 - 2. Size: 21 gram tablets.
 - 3. Nutrient Composition: 20 percent nitrogen, 10 percent phosphorous, and 5 percent potassium, by weight plus micronutrients.
- D. Water: Clean, fresh, and free of substances or matter that could inhibit vigorous growth of plants.

2.03 MULCH MATERIALS

- A. Mulching Material: any species wood ground bark, free of growth or germination inhibiting ingredients.

2.04 ACCESSORIES

- A. Wrapping Materials: Burlap.
- B. Stakes: Softwood lumber, pointed end.
- C. Root Barrier: EP Series Root Barrier Panels, model EP-2450 as manufactured by NDS or approved equal.
- D. Root barrier shall be "Tyvar Biobarrier" root control root fabric in 12", 19.5" or 39" width with Treflan, manufactured by Dow Elanco., as supplied by Butler Mill Co., (619) 263-6181, to match existing. This is a necessary item, that is only available from the listed source, or it is required to match existing Campus standards, and no other product shall be furnished.

2.05 SOURCE QUALITY CONTROL

- A. Provide analysis of topsoil; comply with requirements of Section 01 40 00.
- B. Provide testing of existing topsoil.
- C. Analyze to ascertain percentage of nitrogen, phosphorus, potash, soluble salt and organic matter; pH value.
- D. Submit minimum 10 oz sample of topsoil proposed. Forward sample to testing laboratory in sealed containers to prevent contamination.
- E. Submit soil sample to testing laboratory in sealed containers to prevent contamination.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that prepared subsoil and planters are ready to receive work.

- B. Saturate soil with water to test drainage.
- C. Verify that required underground utilities are available, in proper location, and ready for use.

3.02 PREPARATION OF SUBSOIL

- A. Prepare subsoil to eliminate uneven areas. Maintain profiles and contours. Make changes in grade gradual. Blend slopes into level areas.
- B. Remove foreign materials, weeds and undesirable plants and their roots. Remove contaminated subsoil.
- C. Scarify subsoil to a depth of 6 inches where plants are to be placed. Repeat cultivation in areas where equipment, used for hauling and spreading topsoil, has compacted subsoil.
- D. Dig pits and beds 6 inches larger than plant root system.

3.03 PLACING TOPSOIL

- A. Spread topsoil to a minimum depth of 4 inches over area to be planted. Rake smooth.
- B. Place topsoil during dry weather and on dry unfrozen subgrade.
- C. Remove vegetable matter and foreign non-organic material from topsoil while spreading.
- D. Grade topsoil to eliminate rough, low or soft areas, and to ensure positive drainage.
- E. Install topsoil into pits and beds intended for plant root balls, to a minimum thickness of 6 inches.

3.04 FERTILIZING

- A. Apply fertilizer in accordance with manufacturer's instructions.
 - 1. Place planting tablets in each planting hole at the following rate:
 - a. 4 inch Box Container: One 21 Gram tablet.
 - b. 1 Gallon Container: One 21 Gram tablet.
 - c. 5 Gallon Container: Three 21 Gram tablets.
 - d. 15 Gallon Container: Four 21 Gram tablets.
- B. Apply per soil amendments.
- C. Mix thoroughly into upper 2 inches of topsoil.
- D. Lightly water to aid the dissipation of fertilizer.

3.05 PLANTING

- A. Place plants as indicated.
- B. Place plants for best appearance for review and final orientation by Architect.
- C. Set plants vertical.
- D. Remove non-biodegradable root containers.
- E. Set plants in pits or beds, partly filled with prepared plant mix, at a minimum depth of 6 inches under each plant. Remove burlap, ropes, and wires, from the root ball.
- F. Place bare root plant materials so roots lie in a natural position. Backfill soil mixture in 6 inch layers. Maintain plant life in vertical position.

- G. Saturate soil with water when the pit or bed is half full of topsoil and again when full.

3.06 INSTALLATION OF ACCESSORIES

- A. Place decorative cover and membrane, where indicated on drawings.
- B. Place grates at base of trees where indicated on drawings.

3.07 PLANT SUPPORT

- A. Stake trees per details on Drawings.

3.08 TREE PRUNING

- A. Prune trees as recommended in ANSI A300 Part 1.
- B. Prune newly planted trees as required to remove dead, broken, and split branches.

3.09 FIELD QUALITY CONTROL

- A. Perform field inspection and testing in accordance with Section 01 40 00.
- B. Plants will be rejected if a ball of earth surrounding roots has been disturbed or damaged prior to or during planting.

3.10 MAINTENANCE

- A. See Section 32 01 90 - Operation and Maintenance of Planting for post-occupancy maintenance.

END OF SECTION

PART 1 - GENERAL

1.01 SCOPE OF WORK

- A. The work includes, but is not necessarily limited to, the following:
 - 1. Domestic water piping system.
 - 2. Fire protection piping systems.
 - 3. Sewer piping system.
- B. Other items that may be specified or shown on the Drawings.

1.02 RELATED WORK SPECIFIED ELSEWHERE

- A. Section 01 50 00, Construction Facilities and Temporary Controls.
- B. Section 31 23 33, Trenching and Backfilling.
- C. Section 32 16 00, Site Concrete.
- D. Section 33 00 00, Earthwork.

1.03 QUALITY ASSURANCE

- A. Use only new materials and products, unless existing materials or products are specifically shown otherwise on the drawings to be salvaged and re-used.
 - 1. Sun damaged or discolored PVC pipe will be rejected.
- B. All materials, components, assemblies, workmanship and installation are to be observed by the Owner's Inspector of Record. Work not so inspected is subject to uncovering and replacement.
- C. The representatives of the Owner's testing lab will not act as supervisor of construction, nor will they direct construction operations. Neither the presence of the Owner's testing lab representatives nor the testing by the Owner's testing lab shall excuse the contractors or subcontractors for defects or deficiencies discovered in their work during or following completion of the project. Correcting inadequate compaction is the sole responsibility of the contractor.
- D. Contractor shall be solely responsible for all subgrades built. Any repairs resulting from inadequate compaction or incorrect grades will be the responsibility of the contractor.
- E. Per 2022 NFPA 13 provide Contractor's material and test certificate to the Owner, Architect, Project Inspector and Local Fire Authority.

1.04 SUBMITTALS

- A. Manufacturer's Data: Submit list and complete descriptive data of all products proposed for use. Include manufacturer's specifications, published warranty or guarantee, installation instructions, and maintenance instructions.
- B. Provide sieve analysis from accredited testing lab on pipe bedding material. Analysis shall have a current date not older than project contract signing date.
- C. Substitution: Provide all data of proposed material being submitted as a substitution. Provide comparison with specified product data and identify all differences. Failure to provide comparison will be reason for rejection.

1.05 FEES, PERMITS, AND UTILITY SERVICES

- A. Obtain and pay for permits and service charges required for installation of Work. Arrange for required inspections and secure written approvals from authorities having jurisdiction.
- B. Upon completion of work within right-of-way, provide copies of written final approval to the Architect.

1.06 WARRANTY

- A. Refer to General Conditions and Section 01 78 36.

1.07 REFERENCES AND STANDARDS

- A. ANSI/ASTM D698-00 - Test Methods for Moisture-Density Relations of Soils and Soil-Aggregate Mixtures, Using 5.5 lb (2.49 Kg) Rammer and 12 inch (304.8 mm) Drop.
- B. ANSI/ASTM D1556-00 - Test Method for Density of Soil in Place by the Sand-Cone Method.
- C. ANSI/ASTM D1557-02 - Test Methods for Moisture-Density Relations of Soils and Soil-Aggregate Mixtures Using 10 lb. (4.54 Kg) Rammer and 18 inch (457 mm) Drop.
- D. ANSI/ASTM D 3017-05 Test Methods for Moisture Content of Soils and Soil-Aggregate Mixture by Nuclear Methods (Shallow Depth).
- E. ANSI/ASTM D 4318-05 Test Method for Liquid Limit, Plastic Limit, and Plasticity Limit.
- F. CALTRANS Standard Specifications.
- G. CAL-OSHA, Title 8, Section 1590 (e).
- H. Any work within the street, highway or right-of-way shall be performed in accordance with the requirement of the governmental agencies having jurisdiction, and shall not begin until all of those governing authorities have been notified.
- I. NFPA 13, 24 and 25, latest editions.
- J. California State Health and Safety Code Section 116875, Lead Free Public Water Systems.
- K. California Plumbing Code, latest edition.

1.08 DELIVERY, STORAGE AND HANDLING

- A. Transport, store and handle in strict accord with the local jurisdiction.
- B. Make delivery to job when notified by Contractor verifying that the job is ready to receive the work of this Section and that arrangements have been made to properly store, handle and protect such materials and work.

1.09 PROJECT CONDITIONS

- A. Existing civil, mechanical and electrical improvements are shown on respective site plans to the extent known. Should the Contractor encounter any deviation between actual conditions and those shown, he is to immediately notify the Architect before continuing work.

1.10 EXISTING SITE CONDITIONS

- A. Contractor shall acquaint himself with all site conditions. If unknown active utilities are encountered during work, notify Architect promptly for instructions. Failure to notify will make Contractor liable for damage to these utilities arising from Contractor's operations subsequent to discovery of such unknown active utilities.

1.11 PROTECTION

- A. Adequate protection measures shall be provided to protect workmen and passers-by on and off the site. Adjacent property shall be fully protected throughout the operations. Blasting will not be permitted. Prevent damage to adjoining improvements and properties both above and below grade. Restore such improvements to original condition should damage occur. Replace trees and shrubs outside building area disturbed by operations.
- B. In accordance with generally accepted construction practices, the Contractor shall be solely and completely responsible for working conditions at the job site, including safety of all persons and property during performance of the work. This requirement shall apply continuously and shall not be limited to normal working hours.
- C. Any construction review of the Contractor's performance conducted by the Geotechnical Engineer is not intended to include review of the adequacy of the Contractor's safety measures, in, on, or near the construction site.
- D. Provide shoring, sheeting, sheet piles and or bracing to prevent caving, erosion or gulying of sides of excavation.
- E. Surface Drainage: Provide for surface drainage during period of construction in manner to avoid creating nuisance to adjacent areas. The contractor shall make a reasonable effort on a daily basis to provide pumps and all equipment necessary to keep all excavations and the site free from water during entire progress of work, regardless of cause, source, or nature of water.
- F. Adjacent streets and sidewalks shall be kept free of mud, dirt or similar nuisances resulting from earthwork operations.
- G. The site and adjacent influenced areas shall be watered as required to suppress dust nuisance. Dust control measures shall be in accordance with the local jurisdiction.

- H. Trees: Carefully protect existing trees that are to remain. Provide temporary irrigation as necessary to maintain health of trees.

1.12 SEASONAL LIMITS

- A. No fill material shall be placed, spread or rolled during unfavorable weather conditions. When work is interrupted by rains, fill operations shall not be resumed until field tests indicate that moisture content and density of fill are satisfactory.

1.13 RECORD DRAWINGS

- A. Keep a daily record of all pipe placed in ground, verified by Project Inspector.
- B. Upon completion of this Contract, furnish one tracing showing all outside utility lines, piping, etc., installed under this Contract. Locate and dimension all work with reference to permanent landmarks.
- C. All symbols and designations used in preparing "RECORD" drawings shall match those used in Contract drawings.
- D. Properly identify on as-builts and provide dimensions for all stubs for future connections. Provide concrete markers 6" dia. 12" deep, flush with finish grade at the ends of all stubbed pipes.

PART 2 – PRODUCTS

2.01 MATERIALS - GENERAL

- A. Provide each item listed herein or shown on drawings of quality noted or approved equal. All material shall be new, full weight, standard in all respects and in first-class condition. Insofar as possible, all materials used shall be of same brand or manufacture throughout for each class of material or equipment.
- B. Grade or quality of materials desired is indicated by trade names or catalog numbers stated herein.
- C. Dimensions, sizes, and capacities shown are minimum and shall not be changed without permission of Architect.
- D. All materials in this section used for any public water system or domestic water for human consumption shall be lead free.
 - 1. For the purposes of this section, "lead free" means not more than 0.2 percent lead when used with respect to solder and flux and not more than 8 percent when used with respect to pipes and pipe fittings.
 - 2. All pipe, pipe or plumbing fitting or fixtures, solder, or flux shall be certified by an independent American National Standards Institute (ANSI) accredited third party, including, but not limited to, NSF International, as being in compliance with this section.
- E. All materials used for fire system piping shall be UL and FM approved.

2.02 VALVE BOXES

- A. Provide at each valve or cock in ground a Christy, Brooks, or equal to Christy G05CT, concrete valve box with cover marked for service, domestic water shall be marked "Water" and fire supply shall be marked "Fire". Furnish extension handles for each size square nut valve, and provide "fork" handle for each size of "wheel handle" valve as required. Do not locate valve boxes in walk, or covered passages, curbs, or curb & gutters, unless necessary. If valve location is within concrete or asphalt paved surface valve box shall be as detailed on plans for such condition. Provide valve box extensions as required to set bottom of valve box to bottom of piping in which valve is installed. Provide Owner with set of special wrenches and/or tools as required for operation of valves.

2.03 PIPES AND FITTINGS

- A. Sanitary Sewer: PVC sewer pipe and fittings with Ring-Tite joints, ASTM D3034 SDR35.
- B. Domestic water Lines 3 1/2" and smaller: Type K copper tubing, hard temper, with wrought copper fittings. Schedule 80 PVC.
- C. Water lines 4" and larger: AWWA C-900 Class 150/DR18 with rubber gasket joints.
- D. Fire lines 4" and larger: AWWA C-900 Class 200/DR14 with rubber gasket joints.
- E. Solder: Lead Free. 95/5; 95% Tin / 5% Antimony.
- F. Ductile Iron Pipe; Class 350, Cement Lined
- G. Ductile Iron Pipe Fittings; AWWA C110, C153, Ebba Iron, Star Romac, Sigma, or approved equal.
- H. Mechanical Fitting Bolts; Bolts and nuts shall be carbon steel with a minimum 60,000 psi tensile strength conforming to ASTM A 307, Grade A. Bolts shall be standard ANSI B1.1 Class 2A course threads. Nuts shall conform to ASTM A 563 and be standard ANSI B1.1, Class 2A course thread. All bolts and nuts shall be zinc coated.
- I. Fasteners Anti-Rust Coatings; After assembly, coat all fasteners with an Asphaltic Bituminous coatings conforming to latest edition NFPA 24.
- J. Ductile Iron Pipe Wrap; 8 mil polyethylene pipe wrap conforming to ANSI/AWWA C105/A21.5 standards.
- K. Pipe Insulation; Pipe exposed to atmospheric conditions 1/2" thru 4" NPT; Johns Manville rigid fiberglass insulation, Micro Lok HP; Owens Corning Fiberglas SSL II; Conforming to ASTM C 612, Type 1A or type 1B.
- L. Aluminum field applied pipe insulation jacket; comply with ASTM B209, ASTM C1729, ASTM C1371 Manufacturers; Childers Metals; ITW Insulation Systems Aluminum Jacketing; or an approved equal.
 - 1. Finish shall be flat mill finish
 - 2. Factory Fabricated Fitting Covers; 45 and 90 degree elbows, tee's, valve covers, end caps, unions, shall be of the same thickness and finish of jacket.

- 3. The fittings shall be composed of 2-pieces
 - 4. Adhesives; per the manufacturers requirements
 - 5. Joint Sealant; shall be silicone, and shall be aluminum in color.
- M. Sewer Forced Main; HDPE, DR 11, color gray with green stripe by JM Eagle or approved equal.

2.04 SANITARY SEWER MANHOLES

- A. Shall be constructed as shown on plan details.

2.05 CLEANOUTS

- A. Cleanouts of same diameter as pipe up to 8" in size shall be installed in all horizontal soil and waste lines where indicated and at all points of change in direction. Cleanouts shall be located not less than 18" from building so as to provide sufficient space for rodding. No horizontal run over 100 feet shall be without cleanout whether shown on drawings or not.
- B. All cleanout boxes shall be traffic rated with labeled lid, Christy G05CT or approved equal. Lid shall be vandal proof with stainless steel screws

2.06 UNIONS

- A. Furnish and install one union at each threaded or soldered connection to equipment and 2 unions, one on each side of valves on pipes ½" to 3".
- B. Locate unions so that piping can be easily disconnected for removal of equipment or valve. Provide type specified in following schedule:

Type of Pipe Union

| | |
|------------------|---|
| Steel Pipe: | 150 lb. Screwed malleable ground joint, brass, brass-to-iron seat, black or galvanized to match pipe. |
| Copper tubing: | Brass ground joint with sweat connections. |
| PVC Sch 80 pipe: | PVC union, FIPT X FIPT |

2.07 VALVES

- A. Provide valves as shown and other valves necessary to segregate branches or units. Furnish valves suitable for service intended. Valves shall be properly packed and lubricated. Valves shall be non-rising stem. Place unions adjacent to each threaded or sweat fitting valve. Install valves with bonnets vertical. All valves shall be lead free.
- B. Valves ½" thru 2"; shall be made of bronze, full size of pipe and lead free. Nibco S-113-FL Series; American G-300 Series; Matco 511 FL Series; Apollo 102T-FL Series. Brass valves of brass parts within valves will not be accepted.
- C. Valves, 2 ½" thru 3" shall be class 150; Shall be made of bronze, full size of pipe; Jenkins Fig. 2310 J; Lunkeinheimer Fig. 2153; Crane Fig. 437; Stockham Fig. B-128.

- D. Valves, Flanged; 4" thru 12" Ductile Iron Resilient Wedge Gate Valve; Nibco F 609 RW; American 2500 Series; Kennedy 8561; Mueller 2360 Series.

2.08 TAPPING SLEEVE

- A. Shall be used on pipe sizes 6" thru 12" and shall be made with stainless steel material including stainless steel bolts. Flanges shall be ductile iron or high carbon steel. Gaskets shall seal full circumference of pipe. Shall be manufactured for operating pressure of 200 psi, and shall pass test pressure of 300 psi. Romac SST series; Smithblair 662; Mueller H304; Ford "FAST" tapping sleeve.

2.09 SERVICE SADDLES

- A. Shall be used on pipe size 2" thru 4". Body shall be made from ductile iron with epoxy coating or bronze. Cascade Style CSC-1; A.Y. McDonald model 3891 AWWA/3892 FNPT; Smith-Blair #317; Ford S70, S71, S90, (style B).

2.13 TRACER WIRE

- A. No. 10 THW solid copper wire. Solder all joints

PART 3 - EXECUTION

3.01 DRAWINGS AND COORDINATION

- A. General arrangement and location of piping, etc., are shown on Drawings or herein specified. Install work in accord therewith, except for minor changes that may be necessary on account of other work or existing conditions. Before excavation, carefully examine other work that may conflict with this work. Install this work in harmony with other craft and at proper time to avoid delay of work.
- B. Verify invert elevations at points of connection to existing systems prior to any excavation. If invert elevations differ from that shown on drawings, notify Architect immediately.
- C. In advance of construction, work out minor changes if conflicts occur with electrical or mechanical. Relocate services to suit actual conditions and work of other trades to avoid conflict therewith. Any adjustments or additional fittings to make adjustments shall not be cause for additional costs to the owner.
- D. Execute any work or apparatus shown on drawings and not mentioned in specifications, or vice versa. Omission from Drawings or Specifications of any minor details of construction, installation, materials, or essential specialties does not relieve Contractor of furnishing same in place complete.
- E. Graded pipes shall take precedence. If conflict should occur while placing the domestic water and fire service piping, the contractor shall provide any and all fittings necessary to route the water lines over or under such conflicting pipes at no additional costs to the owner.

3.02 ACCESS

- A. Continuously check for clearance and accessibility of equipment or materials specified herein to be placed. No allowance of any kind shall be made for negligence on part of Contractor to

foresee means of installing his equipment or materials into proper position.

3.03

EXCAVATING AND BACKFILLING

A. Excavation and Bedding:

1. General: Trench straight and true to line and grade with bottom smooth and free of irregularities or rock points. Trench width to be a minimum of 12" wider than outside diameter of pipe. Follow manufacturer's recommendations for use of each kind and type of pipe.
2. Bedding: Provide a bedding as noted on drawing details for the full length of the pipe. Bedding shall have a minimum thickness beneath the pipe of 4" or 1/8 the outside diameter of the pipe, which ever is greater. Provide bell holes and depressions for pipe joints only of size required to properly make joint.
3. If the trenches for the site utilities falls within areas to be lime treated, the piping shall be installed prior to any lime treatment operations, providing the elevation of the piping is below the treatment section.
 - a. If trenching is necessary in areas that have been previously lime treated the contractor shall backfill the trench with class 2 aggregate base, with minimum section equal to the lime treated section and compacted to 95%.

B. Laying of Pipe:

1. General: Inspect pipe prior to placing. Sun damaged pipe will be rejected. Set aside any defective or damaged material. Do not place pipe in water nor place pipe when trenches or weather are unsuitable. Lay pipe bell up grade, true to line and grade.
 - a. Sewer pipe shall be laid in strict conformity to the prescribed line and grade, with grade bars set and each pipe length checked to the grade line. Three consecutive points on the same rate of slope shall be used at all times to detect any variation from a straight grade. In any case of discrepancy, work shall be stopped and the discrepancy immediately reported to the Owner's Representatives. In addition, when requested by the Owner's Representative, a string line shall be used in the bottom of the trench to insure a straight alignment of the sewer pipe between manholes. The maximum deviation from grade shall not be in excess of 1/4 inch. In returning the pipe to grade, no more than 1/4" depression shall result.
 - b. The Contractor shall expose the end of existing pipe to be extended, for verification of alignment and elevation, prior to trenching for any pipe which may be affected. All costs of such excavation and backfill shall be included in the price paid for the various items of work.
 - c. A temporary plug, mechanical type shall be installed on sewer pipe at the point of connection to existing facilities. If connecting to a public facility the plug shall conform to the requirements of the local jurisdiction. This plug shall remain in place until the completion of the balling and flushing operation.
2. Bell and Spigot Joints: Lubricate inside of bells and outside of spigots with soap

solution. Wedge joints tight. Bell of bell and spigot pipe to be pointed upgrade.

- C. Backfilling:
1. General: Do not start backfill operations until required testing has been accomplished.
 2. Compaction and Grading: Remainder of backfill shall be in accordance with Section 31 23 33 – TRENCHING AND BACKFILLING.
 3. If trenching in area previously lime or cement treated backfill top of trench section, same depth as lime or cement treatment with Class 2 Aggregate Base compacted to 95% minimum relative compaction.

3.04 INSTALLATION OF WATER PIPING

- A. The contractor shall be responsible for determining the installed depth of all water piping, based on surface grades and minimum required depth of cover.
- B. Immediately cap or plug ends of, and opening in, pipe and fittings to exclude dirt until final connections made. Use reducing fittings where any change in pipe size occurs. Bushings shall not be used.
- C. General: Should existing conditions or other work prevent the running of pipes or the setting of equipment at the points indicated by drawings, changes as authorized by the Architect shall be made without additional cost to the Owner.
- D. All bolts used on mechanical fittings shall be thoroughly coated with an asphaltic bituminous coating conforming to 2019 NFPA 24, 10.4.1.1.
- E. All buried metal shall be incased with 8 mil polyethylene wrap so that no soil is in contact with metal. Ends of polyethylene wrap shall be taped to provide seal with pipe.
- F. Do not install water lines in same trench with non-metallic sewer lines unless bottom of water pipe at all points is at least 12" above top of sewer line and water line is placed on solid shelf excavated at one side of common trench with a minimum of 12 inch horizontal separation.
- G. Under no circumstance shall a fitting be located directly under a structural footing without prior approval from the Architect.
- H. In locations where existing domestic pipe is rerouted, the new pipe shall be assembled using restrained fittings at all joints including factory pipe joints. Tapped restrained blind flanges shall be temporarily installed at each end of the assembled pipes until testing and chlorination is completed and approved.

3.05 CLOSING IN OF UNINSPECTED WORK

- A. Do not allow or cause work installed to be covered up or enclosed before it has been inspected, tested, and approved. Should work be enclosed or covered up before it has been approved, uncover work at own expense. After it has been inspected, tested and approved, make repairs necessary to restore work of other contractors to condition in which it was found at time of cutting.

3.06 CARE AND CLEANING

- A. Repair or replace broken, damaged, or otherwise defective parts, materials, and work. Leave entire work in new condition satisfactory to Architect. At completion, carefully clean and adjust equipment, fixtures and trim that are installed as part of this work. Leave systems and equipment in satisfactory new operating condition.
- B. Drain and flush piping to remove grease and foreign matter.
- C. Sewer piping shall be balled and flushed.
- D. Clean out and remove surplus materials and debris resulting from the work, including surplus excavated material.
- E. Flush fire service piping in the presence of the project inspector. Flushing shall be continued for a sufficient time as necessary to ensure all foreign material has been removed. Flow rate shall be equal to site fire flow requirements.

3.07 SEWER INTERNAL INSPECTIONS

- A. Upon completion of construction and prior to final inspection, the Contractor shall clean the entire new pipeline of all dirt and debris. Any dirt or debris in previously existing pipes or ditches in the area, which resulted from the new installation, shall also be removed. Pipes shall be cleaned by the controlled balling and flushing method. Temporary plugs shall be installed and maintained during cleaning operations at points of connection to existing facilities to prevent water, dirt, and debris from entering the existing facility.

3.08 TEST OF PIPING

- A. Pressure Test piping at completion of roughing-in, in accord with following schedule, and show no loss in pressure or visible leaks after minimum duration or four (4) hours at test pressures indicated.
- B. Chlorination tests shall be performed after all fixtures and any required mechanical devices are installed and the entire system is complete and closed up.
- C. In cases where new domestic water piping is assembled for re-routing of existing domestic water pipe, the contractor shall perform the following testing prior to connecting the new water pipe to the existing system.
 - 1. The pipe shall be pressure tested and per the test schedule.
 - 2. The pipe shall be pressure tested down within the trench.
 - 3. The contractor shall dig a temporary ditch below the existing pipe to drain to a sump that is lower than the bottom of the trench and to the side of the trench. The sump shall be 30% larger than the total volume of water within the testing pipe assembly.
 - 4. After pressure testing and chlorination has taken place and accepted, the contractor shall drain the pipe into the sump and pump the sump out as it is filling.
 - 5. The temporary test fittings at each end of the pipe assembly shall be removed and the final restrained couplings installed.

6. The existing piping shall be cut and the water within the pipe shall drain below the pipe to the temporary sump. Pump the sump as it is being filled up. Take extreme caution not to contaminate the existing pipe with any contaminants within the trench.
7. Before making the final coupling connections, the restrained couplings at each end of the new pipe shall be thoroughly swabbed inside the fitting with a solution of chlorine mixed with water at a rate of 1part chlorine to 4 parts potable water.
8. After final connections are made, a visual inspection shall be made after fittings are wiped off. If after 1 hr, no noticeable drips are noted the pipe can be backfilled.
9. The contractor shall flush all water piping affected by chlorination until it is within acceptable levels approved by certified testing lab.

TEST SCHEDULE

| <u>System Tested</u> | <u>Test Pressure PSIG Test With</u> |
|---|---|
| Public water mains | Per local jurisdiction requirements. |
| Private domestic water piping and fire mains serving fire hydrants: | 150 Lbs. Water 4 hrs. |
| Fire Protection Piping from PIV to fire riser: | 200 Lbs. Water pressure, 4 hrs duration with no pressure loss. |
| Sanitary Sewer Piping: | Sewer system shall be tested for leakage per local jurisdiction requirements. |

- D. Testing equipment, materials, and labor shall be furnished by contractor.

3.09 WATER SYSTEM STERILIZATION

- A. Public Water Mains: Shall be flushed and disinfected per the local jurisdiction requirements
- B. Clean and disinfect all site water systems connected to the domestic water systems in accordance with AWWA Standard C651 and as required by the local Building and Health Department Codes, and EPA.
 1. Clean and disinfect industrial water system in addition to the domestic water system.
 2. Disinfect existing piping systems as required to provide continuous disinfection upstream to existing valves. At Contractors option, valves may be provided to isolate the existing piping system from the new piping system.
- C. Domestic water sterilization shall be performed by a licensed “qualified applicator” as required by CAL-EPA Pesticide Enforcement Branch for disinfecting and sterilizing drinking water.
- D. Disinfecting Agent: Chlorine product that is a registered product with Cal-EPA for use in California potable water lines, such as Bacticide, CAL-EPA Registration No. 37982-20001.

- E. Contractor to provide a 1" service valve connected to the system at a point within 2'-0" of its junction with the water supply line. After sterilization is complete Contractor to provide cap at valve.
- F. Sterilization Procedure to be as follows:
 - 1. Flush pipe system by opening all outlets and letting water flow through the system until clear water flows from all outlets.
 - 2. Inject disinfecting agent to provide a minimum chlorine residual concentration of at least 50 parts per million (ppm) of free chlorine at each outlet.
 - 3. Provide sign at all outlets which reads "Water Sterilization in Progress – Do not operate". Remove signs at conclusion of test.
 - 4. Close all outlets and valves, including valve connecting to water supply line and 1" service valve. Retain treated water in pipe for a minimum of twenty-four hours. Should chlorine residual at pipe extremities be less than 50 PPM at this time, pipe shall be re-chlorinated. As an option, the water systems may be filled with a water-chlorine solution containing a minimum of 200 PPM of chlorine and allowed to stand for three hours.
 - 5. After chlorination, flush lines of chlorinated water and refill from domestic supply. Continue flushing until residual chlorine is less than or equal to 0.2 ppm, or a residual the same as that of the test water.
- G. Chemical and bacteriological tests shall be conducted by a state-certified laboratory and approved by the local authorities having jurisdiction.
- H. Submit written report to Health Department as required by State Regulations. Provide a copy of report to Architect prior to completion of project.
- I. The costs of sterilization and laboratory testing shall be paid for by the contractor.

3.10 CLEANING

- A. Upon completion of work of this Section promptly remove from the working area all scraps, debris and surplus material of this Section.

END OF SECTION

SITE DRAINAGE

PART 1 - GENERAL

1.02 RELATED WORK SPECIFIED ELSEWHERE

- A. Section 01 50 00, Construction Facilities and Temporary Controls.
- B. Section 31 23 33, Trenching and Backfilling.
- C. Section 32 12 00, Asphalt Concrete Paving.
- D. Section 32 16 00, Site Concrete

1.03 QUALITY ASSURANCE

- A. Use only new materials and products, unless existing materials or products are specifically shown otherwise on the Drawings to be salvaged and re-used.
- B. All materials, components, assemblies, workmanship and installation are to be observed by the Owner's Inspector of Record. Work not so inspected is subject to uncovering and replacement.
- C. The representatives of the Owner's testing lab will not act as supervisor of construction, nor will they direct construction operations. Neither the presence of the Owner's testing lab representatives nor the testing by the Owner's testing lab shall excuse the contractors or subcontractors for defects discovered in their work during or following completion of the project. Correcting inadequate compaction is the sole responsibility of the contractor.
- D. Contractor shall be solely responsible for all subgrades built. Any repairs resulting from inadequate compaction are the responsibility of the contractor.

1.04 SUBMITTALS

- A. Refer to Section 01 33 00.
- B. Manufacturer's Data: Submit list and complete descriptive data of all products proposed for use. Include manufacturer's specifications, published warranty or guarantee, installation instructions, and maintenance instructions.

1.05 WARRANTY

- A. Refer to General Conditions and Section 01 78 36.

1.06 REFERENCES AND STANDARDS

- A. ANSI/ASTM D698-00 - Test Methods for Moisture-Density Relations of Soils and Soil-Aggregate Mixtures, Using 5.5 lb (2.49 Kg) Rammer and 12 inch (304.8 mm) Drop.
- B. ANSI/ASTM D1556-00 - Test Method for Density of Soil in Place by the Sand-Cone Method.

- C. ANSI/ASTM D1557-02 - Test Methods for Moisture-Density Relations of Soils and Soil-Aggregate Mixtures Using 10 lb. (4.54 Kg) Rammer and 18 inch (457 mm) Drop.
- D. ANSI/ASTM D 3017-05 Test Methods for Moisture Content of Soils and Soil-Aggregate Mixture by Nuclear Methods (Shallow Depth).
- E. ANSI/ASTM D 4318-05 Test Method for Liquid Limit, Plastic Limit, and Plasticity Limit.
- F. CALTRANS Standard Specifications.
- G. CAL-OSHA, Title 8, Section 1590 (e).
- H. Any work within the street, highway or right-of-way shall be performed in accordance with the requirement of the governmental agencies having jurisdiction, and shall not begin until all of those governing authorities have been notified.
- I. California Plumbing Code current edition.

1.07 DELIVERY, STORAGE AND HANDLING

- A. Transport, store and handle in strict accord with the local jurisdiction.
- B. Make delivery to job when notified by Contractor verifying that the job is ready to receive the work of this Section and that arrangements have been made to properly store, handle and protect such materials and work.

1.08 PROJECT CONDITIONS

- A. Existing civil, mechanical and electrical improvements are shown on respective site plans to the extent known. Should the Contractor encounter any deviation between actual conditions and those shown, he is to immediately notify the Architect before continuing work.

1.09 EXISTING SITE CONDITIONS

- A. Contractor shall acquaint himself with all site conditions. If unknown active utilities are encountered during work, notify Architect promptly for instructions. Failure to notify will make Contractor liable for damage to these utilities arising from Contractor's operations subsequent to discovery of such unknown active utilities.

1.10 PROTECTION

- A. Adequate protection measures shall be provided to protect workmen and passers-by on and off the site. Adjacent property shall be fully protected throughout the operations. Blasting will not be permitted. Prevent damage to adjoining improvements and properties both above and below grade. Restore such improvements to original condition should damage occur. Replace trees and shrubs outside building area disturbed by operations.
- B. In accordance with generally accepted construction practices, the Contractor shall be solely and completely responsible for working conditions at the job site, including safety of all persons and property during performance of the work. This requirement shall apply continuously and shall not be limited to normal working hours.
- C. Any construction review of the Contractor's performance conducted by the Geotechnical

Engineer is not intended to include review of the adequacy of the Contractor's safety measures, in, on, or near the construction site.

- D. Provide shoring, sheeting, sheet piles and/or bracing to prevent caving, erosion or gulying of sides of excavation.
- E. Surface Drainage: Provide for surface drainage during period of construction in manner to avoid creating nuisance to adjacent areas. The contractor shall make a reasonable effort on a daily basis to provide pumps and all equipment necessary to keep all excavations and the site free from water during entire progress of work, regardless of cause, source, or nature of water.
- F. Adjacent streets and sidewalks shall be kept free of mud, dirt or similar nuisances resulting from earthwork operations.
- G. The site and adjacent influenced areas shall be watered as required to suppress dust nuisance. Dust control measures shall be in accordance with the local jurisdiction.
- H. Trees: Carefully protect existing trees that are to remain.

1.11 SEASONAL LIMITS

- A. No fill material shall be placed, spread or rolled during unfavorable weather conditions. When work is interrupted by rains, fill operations shall not be resumed until field tests indicate that moisture content and density of fill are satisfactory.

1.12 TESTING

- A. General: Refer to Section 01 40 00 – Quality Requirements.
- B. Geotechnical Engineer: Owner is retaining a Geotechnical Engineer to determine compliance of fill with Specifications, and to direct adjustments in fill operations. Costs of Geotechnical Engineer will be borne by Owner; except those costs incurred for re-tests or re-inspection will be paid by Owner and backcharged to Contractor.

1.13 RECORD DRAWINGS

- A. Keep a daily record of all pipe placed in ground, verified by Project Inspector.
- B. Upon completion of this Contract, furnish one tracing showing all outside utility lines, piping, etc., installed under this Contract. Locate and dimension all work with reference to permanent landmarks.
- C. All symbols and designations used in preparing "RECORD" drawings shall match those used in Contract drawings.
- D. Properly identify all stubs for future connections, as to location and use, by setting of concrete marker at finished grade in the manner suitable to Architect.

PART 2 - PRODUCTS

2.01 MATERIALS

- A. Pipe: Use one of the following, unless noted on the Drawings otherwise.
 - 1. Polyvinyl Chloride Pipe (PVC): SDR35 conforming to ASTM D3034 with elastomeric joints conforming to ASTM D3212. Sun damaged pipe will be rejected.
 - 2. High density polyethylene pipe (HDPE): The pipe shall be corrugated exterior/smooth interior pipe and water tight per ASTM D3212 with dual wall water tight gasket fittings.
- B. Perforated Pipe (for subdrains): Shall be ADS N12 pipe, 2 hole, ASTM F 405, AASHTO M 252; PVC ASTM D3034 SDR-35 storm drain pipe
- C. Manhole: Shall be as shown on the drawing details.
- D. Drop Inlet: Shall be as shown on the drawing details.
- E. Curb Inlet: Shall be as shown on the drawing details.
- F. Mortar: For pipe connections to concrete drainage structures, conform to ASTM C270 type N mortar. Place within one half hour after adding water.
- G. Crushed Rock: Imported washed crushed rock. Minimum 100% passing 3/4 inch sieve.
- H. Trench drain: Polycast, Polydrain or equal and as shown on drawings.
- I. Area Drains: Shall be as shown on the drawing details.
- J. Floor Drains: Shall be as shown on the drawing details.
- K. Clean-outs: Shall be as shown on the drawing details.
- L. Planter drains: Shall be as detailed on the drawing details.
- M. Filter Fabric: Mirafi 140N.

PART 3 - EXECUTION

3.01 INSPECTION LAYOUT AND PREPARATION

- A. Prior to installation of the work of this Section, carefully inspect and verify by field measurements that installed work of all other trades is complete to the point were this installation may properly commence
- B. Layout all work, establish grades, locate existing underground utilities, set markers and stakes, setup and maintain barricades and protection facilities; all prior to beginning actual earthwork operations. Layout and staking shall be done by a licensed Land Surveyor or Professional Civil Engineer.
- C. Verify that specified items may be installed in accordance with the approved design.
- D. In event of discrepancy, immediately notify Owner and the Architect. Do not proceed in discrepant areas until discrepancies have been fully resolved.

3.02 INSTALLATION

- A. General: Installation shall be in strict conformance with referenced standards, the manufacturer's written directions, as shown on the drawings and as herein specified.
- B. Verify invert elevations at points of connection to existing systems prior to any excavation. If invert elevations differ from that shown on drawings, notify Architect immediately.
- C. Excavation and Bedding:
1. General: Trench straight and true to line and grade with bottom smooth and free of irregularities or rock points. Trench width in accordance with pipe manufacturer's recommendations and as per the drawings. Follow manufacturer's recommendations for use of each kind and type of pipe.
 2. Bedding: Provide bedding as detailed on plans for the full length of the pipe. Bedding shall have a minimum thickness beneath the pipe of 4" or 1/8 the outside diameter of the pipe, whichever is greater. Provide bell holes and depressions for pipe joints only of size required to properly make joint.
 3. If the trenches for the site drainage fall within areas to be lime treated, the piping shall be installed prior to any lime treatment operations.
 - a. If additional piping is added to previously lime treated areas, the contractor shall backfill the trench with class 2 aggregate base and compact to 95%.
- D. Laying of Pipe:
1. General: Inspect pipe prior to placing. Set aside any defective or damaged material. Do not place pipe in water nor place pipe when trenches or weather are unsuitable. Lay pipe upgrade, true to line and grade.
 2. Bell and Spigot Joints: Lubricate inside of bells and outside of spigots with soap solution or as recommended by manufacture. Wedge joints tight. Bell of bell and spigot pipe to be pointed upgrade.
 3. Pipe shall be bedded uniformly throughout its length.
 4. Pipe elevation shall be within 0.02 feet of design elevation as shown on plans.
 5. Off Site Work: All work beyond the property lines shall be done in strict conformance with the requirements of the governing agency.
- E. Backfilling:
1. General: Do not start backfill operations until required testing has been accomplished.
 2. Trenches and Excavations: Backfill with material as detailed on plans, filling both sides of the pipe at the same time, carefully tamping to hold pipe in place without movement. Refer to Section 31 23 33 – TRENCHING AND BACKFILLING for fill above this layer.
- F. Grouting of Pipes: Grout pipes smooth and water tight at drop inlet, manholes, and curb inlets. Grout back side of hood at curb inlets all grouting shall be smooth and consistent.
- G. Off Site Work: All work beyond the property lines shall be done in strict conformance with the

requirements of the local agency.

- H. Cutting and Patching: Remove and replace existing surface features per applicable specification section (i.e. asphaltic concrete or concrete paving) where pipe is installed in areas of existing improvements.

3.03 TOLERANCES

- A. Storm Drain structure grates
 - 1. In landscape and lawn areas +/- 0.05'.
 - 2. In sidewalk and asphalt pavement +/-0.025'.
 - 3. In curb and gutter application +/-0.0125'.
- B. Cleanout Boxes and Lids
 - 1. In landscape areas; 0.10 higher than surrounding finish grade, +/-0.05'.
 - 2. In sidewalks and asphalt pavement; Flush with surrounding finish grade, +/-0.025'.

3.03 DEWATERING

- A. Contractor to provide trench dewatering as necessary, no matter what the source is, at no additional cost to the owner.
- B. If the previously excavated material from trenching is too wet to achieve trench backfill compaction the contractor shall make a reasonable effort to aerate and dry the material per section 31 00 00, 3.08, B

3.04 FLUSHING

- A. The Contractor shall thoroughly ball and flush the storm drain system to remove all dirt and debris. Discharge water to an approved location.

3.05 CLEANING

- A. Refer to Section 01 74 00.
- B. Upon completion of work of this Section promptly remove from the working area all scraps, debris and surplus material of this Section.
- C. Clean the dirt, rocks, and debris from all storm drain inlets, structures, and connecting pipes.

END OF SECTION